

COMPANY	Southwestern Electric Power Company	Southwestern Electric Power Company	Southwestern Electric Power Company
PLANT	Welsh	Welsh	Welsh
ASH MANAGEMENT UNIT	Primary Ash Pond	Secondary Ash Pond	Active Bottom Ash Storage
QUESTION 1			
Dam Hazard Rating			
Who Established Rating			
Basis for Rating			
No Rating Assigned	X	X	X
QUESTION 2			
Year Commissioned	1977	1977	2000
Year(s) Expanded			
QUESTION 3 - Mark all that apply			
Fly Ash	X	X - Minimal	X
Bottom Ash	X	X - Minimal	X
Boiler Slag			
Flue Gas Emission Control Residuals			
Other (Specify)			
QUESTION 4			
Designed by P.E.	Yes	Yes	Yes
Constructed under P.E. Supervision	Yes	Yes	Yes
Inspection/monitoring under P.E. Supervision	Yes	Yes	Yes
QUESTION 5			
Date of Last Company Safety Assessment	3/18/2009	3/18/2009	3/18/2009
Describe Evaluator's Credentials	PE	PE	PE
Describe Past Followup Corrective Actions	Report not yet received	Report not yet received	Report not yet received
Describe Credentials of Corrective Action Implementers			
Describe Planned Followup Actions			
Date of Next Safety Assessment	2012 (AEP considers this facility to be Low Hazard)	2012 (AEP considers this facility to be Low Hazard)	2012 (AEP considers this facility to be Low Hazard)
QUESTION 6			
Date of Last Regulatory Safety Inspection	1/13/2009	1/13/2009	1/13/2009
Agency Name	Texas Commission on Environmental Quality	Texas Commission on Environmental Quality	Texas Commission on Environmental Quality
Date of Planned Regulatory Safety Inspection			
Agency Name			
Copy of Most Recent Regulatory Inspection Included	Attached	Attached	Attached
QUESTION 7			
Safety Issues from Regulatory Inspections w/in Past Year	None Found	None Found	None Found
Corrective Actions			
Documentation Included			
QUESTION 8			
Surface Area (acres)	98.1 acres	4.2 acres	20 acres
Total Storage Capacity	307.4 acre-ft	36.9 acre-ft	270 acre-ft
Volume Currently Stored	Approx. 30,000 c.y. - pond is periodically dredged	Approx. 7,200 c.y.	Approx. 200,000 c.y.
Date of Volume Measurement	3/1/2009	11/1/2007	4/1/2008
Maximum Height (feet)	20	20	34.6
QUESTION 9			
Spills or Unpermitted Release History (10 Years)	None	None	None
QUESTION 10			
All legal owner(s) and operator(s)	Southwestern Electric Power Company	Southwestern Electric Power Company	Southwestern Electric Power Company