

Table 2- Levels Of Evacuation Which Must Be Achieved By Recovery Or Recycling Equipment Intended For Use With Appliances Manufactured On Or After November, 15 1993¹

Type of appliance with which recovery or recycling machine is intended to be used	Inches of Hg vacuum
HCFC-22 appliances, or isolated component of such appliances, normally containing less than 200 pounds of refrigerant	0
HCFC-22 appliances, or isolated component of such appliances, normally containing 200 pounds or more of refrigerant	10
Very high pressure appliances	0
Other high- pressure appliances, or isolated component of such appliances, normally containing less than 200 pounds of refrigerant	10
Other high- pressure appliances, or isolated component of such appliances, normally containing 200 pounds or more of refrigerant	15
Low pressure appliances	² 25

¹ Except for small appliances, MVACs, and MVAC-like appliances.

² mm Hg absolute