

Owner	Facility Name	Account	Co.	Site	Tank	Location	Last Inspected Date	Action Taken to Ensure Compliance	Comment
Perry County Commission	Perry County Hwy. Dpt.	13838	105	1734	24467	Hwy. 14 W., Marion, Perry County, AL 36756	10/21/2003	On June 26, 2007 a Notice of Noncompliance requiring closure was mailed to the facility. ADEM will track and follow-up as appropriate.	Not Upgraded-Tank & Pipe
Perry County Commission	Perry County Hwy. Dpt.	13838	105	1734	24470	Hwy. 14 W., Marion, Perry County, AL 36756	10/21/2003	On June 26, 2007 a Notice of Noncompliance requiring closure was mailed to the facility. ADEM will track and follow-up as appropriate.	Not Upgraded-Tank & Pipe
City of Carbon Hill	City of Carbon Hill	10996	127	1827	6885	2nd Ave. and Maple St., Carbon Hill, Walker County, AL 35549	9/17/2003	On June 29, 2007 a Notice of Noncompliance requiring closure was mailed to the facility. The facility responded July 2 and stated they were contracting for Closure. ADEM will track and follow-up as appropriate.	Steel Piping-No CP, no overflow, no spill
Tallapoosa County Commission	Tallapoosa County District 4 Shop	14797	123	2854	31229	393 County Shop Road, Dadeville, Tallapoosa County, AL 36853	2/14/2001	On June 27, 2007 a Notice of Noncompliance requiring closure was mailed to the facility. ADEM will track and follow-up as appropriate.	Not Upgraded Tank & Pipe
Pike County Board of Education	Pike County School Bus Shop	15723	109	13683	45181	317 Montgomery St., Troy, Pike County, AL 36081	10/19/2006	ADEM has attempted to notify the site of the discrepancy. ADEM will track and follow up as appropriate.	Data base indicates current w/o overflow
Coffee County Board of Education	Bus Shop	11156	31	1426	45221	210 School St., New Brocton, Bibb County, AL 36351	11/9/2005	On June 22, 2007 a Notice of Noncompliance was mailed to the facility. ADEM will track and follow-up as appropriate.	No '05-'06 SIR reports
Coffee County Board of Education	Bus Shop	11156	31	1426	47545	210 School St., New Brocton, Bibb County, AL 36351	11/9/2005	On June 22, 2007 a Notice of Noncompliance was mailed to the facility. ADEM will track and follow-up as appropriate.	No '05-'06 SIR reports
City of Sumiton	City of Sumiton	11078	127	19146	51090	416 State St., Sumiton, Walker County, AL 35148	12/20/2006	On June 22, 2007 a Notice of Noncompliance was mailed to the facility. ADEM will track and follow-up as appropriate.	No '06 SIR Report
AL State Military Dpt.	DET 1 HHC 2/152nd AR	14587	121	10478	9666	Limbaugh Blvd., Childersburg, Talladega County, AL 35044	12/8/2006	On June 28, 2007 a Notice of Noncompliance requiring closure was mailed to the facility. ADEM will track and follow-up as appropriate.	Unknown material of constr_ Tank & Lines-Rcvd 3-20-92 NOV for temp close > 12 mos. Temp 1-1-89 This was also on the No Spill prevention list
Shoals Community College	Shoals Community College	16736	33	14709	47191	810 George Wallace Blvd, Muscle Shoals, Colbert County 35661	12/11/2006	On March 26, 2007 a Notice of Delinquency was mailed to the facility. On August 7 site representative called and requested a list of CP testers. ADEM will track and follow up as appropriate.	Late CP Test_Post Card NOD