

## **Implementation of Clean Air Act Requirements for Advanced Coal Technologies**

**Steve Jenkins**



**Tampa, FL**

**Advanced Coal Technology Work Group  
March 6, 2007**

### **Topics**

- Bob Wayland has discussed overall CAA:
  - Rules and how they apply to utility sector
  - Timeline
  - Regulatory process
  - Projected emissions and retrofits to comply with CAIR, CAMR, CAVR
  - BACT and LAER
- Now let's see how ACTs that being planned are going to comply with these rules:
  - How emission control systems for PC and IGCC are different
  - Focus on New Source Performance Standards
  - How emission limits compare

## Applicable Air Regulations

- National Ambient Air Quality Standards (NAAQS)
- New Source Review (NSR) requirements, including Prevention of Significant Deterioration (PSD) and Non-Attainment NSR; and BACT/LAER
- **New Source Performance Standards (NSPS)**
- National Emission Standards for Hazardous Air Pollutants (NESHAPs) including proposed Utility MACT and Combustion Turbine MACT rules
- Federal Acid Rain Program (Title IV)
- Operating permit (Title V)
- Clean Air Interstate Rule (CAIR)
- Clean Air Mercury Rule (CAMR)

3



## Technology Comparison

	<b>PC</b>	<b>IGCC</b>
<b>Feedstock</b>	-	Coal
<b>Fuel</b>	Coal	Syngas
<b>Combustion</b>	Coal in boiler	Syngas in gas turbine
<b>Emission Control</b>	Post-combustion clean-up of large volume of exhaust gas	Pre-combustion clean-up of small volume of syngas

4



## Comparison of Air Emission Controls: PC and IGCC

	SO <sub>2</sub>	NOx	PM	Mercury
PC	Limestone-based FGD system	Low-NOx burners and SCR	ESP or baghouse	Inject activated carbon into flue gas
IGCC	Amine system removes H <sub>2</sub> S from syngas	Syngas saturation and N <sub>2</sub> diluent	Wet scrubber, high temperature cyclone, ceramic filter	Pre-sulfided activated carbon bed in syngas stream

5



## IGCC - a Different Environment Than PC

- Gasification occurs in a reducing atmosphere
  - sulfur compounds are liberated as H<sub>2</sub>S and COS
  - removed by refinery industry technologies to levels ≥99%
- Low levels of H<sub>2</sub>S in the syngas are burned in the gas turbine and become SO<sub>2</sub> in exhaust
- NOx is controlled by injecting N<sub>2</sub> at ~1:1 ratio with syngas, as well as saturating the syngas stream with water or steam (cools the flame)



6



## New NSPS

Emission	NSPS	NSPS on Input Basis for IGCC (estimated)	NSPS on Input Basis for PC (estimated)
<b>NOx</b>	1.0 lb/MWh*	0.132 lb/MMBtu	0.11 lb/MMBtu
<b>SO<sub>2</sub></b>	1.4 lb/MWh* and minimum 95% removal	0.185 lb/MMBtu	0.155 lb/MMBtu
<b>PM</b>	Lesser of 0.14 lb/MWh* or 0.015 lb/MMBtu	0.015 lb/MMBtu	0.015 lb/MMBtu
<b>Mercury</b>	20 x 10 <sup>-6</sup> lb/MWh* (bituminous)	2.6 lb/TBtu	2.2 lb/TBtu

\*output-based standards are on a gross generation basis, so gross heat rate is used to calculate estimated input-based limit

7



## New Source Performance Standards

- NSPS for Electric Utility Steam Generating Units (Subpart Da), February, 2006:
  - Applies to IGCC combustion turbines that burn  $\geq 75\%$  “synthetic coal gas”
  - When burning  $<75\%$  syngas (12-month rolling average), Subpart KKKK applies
    - This could be a problem during initial start-up
    - Meeting the NSPS for NOx may not be possible when burning natural gas in diffusion burners designed for syngas
  - Industry requested modification to regulations

8



## New Source Performance Standards

- EPA proposed changes in February 2007
- IGCC is only covered by subpart Da, if:
  - “The combined cycle gas turbine is **designed and intended** to burn fuels containing 50 percent (by heat input) or more solid-derived fuel not meeting the definition of natural gas on a 12-month rolling average basis; and
  - The combined cycle gas turbine commenced construction, modification, or reconstruction after February 28, 2005.”

9



## New Source Performance Standards

- *Coal-fired electric utility steam generating unit* means an electric utility steam generating unit that burns coal, coal refuse, or a **synthetic gas** derived from coal either exclusively, in any combination together, or in any combination with other fuels in any amount.

10



## New Source Performance Standards

- *Integrated gasification combined cycle electric utility steam generating unit or IGCC* means a coal-fired electric utility steam generating unit that burns a **synthetic gas** derived from coal in a combined-cycle gas turbine. No coal is directly burned in the unit during operation.

11



## Air Permitting Requirements

- IGCC and PC plants are similar
  - Fugitive dust controls
    - Coal delivery, unloading and handling
  - Cooling towers
    - But IGCC cooling towers would have lower duty since only 40% of plant output is from steam turbine generator
  - Air dispersion modeling
  - BACT analysis for emission controls



12



## Air Permitting: IGCC

- Unique emission points depend on technology provider
  - Flare
  - Start-up burner
  - Gasifier pre-heat burner
  - Sulfur Recovery Unit tail gas incinerator
  - Sulfuric Acid Plant stack
  - Tank vents
  - Air Separation Unit cooling tower



13



## Air Permitting: IGCC


- For air permit application:
  - Inventory of emission points has to be developed early in the engineering process
  - Emission limits in lb/hr are easier for measurement and compliance than ppm or lb/MMBtu
  - Startup, shutdown and emergency emissions must be calculated – and can be substantial
  - Emissions from flare are critical
    - Raw syngas
    - Clean syngas
    - Duration
    - Number of flare events/year

14



## What About SCR for IGCC?


- Technical issues
  - The fuel is syngas, not natural gas as in NGCC
  - Ammonium sulfate/bisulfate deposits in the HRSG, causing corrosion and plugging, requiring more downtime for washdowns
  - Possible poisoning of SCR catalyst from syngas
  - No coal-based IGCC system in the world uses SCR
- Economic Issues
  - No commercial guarantees yet with syngas
  - SCR would require deeper sulfur removal to reduce sulfate formation to low levels
    - Selexol
    - Higher capital costs



15



## SCR in a PC Plant



16






## SCR: PC vs IGCC

### • SCR in a PC plant

- Air pre-heater baskets:
  - have large openings due to the fly ash in the exhaust gas stream
  - are designed for removal, replacement and cleaning
- Particulates are removed downstream in the ESP, FGD system, or baghouse



17



## SCR: PC vs IGCC

### • SCR in an IGCC plant

- heat transfer occurs in the HRSG
  - on fixed finned tubing with small clearances
  - designed for exhaust gas from natural gas combustion – no sulfates/bisulfates
  - sulfate/bisulfate deposition would be a problem on finned tubing
  - finned tubing is not designed for removal, replacement or easy cleaning



18



## Why SCR?


- But more IGCC plants are being proposed with SCR than without SCR
- Reasons:
  - As BACT
  - As Innovative Control Technology to reduce emissions beyond diluent injection
  - As a trial/experiment, with emission limits proposed only for natural gas use
  - To evaluate SCR as part of DOE demonstration program with a syngas-fired combined cycle unit
  - To minimize NOx emissions in order to reduce NOx emission allowance costs

19



## NOx BACT

- EPA has addressed this issue
- Report notes technical problems with using SCR w/IGCC
- Looked at SCR w/Selexol for deep sulfur removal
- EPA concluded that:
  - even w/Selexol, problems are not solved
  - additional cost and reduced output are negative impacts to IGCC
  - BACT will continue to be a case-by-case issue



20



## Mercury Removal: PC

- Inject activated carbon in flue gas stream
- Mercury adsorbed onto carbon particle
- Particles removed in ESP or baghouse

21



## Mercury Removal: IGCC

- Pre-sulfided carbon beds in syngas stream
- Forms a mercury-sulfur complex
- Spent carbon disposed of in drums once/year
- Most IGCC plants plan to use this technology



Source: Eastman Chemical

22




## NOx and SO<sub>2</sub> Emissions

- NOx emission rates not very different for proposed PC and IGCC units
- IGCC units being proposed with much lower SO<sub>2</sub> emission rates
  - due to ability to remove higher percentages of H<sub>2</sub>S vs SO<sub>2</sub>
- Mercury emission rates about the same for PC and IGCC

23



## Air Emission Comparisons - NOx



24



