
2013 – 2nd Quarter Report
Support for Conducting Systems &
Performance Audits of CASTNET Sites and
NADP Monitoring Stations

EPA Contract No. EPW12019

Prepared for:

U. S. Environmental Protection Agency

Prepared by:



1128 NW 39th Drive
Gainesville, FL 32605

July 2013

Table of Contents

1.0 CASTNET Quarterly Report.....	1-1
1.1 Introduction.....	1-1
1.2 Project Objectives	1-1
1.3 Sites Visited Second Quarter 2013	1-3
1.4 Audit Results.....	1-4
2.0 NADP Quarterly Report	2-1
2.1 Introduction.....	2-1
2.2 Project Objectives	2-1
2.3 Sites Visited Second Quarter 2013	2-2
2.4 Survey Results.....	2-3

List of Appendices

- Appendix A** CASNET Audit Report Forms
- Appendix B** CASTNET Site Spot Report Forms
- Appendix C** CASTNET Ozone Performance Evaluation Forms

List of Tables

Table 1. Performance Audit Challenge and Acceptance Criteria	1-2
Table 2. Site Audit Visits	1-3
Table 3. Site Ozone PE Visits	1-4
Table 4. Sites Surveyed – Second Quarter 2013	2-2

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialist, Inc.
ASTM	American Society for Testing and Materials
CASTNET	Clean Air Status and Trends Network
DAS	data acquisition system
DC	direct current
deg	degree
DVM	digital voltmeter
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSAD	Field Site Audit Database
GPS	geographical positioning system
lpm	liters per minute
MLM	Multilayer Model
m/s	meters per second
mv	milivolt
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
QAPP	Quality Assurance Project Plan
SOP	standard operating procedure
TEI	Thermo Environmental Instruments
USNO	United States Naval Observatory
V	volts
WRR	World Radiation Reference

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program developed under mandate of the 1990 Clean Air Act Amendments. Each site in the network measures acidic gases and particles and other forms of atmospheric pollution using a continuous collection filter aggregated over a one week period. Hourly averages of surface ozone concentrations and selected meteorological variables are also measured.

Site measurements are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and effects research.

CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and model-estimated deposition velocities. Currently, the National Oceanic and Atmospheric Administration's multilayer inferential model (NOAA-MLM) described by Meyers et al. [1998] is used to derive deposition velocity estimates.

As of June 2013, the network is comprised of 93 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Environment Canada, and several independent partners. AMEC is responsible for operating the EPA and Environment Canada sponsored sites, and Air Resource Specialist, Inc. (ARS) is responsible for operating the NPS sponsored sites.

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all evaluated variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific

accuracy goals are presented in Table 1. Only four EPA sponsored sites continue to operate meteorological sensors. Those sites are BEL116, BVL30, CHE185, and PAL190.

Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^\circ$ C
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^\circ$ C
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^\circ$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	$\leq \pm 5^\circ$ mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5$ mps below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003$ VDC

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, and certified as current.

Site systems audits are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 Sites Visited Second Quarter 2013

This report consists of the systems and performance audit results from the CASTNET sites audited during the first quarter (April through June) of 2013. The locations and dates of the audits are presented in Table 2.

Table 2. Site Audit Visits

<u>Side ID</u>	<u>Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
CNT169	Audit w/o met	EPA	5/14/2013	Centennial
DCP114	Audit w/o met	EPA	4/22/2013	Deer Creek St. Park
GTH161	Audit w/o met	EPA	6/13/2013	Gothic

<u>Side ID</u>	<u>Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
KNZ184	Audit w/o met	EPA	4/26/2013	Konza Prairie
LAV410	Audit with met	NPS	5/7/2013	Lassen Volcanic NP
OXF122	Audit w/o met	EPA	5/8/2013	Oxford
PIN414	Audit with met	NPS	4/11/2013	Pinnacles NM
PND165	Audit w/o met	EPA	5/12/2013	Pinedale
QAK172	Audit w/o met	EPA	5/9/2013	Quaker City
ROM206	Audit w/o met	EPA	6/11/2013	Rocky Mountain NP
ROM406	Audit with met	NPS	6/10/2013	Rocky Mountain NP (NPS)
SAN189	Audit w/o met	EPA	4/25/2013	Santee Sioux
SEK430	Audit with met	NPS	5/3/2013	Sequoia NP - Ash Mountain
YEL408	Audit with met	NPS	6/6/2013	Yellowstone NP
YOS404	Audit with met	NPS	5/1/2013	Yosemite NP

In addition to the sites listed in Table 2. that were visited for complete audits, the sites listed in Table 3. were visited to conduct Through-The-Probe (TTP) ozone Performance Evaluations (PE).

Table 3. Site Ozone PE Visits

<u>Site ID</u>	<u>Sponsor Agency</u>	<u>Site Location</u>	<u>Visit dates</u>
CAN407	NPS	Canyonlands NP	4/19/2013
CHA467	NPS	Chiricahua NM	4/1/1013
DEN417	NPS	Denali NP	6/15/2013
GRB411	EPA	Great Basin NP	4/16/2013
GRC474	NPS	Grand Canyon NP	4/4/2013
JOT403	NPS	Joshua Tree NP	4/8/2013
MCK231	EPA	Mackville (precision site)	5/18/2013
MEV405	NPS	Mesa Verde NP	4/18/2013
MOR409	NPS	Mount Rainier NP	6/17/2013
PET427	NPS	Petrified Forest NP	4/2/2013
PNF126	EPA	Cranberry	5/12/2013

1.4 Audit Results

The observations and results of the systems and performance audits are included in Appendix A, *Audit Report Forms* by site, arranged by audit date.

One kilometer, five kilometer, and forty kilometer radius maps are only included for those sites not previously audited. Other photographs of site conditions are included within each systems report where necessary.

Copies of the spot reports that were sent immediately following the audit of each site are included as Appendix B, *Site Spot Report Forms*.

The Ozone PE results and observations are included in Appendix C, *Ozone Performance Evaluation Forms*.

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates three precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 200 sites. The Atmospheric Integrated Research Monitoring Network (AIRMoN) began operation in 1992 and currently measures event based precipitation events at 7 sites. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from more than 100 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry.

The NADP Program Office operates and administers the three precipitation chemistry networks (NTN, MDN and AIRMoN), two atmospheric concentration networks (AMNet and AMoN), two analytical laboratories (the Central Analytical Laboratory (CAL) located at the University of Illinois/Illinois State Water Survey and the Mercury Analytical Laboratory (HAL) located at Frontier Global Sciences), and the network equipment depot (NED).

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites along with its operations. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 Sites Visited Second Quarter 2013

This report covers the results from the NADP sites surveyed during the first quarter (April through June) of 2013. The station name and dates of the audits are presented in Table 4.

Table 4. Sites Surveyed – Second Quarter 2013

Side ID	Network	Survey Date	Station Name
AK01	NTN	6/14/2013	Poker Creek
AK03	NTN	6/15/2013	Denali National Park-Mt. McKinley
AK06	MDN/NTN	6/14/2013	Gates of the Arctic National Park - Bettles
AK97	NTN	6/9/2013	Katmai National Park-King Salmon
AK98	MDN	6/11/2013	Kodiak
AZ02	MDN	4/3/2013	Sycamore Canyon
CA20	MDN	5/9/2013	Yurok Tribe-Requa
CA42	NTN	4/10/2013	Tanbark Flat
CA45	NTN	5/6/2013	Hopland
CA50	NTN	4/28/2013	Sagehen Creek
CA66	NTN	4/11/2013	Pinnacles National Monument-Bear Valley
CA67	NTN/AMoN	4/8/2013	Joshua Tree National Park-Black Rock
CA75	MDN/NTN	5/3/2013	Sequoia National Park-Giant Forest
CA76	NTN	5/10/2013	Montague
CA88	NTN	4/30/2013	Davis
CA94	MDN/NTN	4/9/2013	Converse Flats
CA96	NTN	5/7/2013	Lassen Volcanic National Park-Manzanita Lake
CA99	NTN	5/1/2013	Yosemite National Park - Hogdon Meadow
IN34	NTN	4/23/2013	Indiana Dunes National Lakeshore
KY35	NTN	5/7/2013	Clark State Fish Hatchery
MA01	MDN/NTN	5/21/2013	North Atlantic Coastal Lab
MA08	NTN	5/22/2013	Quabbin Reservoir
MD08	MDN/NTN/AMoN	5/10/2013	Piney Reservoir
MD15	NTN	5/28/2013	Smith Island
MD18	NTN	5/24/2013	Assateague Island National Seashore-Woodcock

Side ID	Network	Survey Date	Station Name
MT07	NTN	6/5/2013	Clancy
MT95	MDN	6/3/2013	Badger Peak
NY96	NTN	5/23/2013	Cedar Beach, Southold
OH17	NTN	5/8/2013	Delware
SC03	MDN/NTN	4/2/2013	Savannah River
TN00	AIRMoN	4/29/2013	Walker Branch Watershed
WA98	NTN	6/17/2013	Columbia River Gorge
WV05	NTN	4/20/2013	Cedar Creek State Park
WV18	NTN	4/19/2013	Parsons
WY00	NTN	5/14/2013	Snowy Range
WY02	NTN	5/15/2013	Sinks Canyon
WY06	NTN	5/12/2013	Pinedale
WY08	MDN/NTN	6/4/2013	Yellowstone National Park-Tower Falls
WY26	MDN	5/16/2013	Roundtop Mountain
WY95	NTN	5/14/2013	Brooklyn Lake
WY97	NTN	5/15/2013	South Pass City
WY98	NTN	5/13/2013	Gypsum Creek

2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to EEMS' server where the NADP PO and the U.S. EPA POs can access them and download them as needed by login into the server site.

Given the volume of data generated, and the fact that data is distributed and/or is available through EEMS' server, no survey results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PIN414-Eric Hebert-04/11/2013</i>						
1	4/11/2013	Computer	Gateway	none	Solo	unknown
2	4/11/2013	DAS	Environmental Sys Corp	90612	8816	2615
3	4/11/2013	Elevation	Elevation	None	1	None
4	4/11/2013	F460 translator	Climatronics	none	100163	788
5	4/11/2013	Filter pack flow pump	Thomas	none	107CA18	1088002897
6	4/11/2013	Flow Rate	Tylan	03385	FC280	AW9403017
7	4/11/2013	Infrastructure	Infrastructure	none	none	none
8	4/11/2013	MFC power supply	Tylan	03685	RO-32	FP9404005
9	4/11/2013	Modem	US Robotics	none	33.6 fax modem	unknown
10	4/11/2013	Ozone	ThermoElectron Inc	90765	49C	49c-74530376
11	4/11/2013	Ozone Standard	ThermoElectron Inc	90752	49C	49C-74532-376
12	4/11/2013	Precipitation	Climatronics	91040	100508-2	illegible
13	4/11/2013	Printer	Hewlett Packard	none	842C	unknown
14	4/11/2013	Relative Humidity	Vaisala	none	HMP45ASP	A1040016
15	4/11/2013	Sample Tower	Aluma Tower	928348	B	AT-5381-F9-3
16	4/11/2013	Shelter Temperature	ARS	none	none	none
17	4/11/2013	Siting Criteria	Siting Criteria	None	1	None
18	4/11/2013	Solar Radiation	Licor	none	LI-200	PY29490
19	4/11/2013	Solar Radiation Translator	Climatronics	none	100144	350
20	4/11/2013	Temperature	Climatronics	none	100093	missing
21	4/11/2013	Temperature Translator	Climatronics	none	100088-2	397
22	4/11/2013	Wind Direction	Climatronics	none	100076	1808
23	4/11/2013	Wind Speed	Climatronics	91053	100076	4559
24	4/11/2013	Zero air pump	Werther International	none	PC 70/4	000706555

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2615	PIN414	Eric Hebert	04/11/2013	DAS	Primary

Das Date:	<input type="text" value="4 /11/2013"/>	Audit Date	<input type="text" value="4 /11/2013"/>
Das Time:	<input type="text" value="17:03:30"/>	Audit Time	<input type="text" value="17:04:10"/>
Das Day:	<input type="text" value="101"/>	Audit Day	<input type="text" value="101"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0003"/>	Max Diff:	<input type="text" value="0.0007"/>
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
2	0.0000	0.0000	-0.0001	V	V	-0.0001
2	0.1000	0.1000	0.1000	V	V	0.0000
2	0.3000	0.3000	0.3001	V	V	0.0001
2	0.5000	0.5000	0.5003	V	V	0.0003
2	0.7000	0.7000	0.7004	V	V	0.0004
2	0.9000	0.9000	0.9005	V	V	0.0005
2	1.0000	1.0000	1.0007	V	V	0.0007
9	0.0000	0.0000	0.0000	V	V	0.0000
9	0.1000	0.1000	0.1002	V	V	0.0002
9	0.3000	0.3000	0.3000	V	V	0.0000
9	0.5000	0.5000	0.4999	V	V	-0.0001
9	0.7000	0.7000	0.7002	V	V	0.0002
9	0.9000	0.9000	0.8999	V	V	-0.0001
9	1.0000	1.0000	1.0002	V	V	0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403017		PIN414	Eric Hebert	04/11/2013	Flow Rate	03385

Mfg	Tylan
SN/Owner ID	FP9404005 03685
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.11%	0.14%

Cal Factor Zero	0
Cal Factor Full Scale	0
Rotometer Reading:	2.95

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.53	-0.476	0.03	l/m	l/m	
primary	leak check	0.000	0.000	-0.53	-0.476	0.03	l/m	l/m	
primary	test pt 1	0.000	3.024	2.49	2.254	3.02	l/m	l/m	-0.14%
primary	test pt 2	0.000	3.023	2.49	2.254	3.02	l/m	l/m	-0.11%
primary	test pt 3	0.000	3.022	2.49	2.254	3.02	l/m	l/m	-0.07%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	Filter Depth	Condition	0.0 cm	Status	pass
Sensor Component	Filter Position	Condition	Fair	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49c-74530376		PIN414	Eric Hebert	04/11/2013	Ozone	90765

Slope:	0.98686	Slope:	0.00000
Intercept	0.13471	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.1%	1.7%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.05	-0.13	-0.01	ppb	
primary	2	30.65	30.55	30.03	ppb	-1.70%
primary	3	49.69	49.64	49.40	ppb	-0.48%
primary	4	84.48	84.53	83.76	ppb	-0.91%
primary	5	109.50	109.62	108.10	ppb	-1.39%

Sensor Component	Cell B Noise	Condition	0.4 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	1.0016	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	1.2	Status	pass
Sensor Component	Span	Condition	1.002	Status	pass
Sensor Component	Cell B Freq.	Condition	72.1 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.75 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	38.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	707 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	77.2 kHz	Status	Fail
Sensor Component	Cell A Flow	Condition	0.76 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0006	Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	4559		PIN414	Eric Hebert	04/11/2013	Wind Speed	91053

Mfg	Climatronics
SN/Owner ID	788 none
Parameter	F460 translator

Prop or Cups SN

Prop or Cups Torque to

Prop Correction Fact

Mfg	RM Young	Parameter	wind speed
Serial Number	<input type="text"/>	Tfer Desc.	wind speed motor (h
Tfer ID	01262		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind speed
Serial Number	<input type="text"/>	Tfer Desc.	wind speed motor (l
Tfer ID	01261		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.01"/>	<input type="text" value="0.28%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.03"/>	<input type="text" value="0.33%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	00000	0	0.20	0.000	0.2		0.03
primary	00000	50	1.40	0.000	1.4		0.00
primary	00000	100	2.57	0.000	2.6		0.01
primary	00000	170	4.22	0.000	4.2		0.01
primary	00000	250	6.10	0.000	6.1	0.33%	
primary	00000	500	11.97	0.000	12.0	0.17%	
primary	00000	800	19.02	0.000	19.1	0.32%	
primary	00000	2000	47.22	0.000	47.4	0.30%	

Sensor Component	System Memo	Condition	<input type="text"/>	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Sensor Heater	Condition	N/A	Status	pass
Sensor Component	Prop or Cups Condition	Condition	Good	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Torque	Condition	Fair	Status	pass

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	1808		PIN414	Eric Hebert	04/11/2013	Wind Direction	none

Mfg	Climatronics
SN/Owner ID	788 none
Parameter	F460 translator

Vane SN: 3503 C. A. Align. deg. true: 3
 Vane Torque 8 to 8

Mfg	Ushikata	Parameter	wind direction
Serial Number	190037	Tfer Desc.	transit
Tfer ID	01265		
Slope	1.00000	Intercept	0.00000
Cert Date	1/4/2011	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind direction
Serial Number		Tfer Desc.	wind direction wheel
Tfer ID	01266		

DAS 1:	DAS 2:		
Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err 3.4	2.3		
Abs Max Er 6	6		

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01266	0	<input checked="" type="checkbox"/>	0.000	0	0	46	1
primary	01266	45	<input checked="" type="checkbox"/>	0.000	43	2	43	-2
primary	01266	90	<input checked="" type="checkbox"/>	0.000	87	3	44	-1
primary	01266	135	<input checked="" type="checkbox"/>	0.000	132	3	45	0
primary	01266	180	<input checked="" type="checkbox"/>	0.000	183	3	51	6
primary	01266	225	<input checked="" type="checkbox"/>	0.000	223	2	40	-5
primary	01266	270	<input checked="" type="checkbox"/>	0.000	270	0	47	2
primary	01266	315	<input checked="" type="checkbox"/>	0.000	314	1	44	-1
primary	01265	3	<input type="checkbox"/>	0.000	0	3		3
primary	01265	93	<input type="checkbox"/>	0.000	88	5		5
primary	01265	93	<input type="checkbox"/>	0.000	87	6		6
primary	01265	183	<input type="checkbox"/>	0.000	183	0		0
primary	01265	273	<input type="checkbox"/>	0.000	270	3		3

Sensor Component	Mast	Condition	Good	Status	pass
Sensor Component	Condition	Condition	Poor	Status	Fail
Sensor Component	Sensor Heater	Condition	N/A	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Torque	Condition	Good	Status	pass
Sensor Component	Vane Condition	Condition	Good	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	missing		PIN414	Eric Hebert	04/11/2013	Temperature	none

Mfg	Climatronics
SN/Owner ID	397 none
Parameter	Temperature Translator

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.08	0.11		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.07	0.05	0.000	0.2	C	0.1
primary	Temp Mid Range	17.35	17.35	0.000	17.2	C	-0.11
primary	Temp High Range	45.87	45.66	0.000	45.7	C	0.02

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	A1040016		PIN414	Eric Hebert	04/11/2013	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	124432	Tfer Desc.	Hygroclip
Tfer ID	01225		
Slope	1.00000	Intercept	0.00000
Cert Date	1/29/2013	CorrCoff	1.00000

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	2.5	4.0		
Abs Max Er	4.2	4.0		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	30.3	32.8	0.320	32.0	-0.8
primary	RH Low Range	Hygroclip	52.9	48.9	52.9	0.487	48.7	-4.2
primary	RH High Range	Hygroclip	93.6	88.1	93.6	0.896	89.6	-4.0

Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	illegible		PIN414	Eric Hebert	04/11/2013	Precipitation	91040

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.0%	4.0%		

Mfg	PMP	Parameter	Precipitation
Serial Number	EW-06134-50	Tfer Desc.	250ml graduate
Tfer ID	01250		
Slope	1.00000	Intercept	0.00000
Cert Date	9/5/2005	CorrCoff	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	2 sec	1.00	1.00	mm	mm	ml	
primary	test 1	231.5	1	10 sec	5.00	5.00	mm	mm	ml	0.0%
primary	test 2	231.5	2	10 sec	5.00	4.80	mm	mm	ml	-4.0%

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Heater	Condition	Not functioning	Status	Fail
Sensor Component	Properly Sited	Condition	See comments	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Not installed	Status	Fail
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Fair	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Alan pre-fab"/>	<input type="text" value="s/n 861168 1808"/>	<input type="text" value="512 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="1/2 inch Teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	PIN414	Eric Hebert	04/11/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.28	2.09		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	20.17	20.15	0.000	22.2	C	2.09
primary	Temp Mid Range	24.51	24.45	0.000	23.4	C	-1.04
primary	Temp Mid Range	22.50	22.46	0.000	23.2	C	0.71

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	PIN414	Eric Hebert	04/11/2013	Cell B Freq.	ThermoElectron	2770	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	PIN414	Eric Hebert	04/11/2013	Cell A Freq.	ThermoElectron	2770	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Precipitation	PIN414	Eric Hebert	04/11/2013	Properly Sited	Climatronics	2767	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Objects violate the 45 degree rule for the tipping bucket rain gage.								
Precipitation	PIN414	Eric Hebert	04/11/2013	Sensor Heater	Climatronics	2767	<input type="checkbox"/>	<input type="checkbox"/>
The tipping bucket rain gauge heater is not functioning.								
Wind Direction	PIN414	Eric Hebert	04/11/2013	Condition	Climatronics	3738	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.								

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator reported that the flow pump is routinely turned on while the tower is down after the dry deposition filter is installed. She reported that she was instructed by ARS to operate the flow pump while the tower was in the down position to check for proper filter pack installation. It was discussed that this is not a proper check of filter installation since air flow could be going through the connector with the connector completely locked in place. The operator reported that the plastic bag is used to handle the filter and that gloves are not used. The site operator reported that the ozone inlet filter is changed while the dry deposition filter is still installed and exposed on the tower.

2 Parameter: SiteOpsProcedures

The site operator reviews data each week to ensure proper operation of sensors and instruments.

3 Parameter: ShelterCleanNotes

Shelter has some loose tiles and signs of a leak in the SW corner. It is somewhat cluttered with equipment that is unused and some that requires installation. The lighting is poor.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="North Chalone Peak"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="36.4850"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-121.1556"/>
Land Use	<input type="text" value="woodland - scrub"/>	QAPP Elevation Meters	<input type="text" value="335"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(831) 389-4586"/>	Audit Latitude	<input type="text" value="36.483235"/>
Site Address 1	<input type="text" value="5000 Hwy 146"/>	Audit Longitude	<input type="text" value="-121.156876"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="317"/>
County	<input type="text" value="San Benito"/>	Audit Declination	<input type="text" value="13.5"/>
City, State	<input type="text" value="Paicines, CA"/>		
Zip Code	<input type="text" value="95043"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="inspected 5/19/2012"/>
Time Zone	<input type="text" value="Pacific"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|--------------------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | 1/2 bubble off level |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | 45 degree rule violation |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged? N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Precipitation	Climatronics	100508-2	illegible	91040
Solar Radiation	Licor	LI-200	PY29490	none
Relative Humidity	Vaisala	HMP45ASP	A1040016	none
Temperature	Climatronics	100093	missing	none
Wind Direction	Climatronics	100076	1808	none
Wind Speed	Climatronics	100076	4559	91053

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 1/2 teflon by 10 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-5381-F9-3	928348
Ozone	ThermoElectron Inc	49C	49c-74530376	90765
MFC power supply	Tylan	RO-32	FP9404005	03685
Filter pack flow pump	Thomas	107CA18	1088002897	none
Zero air pump	Werther International	PC 70/4	000706555	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- Stable**

Grounded
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Gateway	Solo	unknown	none
DAS	Environmental Sys Corp	8816	2615	90612
F460 translator	Climatronics	100163	788	none
Modem	US Robotics	33.6 fax modem	unknown	none
Printer	Hewlett Packard	842C	unknown	none
Solar Radiation Translator	Climatronics	100144	350	none
Temperature Translator	Climatronics	100088-2	397	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID Technician Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Jan 2006"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text" value="Not current"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- Is the station log properly completed during every site visit?
- Are the Site Status Report Forms being completed and current?
- Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings 90%
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF and dataview checklists
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Bag used as glove, gloves not used
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator reported that the flow pump is routinely turned on while the tower is down after the dry deposition filter is installed. She reported that she was instructed by ARS to operate the flow pump while the tower was in the down position to check for proper filter pack installation. It was discussed that this is not a proper check of filter installation since air flow could be going through the connector with the connector completely locked in place. The operator reported that the plastic bag is used to handle the filter and that gloves are not used. The site operator reported that the ozone inlet filter is changed while the dry deposition filter is still installed and exposed on the tower.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

DCP114-Sandy Grenville-04/22/2013

1	4/22/2013	DAS	Campbell	000345	CR3000	2124
2	4/22/2013	Elevation	Elevation	None	1	None
3	4/22/2013	Filter pack flow pump	Thomas	04926	107CAB18	100300020819
4	4/22/2013	Flow Rate	Apex	000659	AXMC105LPMDPCV	54748
5	4/22/2013	Infrastructure	Infrastructure	none	none	none
6	4/22/2013	Modem	Raven	06479	H4222-C	0808311283
7	4/22/2013	Ozone	ThermoElectron Inc	000732	49i A1NAA	1105347319
8	4/22/2013	Ozone Standard	ThermoElectron Inc	000545	49i A3NAA	0929938241
9	4/22/2013	Sample Tower	Aluma Tower	000030	B	AT-81056-J-4
10	4/22/2013	Shelter Temperature	Campbell	none	107-L	none
11	4/22/2013	Siting Criteria	Siting Criteria	None	1	None
12	4/22/2013	Temperature	RM Young	02828	41342	illegible
13	4/22/2013	Zero air pump	Werther International	06939	PC70/4	000829175

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2124	DCP114	Sandy Grenville	04/22/2013	DAS	Primary

Das Date:	<input type="text" value="4 /22/2013"/>	Audit Date:	<input type="text" value="4 /22/2013"/>
Das Time:	<input type="text" value="14:31:37"/>	Audit Time:	<input type="text" value="14:31:37"/>
Das Day:	<input type="text" value="112"/>	Audit Day:	<input type="text" value="112"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0001	V	V	0.0001
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.2998	0.2998	V	V	0.0000
7	0.5000	0.4997	0.4998	V	V	0.0001
7	0.7000	0.6997	0.6997	V	V	0.0000
7	0.9000	0.8996	0.8997	V	V	0.0001
7	1.0000	0.9994	0.9995	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54748		DCP114	Sandy Grenville	04/22/2013	Flow Rate	000659

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00000	Intercept	0.00000
Cert Date	6/13/2012	CorrCoff	1.00000
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00000	Intercept	0.00000
Cert Date	1/27/2012	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.64%	1.70%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.09
Cal Factor Full Scale	0.98
Rotometer Reading:	1.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.01	0.007	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.001	-0.02	l/m	l/m	
primary	test pt 1	1.541	1.524	1.53	1.518	1.50	l/m	l/m	-1.57%
primary	test pt 2	1.542	1.525	1.52	1.515	1.50	l/m	l/m	-1.64%
primary	test pt 3	1.543	1.526	1.52	1.518	1.50	l/m	l/m	-1.70%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	Not tested	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347319	DCP114	Sandy Grenville	04/22/2013	Ozone	000732

Slope:	0.99300	Slope:	0.00000
Intercept	0.92403	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.0%	2.6%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00308	Intercept	-0.17961
Cert Date	4/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.00	0.17	1.17	ppb	
primary	2	31.00	31.08	31.90	ppb	2.64%
primary	3	50.74	50.76	51.09	ppb	0.65%
primary	4	80.16	80.09	80.30	ppb	0.26%
primary	5	103.74	103.60	104.00	ppb	0.39%

Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	< 1 %	Status	pass
Sensor Component	Offset	Condition	-0.60	Status	pass
Sensor Component	Span	Condition	0.998	Status	pass
Sensor Component	Cell B Freq.	Condition	99.5 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.73 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	725 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	113.8 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.74 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	illegible		DCP114	Sandy Grenville	04/22/2013	Temperature	02828

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.13	0.15		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.10	-0.02	0.000	0.1	C	0.1
primary	Temp Mid Range	24.51	24.49	0.000	24.6	C	0.15
primary	Temp High Range	48.36	48.23	0.000	48.4	C	0.13

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower Status Switch	Condition	Functioning	Status	pass
Sensor Component	Blower	Condition	Not functioning	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-13)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	DCP114	Sandy Grenville	04/22/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.11	0.12		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	25.84	25.81	0.000	25.7	C	-0.1
primary	Temp Mid Range	25.14	25.12	0.000	25.0	C	-0.11
primary	Temp Mid Range	25.07	25.05	0.000	24.9	C	-0.12

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Temperature	DCP114	Sandy Grenville	04/22/2013	Blower	RM Young	1006	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The forced-air blower for the shield is not functioning.								

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator is following procedures and doing a very good job with filter handling.

2 Parameter: DasComments

One leg of the meteorological sensor tower is damaged and has a hole near the midpoint of the tower.

3 Parameter: SiteOpsProcedures

The ozone inlet filter is replaced and the sample line is leak-tested every two weeks.

4 Parameter: SitingCriteriaCom

The site is located in a wooded thicket within a state park. The area surrounding the park is almost completely intensive agriculture. The site may not be regionally representative.

5 Parameter: ShelterCleanNotes

The shelter is currently in fair condition. There are loose floor tiles. There are signs of rodent infestation.

6 Parameter: MetOpMaintCom

The blower for the aspirated temperature sensor shield is not functioning. This will affect sensor accuracy and data quality.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Mount Sterling"/>
Operating Group	<input type="text" value="private / state"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="39-047-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="39.6358"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-83.2600"/>
Land Use	<input type="text" value="agriculture, woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="267"/>
Terrain	<input type="text" value="flat"/>	QAPP Declination	<input type="text" value="6.25"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/23/2006"/>
Site Telephone	<input type="text" value="(740) 869-4722"/>	Audit Latitude	<input type="text" value="39.635888"/>
Site Address 1	<input type="text" value="Waterloo Road"/>	Audit Longitude	<input type="text" value="-83.260563"/>
Site Address 2	<input type="text" value="Deer Creek State Park"/>	Audit Elevation	<input type="text" value="264"/>
County	<input type="text" value="Fayette"/>	Audit Declination	<input type="text" value="-6.3"/>
City, State	<input type="text" value="Mount Sterling, OH"/>		
Zip Code	<input type="text" value="43143"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="none"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	15 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located in a wooded thicket within a state park. The area surrounding the park is almost completely intensive agriculture. The site may not be regionally representative.

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- | | | | |
|---|--|-------------------------------------|------------------|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | Moderately clean |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | Not functioning |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	illegible	02828

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The blower for the aspirated temperature sensor shield is not functioning. This will affect sensor accuracy and data quality.

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? Small trees within 10 meters

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-81056-J-4	000030
Filter pack flow pump	Thomas	107CAB18	100300020819	04926
Zero air pump	Werther International	PC70/4	000829175	06939
Ozone	ThermoElectron Inc	49i A1NAA	1105347319	000732

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Towers are not grounded

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR3000	2124	000345
Modem	Raven	H4222-C	0808311283	06479

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

One leg of the meteorological sensor tower is damaged and has a hole near the midpoint of the tower.

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|--------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | Filter changed morinings |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input checked="" type="checkbox"/> | |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | No longer required |
| 4 | Are general observations being made and recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF, call-in |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | Clean gloves on and off |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is following procedures and doing a very good job with filter handling.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>SAN189-Sandy Grenville-04/25/2013</i>						
1	4/25/2013	Computer	Dell	000271	D520	unknown
2	4/25/2013	DAS	Campbell	000360	CR3000	2138
3	4/25/2013	Elevation	Elevation	None	1	None
4	4/25/2013	Filter pack flow pump	Thomas	06026	107CAB18	060400022659
5	4/25/2013	flow rate	Tylan	000174	FC280SAV	AW423006
6	4/25/2013	Infrastructure	Infrastructure	none	none	none
7	4/25/2013	MFC power supply	MACTEC	none	none	none
8	4/25/2013	Modem	Raven	06453	V4221-V	0808337397
9	4/25/2013	Ozone	ThermoElectron Inc	000740	49i A1NAA	1105347311
10	4/25/2013	Ozone Standard	ThermoElectron Inc	000444	49i A3NAA	CM08200020
11	4/25/2013	Sample Tower	Aluma Tower	000207	B	none
12	4/25/2013	Shelter Temperature	Campbell	none	107-L	223461
13	4/25/2013	Siting Criteria	Siting Criteria	None	1	None
14	4/25/2013	Temperature	RM Young	06537	41342VC	14798
15	4/25/2013	Zero air pump	Werther International	06875	C 70/4	000814272

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2138	SAN189	Sandy Grenville	04/25/2013	DAS	Primary

Das Date:	<input type="text" value="4 /25/2013"/>	Audit Date	<input type="text" value="4 /25/2013"/>
Das Time:	<input type="text" value="15:46:01"/>	Audit Time	<input type="text" value="15:46:01"/>
Das Day:	<input type="text" value="115"/>	Audit Day	<input type="text" value="115"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2999	0.2998	V	V	-0.0001
7	0.5000	0.4997	0.4997	V	V	0.0000
7	0.7000	0.6997	0.6996	V	V	-0.0001
7	0.9000	0.8996	0.8995	V	V	-0.0001
7	1.0000	0.9994	0.9993	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW423006		SAN189	Sandy Grenville	04/25/2013	flow rate	000174

Mfg	MACTEC	
SN/Owner ID	none	none
Parameter	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00000	Intercept	0.00000
Cert Date	6/13/2012	CorrCoff	1.00000
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00000	Intercept	0.00000
Cert Date	1/27/2012	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.13%	1.15%

Cal Factor Zero	-0.02
Cal Factor Full Scale	1.01
Rotometer Reading:	1.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.11	-0.011	-0.03	l/m	l/m	
primary	leak check	0.000	0.000	-0.11	-0.011	-0.03	l/m	l/m	
primary	test pt 1	3.121	2.966	2.82	2.816	3.00	l/m	l/m	1.15%
primary	test pt 2	3.121	2.966	2.82	2.817	3.00	l/m	l/m	1.15%
primary	test pt 3	3.121	2.968	2.82	2.816	3.00	l/m	l/m	1.08%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	Filter Depth	Condition	3.5 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	3.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347311	SAN189	Sandy Grenville	04/25/2013	Ozone	000740

Slope:	0.95175	Slope:	0.00000
Intercept	1.21042	Intercept	0.00000
CorrCoff	0.99993	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
3.0%	3.6%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00308	Intercept	-0.17961
Cert Date	4/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.00	0.17	1.85	ppb	
primary	2	30.02	30.10	29.50	ppb	-1.99%
primary	3	51.62	51.64	49.76	ppb	-3.64%
primary	4	82.16	82.08	79.69	ppb	-2.91%
primary	5	101.29	101.15	97.60	ppb	-3.51%

Sensor Component	Cell B Noise	Condition	0.4 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	< 1 %	Status	pass
Sensor Component	Offset	Condition	-0.10	Status	pass
Sensor Component	Span	Condition	1.005	Status	pass
Sensor Component	Cell B Freq.	Condition	83.7 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.65 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.9 C	Status	pass
Sensor Component	Cell A Pressure	Condition	688 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.4 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	92.0 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14798		SAN189	Sandy Grenville	04/25/2013	Temperature	06537

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.11	0.24		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.32	0.40	0.000	0.5	C	0.09
primary	Temp Mid Range	24.20	24.18	0.000	24.2	C	-0.01
primary	Temp High Range	48.31	48.19	0.000	48.0	C	-0.24

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	Functioning	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Shelter One"/>	<input type="text" value="E8109-26012"/>	<input type="text" value="720 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="Pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="1/4 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	223461	SAN189	Sandy Grenville	04/25/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.34	0.65		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	27.38	27.35	0.000	27.4	C	0.04
primary	Temp Mid Range	27.38	27.35	0.000	27.7	C	0.32
primary	Temp Mid Range	23.36	23.34	0.000	22.7	C	-0.65

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator was observed to be not completely familiar with all aspects of CASTNET site operation. Additional training is recommended. Flow rate leak checks are not performed although they are reported. The initial and final flow rates are not recorded correctly. These observations were reported following the previous audit.

2 Parameter: SiteOpsProcedures

CASTNET procedures including filter pack leak check and filter pack final flow rate are not being performed correctly. Additional training is recommended.

3 Parameter: ShelterCleanNotes

The shelter is in very good condition, however somewhat cluttered.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Santee"/>
Operating Group	<input type="text" value="Santee Sioux Nation"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="31-107-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, SO2, NOx, CO"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="range"/>	QAPP Elevation Meters	<input type="text" value="429"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="6/21/2006"/>
Site Telephone	<input type="text" value="(402) 857-2546"/>	Audit Latitude	<input type="text" value="42.829154"/>
Site Address 1	<input type="text" value="SR S54D"/>	Audit Longitude	<input type="text" value="-97.854128"/>
Site Address 2	<input type="text" value="Santee Sioux Indian Reservation"/>	Audit Elevation	<input type="text" value="434"/>
County	<input type="text" value="Knox"/>	Audit Declination	<input type="text" value="5.0"/>
City, State	<input type="text" value="Niobrara, NE"/>		
Zip Code	<input type="text" value="68760"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Time Zone	<input type="text" value="Central"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Shelter One"/>	Model <input type="text" value="E8109-26012"/>	Shelter Size <input type="text" value="720 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in very good condition, however somewhat cluttered."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Yankton, South Dakota go south on route 81. Turn right (south) at the intersection of route 12 and continue approximately 26 miles. Just past the casino and gas station, turn right (north) onto SR 54 toward Santee. Continue approximately 6.5 miles. The site will be visible through the farm gate on the left at the top of a hill just before reaching Santee.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID

Technician

Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

N/A
N/A
N/A
N/A

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342VC	14798	06537

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 16 meters |
| 4 | Describe dry dep sample tube. | | 1/4 teflon by 16 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input type="checkbox"/> | |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input type="checkbox"/> | |

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	000207
MFC power supply	MACTEC	none	none	none
Ozone	ThermoElectron Inc	49i A1NAA	1105347311	000740
Filter pack flow pump	Thomas	107CAB18	060400022659	06026
Zero air pump	Werther International	C 70/4	000814272	06875

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000271
DAS	Campbell	CR3000	2138	000360
Modem	Raven	V4221-V	0808337397	06453

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2005	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2005	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

CASTNET procedures including filter pack leak check and filter pack final flow rate are not being performed correctly. Additional training is recommended.

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input type="checkbox"/>	<input type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> N/A	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was observed to be not completely familiar with all aspects of CASTNET site operation. Additional training is recommended. Flow rate leak checks are not performed although they are reported. The initial and final flow rates are not recorded correctly. These observations were reported following the previous audit.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

KNZ184-Sandy Grenville-04/26/2013

1	4/26/2013	Computer	Dell	000278	D520	unknown
2	4/26/2013	DAS	Campbell	000361	CR3000	2139
3	4/26/2013	Elevation	Elevation	None	1	None
4	4/26/2013	Filter pack flow pump	Thomas	04925	107CAB18D	100300020744
5	4/26/2013	Flow Rate	Apex	000654	AXMC105LPMDPCV	54774
6	4/26/2013	Infrastructure	Infrastructure	none	none	none
7	4/26/2013	Modem	Raven	06478	V4221-V	0808311141
8	4/26/2013	Ozone	ThermoElectron Inc	000616	49i A1NAA	1009241781
9	4/26/2013	Ozone Standard	ThermoElectron Inc	000495	49i A3NAA	0622717849
10	4/26/2013	Sample Tower	Aluma Tower	missing	B	none
11	4/26/2013	Shelter Temperature	Campbell	none	107-L	none
12	4/26/2013	Siting Criteria	Siting Criteria	None	1	None
13	4/26/2013	Temperature	RM Young	04686	41342VC	6700
14	4/26/2013	Zero air pump	Werther International	000626	PC 70/4	000815300

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2139	KNZ184	Sandy Grenville	04/26/2013	DAS	Primary

Das Date:	<input type="text" value="4 /26/2013"/>	Audit Date	<input type="text" value="4 /26/2013"/>
Das Time:	<input type="text" value="17:37:25"/>	Audit Time	<input type="text" value="17:37:25"/>
Das Day:	<input type="text" value="116"/>	Audit Day	<input type="text" value="116"/>

Low Channel:	High Channel:		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.2998	0.2998	V	V	0.0000
7	0.5000	0.4997	0.4997	V	V	0.0000
7	0.7000	0.6997	0.6997	V	V	0.0000
7	0.9000	0.8996	0.8995	V	V	-0.0001
7	1.0000	0.9995	0.9994	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54774		KNZ184	Sandy Grenville	04/26/2013	Flow Rate	000654

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00000	Intercept	0.00000
Cert Date	6/13/2012	CorrCoff	1.00000
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00000	Intercept	0.00000
Cert Date	1/27/2012	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.08%	0.13%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.01
Cal Factor Full Scale	1.01
Rotometer Reading:	3

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.002	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.006	0.00	l/m	l/m	
primary	test pt 1	3.048	2.994	2.96	2.954	2.99	l/m	l/m	-0.13%
primary	test pt 2	3.055	2.993	2.96	2.953	2.99	l/m	l/m	-0.10%
primary	test pt 3	3.051	2.990	2.96	2.948	2.99	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	Filter Depth	Condition	3.5 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	6700		KNZ184	Sandy Grenville	04/26/2013	Temperature	04686

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.17	0.19		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.04	0.12	0.000	0.3	C	0.17
primary	Temp Mid Range	27.26	27.23	0.000	27.4	C	0.14
primary	Temp High Range	48.58	48.45	0.000	48.6	C	0.19

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	Functioning	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Wells Cargo"/>	<input type="text" value="EW1211 (s/n 1WC200E1623048028)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	KNZ184	Sandy Grenville	04/26/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.93	1.17		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	24.93	24.91	0.000	23.7	C	-1.17
primary	Temp Mid Range	26.84	26.81	0.000	25.9	C	-0.95
primary	Temp Mid Range	27.00	26.97	0.000	26.3	C	-0.67

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

One clean glove is used to handle the filter for removal and installation.

2 **Parameter:** SiteOpsProcedures

Ozone monitor not operating.

3 **Parameter:** SitingCriteriaCom

The site is located at a Long Term Ecological Research site operated by KSU.

4 **Parameter:** ShelterCleanNotes

The shelter is very clean, neat, well organized and well maintained.

5 **Parameter:** PollAnalyzerCom

By request of the Kansas Department of Health and Environment, the site ozone monitor was not operating at the time of the site audit.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Swede Creek"/>
Operating Group	<input type="text" value="Kansas State University"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="20-161-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="39.1021"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-96.6096"/>
Land Use	<input type="text" value="range"/>	QAPP Elevation Meters	<input type="text" value="348"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text" value="4.5"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="01/07/2005"/>
Site Telephone	<input type="text" value="(785) 770-8426"/>	Audit Latitude	<input type="text" value="39.10216"/>
Site Address 1	<input type="text" value="Konza Prairie Lane"/>	Audit Longitude	<input type="text" value="-96.609583"/>
Site Address 2	<input type="text" value="CR 901"/>	Audit Elevation	<input type="text" value="346"/>
County	<input type="text" value="Riley"/>	Audit Declination	<input type="text" value="4.2"/>
City, State	<input type="text" value="Manhattan, KZ"/>		
Zip Code	<input type="text" value="66502"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Feb 2002"/>
Time Zone	<input type="text" value="central"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Wells Cargo"/>	Model <input type="text" value="EW1211 (s/n 1WC20)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is very clean, neat, well organized and well maintained."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO ₂ or NO _x	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- | | | | |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | N/A |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | N/A |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342VC	6700	04686

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	missing
Ozone	ThermoElectron Inc	49i A1NAA	1009241781	000616
Filter pack flow pump	Thomas	107CAB18D	100300020744	04925
Zero air pump	Werther International	PC 70/4	000815300	000626

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

By request of the Kansas Department of Health and Environment, the site ozone monitor was not operating at the time of the site audit.

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000278
DAS	Campbell	CR3000	2139	000361
Modem	Raven	V4221-V	0808311141	06478

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|-----------------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | Filter changed morinings |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input checked="" type="checkbox"/> | |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | No longer required |
| 4 | Are general observations being made and recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF, call-in |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | Clean glove (one only) on and off |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> <input type="text"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

YOS404-Eric Hebert-05/01/2013

1	5/1/2013	DAS	Environmental Sys Corp	90645	8816	2558
2	5/1/2013	Elevation	Elevation	None	1	None
3	5/1/2013	F460 translator	Climatronics	none	100163	1101
4	5/1/2013	Filter pack flow pump	Thomas	00253	107CA18	0688001767
5	5/1/2013	flow rate	Tylan	none	FC280SAV	AW02213002
6	5/1/2013	Infrastructure	Infrastructure	none	none	none
7	5/1/2013	Met tower	unknown	none	unknown	none
8	5/1/2013	MFC power supply	Tylan	03870	RO-32	FP9508008
9	5/1/2013	Modem	US Robotics	none	V.92	unknown
10	5/1/2013	Ozone	ThermoElectron Inc	90763	49C	49C-74534-376
11	5/1/2013	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130450190
12	5/1/2013	Precipitation	Climatronics	illegible	100508-2	illegible
13	5/1/2013	Relative Humidity	Rotronic	none	MP 601A	59018
14	5/1/2013	Sample Tower	Aluma Tower	none	B	none
15	5/1/2013	Shelter Temperature	ARS	none	none	none
16	5/1/2013	Siting Criteria	Siting Criteria	None	1	None
17	5/1/2013	Solar Radiation	Licor	none	LI-200	PY77051
18	5/1/2013	Solar Radiation Translator	RM Young	03184	70101-X	none
19	5/1/2013	Temperature	RM Young	none	41342	18748
20	5/1/2013	Wind Direction	Climatronics	90832	100076	4058
21	5/1/2013	Wind Speed	Climatronics	91022	100075	4088
22	5/1/2013	Zero air pump	Werther International	none	PC70/4	531397

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2558	YOS404	Eric Hebert	05/01/2013	DAS	Primary

Das Date: **Audit Date:**
Das Time: **Audit Time:**
Das Day: **Audit Day:**

Low Channel: **High Channel:**
Avg Diff: **Max Diff:** **Avg Diff:** **Max Diff:**

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
6	0.0000	0.0000	0.0000	V	V	0.0000
6	0.1000	0.1000	0.1000	V	V	0.0000
6	0.3000	0.3000	0.3000	V	V	0.0000
6	0.5000	0.5000	0.5000	V	V	0.0000
6	0.7000	0.7000	0.7001	V	V	0.0001
6	0.9000	0.9001	0.9001	V	V	0.0000
6	1.0000	1.0001	1.0001	V	V	0.0000
15	0.0000	0.0000	0.0000	V	V	0.0000
15	0.1000	0.1000	0.0999	V	V	-0.0001
15	0.3000	0.3000	0.3001	V	V	0.0001
15	0.5000	0.5000	0.4999	V	V	-0.0001
15	0.7000	0.7000	0.6999	V	V	-0.0001
15	0.9000	0.9000	0.8997	V	V	-0.0003
15	1.0000	1.0000	0.9999	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW02213002		YOS404	Eric Hebert	05/01/2013	flow rate	none

Mfg	Tylan
SN/Owner ID	FP9508008 03870
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
3.14%	3.22%

Cal Factor Zero	0.28
Cal Factor Full Scale	10.88
Rotometer Reading:	3.45

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.20	-0.1670	-0.07	l/m	l/m	
primary	leak check	0.000	0.000	-0.19	-0.1680	-0.06	l/m	l/m	
primary	test pt 1	0.000	3.086	1.26	1.2770	2.99	l/m	l/m	-3.10%
primary	test pt 2	0.000	3.090	1.26	1.2770	2.99	l/m	l/m	-3.22%
primary	test pt 3	0.000	3.086	1.26	1.2770	2.99	l/m	l/m	-3.11%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	135 deg	Status	pass
Sensor Component	Filter Depth	Condition	- 1.0 cm	Status	Fail
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	3.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-74534-376		YOS404	Eric Hebert	05/01/2013	Ozone	90763

Slope:	1.00354	Slope:	0.00000
Intercept	-0.98519	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.3%	1.9%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.65	0.46	-0.72	ppb	
primary	2	30.22	30.12	29.56	ppb	-1.86%
primary	3	49.95	49.90	48.96	ppb	-1.88%
primary	4	79.75	79.78	79.21	ppb	-0.71%
primary	5	109.60	109.72	109.00	ppb	-0.66%

Sensor Component	Cell B Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	1.0031	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.3	Status	pass
Sensor Component	Span	Condition	1.012	Status	pass
Sensor Component	Cell B Freq.	Condition	85.1 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.62 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.5 C	Status	pass
Sensor Component	Cell A Pressure	Condition	621 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	2.0 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	78.6kHz	Status	Fail
Sensor Component	Cell A Flow	Condition	0.62 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0044	Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	4088		YOS404	Eric Hebert	05/01/2013	Wind Speed	91022

Mfg	Climatronics
SN/Owner ID	1101 none
Parameter	F460 translator

Prop or Cups SN	2335
Prop or Cups Torque	0.3 to 0.3
Prop Correction Fact	N/A

Mfg	RM Young	Parameter	wind speed
Serial Number		Tfer Desc.	wind speed motor (h
Tfer ID	01262		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind speed
Serial Number		Tfer Desc.	wind speed motor (l
Tfer ID	01261		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	0.02	0.70%		
Abs Max Er	0.03	0.75%		

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	00000	0	0.20	0.0000	0.2		0.02
primary	00000	50	1.40	0.0000	1.4		-0.01
primary	00000	100	2.57	0.0000	2.6		-0.01
primary	00000	170	4.22	0.0000	4.2		-0.03
primary	00000	250	6.10	0.0000	6.1	-0.66%	
primary	00000	500	11.97	0.0000	11.9	-0.75%	
primary	00000	800	19.02	0.0000	18.9	-0.68%	
primary	00000	2000	47.22	0.0000	46.9	-0.70%	

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Prop or Cups Condition	Condition	Good	Status	pass
Sensor Component	Condition	Condition	Poor	Status	Fail
Sensor Component	Torque	Condition	Good	Status	pass

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	4058		YOS404	Eric Hebert	05/01/2013	Wind Direction	90832

Mfg	Climatronics
SN/Owner ID	1101 none
Parameter	F460 translator

Vane SN: 3063 **C. A. Align. deg. true:**

Vane Torque 8 to 8 **2**

Mfg	Ushikata	Parameter	wind direction
Serial Number	190037	Tfer Desc.	transit
Tfer ID	01265		
Slope	1.00000	Intercept	0.00000
Cert Date	1/4/2011	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind direction
Serial Number		Tfer Desc.	wind direction wheel
Tfer ID	01266		

DAS 1:	DAS 2:		
Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	10.8	1.5	
Abs Max Er	13	4	

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01266	0	<input checked="" type="checkbox"/>	0.0000	353	7	46	1
primary	01266	45	<input checked="" type="checkbox"/>	0.0000	34	11	41	-4
primary	01266	90	<input checked="" type="checkbox"/>	0.0000	79	11	45	0
primary	01266	135	<input checked="" type="checkbox"/>	0.0000	124	11	45	0
primary	01266	180	<input checked="" type="checkbox"/>	0.0000	172	8	48	3
primary	01266	225	<input checked="" type="checkbox"/>	0.0000	215	10	43	-2
primary	01266	270	<input checked="" type="checkbox"/>	0.0000	261	9	46	1
primary	01266	315	<input checked="" type="checkbox"/>	0.0000	307	8	46	1
primary	01265	2	<input type="checkbox"/>	0.0000	353	9		9
primary	01265	92	<input type="checkbox"/>	0.0000	79	13		13
primary	01265	182	<input type="checkbox"/>	0.0000	172	10		10
primary	01265	272	<input type="checkbox"/>	0.0000	261	11		11

Sensor Component	Mast	Condition	Good	Status	pass
Sensor Component	Condition	Condition	Poor	Status	Fail
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Torque	Condition	Good	Status	pass
Sensor Component	Vane Condition	Condition	Poor	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	18748		YOS404	Eric Hebert	05/01/2013	Temperature	none

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.05	0.12		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.03	0.09	0.0000	0.1	C	-0.04
primary	Temp Mid Range	25.31	25.25	0.0000	25.3	C	0
primary	Temp High Range	47.26	47.04	0.0000	47.2	C	0.12

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Rotronic	59018		YOS404	Eric Hebert	05/01/2013	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	124432	Tfer Desc.	Hygroclip
Tfer ID	01225		
Slope	1.00000	Intercept	0.00000
Cert Date	1/29/2013	CorrCoff	1.00000

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	3.3	2.1		
Abs Max Er	4.3	2.1		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	34.8	32.8	0.3497	35.0	2.2
primary	RH Low Range	Hygroclip	52.9	55.1	52.9	0.5724	57.2	4.3
primary	RH High Range	Hygroclip	93.6	89.4	93.6	0.9574	95.7	2.1

Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	illegible		YOS404	Eric Hebert	05/01/2013	Precipitation	illegible

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.0%	4.0%		

Mfg	PMP	Parameter	Precipitation
Serial Number	EW-06134-50	Tfer Desc.	250ml graduate
Tfer ID	01250		
Slope	1.00000	Intercept	0.00000
Cert Date	9/5/2005	CorrCoff	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	2 sec	1.00	1.00	mm	mm	ml	
primary	test 1	231.5	1	8 sec	5.00	4.80	mm	mm	ml	-4.0%
primary	test 2	231.5	2	10 sec	5.00	4.90	mm	mm	ml	-2.0%

Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Not installed	Status	Fail
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Not installed	Status	Fail

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8812 (s/n 3515-2)"/>	<input type="text" value="768 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	YOS404	Eric Hebert	05/01/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
2.83	3.60		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	24.40	24.35	0.000	26.5	C	2.11
primary	Temp Mid Range	24.69	24.63	0.000	27.4	C	2.78
primary	Temp Mid Range	24.71	24.65	0.000	21.1	C	-3.6

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	YOS404	Eric Hebert	05/01/2013	Filter Position	Tylan	1254	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.								
Ozone	YOS404	Eric Hebert	05/01/2013	Cell A Freq.	ThermoElectron	438	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Wind Direction	YOS404	Eric Hebert	05/01/2013	Vane Condition	Climatronics	3750	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The wind direction vane is slightly bent and could be causing additional bias in wind direction measurements.								
Wind Direction	YOS404	Eric Hebert	05/01/2013	Condition	Climatronics	3750	<input type="checkbox"/>	<input type="checkbox"/>
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.								
Wind Speed	YOS404	Eric Hebert	05/01/2013	Condition	Climatronics	3751	<input type="checkbox"/>	<input type="checkbox"/>
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.								

Field Systems Comments

1 Parameter: PollAnalyzerCom

The DAS full scale and zero factors for the ozone channel are set to 497 and -3 respectively. The usual settings are 500 and 0. This may not be a problem but it does contribute to the error observed during the ozone accuracy check. It is possible that polled data at the central polling station have different factors.

2 Parameter: ShelterCleanNotes

The site is neat, clean, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="El Capitan"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="06-043-0003"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, CO, NOx, IMPROVE"/>	QAPP Latitude	<input type="text" value="37.7133"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-119.7061"/>
Land Use	<input type="text" value="mountain top, woodland - evergreen"/>	QAPP Elevation Meters	<input type="text" value="1605"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(209) 372-4411"/>	Audit Latitude	<input type="text" value="37.713251"/>
Site Address 1	<input type="text" value="Turtleback Dome"/>	Audit Longitude	<input type="text" value="-119.706196"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="1599"/>
County	<input type="text" value="Mariposa"/>	Audit Declination	<input type="text" value="13.5"/>
City, State	<input type="text" value="Yosemite National Park, CA"/>		
Zip Code	<input type="text" value="95389"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text" value="Not present"/>
Time Zone	<input type="text" value="Pacific"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8812 (s/n 3515-2)"/>	Shelter Size <input type="text" value="768 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The site is neat, clean, and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Mariposa take route 140 into Yosemite. From the loop road, take route 41 toward Oakhurst. Continue uphill and through the tunnel. Approximately one mile past the tunnel look for a dirt road on the left. Continue approximately 1/2 mile past the gate to the communication station at the top of Turtleback Dome. The site is another 100 yards on the path behind the station.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged? N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Precipitation	Climatronics	100508-2	illegible	illegible
Relative Humidity	Rotronic	MP 601A	59018	none
Met tower	unknown	unknown	none	none
Wind Direction	Climatronics	100076	4058	90832
Wind Speed	Climatronics	100075	4088	91022
Temperature	RM Young	41342	18748	none
Solar Radiation	Licor	LI-200	PY77051	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	none
Ozone	ThermoElectron Inc	49C	49C-74534-376	90763
Filter pack flow pump	Thomas	107CA18	0688001767	00253
MFC power supply	Tylan	RO-32	FP9508008	03870
Zero air pump	Werther International	PC70/4	531397	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The DAS full scale and zero factors for the ozone channel are set to 497 and -3 respectively. The usual settings are 500 and 0. This may not be a problem but it does contribute to the error observed during the ozone accuracy check. It is possible that polled data at the central polling station have different factors.

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8816	2558	90645
F460 translator	Climatronics	100163	1101	none
Modem	US Robotics	V.92	unknown	none
Solar Radiation Translator	RM Young	70101-X	none	03184

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Jan 2006"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text" value="10/11/2012"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency		Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency		Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input type="checkbox"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>	<input type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	Flow section only
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Single clean glove used to handle filter
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input type="checkbox"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>SEK430-Eric Hebert-05/03/2013</i>						
1	5/3/2013	Computer	Gateway	none	Solo	B2500251306
2	5/3/2013	DAS	Environmental Sys Corp	90649	8816	2562
3	5/3/2013	Elevation	Elevation	None	1	None
4	5/3/2013	Filter pack flow pump	Thomas	none	107CAB11A	109500000039
5	5/3/2013	flow rate	Tylan	03384	FC280AV	AW9403014
6	5/3/2013	Infrastructure	Infrastructure	none	none	none
7	5/3/2013	Met tower	Aluma Tower	none	B	none
8	5/3/2013	MFC power supply	Tylan	03679	RO-32	FP9403015
9	5/3/2013	Modem	US Robotics	none	56k	unknown
10	5/3/2013	Ozone	ThermoElectron Inc	90835	49C	0520012327
11	5/3/2013	Ozone Standard	ThermoElectron Inc	90729	49C	49C-90523-366
12	5/3/2013	Precipitation	Novalynx	none	260-2500	0977
13	5/3/2013	Printer	Hewlett Packard	none	842C	unknown
14	5/3/2013	Relative Humidity	Rotronic	none	MP 100	14103
15	5/3/2013	Shelter Temperature	ARS	none	none	none
16	5/3/2013	Shield (10 meter)	RM Young	90810	Aspirated 43408	none
17	5/3/2013	Siting Criteria	Siting Criteria	None	1	None
18	5/3/2013	Solar Radiation	Licor	none	LI-200	PY37610
19	5/3/2013	Solar Radiation Translator	RM Young	none	70101-X	none
20	5/3/2013	Temperature	RM Young	none	41342	8472
21	5/3/2013	Temperature Translator	RM Young	00819	41406-X	063143
22	5/3/2013	Wind Direction	RM Young	90850	AQ05103-5	59339wdr
23	5/3/2013	Wind Speed	RM Young	90850	AQ05103-5	59339wsp
24	5/3/2013	Zero air pump	Werther International	none	PC 70/4	627676

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2562	SEK430	Eric Hebert	05/03/2013	DAS	Primary

Das Date:	<input type="text" value="5 /3 /2013"/>	Audit Date	<input type="text" value="5 /3 /2013"/>
Das Time:	<input type="text" value="13:14:45"/>	Audit Time	<input type="text" value="13:14:25"/>
Das Day:	<input type="text" value="124"/>	Audit Day	<input type="text" value="124"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0002"/>	Max Diff:	<input type="text" value="0.0004"/>
		Avg Diff:	<input type="text" value="0.0002"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
2	0.0000	0.0000	0.0000	V	V	0.0000
2	0.1000	0.1000	0.1000	V	V	0.0000
2	0.3000	0.3000	0.3001	V	V	0.0001
2	0.5000	0.5000	0.5002	V	V	0.0002
2	0.7000	0.7000	0.7003	V	V	0.0003
2	0.9000	0.9000	0.9003	V	V	0.0003
2	1.0000	1.0000	1.0004	V	V	0.0004
9	0.0000	0.0000	0.0000	V	V	0.0000
9	0.1000	0.1000	0.1000	V	V	0.0000
9	0.3000	0.3000	0.3001	V	V	0.0001
9	0.5000	0.5000	0.5002	V	V	0.0002
9	0.7000	0.7000	0.7002	V	V	0.0002
9	0.9000	0.9000	0.9003	V	V	0.0003
9	1.0000	1.0001	1.0004	V	V	0.0003

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403014		SEK430	Eric Hebert	05/03/2013	flow rate	03384

Mfg	Tylan
SN/Owner ID	FP9403015 03679
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.20%	0.31%

Cal Factor Zero	0.13
Cal Factor Full Scale	5.56
Rotometer Reading:	3.05

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.08	-0.0570	0.07	l/m	l/m	
primary	leak check	0.000	0.000	-0.08	-0.0570	0.07	l/m	l/m	
primary	test pt 1	0.000	2.999	2.45	2.6370	2.99	l/m	l/m	-0.31%
primary	test pt 2	0.000	2.996	2.45	2.6370	2.99	l/m	l/m	-0.20%
primary	test pt 3	0.000	2.987	2.45	2.6370	2.99	l/m	l/m	0.09%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	Filter Depth	Condition	- 0.5 cm	Status	Fail
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	0520012327		SEK430	Eric Hebert	05/03/2013	Ozone	90835

Slope:	0.98730	Slope:	0.00000
Intercept	0.82037	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.9%	2.4%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.38	-0.56	0.16	ppb	
primary	2	24.51	24.39	24.97	ppb	2.38%
primary	3	54.75	54.71	54.91	ppb	0.37%
primary	4	83.46	83.50	83.33	ppb	-0.20%
primary	5	109.66	109.78	109.10	ppb	-0.62%

Sensor Component	Cell B Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9994	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.2	Status	pass
Sensor Component	Span	Condition	1.016	Status	pass
Sensor Component	Cell B Freq.	Condition	97.0 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	39.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	698 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	113.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	-0.0006	Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	59339wsp		SEK430	Eric Hebert	05/03/2013	Wind Speed	90850

Prop or Cups SN
Prop or Cups Torque to
Prop Correction Fact

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (h"/>
Tfer ID	<input type="text" value="01262"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/13/2010"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (l"/>
Tfer ID	<input type="text" value="01261"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/13/2010"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.07"/>	<input type="text" value="0.25%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.19"/>	<input type="text" value="0.49%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	none	0	0.20	0.0000	0.0		-0.19
primary	01262	200	1.02	0.0000	1.0		0.02
primary	01262	400	2.05	0.0000	2.1		0.04
primary	01262	800	4.10	0.0000	4.1		0.03
primary	01262	1200	6.14	0.0000	6.2	0.49%	
primary	01262	2400	12.29	0.0000	12.3	0.24%	
primary	01262	4000	20.48	0.0000	20.5	0.20%	
primary	01262	9400	48.13	0.0000	48.2	0.06%	

Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Prop or Cups Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	59339wdr		SEK430	Eric Hebert	05/03/2013	Wind Direction	90850

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/4/2011"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value=""/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		

DAS 1:	DAS 2:		
Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	<input type="text" value="2.8"/>	<input type="text" value="1.8"/>	<input type="text" value=""/>
Abs Max Er	<input type="text" value="5"/>	<input type="text" value="3"/>	<input type="text" value=""/>

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01266	0	<input checked="" type="checkbox"/>	0.0000	356	4	42	-3
primary	01266	45	<input checked="" type="checkbox"/>	0.0000	44	1	48	3
primary	01266	90	<input checked="" type="checkbox"/>	0.0000	88	2	44	-1
primary	01266	135	<input checked="" type="checkbox"/>	0.0000	132	3	44	-1
primary	01266	180	<input checked="" type="checkbox"/>	0.0000	180	0	48	3
primary	01266	225	<input checked="" type="checkbox"/>	0.0000	223	2	43	-2
primary	01266	270	<input checked="" type="checkbox"/>	0.0000	269	1	46	1
primary	01266	315	<input checked="" type="checkbox"/>	0.0000	314	1	45	0
primary	01265	1	<input type="checkbox"/>	0.0000	356	5		5
primary	01265	91	<input type="checkbox"/>	0.0000	88	3		3
primary	01265	181	<input type="checkbox"/>	0.0000	180	1		1
primary	01265	271	<input type="checkbox"/>	0.0000	269	2		2

Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text" value=""/>	Status	<input type="text" value="pass"/>

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	8472		SEK430	Eric Hebert	05/03/2013	Temperature	none

Mfg	RM Young	
SN/Owner ID	063143	00819
Parameter	Temperature Translator	

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.13	0.21		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.14	0.26	0.0000	0.1	C	-0.21
primary	Temp Mid Range	19.46	19.44	0.0000	19.3	C	-0.11
primary	Temp High Range	44.08	43.88	0.0000	43.8	C	-0.08

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Not functioning	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Rotronic	14103		SEK430	Eric Hebert	05/03/2013	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	124432	Tfer Desc.	Hygroclip
Tfer ID	01225		
Slope	1.00000	Intercept	0.00000
Cert Date	1/29/2013	CorrCoff	1.00000

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	2.0	2.0		
Abs Max Er	2.9	2.0		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	33.8	32.8	0.3178	31.8	-1.0
primary	RH Low Range	Hygroclip	52.9	51.4	52.9	0.4995	50.0	-2.9
primary	RH High Range	Hygroclip	93.6	89.9	93.6	0.9163	91.6	-2.0

Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Novalynx	0977		SEK430	Eric Hebert	05/03/2013	Precipitation	none

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
4.7%	5.5%		

Mfg	PMP	Parameter	Precipitation
Serial Number	EW-06134-50	Tfer Desc.	250ml graduate
Tfer ID	01250		
Slope	1.00000	Intercept	0.00000
Cert Date	9/5/2005	CorrCoff	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	3 sec	2.50	2.50	mm	mm	ml	
primary	test 1	231.5	1	10 sec	7.14	6.86	mm	mm	ml	-3.9%
primary	test 2	563	1	10 sec	14.28	13.49	mm	mm	ml	-5.5%

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Heater	Condition	Not functioning	Status	Fail
Sensor Component	Properly Sited	Condition	See comments	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Installed	Status	pass
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Alan pre-fab"/>	<input type="text" value="s/n 861166 1808"/>	<input type="text" value="512 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="Pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	SEK430	Eric Hebert	05/03/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.42	1.50		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	23.06	23.02	0.000	24.4	C	1.37
primary	Temp Mid Range	22.97	22.93	0.000	24.4	C	1.5
primary	Temp Mid Range	23.10	23.06	0.000	24.5	C	1.39

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	SEK430	Eric Hebert	05/03/2013	Filter Position	Tylan	1414	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.								
Precipitation	SEK430	Eric Hebert	05/03/2013	Sensor Heater	Novalynx	1409	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The tipping bucket rain gauge heater is not functioning.								
Precipitation	SEK430	Eric Hebert	05/03/2013	Properly Sited	Novalynx	1409	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Objects violate the 45 degree rule for the tipping bucket rain gage.								
Temperature	SEK430	Eric Hebert	05/03/2013	Blower	RM Young	1405	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The forced-air blower for the shield is not functioning.								

Field Systems Comments

1 Parameter: SitingCriteriaCom

The site is a wooded area with spaced trees on three sides and a steep drop in elevation on the west side. Although not strictly conforming to siting criteria it is elevated in a wide valley and representative of the area. Some trees have been trimmed since the previous site audit. Trees are still within 5 meters, however none are higher than the CASTNET sample inlets.

2 Parameter: ShelterCleanNotes

The shelter is aging but is in fair condition and kept clean, neat, and well organized.

3 Parameter: MetSensorComme

The rain gauge is mounted near the tower.

4 Parameter: MetOpMaintCom

The temperature sensor aspirated shield blower is not functioning which will impact temperature data accuracy.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Case Mountain"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="06-107-0009"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE, BAM"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="36.489469"/>
Site Address 1	<input type="text" value="Southern Sierra Research Center"/>	Audit Longitude	<input type="text" value="-118.829153"/>
Site Address 2	<input type="text" value="Highway 198"/>	Audit Elevation	<input type="text" value="510"/>
County	<input type="text" value="Tulare"/>	Audit Declination	<input type="text" value="13.1"/>
City, State	<input type="text" value="Sequoia National Park, CA"/>		
Zip Code	<input type="text" value="93262"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected May 2012"/>
Time Zone	<input type="text" value="Pacific"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Alan pre-fab"/>	Model <input type="text" value="s/n 861166 1808"/>	Shelter Size <input type="text" value="512 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is aging but is in fair condition and kept clean, neat, and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO ₂ or NO _x	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	40 m	<input type="checkbox"/>
Tree line	50 m	5 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is a wooded area with spaced trees on three sides and a steep drop in elevation on the west side. Although not strictly conforming to siting criteria it is elevated in a wide valley and representative of the area. Some trees have been trimmed since the previous site audit. Trees are still within 5 meters, however none are higher than the CASTNET sample inlets.

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The rain gauge is mounted near the tower.

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged? N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained? Signs of wear
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Met tower	Aluma Tower	B	none	none
Solar Radiation	Licor	LI-200	PY37610	none
Precipitation	Novalynx	260-2500	0977	none
Temperature	RM Young	41342	8472	none
Shield (10 meter)	RM Young	Aspirated 43408	none	90810
Wind Direction	RM Young	AQ05103-5	59339wdr	90850
Wind Speed	RM Young	AQ05103-5	59339wsp	90850
Relative Humidity	Rotronic	MP 100	14103	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor aspirated shield blower is not functioning which will impact temperature data accuracy.

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? Trees within 10 meters

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 16 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines? Flow line only
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Ozone	ThermoElectron Inc	49C	0520012327	90835
Filter pack flow pump	Thomas	107CAB11A	109500000039	none
MFC power supply	Tylan	RO-32	FP9403015	03679
Zero air pump	Werther International	PC 70/4	627676	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded? The shelter ground may not be adequate
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- Stable**

Grounded
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Gateway	Solo	B2500251306	none
DAS	Environmental Sys Corp	8816	2562	90649
Modem	US Robotics	56k	unknown	none
Printer	Hewlett Packard	842C	unknown	none
Solar Radiation Translator	RM Young	70101-X	none	none
Temperature Translator	RM Young	41406-X	063143	00819

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Jan 2006"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text" value="Not available on-site"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- Is the station log properly completed during every site visit?
- Are the Site Status Report Forms being completed and current?
- Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	Flow and observation sections only
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>LAV410-Eric Hebert-05/07/2013</i>						
1	5/7/2013	Computer	Gateway	0019275982	Solo	B52500251350
2	5/7/2013	DAS	Environmental Sys Corp	90535	8816	2026
3	5/7/2013	Elevation	Elevation	None	1	None
4	5/7/2013	F460 translator	Climatronics	00853	100163	unknown
5	5/7/2013	Filter pack flow pump	Thomas	00253	107CA18	0688001767
6	5/7/2013	flow rate	Tylan	03379	FC280AV	AW9403023
7	5/7/2013	Infrastructure	Infrastructure	none	none	none
8	5/7/2013	Mainframe	Climatronics	none	100081	1377
9	5/7/2013	Mainframe power supply	Climatronics	none	101074	858
10	5/7/2013	Met tower	Rohn	none	unknown	none
11	5/7/2013	MFC power supply	Tylan	03684	RO-32	FP9404003
12	5/7/2013	Modem	US Robotics	none	56k	unknown
13	5/7/2013	Ozone	ThermoElectron Inc	90834	49C	49C-520012-328
14	5/7/2013	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1030745083
15	5/7/2013	Precipitation	Texas Electronics	none	TR-525i-HT	20895-398
16	5/7/2013	Printer	Hewlett Packard	none	842C	unknown
17	5/7/2013	Relative Humidity	Rotronic	none	MP 601A	52062
18	5/7/2013	Sample Tower	Aluma Tower	923314	B	AT-5324-F6-O
19	5/7/2013	Shelter Temperature	ARS	none	none	003
20	5/7/2013	Shield (10 meter)	Climatronics	01199	100325	1290
21	5/7/2013	Siting Criteria	Siting Criteria	None	1	None
22	5/7/2013	Solar Radiation	Licor	none	LI-200	PY49113
23	5/7/2013	Solar Radiation Translator	Climatronics	none	100144	391
24	5/7/2013	Temperature	Climatronics	03794	100093	ARS101
25	5/7/2013	Temperature Translator	Climatronics	03629	100088-2	398
26	5/7/2013	Wind Direction	Climatronics	90831	100076	1494
27	5/7/2013	Wind Speed	Climatronics	90843	100075	4265
28	5/7/2013	Zero air pump	Werther International	none	PC70/4	434533

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2026	LAV410	Eric Hebert	05/07/2013	DAS	Primary

Das Date:	<input type="text" value="5 /7 /2013"/>	Audit Date	<input type="text" value="5 /7 /2013"/>
Das Time:	<input type="text" value="15:09:00"/>	Audit Time	<input type="text" value="15:09:09"/>
Das Day:	<input type="text" value="127"/>	Audit Day	<input type="text" value="127"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
2	0.0000	0.0000	0.0000	V	V	0.0000
2	0.1000	0.1000	0.1000	V	V	0.0000
2	0.3000	0.3001	0.3001	V	V	0.0000
2	0.5000	0.5001	0.5001	V	V	0.0000
2	0.7000	0.7002	0.7001	V	V	-0.0001
2	0.9000	0.9002	0.9001	V	V	-0.0001
2	1.0000	1.0003	1.0002	V	V	-0.0001
9	0.0000	0.0000	0.0000	V	V	0.0000
9	0.1000	0.1000	0.1000	V	V	0.0000
9	0.3000	0.3001	0.3000	V	V	-0.0001
9	0.5000	0.5001	0.5000	V	V	-0.0001
9	0.7000	0.7002	0.7001	V	V	-0.0001
9	0.9000	0.9002	0.9000	V	V	-0.0002
9	1.0000	1.0003	1.0003	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403023		LAV410	Eric Hebert	05/07/2013	flow rate	03379

Mfg	Tylan
SN/Owner ID	FP9404003 03684
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.13%	1.26%

Cal Factor Zero	0.32
Cal Factor Full Scale	5.9
Rotometer Reading:	4.3

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.34	-0.2790	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.32	-0.2560	0.03	l/m	l/m	
primary	test pt 1	0.000	2.963	2.40	2.4030	3.00	l/m	l/m	1.26%
primary	test pt 2	0.000	2.965	2.40	2.4030	3.00	l/m	l/m	1.18%
primary	test pt 3	0.000	2.972	2.40	2.4030	3.00	l/m	l/m	0.95%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	Filter Depth	Condition	- 1.0 cm	Status	Fail
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-520012-328		LAV410	Eric Hebert	05/07/2013	Ozone	90834

Slope:	0.98219	Slope:	0.00000
Intercept	1.20291	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.0%	2.1%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.18	0.00	1.29	ppb	
primary	2	29.23	29.12	29.72	ppb	2.06%
primary	3	50.74	50.69	51.10	ppb	0.81%
primary	4	82.58	82.62	82.05	ppb	-0.69%
primary	5	115.13	115.26	114.60	ppb	-0.57%

Sensor Component	Cell B Noise	Condition	Not tested	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	Not tested	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.002	Status	pass
Sensor Component	Cell B Freq.	Condition	67 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.4 C	Status	pass
Sensor Component	Cell A Pressure	Condition	608 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	Not tested	Status	pass
Sensor Component	Cell A Freq.	Condition	64 kHz	Status	Fail
Sensor Component	Cell A Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	Not tested	Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	4265		LAV410	Eric Hebert	05/07/2013	Wind Speed	90843

Mfg	Climatronics	
SN/Owner ID	unknown	00853
Parameter	F460 translator	

Prop or Cups SN	573
Prop or Cups Torque	0.3 to 0.3
Prop Correction Fact	N/A

Mfg	RM Young	Parameter	wind speed
Serial Number		Tfer Desc.	wind speed motor (h
Tfer ID	01262		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind speed
Serial Number		Tfer Desc.	wind speed motor (l
Tfer ID	01261		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	0.01	0.10%		
Abs Max Er	0.03	0.25%		

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	none	0	0.20	0.0000	0.2		0.00
primary	01261	50	1.40	0.0000	1.4		0.00
primary	01261	100	2.57	0.0000	2.6		0.03
primary	01261	170	4.22	0.0000	4.2		-0.02
primary	01261	250	6.10	0.0000	6.1	0.00%	
primary	01262	500	11.97	0.0000	12.0	0.25%	
primary	01262	800	19.02	0.0000	19.0	-0.11%	
primary	01262	2000	47.22	0.0000	47.2	-0.04%	

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Prop or Cups Condition	Condition	Poor	Status	Fail
Sensor Component	Condition	Condition	Fair	Status	pass
Sensor Component	Torque	Condition	Good	Status	pass

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	1494		LAV410	Eric Hebert	05/07/2013	Wind Direction	90831

Mfg	Climatronics
SN/Owner ID	unknown 00853
Parameter	F460 translator

Vane SN: 3946 **C. A. Align. deg. true:**

Vane Torque 5 to 10 0

Mfg	Ushikata	Parameter	wind direction
Serial Number	190037	Tfer Desc.	transit
Tfer ID	01265		
Slope	1.00000	Intercept	0.00000
Cert Date	1/4/2011	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind direction
Serial Number		Tfer Desc.	wind direction wheel
Tfer ID	01266		

DAS 1:	DAS 2:		
Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	3.3 2.0		
Abs Max Er	5 4		

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01266	0	<input checked="" type="checkbox"/>	0.0000	2	2	41	-4
primary	01266	45	<input checked="" type="checkbox"/>	0.0000	46	1	44	-1
primary	01266	90	<input checked="" type="checkbox"/>	0.0000	92	2	46	1
primary	01266	135	<input checked="" type="checkbox"/>	0.0000	138	3	46	1
primary	01266	180	<input checked="" type="checkbox"/>	0.0000	184	4	46	1
primary	01266	225	<input checked="" type="checkbox"/>	0.0000	226	1	42	-3
primary	01266	270	<input checked="" type="checkbox"/>	0.0000	275	5	49	4
primary	01266	315	<input checked="" type="checkbox"/>	0.0000	321	6	46	1
primary	01265	0	<input type="checkbox"/>	0.0000	2	2		2
primary	01265	90	<input type="checkbox"/>	0.0000	92	2		2
primary	01265	180	<input type="checkbox"/>	0.0000	184	4		4
primary	01265	270	<input type="checkbox"/>	0.0000	275	5		5

Sensor Component	Mast	Condition	Good	Status	pass
Sensor Component	Condition	Condition	Poor	Status	Fail
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Torque	Condition	Good	Status	pass
Sensor Component	Vane Condition	Condition	Good	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	ARS101		LAV410	Eric Hebert	05/07/2013	Temperature	03794

Mfg	Climatronics
SN/Owner ID	398 03629
Parameter	Temperature Translator

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.15	0.34		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.05	0.17	0.0000	0.2	C	0.04
primary	Temp Mid Range	20.25	20.23	0.0000	20.2	C	-0.08
primary	Temp High Range	47.91	47.68	0.0000	47.3	C	-0.34

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Rotronic	52062		LAV410	Eric Hebert	05/07/2013	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	124432	Tfer Desc.	Hygroclip
Tfer ID	01225		
Slope	1.00000	Intercept	0.00000
Cert Date	1/29/2013	CorrCoff	1.00000

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	8.0	1.0		
Abs Max Er	11.4	1.0		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	39.3	32.8	0.3735	37.4	4.6
primary	RH Low Range	Hygroclip	52.9	58.7	52.9	0.6427	64.3	11.4
primary	RH High Range	Hygroclip	93.6	89.4	93.6	0.9464	94.6	1.0

Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Texas Electronics	20895-398		LAV410	Eric Hebert	05/07/2013	Precipitation	none

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.0%	4.0%		

Mfg	PMP	Parameter	Precipitation
Serial Number	EW-06134-50	Tfer Desc.	250ml graduate
Tfer ID	01250		
Slope	1.00000	Intercept	0.00000
Cert Date	9/5/2005	CorrCoff	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	2 sec	1.00	1.00	mm	mm	ml	
primary	test 1	231.5	1	8 sec	5.00	4.90	mm	mm	ml	-2.0%
primary	test 2	231.5	2	10 sec	5.00	4.80	mm	mm	ml	-4.0%

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Properly Sited	Condition	See comments	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Installed	Status	pass
Sensor Component	Level	Condition	1/2 bubble off level	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Funnel Clean	Condition	Moderately clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass

Infrastructure Data For

Site ID **Technician** **Site Visit Date**

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text" value="1150 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	003	LAV410	Eric Hebert	05/07/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.27	1.68		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	21.48	21.45	0.000	22.7	C	1.2
primary	Temp Mid Range	21.61	21.58	0.000	22.5	C	0.93
primary	Temp Mid Range	20.90	20.87	0.000	22.6	C	1.68

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	LAV410	Eric Hebert	05/07/2013	Filter Position	Tylan	1345	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.								
Ozone	LAV410	Eric Hebert	05/07/2013	Cell B Freq.	ThermoElectron	1344	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	LAV410	Eric Hebert	05/07/2013	Cell A Freq.	ThermoElectron	1344	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Precipitation	LAV410	Eric Hebert	05/07/2013	System Memo	Texas Electronic	1339	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The edge of the tipping bucket funnel rests on the pipe that supports the rain gauge. This causes the funnel to be out of level.								
Precipitation	LAV410	Eric Hebert	05/07/2013	Properly Sited	Texas Electronic	1339	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Objects violate the 45 degree rule for the tipping bucket rain gage.								
Wind Direction	LAV410	Eric Hebert	05/07/2013	Condition	Climatronics	3135	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.								
Wind Speed	LAV410	Eric Hebert	05/07/2013	Prop or Cups Con	Climatronics	2759	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Both set screws are stripped.								

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone inlet filter is changed and the sample line conditioned every two weeks.

2 Parameter: DocumentationCo

The most recent calibration and verification results are not available on-site.

3 Parameter: SitingCriteriaCom

The site is located at the end of a park service facility parking lot, in a fire station. The tree line is near the building, but the prevailing wind direction is from the clearing. Tree height above the sample inlet is not twice as far away as it is high above the inlet.

4 Parameter: ShelterCleanNotes

The inside equipment is located in room within the fire station, clean, neat, and organized.

5 Parameter: MetSensorComme

The rain gauge funnel is contacting the tipping bucket mounting post causing it to be 1/2 bubble off level. Objects violate the 45 degree rule.

6 Parameter: MetOpMaintCom

The signal cables are showing signs of wear.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Manzanita Lake"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="40.5403"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-121.5764"/>
Land Use	<input type="text" value="woodland - evergreen"/>	QAPP Elevation Meters	<input type="text" value="1756"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(530) 335-7214"/>	Audit Latitude	<input type="text" value="40.539991"/>
Site Address 1	<input type="text" value="38050 Hwy 36E"/>	Audit Longitude	<input type="text" value="-121.576462"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="1755"/>
County	<input type="text" value="Shasta"/>	Audit Declination	<input type="text" value="14.5"/>
City, State	<input type="text" value="Mineral, CA"/>		
Zip Code	<input type="text" value="96063"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text" value="Out for service"/>
Time Zone	<input type="text" value="Pacific"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions From Redding take route 44 east for approximately 45 miles. At the park, and intersection of 44 and 89, turn right onto route 89. Turn right at the first road into the fire station and maintenance area. Take the first left, the site is behind the fire station at the end of the parking lot. One room in the fire station houses the climate controlled equipment.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO ₂ or NO _x	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m	25 m	<input type="checkbox"/>
Tree line	50 m	10 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located at the end of a park service facility parking lot, in a fire station. The tree line is near the building, but the prevailing wind direction is from the clearing. Tree height above the sample inlet is not twice as far away as it is high above the inlet.

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|----------------------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | 1/2 bubble off level |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input type="checkbox"/> | 1/2 bubble off level (pic) |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | 45 degree rule violation |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The rain gauge funnel is contacting the tipping bucket mounting post causing it to be 1/2 bubble off level. Objects violate the 45 degree rule.

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged? N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained? Signs of wear
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Shield (10 meter)	Climatronics	100325	1290	01199
Wind Speed	Climatronics	100075	4265	90843
Wind Direction	Climatronics	100076	1494	90831
Solar Radiation	Licor	LI-200	PY49113	none
Met tower	Rohn	unknown	none	none
Relative Humidity	Rotronic	MP 601A	52062	none
Precipitation	Texas Electronics	TR-525i-HT	20895-398	none
Temperature	Climatronics	100093	ARS101	03794

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The signal cables are showing signs of wear.

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? < 10 meters

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 10 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 10 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines? Flow line only
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-5324-F6-O	923314
Ozone	ThermoElectron Inc	49C	49C-520012-328	90834
Filter pack flow pump	Thomas	107CA18	0688001767	00253
MFC power supply	Tylan	RO-32	FP9404003	03684
Zero air pump	Werther International	PC70/4	434533	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- Stable**

Grounded
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Gateway	Solo	B52500251350	0019275982
DAS	Environmental Sys Corp	8816	2026	90535
F460 translator	Climatronics	100163	unknown	00853
Mainframe	Climatronics	100081	1377	none
Mainframe power supply	Climatronics	101074	858	none
Modem	US Robotics	56k	unknown	none
Printer	Hewlett Packard	842C	unknown	none
Solar Radiation Translator	Climatronics	100144	391	none
Temperature Translator	Climatronics	100088-2	398	03629

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="July 2012"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text" value="Not current"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed? Informal training provided by ARS during maintenance visits
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	Semiannually	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	Monthly	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	Weekly	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	N/A	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	Monthly and semiannually	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	Daily	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	As needed	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	Alarm values only	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	Every 2 weeks	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>		<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>		<input type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>		<input type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? Dataview

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone inlet filter is changed and the sample line conditioned every two weeks.

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed 80% in morning
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>OXF122-Sandy Grenville-05/08/2013</i>						
1	5/8/2013	Computer	Dell	000246	D520	unknown
2	5/8/2013	DAS	Campbell	000425	CR3000	2528
3	5/8/2013	Elevation	Elevation	None	1	None
4	5/8/2013	Filter pack flow pump	Thomas	04924	107CAB18	100300020817
5	5/8/2013	Flow Rate	Apex	000547	AXMC105LPMDPCV	50743
6	5/8/2013	Infrastructure	Infrastructure	none	none	none
7	5/8/2013	Modem	Raven	06468	H4222-C	0808310523
8	5/8/2013	Ozone	ThermoElectron Inc	000693	49i A1NAA	1030244806
9	5/8/2013	Ozone Standard	ThermoElectron Inc	000199	49i A3NAA	0607315737
10	5/8/2013	Sample Tower	Aluma Tower	000018	B	AT-61152-A-H8-E
11	5/8/2013	Shelter Temperature	Campbell	none	107-L	10755-148
12	5/8/2013	Siting Criteria	Siting Criteria	None	1	None
13	5/8/2013	Temperature	RM Young	02823	41342	illegible
14	5/8/2013	UPS	APC	05072	RS800	unknown
15	5/8/2013	Zero air pump	Werther International	06911	PC70/4	000829167

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2528	OXF122	Sandy Grenville	05/08/2013	DAS	Primary

Das Date:	<input type="text" value="5 / 8 / 2013"/>	Audit Date:	<input type="text" value="5 / 8 / 2013"/>
Das Time:	<input type="text" value="11:10:01"/>	Audit Time:	<input type="text" value="11:10:00"/>
Das Day:	<input type="text" value="128"/>	Audit Day:	<input type="text" value="128"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0000"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0000"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.2998	0.2999	V	V	0.0001
7	0.5000	0.4997	0.4997	V	V	0.0000
7	0.7000	0.6996	0.6996	V	V	0.0000
7	0.9000	0.8995	0.8995	V	V	0.0000
7	1.0000	0.9995	0.9994	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	50743		OXF122	Sandy Grenville	05/08/2013	Flow Rate	000547

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00000	Intercept	0.00000
Cert Date	6/13/2012	CorrCoff	1.00000
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00000	Intercept	0.00000
Cert Date	1/27/2012	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.12%	0.20%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.032
Cal Factor Full Scale	0.966
Rotometer Reading:	1.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.01	0.013	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.005	-0.03	l/m	l/m	
primary	test pt 1	1.539	1.499	1.54	1.533	1.50	l/m	l/m	-0.08%
primary	test pt 2	1.544	1.500	1.54	1.532	1.50	l/m	l/m	-0.20%
primary	test pt 3	1.543	1.499	1.54	1.535	1.50	l/m	l/m	0.07%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	Filter Depth	Condition	6.4 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	3 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244806		OXF122	Sandy Grenville	05/08/2013	Ozone	000693

Slope:	0.99852	Slope:	0.00000
Intercept	0.14735	Intercept	0.00000
CorrCoff	0.99992	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
0.7%	1.7%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00308	Intercept	-0.17961
Cert Date	4/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.50	-0.31	0.30	ppb	
primary	2	30.57	30.65	30.12	ppb	-1.73%
primary	3	49.19	49.21	49.02	ppb	-0.39%
primary	4	80.49	80.42	81.00	ppb	0.72%
primary	5	100.76	100.62	100.50	ppb	-0.12%

Sensor Component	Cell B Noise	Condition	2.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	< 1 %	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.023	Status	pass
Sensor Component	Cell B Freq.	Condition	126.9 kHz	Status	fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.4 C	Status	pass
Sensor Component	Cell A Pressure	Condition	713 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	2.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	98.3 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	illegible		OXF122	Sandy Grenville	05/08/2013	Temperature	02823

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.44	0.97		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.90	0.98	0.000	0.0	C	-0.97
primary	Temp Mid Range	24.50	24.48	0.000	24.6	C	0.12
primary	Temp High Range	48.70	48.57	0.000	48.8	C	0.23

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2107-4)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	10755-148	OXF122	Sandy Grenville	05/08/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.45	0.52		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	23.20	23.18	0.000	23.7	C	0.52
primary	Temp Mid Range	23.10	23.08	0.000	23.5	C	0.42
primary	Temp Mid Range	23.40	23.38	0.000	23.8	C	0.42

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	OXF122	Sandy Grenville	05/08/2013	Cell B Freq.	ThermoElectron	3365	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

Due to the high operator turn-over rate, the operators are unfamiliar with some minor aspects of site operation.

2 **Parameter:** DasComments

The met tower is operated by the university and the temperature sensor has been moved to the sample tower in a naturally aspirated shield.

3 **Parameter:** SitingCriteriaCom

The site is located in university agriculture research facility.

4 **Parameter:** ShelterCleanNotes

The shelter roof is in poor condition with several leaks.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Oxford"/>
Operating Group	<input type="text" value="Miami University"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="39-017-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="39.5314"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-84.7231"/>
Land Use	<input type="text" value="agriculture, woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="284"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text" value="5.2"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="2/23/2007"/>
Site Telephone	<input type="text" value="(513) 523-6912"/>	Audit Latitude	<input type="text" value="39.531115"/>
Site Address 1	<input type="text" value="Ecological Research Center"/>	Audit Longitude	<input type="text" value="-84.723547"/>
Site Address 2	<input type="text" value="Somerville Rd."/>	Audit Elevation	<input type="text" value="284"/>
County	<input type="text" value="Butler"/>	Audit Declination	<input type="text" value="-5.6"/>
City, State	<input type="text" value="Oxford, OH"/>		
Zip Code	<input type="text" value="45056"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Nov 1992"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2107-4)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter roof is in poor condition with several leaks."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text" value="25 m"/>	<input type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- | | | | |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | N/A |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	illegible	02823

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 15 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-61152-A-H8-E	000018
Ozone	ThermoElectron Inc	49i A1NAA	1030244806	000693
Filter pack flow pump	Thomas	107CAB18	100300020817	04924
Zero air pump	Werther International	PC70/4	000829167	06911

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000246
DAS	Campbell	CR3000	2528	000425
Modem	Raven	H4222-C	0808310523	06468
UPS	APC	RS800	unknown	05072

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The met tower is operated by the university and the temperature sensor has been moved to the sample tower in a naturally aspirated shield.

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> <input type="text"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Due to the high operator turn-over rate, the operators are unfamiliar with some minor aspects of site operation.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>QAK172-Sandy Grenville-05/09/2013</i>						
1	5/9/2013	Computer	Dell	000456	D530	unknown
2	5/9/2013	DAS	Campbell	000418	CR3000	2518
3	5/9/2013	Elevation	Elevation	None	1	None
4	5/9/2013	Filter pack flow pump	Thomas	02357	107CAB18	1089005314
5	5/9/2013	flow rate	Tylan	05094	FC280V	AW801210
6	5/9/2013	Infrastructure	Infrastructure	none	none	none
7	5/9/2013	MFC power supply	MACTEC	05037	none	none
8	5/9/2013	Modem	Raven	06467	V4221-V	0808338316
9	5/9/2013	Ozone	ThermoElectron Inc	000739	49i A1NAA	1105347318
10	5/9/2013	Ozone Standard	ThermoElectron Inc	000511	49i A3NAA	0922236888
11	5/9/2013	Sample Tower	Aluma Tower	666368	B	AT-5107-E-4-8
12	5/9/2013	Shelter Temperature	Campbell	60712	107-L	230826
13	5/9/2013	Siting Criteria	Siting Criteria	None	1	None
14	5/9/2013	Temperature	RM Young	06540	41342	14801
15	5/9/2013	UPS	APC	06798	RS900	unknown
16	5/9/2013	Zero air pump	Werther International	06870	PC70/4	000814278

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2518	QAK172	Sandy Grenville	05/09/2013	DAS	Primary

Das Date:	<input type="text" value="5/9/2013"/>	Audit Date	<input type="text" value="5/9/2013"/>
Das Time:	<input type="text" value="13:34:03"/>	Audit Time	<input type="text" value="13:34:03"/>
Das Day:	<input type="text" value="129"/>	Audit Day	<input type="text" value="129"/>

Low Channel:	High Channel:		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0001"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0001	V	V	0.0001
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.2998	0.2998	V	V	0.0000
7	0.5000	0.4997	0.4998	V	V	0.0001
7	0.7000	0.6997	0.6997	V	V	0.0000
7	0.9000	0.8996	0.8996	V	V	0.0000
7	1.0000	0.9995	0.9996	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW801210		QAK172	Sandy Grenville	05/09/2013	flow rate	05094

Mfg	MACTEC	
SN/Owner ID	none	05037
Parameter	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00000	Intercept	0.00000
Cert Date	6/13/2012	CorrCoff	1.00000
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00000	Intercept	0.00000
Cert Date	1/27/2012	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
2.43%	2.47%

Cal Factor Zero	0.02
Cal Factor Full Scale	0.66
Rotometer Reading:	1.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.02	-0.001	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	-0.002	0.02	l/m	l/m	
primary	test pt 1	1.585	1.538	2.32	2.320	1.50	l/m	l/m	-2.47%
primary	test pt 2	1.585	1.537	2.32	2.323	1.50	l/m	l/m	-2.41%
primary	test pt 3	1.585	1.537	2.32	2.322	1.50	l/m	l/m	-2.41%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	Filter Depth	Condition	5.0 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	4.2 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347318		QAK172	Sandy Grenville	05/09/2013	Ozone	000739

Slope:	0.99551	Slope:	0.00000
Intercept	0.61213	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
0.8%	1.3%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00308	Intercept	-0.17961
Cert Date	4/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.00	0.17	0.78	ppb	
primary	2	29.94	30.02	30.40	ppb	1.27%
primary	3	50.24	50.26	50.59	ppb	0.66%
primary	4	80.13	80.06	80.80	ppb	0.92%
primary	5	100.20	100.07	99.90	ppb	-0.17%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	< 1 %	Status	pass
Sensor Component	Offset	Condition	-0.80	Status	pass
Sensor Component	Span	Condition	1.026	Status	pass
Sensor Component	Cell B Freq.	Condition	99.2 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	32.4 C	Status	pass
Sensor Component	Cell A Pressure	Condition	701 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	113.7 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14801		QAK172	Sandy Grenville	05/09/2013	Temperature	06540

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.17	0.22		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.10	-0.02	0.000	0.2	C	0.22
primary	Temp Mid Range	24.90	24.88	0.000	24.8	C	-0.08
primary	Temp High Range	47.20	47.08	0.000	47.3	C	0.22

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	Functioning	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2625-2)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	230826	QAK172	Sandy Grenville	05/09/2013	Shelter Temperature	60712

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.61	0.81		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00435	Intercept	-0.08480
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	20.10	20.10	0.000	20.9	C	0.8
primary	Temp Mid Range	21.30	21.29	0.000	22.1	C	0.81
primary	Temp Mid Range	21.20	21.19	0.000	21.4	C	0.21

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator is doing an excellent job maintaining the site.

2 **Parameter:** ShelterCleanNotes

The shelter is in good condition. It is clean, well organized, and well maintained.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Quaker City"/>
Operating Group	<input type="text" value="Private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="39-121-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="39.9431"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-81.3378"/>
Land Use	<input type="text" value="woodland - mixed, agriculture"/>	QAPP Elevation Meters	<input type="text" value="372"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text" value="7.9"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(740) 679-3345"/>	Audit Latitude	<input type="text" value="39.942714"/>
Site Address 1	<input type="text" value="58163 St. Johns Road"/>	Audit Longitude	<input type="text" value="-81.337914"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="371"/>
County	<input type="text" value="Noble"/>	Audit Declination	<input type="text" value="-8.2"/>
City, State	<input type="text" value="Quaker City, OH"/>		
Zip Code	<input type="text" value="43773"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected May 1993"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2625-2)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in good condition. It is clean, well organized, and well maintained."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From I-70 take exit 193, route 513 south to Quaker City. At the 4-way stop turn right and continue approximately 0.8 miles and turn left onto CR943. Continue approximately 2 miles and turn right onto Noble County Rd 34 (also St. Johns Road). Continue approximately 1.5 miles and turn left onto a dirt road which is the driveway up a steep hill to the site.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- | | | | |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | N/A |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | N/A |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	14801	06540

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 15 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-5107-E-4-8	666368
MFC power supply	MACTEC	none	none	05037
Ozone	ThermoElectron Inc	49i A1NAA	1105347318	000739
Filter pack flow pump	Thomas	107CAB18	1089005314	02357
Zero air pump	Werther International	PC70/4	000814278	06870

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- Stable**

Grounded
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D530	unknown	000456
DAS	Campbell	CR3000	2518	000418
Modem	Raven	V4221-V	0808338316	06467
UPS	APC	RS900	unknown	06798

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	records MFC display as DAS flow value
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is doing an excellent job maintaining the site.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PND165-Eric Hebert-05/12/2013</i>						
1	5/12/2013	Computer	Dell	000258	D520	unknown
2	5/12/2013	DAS	Campbell	000403	CR3000	2516
3	5/12/2013	Elevation	Elevation	None	1	None
4	5/12/2013	Filter pack flow pump	Thomas	03631	107CAB18	049400004449
5	5/12/2013	flow rate	Tylan	02135	FC280V	AW901290
6	5/12/2013	Infrastructure	Infrastructure	none	none	none
7	5/12/2013	MFC power supply	Tylan	01695	RO-32	FP902019
8	5/12/2013	Modem	Raven	06474	H4222-C	0808311240
9	5/12/2013	Ozone	ThermoElectron Inc	000627	49i A1NAA	1009241772
10	5/12/2013	Ozone Standard	ThermoElectron Inc	000208	49i A3NAA	0611416461
11	5/12/2013	Sample Tower	Aluma Tower	000055	B	AT-81213-J12
12	5/12/2013	Shelter Temperature	Campbell	none	107-L	none
13	5/12/2013	Siting Criteria	Siting Criteria	None	1	None
14	5/12/2013	Temperature	RM Young	06539	41342	14800
15	5/12/2013	Zero air pump	Werther International	06926	PC70/4	000836218

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2516	PND165	Eric Hebert	05/12/2013	DAS	Primary

Das Date:	<input type="text" value="5 /13/2013"/>	Audit Date	<input type="text" value="5 /13/2013"/>
Das Time:	<input type="text" value="9:00:00"/>	Audit Time	<input type="text" value="9:00:05"/>
Das Day:	<input type="text" value="133"/>	Audit Day	<input type="text" value="133"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0003"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.0999	V	V	-0.0001
7	0.3000	0.3000	0.2999	V	V	-0.0001
7	0.5000	0.5000	0.4999	V	V	-0.0001
7	0.7000	0.7000	0.6999	V	V	-0.0001
7	0.9000	0.9001	0.8998	V	V	-0.0003
7	1.0000	1.0001	0.9998	V	V	-0.0003

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW901290		PND165	Eric Hebert	05/12/2013	flow rate	02135

Mfg	Tylan
SN/Owner ID	FP902019 01695
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.02%	1.36%

Cal Factor Zero	-0.09
Cal Factor Full Scale	1
Rotometer Reading:	3.95

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.03	0.000	-0.04	l/m	l/m	
primary	leak check	0.000	0.000	0.03	0.000	-0.04	l/m	l/m	
primary	test pt 1	0.000	2.975	2.82	0.000	3.00	l/m	l/m	0.83%
primary	test pt 2	0.000	2.975	2.82	0.000	3.00	l/m	l/m	0.86%
primary	test pt 3	0.000	2.970	2.83	0.000	3.01	l/m	l/m	1.36%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241772		PND165	Eric Hebert	05/12/2013	Ozone	000627

Slope:	0.95790	Slope:	0.00000
Intercept	0.02026	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
4.1%	4.4%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.35	0.16	0.06	ppb	
primary	2	28.90	28.79	27.59	ppb	-4.17%
primary	3	49.75	49.70	47.73	ppb	-3.96%
primary	4	79.85	79.88	76.77	ppb	-3.89%
primary	5	109.80	109.92	105.10	ppb	-4.39%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.10	Status	pass
Sensor Component	Span	Condition	1.003	Status	pass
Sensor Component	Cell B Freq.	Condition	83.5 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	37.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	569 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	84.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.61 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14800		PND165	Eric Hebert	05/12/2013	Temperature	06539

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.05	0.14		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.09	0.03	0.000	0.0	C	0
primary	Temp Mid Range	26.06	25.99	0.000	26.0	C	0.02
primary	Temp High Range	42.11	41.93	0.000	42.1	C	0.14

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	Functioning	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-22)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	PND165	Eric Hebert	05/12/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.43	2.26		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	24.20	24.15	0.000	26.4	C	2.26
primary	Temp Mid Range	25.28	25.22	0.000	26.6	C	1.4
primary	Temp Mid Range	25.74	25.68	0.000	26.3	C	0.63

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator uses the filter bag received with the new filter to send the filter removed from the tower back to the lab. There is no bag for the sample filter on site for storing the filter when it is removed from the tower.

2 **Parameter:** DasComments

Both the heat and the air conditioner are running simultaneously.

3 **Parameter:** DocumentationCo

General site observations are not being recorded on the SSRF. The purpose for recording the general observations was discussed with the site operator.

4 **Parameter:** ShelterCleanNotes

The shelter is well maintained.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Fremont Lake South"/>
Operating Group	<input type="text" value="Private / BLM"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="56-035-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="42.9214"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-109.7900"/>
Land Use	<input type="text" value="range"/>	QAPP Elevation Meters	<input type="text" value="2388"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="12.75"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(307) 367-6584"/>	Audit Latitude	<input type="text" value="42.929031"/>
Site Address 1	<input type="text" value="Skyline Drive"/>	Audit Longitude	<input type="text" value="-109.787796"/>
Site Address 2	<input type="text" value="Fremont Lake Rd."/>	Audit Elevation	<input type="text" value="2386"/>
County	<input type="text" value="Sublette"/>	Audit Declination	<input type="text" value="11.4"/>
City, State	<input type="text" value="Pinedale, WY"/>		
Zip Code	<input type="text" value="82941"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2149-22)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is well maintained."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID

Technician

Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

N/A
N/A

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	14800	06539

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-81213-J12	000055
Ozone	ThermoElectron Inc	49i A1NAA	1009241772	000627
Filter pack flow pump	Thomas	107CAB18	049400004449	03631
MFC power supply	Tylan	RO-32	FP902019	01695
Zero air pump	Werther International	PC70/4	000836218	06926

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded? Stable Grounded
- 10 Is the sample tower stable and grounded? Stable Grounded
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000258
DAS	Campbell	CR3000	2516	000403
Modem	Raven	H4222-C	0808311240	06474

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID Technician Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- Is the station log properly completed during every site visit?
- Are the Site Status Report Forms being completed and current? General observations not complete
- Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

General site observations are not being recorded on the SSRF. The purpose for recording the general observations was discussed with the site operator.

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|---|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | Filter changed afternoons approximately 80% |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input type="checkbox"/> | General observations are not recorded |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | No longer required |
| 4 | Are general observations being made and recorded? How? | <input type="checkbox"/> | |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF, call-in |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | One set of gloves only |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator uses the filter bag received with the new filter to send the filter removed from the tower back to the lab. There is no bag for the sample filter on site for storing the filter when it is removed from the tower.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>CNT169-Eric Hebert-05/14/2013</i>						
1	5/14/2013	Computer	Dell	000241	D520	unknown
2	5/14/2013	DAS	Campbell	000417	CR3000	2515
3	5/14/2013	Elevation	Elevation	None	1	None
4	5/14/2013	Filter pack flow pump	Thomas	02753	107CAB18	1192001900
5	5/14/2013	flow rate	Tylan	000086	FC280SAV	AW99013049
6	5/14/2013	Infrastructure	Infrastructure	none	none	none
7	5/14/2013	MFC power supply	MACTEC	05031	none	none
8	5/14/2013	Modem	Raven	06600	V4221-V	0844349098
9	5/14/2013	Ozone	ThermoElectron Inc	000682	49i A1NAA	1030244796
10	5/14/2013	Ozone Standard	ThermoElectron Inc	000369	49i A3NAA	0726124690
11	5/14/2013	Sample Tower	Aluma Tower	000179	B	unknown
12	5/14/2013	Shelter Temperature	Campbell	none	107-L	none
13	5/14/2013	Siting Criteria	Siting Criteria	None	1	None
14	5/14/2013	Temperature	RM Young	06559	41342	illegible
15	5/14/2013	Zero air pump	Werther International	06925	P 70/4	000836220

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2515	CNT169	Eric Hebert	05/14/2013	DAS	Primary

Das Date:	<input type="text" value="5 /14/2013"/>	Audit Date	<input type="text" value="5 /14/2013"/>
Das Time:	<input type="text" value="10:30:00"/>	Audit Time	<input type="text" value="10:30:00"/>
Das Day:	<input type="text" value="134"/>	Audit Day	<input type="text" value="134"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5000	0.4999	V	V	-0.0001
7	0.7000	0.7001	0.7000	V	V	-0.0001
7	0.9000	0.9001	0.9000	V	V	-0.0001
7	1.0000	1.0001	0.9999	V	V	-0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW99013049		CNT169	Eric Hebert	05/14/2013	flow rate	000086

Mfg	MACTEC	
SN/Owner ID	none	05031
Parameter	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
5.76%	6.13%

Cal Factor Zero	0
Cal Factor Full Scale	0
Rotometer Reading:	3.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.02	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	-0.02	0.000	0.01	l/m	l/m	
primary	test pt 1	0.000	2.842	2.58	0.000	3.00	l/m	l/m	5.56%
primary	test pt 2	0.000	2.841	2.58	0.000	3.00	l/m	l/m	5.59%
primary	test pt 3	0.000	2.827	2.58	0.000	3.00	l/m	l/m	6.13%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244796		CNT169	Eric Hebert	05/14/2013	Ozone	000682

Slope:	0.95862	Slope:	0.00000
Intercept	0.26392	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
3.5%	4.1%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.41	0.22	0.32	ppb	
primary	2	29.72	29.61	28.66	ppb	-3.21%
primary	3	50.00	49.95	48.32	ppb	-3.26%
primary	4	80.25	80.29	77.42	ppb	-3.57%
primary	5	110.20	110.32	105.80	ppb	-4.10%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.3	Status	pass
Sensor Component	Span	Condition	1.012	Status	pass
Sensor Component	Cell B Freq.	Condition	99.8 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.51 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	40.9 C	Status	Fail
Sensor Component	Cell A Pressure	Condition	502 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	98.9 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.52 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	illegible		CNT169	Eric Hebert	05/14/2013	Temperature	06559

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.10	0.17		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.13	-0.01	0.000	-0.1	C	-0.05
primary	Temp Mid Range	28.44	28.36	0.000	28.4	C	0.07
primary	Temp High Range	44.20	44.00	0.000	44.2	C	0.17

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-19)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	CNT169	Eric Hebert	05/14/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.69	0.99		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	23.39	23.34	0.000	24.3	C	0.99
primary	Temp Mid Range	24.35	24.30	0.000	24.9	C	0.55
primary	Temp Mid Range	24.64	24.58	0.000	25.1	C	0.52

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	CNT169	Eric Hebert	05/14/2013	Cell A Tmp.	ThermoElectron	3483	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-------	--------	-------------	------------	-------------	----------------	------	--------------------------	-------------------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 Parameter: DasComments

The sample tower has been replaced and the met tower removed since the previous site audit visit.

2 Parameter: SiteOpsProcedures

The ozone inlet filter is changed once each month and the ozone sample line is leak tested every two weeks.

3 Parameter: ShelterCleanNotes

The shelter is dirty. Some floor tiles have been repaired since the previous audit visit.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Centennial"/>
Operating Group	<input type="text" value="Forest Service"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="56-001-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="41.3722"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-106.2422"/>
Land Use	<input type="text" value="woodland - evergreen"/>	QAPP Elevation Meters	<input type="text" value="3178"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="10.9"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="12/28/2004"/>
Site Telephone	<input type="text" value="(307) 742-7229"/>	Audit Latitude	<input type="text" value="41.364531"/>
Site Address 1	<input type="text" value="Brooklyn Lake Guard Station"/>	Audit Longitude	<input type="text" value="-106.24002"/>
Site Address 2	<input type="text" value="Medicine Bow National Forest"/>	Audit Elevation	<input type="text" value="3175"/>
County	<input type="text" value="Albany"/>	Audit Declination	<input type="text" value="9.5"/>
City, State	<input type="text" value="Centennial, WY"/>		
Zip Code	<input type="text" value="82055"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2149-19)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input type="checkbox"/>	Notes <input type="text" value="The shelter is dirty. Some floor tiles have been repaired since the previous audit visit."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Laramie take route 130 west to Centennial. Continue through town and into the Medicine Bow National Forest. Turn right near the summit onto a dirt road at the sign for Brooklyn Lake Campground. Continue approximately 1.5 miles to Little Brooklyn Lake. There will be a small chapel on the right. Park at the chapel and walk approximately 200 meters up the hill past the chapel to the site.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | N/A |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	illegible	06559

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
MFC power supply	MACTEC	none	none	05031
Ozone	ThermoElectron Inc	49i A1NAA	1030244796	000682
Filter pack flow pump	Thomas	107CAB18	1192001900	02753
Zero air pump	Werther International	P 70/4	000836220	06925
Sample Tower	Aluma Tower	B	unknown	000179

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?

Stable	Grounded
<input type="checkbox"/>	<input type="checkbox"/>
- 10 Is the sample tower stable and grounded?

<input type="checkbox"/>	<input type="checkbox"/>
--------------------------	--------------------------
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000241
DAS	Campbell	CR3000	2515	000417
Modem	Raven	V4221-V	0844349098	06600

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|--|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | filter changed afternoons, 80% of the time |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input checked="" type="checkbox"/> | |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | No longer required |
| 4 | Are general observations being made and recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF, call-in |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | One set of gloves only |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

YELA08-Eric Hebert-06/06/2013

1	6/6/2013	Computer	Gateway	none	Solo	2500251339
2	6/6/2013	DAS	Environmental Sys Corp	90647	8816	2560
3	6/6/2013	Elevation	Elevation	None	1	None
4	6/6/2013	F460 translator	Climatronics	none	100163	686
5	6/6/2013	Filter pack flow pump	Thomas	none	107CA18	099800009748
6	6/6/2013	flow rate	Tylan	none	FC280SAV	AW9710138
7	6/6/2013	Infrastructure	Infrastructure	none	none	none
8	6/6/2013	Mainframe	Climatronics	none	100081	1380
9	6/6/2013	Mainframe power supply	Climatronics	none	101074	688
10	6/6/2013	Met tower	Climatronics	01362	14 inch taper	illegible
11	6/6/2013	MFC power supply	Tylan	03687	RO-32	FP9403014
12	6/6/2013	Modem	US Robotics	none	56k fax modem	unknown
13	6/6/2013	Ozone	ThermoElectron Inc	90714	49C	49C-66828-354
14	6/6/2013	Ozone Standard	ThermoElectron Inc	none	49C	0425208056
15	6/6/2013	Precipitation	Climatronics	02531	100508-2	illegible
16	6/6/2013	Printer	Hewlett Packard	none	840C	unknown
17	6/6/2013	Relative Humidity	Rotronic	none	MP 601A	75277
18	6/6/2013	Sample Tower	Aluma Tower	illegible	B	none
19	6/6/2013	Shelter Temperature	ARS	none	none	none
20	6/6/2013	Shield (10 meter)	Climatronics	01050	100325	1235
21	6/6/2013	Siting Criteria	Siting Criteria	None	1	None
22	6/6/2013	Solar Radiation	Licor	none	LI-200	PY18097
23	6/6/2013	Solar Radiation Translator	Climatronics	none	100144	381
24	6/6/2013	Temperature	Climatronics	ARS100	100093	none
25	6/6/2013	Temperature Translator	Climatronics	03626	100088-2	396
26	6/6/2013	Wind Direction	Climatronics	90876	100076	222
27	6/6/2013	Wind Speed	Climatronics	90881	100075	1697
28	6/6/2013	Zero air pump	Werther International	none	PC70/4	531393

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2560	YEL408	Eric Hebert	06/06/2013	DAS	Primary

Das Date:	<input type="text" value="6 /6 /2013"/>	Audit Date	<input type="text" value="6 /6 /2013"/>
Das Time:	<input type="text" value="9:55:00"/>	Audit Time	<input type="text" value="9:55:31"/>
Das Day:	<input type="text" value="157"/>	Audit Day	<input type="text" value="157"/>

Low Channel:	High Channel:		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>	<input type="text" value="0.0003"/>	<input type="text" value="0.0005"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
2	0.0000	0.0000	0.0000	V	V	0.0000
2	0.1000	0.1000	0.0999	V	V	-0.0001
2	0.3000	0.3000	0.2998	V	V	-0.0002
2	0.5000	0.5000	0.5000	V	V	0.0000
2	0.7000	0.7001	0.7001	V	V	0.0000
2	0.9000	0.9001	0.9001	V	V	0.0000
2	1.0000	1.0001	1.0000	V	V	-0.0001
16	0.0000	0.0000	0.0000	V	V	0.0000
16	0.1000	0.1000	0.1000	V	V	0.0000
16	0.3000	0.3000	0.3002	V	V	0.0002
16	0.5000	0.5000	0.5003	V	V	0.0003
16	0.7000	0.7000	0.7004	V	V	0.0004
16	0.9000	0.9001	0.9005	V	V	0.0004
16	1.0000	1.0001	1.0006	V	V	0.0005

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9710138		YEL408	Eric Hebert	06/06/2013	flow rate	none

Mfg	Tylan
SN/Owner ID	FP9403014 03687
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.49%	0.87%

Cal Factor Zero	0.4
Cal Factor Full Scale	5.8
Rotometer Reading:	3.6

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.35	-0.3250	0.05	l/m	l/m	
primary	leak check	0.000	0.000	-0.35	-0.3250	0.05	l/m	l/m	
primary	test pt 1	0.000	2.999	2.40	2.4130	3.00	l/m	l/m	0.05%
primary	test pt 2	0.000	3.016	2.40	2.4130	3.00	l/m	l/m	-0.54%
primary	test pt 3	0.000	3.036	2.40	2.4130	3.01	l/m	l/m	-0.87%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	Filter Depth	Condition	- 1.0 cm	Status	Fail
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-66828-354		YEL408	Eric Hebert	06/06/2013	Ozone	90714

Slope:	1.02906	Slope:	0.00000
Intercept	-0.33928	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.0%	2.8%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.40	0.21	0.19	ppb	
primary	2	30.41	30.31	30.48	ppb	0.56%
primary	3	50.00	49.95	50.86	ppb	1.82%
primary	4	79.43	79.46	81.67	ppb	2.78%
primary	5	110.00	110.12	113.00	ppb	2.62%

Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	1.0003	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	1.6	Status	pass
Sensor Component	Span	Condition	1.045	Status	pass
Sensor Component	Cell B Freq.	Condition	83.0 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	561 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	107 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0005	Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	1697	YEL408	Eric Hebert	06/06/2013	Wind Speed	90881

Mfg	Climatronics
SN/Owner ID	686 none
Parameter	F460 translator

Prop or Cups SN

Prop or Cups Torque to

Prop Correction Fact

Mfg	RM Young	Parameter	wind speed
Serial Number	<input type="text"/>	Tfer Desc.	wind speed motor (h
Tfer ID	01262		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind speed
Serial Number	<input type="text"/>	Tfer Desc.	wind speed motor (l
Tfer ID	01261		
Slope	1.00000	Intercept	0.00000
Cert Date	1/13/2010	CorrCoff	1.00000

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.09"/>	<input type="text" value="1.09%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.13"/>	<input type="text" value="1.64%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	none	0	0.20	0.0000	0.3		0.13
primary	01261	50	1.40	0.0000	1.5		0.06
primary	01261	100	2.57	0.0000	2.6		0.06
primary	01261	170	4.22	0.0000	4.3		0.09
primary	01261	250	6.10	0.0000	6.2	1.64%	
primary	01262	500	11.97	0.0000	12.1	1.17%	
primary	01262	800	19.02	0.0000	19.2	0.79%	
primary	01262	2000	47.22	0.0000	47.6	0.74%	

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Prop or Cups Condition	Condition	Good	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Torque	Condition	Good	Status	pass

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	222		YEL408	Eric Hebert	06/06/2013	Wind Direction	90876

Mfg	Climatronics
SN/Owner ID	686 none
Parameter	F460 translator

Vane SN: 1149 **C. A. Align. deg. true:**

Vane Torque 8 to 8 180

Mfg	Ushikata	Parameter	wind direction
Serial Number	190037	Tfer Desc.	transit
Tfer ID	01265		
Slope	1.00000	Intercept	0.00000
Cert Date	1/4/2011	CorrCoff	1.00000
Mfg	RM Young	Parameter	wind direction
Serial Number		Tfer Desc.	wind direction wheel
Tfer ID	01266		

DAS 1:	DAS 2:		
Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	9.5	1.3	
Abs Max Er	13	5	

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01266	0	<input checked="" type="checkbox"/>	0.0000	352	8	45	0
primary	01266	45	<input checked="" type="checkbox"/>	0.0000	36	9	44	-1
primary	01266	90	<input checked="" type="checkbox"/>	0.0000	80	10	44	-1
primary	01266	135	<input checked="" type="checkbox"/>	0.0000	125	10	45	0
primary	01266	180	<input checked="" type="checkbox"/>	0.0000	168	12	43	-2
primary	01266	225	<input checked="" type="checkbox"/>	0.0000	218	7	50	5
primary	01266	270	<input checked="" type="checkbox"/>	0.0000	263	7	45	0
primary	01266	315	<input checked="" type="checkbox"/>	0.0000	307	8	44	-1
primary	01265	90	<input type="checkbox"/>	0.0000	80	10		10
primary	01265	136	<input type="checkbox"/>	0.0000	123	13		13
primary	01265	180	<input type="checkbox"/>	0.0000	173	7		7
primary	01265	360	<input type="checkbox"/>	0.0000	352	8		8

Sensor Component	Mast	Condition	Good	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	Torque	Condition	Good	Status	pass
Sensor Component	Vane Condition	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	none		YEL408	Eric Hebert	06/06/2013	Temperature	ARS100

Mfg	Climatronics
SN/Owner ID	396 03626
Parameter	Temperature Translator

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.05	0.11		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.01	0.13	0.0000	0.2	C	0.11
primary	Temp Mid Range	24.00	23.95	0.0000	23.9	C	-0.04
primary	Temp High Range	49.56	49.32	0.0000	49.3	C	-0.01

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Rotronic	75277		YEL408	Eric Hebert	06/06/2013	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	124432	Tfer Desc.	Hygroclip
Tfer ID	01225		
Slope	1.00000	Intercept	0.00000
Cert Date	1/29/2013	CorrCoff	1.00000

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	2.2	0.9		
Abs Max Er	2.8	0.9		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	32.8	32.8	0.3561	35.6	2.8
primary	RH Low Range	Hygroclip	52.9	52.9	52.9	0.5450	54.5	1.6
primary	RH High Range	Hygroclip	93.6	93.6	93.6	0.9450	94.5	0.9

Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	illegible		YEL408	Eric Hebert	06/06/2013	Precipitation	02531

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.0%	4.0%		

Mfg	PMP	Parameter	Precipitation
Serial Number	EW-06134-50	Tfer Desc.	250ml graduate
Tfer ID	01250		
Slope	1.00000	Intercept	0.00000
Cert Date	9/5/2005	CorrCoff	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	2 sec	1.00	1.00	mm	mm	ml	
primary	test 1	231.5	1	10 sec	5.00	5.20	mm	mm	ml	4.0%
primary	test 2	231.5	2	10 sec	5.00	5.10	mm	mm	ml	2.0%

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Properly Sited	Condition	See comments	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Not installed	Status	Fail
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2880-1)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	YEL408	Eric Hebert	06/06/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.68	2.06		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	23.14	23.09	0.000	24.7	C	1.61
primary	Temp Mid Range	23.44	23.39	0.000	24.8	C	1.36
primary	Temp Mid Range	22.63	22.59	0.000	24.7	C	2.06

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	YEL408	Eric Hebert	06/06/2013	Filter Position	Tylan	1647	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<p>The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.</p>								
Precipitation	YEL408	Eric Hebert	06/06/2013	Properly Sited	Climatronics	3766	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<p>Objects violate the 45 degree rule for the tipping bucket rain gage.</p>								
Wind Speed	YEL408	Eric Hebert	06/06/2013	System Memo	Climatronics	2863	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<p>The external heater that wraps around the sensor was found to be impeding the rotation of the sensor shaft. This condition impacts data accuracy. The condition was corrected during the sensor audit.</p>								

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

Gloves are no longer used to handle the filter pack.

2 **Parameter:** SitingCriteriaCom

The site is located at the edge of a tree line. The trees close to the inlet are approximately 5 meters tall. Trees taller than 10 meters are 15 meters from the inlet.

3 **Parameter:** ShelterCleanNotes

The shelter is organized and well maintained.

4 **Parameter:** PollAnalyzerCom

The shelter and sample tower are located at the edge of the tree line and mountain slope. Small trees are encroaching on the sample tower. Taller trees are 10 to 15 meters from the sample tower.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Lake"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="56-039-1011"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="44.5597"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-110.4006"/>
Land Use	<input type="text" value="woodland - evergreen"/>	QAPP Elevation Meters	<input type="text" value="2400"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(307) 242-2410"/>	Audit Latitude	<input type="text" value="44.565356"/>
Site Address 1	<input type="text" value="Lake Ranger Station"/>	Audit Longitude	<input type="text" value="-110.400338"/>
Site Address 2	<input type="text" value="route 14"/>	Audit Elevation	<input type="text" value="2430"/>
County	<input type="text" value="Teton"/>	Audit Declination	<input type="text" value="11.9"/>
City, State	<input type="text" value="Yellowstone National Park, WY"/>		
Zip Code	<input type="text" value="82190"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text"/>
Time Zone	<input type="text" value="Mountain"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions From Jackson take route 191 / 89 north to Yellowstone National Park. At Thumb Junction take 14 east around Yellowstone Lake. Turn left just past the Lake Area (and hotel) into the park residence and office compound. Continue through the compound past the housing area. The site is up the hill through the gate to the water supply tank for the compound.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	15 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located at the edge of a tree line. The trees close to the inlet are approximately 5 meters tall. Trees taller than 10 meters are 15 meters from the inlet.

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|----------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | 45 degree rule |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged? N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Met tower	Climatronics	14 inch taper	illegible	01362
Temperature	Climatronics	100093	none	ARS100
Shield (10 meter)	Climatronics	100325	1235	01050
Wind Direction	Climatronics	100076	222	90876
Wind Speed	Climatronics	100075	1697	90881
Solar Radiation	Licor	LI-200	PY18097	none
Relative Humidity	Rotronic	MP 601A	75277	none
Precipitation	Climatronics	100508-2	illegible	02531

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? 10 to 15 meters from trees

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 9 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines? Flow line only
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	illegible
Ozone	ThermoElectron Inc	49C	49C-66828-354	90714
Filter pack flow pump	Thomas	107CA18	099800009748	none
MFC power supply	Tylan	RO-32	FP9403014	03687
Zero air pump	Werther International	PC70/4	531393	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The shelter and sample tower are located at the edge of the tree line and mountain slope. Small trees are encroaching on the sample tower. Taller trees are 10 to 15 meters from the sample tower.

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- Stable**

Grounded
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Gateway	Solo	2500251339	none
DAS	Environmental Sys Corp	8816	2560	90647
F460 translator	Climatronics	100163	686	none
Mainframe	Climatronics	100081	1380	none
Mainframe power supply	Climatronics	101074	688	none
Modem	US Robotics	56k fax modem	unknown	none
Printer	Hewlett Packard	840C	unknown	none
Solar Radiation Translator	Climatronics	100144	381	none
Temperature Translator	Climatronics	100088-2	396	03626

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Jan 2006"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text" value="Not current"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview, SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input type="checkbox"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Gloves are no longer used to handle the filter pack.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>ROM206-Eric Hebert-06/10/2013</i>						
1	6/10/2013	Computer	Dell	000454	D530	unknown
2	6/10/2013	DAS	Campbell	000415	CR3000	2510
3	6/10/2013	Elevation	Elevation	None	1	None
4	6/10/2013	Filter pack flow pump	Thomas	04986	107CA18	040400022185
5	6/10/2013	Flow Rate	Apex	000598	AXMC105LPMDPCV	unknown
6	6/10/2013	Infrastructure	Infrastructure	none	none	none
7	6/10/2013	Modem	Raven	06473	V4221-V	0808311135
8	6/10/2013	Ozone	ThermoElectron Inc	000734	49i A1NAA	1105347317
9	6/10/2013	Ozone Standard	ThermoElectron Inc	000437	49i A3NAA	CM08200013
10	6/10/2013	Sample Tower	Aluma Tower	666369	B	illegible
11	6/10/2013	Shelter Temperature	Campbell	none	107-L	none
12	6/10/2013	Siting Criteria	Siting Criteria	None	1	None
13	6/10/2013	Temperature	RM Young	02679	41342	none
14	6/10/2013	Zero air pump	Werther International	06900	PC70/4	000821894

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2510	ROM206	Eric Hebert	06/10/2013	DAS	Primary

Das Date:	<input type="text" value="6 /10/2013"/>	Audit Date:	<input type="text" value="6 /10/2013"/>
Das Time:	<input type="text" value="12:31:59"/>	Audit Time:	<input type="text" value="12:32:00"/>
Das Day:	<input type="text" value="161"/>	Audit Day:	<input type="text" value="161"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0003"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.2999	V	V	-0.0001
7	0.5000	0.5000	0.4999	V	V	-0.0001
7	0.7000	0.7001	0.6999	V	V	-0.0002
7	0.9000	0.9001	0.8998	V	V	-0.0003
7	1.0000	1.0001	0.9998	V	V	-0.0003

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		ROM206	Eric Hebert	06/10/2013	Flow Rate	000598

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	-0.06
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.95
0.78%	0.94%	Rotometer Reading:	3.75

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.01	0.000	-0.03	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	-0.03	l/m	l/m	
primary	test pt 1	0.000	2.976	3.00	0.000	3.00	l/m	l/m	0.81%
primary	test pt 2	0.000	2.982	3.00	0.000	3.00	l/m	l/m	0.60%
primary	test pt 3	0.000	2.972	3.00	0.000	3.00	l/m	l/m	0.94%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	Filter Depth	Condition	4.0 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347317		ROM206	Eric Hebert	06/10/2013	Ozone	000734

Slope:	0.99603	Slope:	0.00000
Intercept	0.31352	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
0.5%	0.8%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.59	0.40	0.82	ppb	
primary	2	30.46	30.36	30.15	ppb	-0.69%
primary	3	50.29	50.24	50.64	ppb	0.80%
primary	4	79.97	80.00	80.10	ppb	0.12%
primary	5	110.40	110.52	110.30	ppb	-0.20%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.30	Status	pass
Sensor Component	Span	Condition	1.036	Status	pass
Sensor Component	Cell B Freq.	Condition	105.5 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.34 lpm	Status	Fail
Sensor Component	Cell A Tmp.	Condition	37.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	542 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.3 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	92.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.36 lpm	Status	Fail
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	none		ROM206	Eric Hebert	06/10/2013	Temperature	02679

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.08	0.12		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.08	0.04	0.000	-0.1	C	-0.1
primary	Temp Mid Range	24.80	24.74	0.000	24.7	C	-0.01
primary	Temp High Range	45.68	45.47	0.000	45.6	C	0.12

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2182-1)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ROM206	Eric Hebert	06/10/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.52	0.54		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	24.83	24.77	0.000	25.3	C	0.48
primary	Temp Mid Range	23.78	23.73	0.000	24.3	C	0.54
primary	Temp Mid Range	26.34	26.27	0.000	25.7	C	-0.54

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	ROM206	Eric Hebert	06/10/2013	Cell B Flow	ThermoElectron	3593	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	ROM206	Eric Hebert	06/10/2013	Cell A Flow	ThermoElectron	3593	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Field Systems Comments

1 **Parameter:** ShelterCleanNotes

The shelter is clean, neat, and well organized. There are signs of previous roof leaks, but they have been repaired. The floor and counter top have been replaced.

2 **Parameter:** MetSensorComme

The temperature sensor has been removed from the met tower and mounted in a naturally aspirated shield on the sample tower.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Longs Peak"/>
Operating Group	<input type="text" value="private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="08-069-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="40.2778"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-105.5453"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="2743"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="10.3"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(970) 586-2598"/>	Audit Latitude	<input type="text" value="40.278129"/>
Site Address 1	<input type="text" value="High Peak Camp"/>	Audit Longitude	<input type="text" value="-105.545635"/>
Site Address 2	<input type="text" value="Route 7"/>	Audit Elevation	<input type="text" value="2742"/>
County	<input type="text" value="Larimer"/>	Audit Declination	<input type="text" value="9.0"/>
City, State	<input type="text" value="Estes Park, CO"/>		
Zip Code	<input type="text" value="80517"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected April 2001"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor has been removed from the met tower and mounted in a naturally aspirated shield on the sample tower.

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- | | | | |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | N/A |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	none	02679

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	illegible	666369
Ozone	ThermoElectron Inc	49i A1NAA	1105347317	000734
Zero air pump	Werther International	PC70/4	000821894	06900
Filter pack flow pump	Thomas	107CA18	040400022185	04986

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded? Stable Grounded
- 10 Is the sample tower stable and grounded? Stable Grounded
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D530	unknown	000454
DAS	Campbell	CR3000	2510	000415
Modem	Raven	V4221-V	0808311135	06473

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2011	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|--|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | Filter changed morinings 50% of the time |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input checked="" type="checkbox"/> | |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | No longer required |
| 4 | Are general observations being made and recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF, call-in |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | one set of gloves only |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> <input type="text"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> N/A	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>ROM406-Eric Hebert-06/10/2013</i>						
1	6/10/2013	Computer	Toshiba	none	Terca	unknown
2	6/10/2013	DAS	Environmental Sys Corp	90535	8816	2025
3	6/10/2013	Elevation	Elevation	None	1	None
4	6/10/2013	Filter pack flow pump	Thomas	02978	107CAB18	0493002494
5	6/10/2013	flow rate	Tylan	03393	FC280AV	AW9403024
6	6/10/2013	Infrastructure	Infrastructure	none	none	none
7	6/10/2013	Met tower	Rohn	none	unknown	none
8	6/10/2013	MFC power supply	Tylan	none	RO-32	illegible
9	6/10/2013	Modem	US Robotics	none	33.6 fax modem	unknown
10	6/10/2013	Ozone	ThermoElectron Inc	none	49i A3NAA	1030745086
11	6/10/2013	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130450194
12	6/10/2013	Precipitation	Climatronics	01620	100508-2	illegible
13	6/10/2013	Printer	Hewlett Packard	none	842C	unknown
14	6/10/2013	Relative Humidity	Rotronic	none	MP 601A	56091
15	6/10/2013	Sample Tower	Aluma Tower	illegible	B	none
16	6/10/2013	Shelter Temperature	ARS	none	none	none
17	6/10/2013	Shield (10 meter)	RM Young	none	unknown	none
18	6/10/2013	Shield (2 meter)	RM Young	none	unknown	none
19	6/10/2013	Siting Criteria	Siting Criteria	None	1	None
20	6/10/2013	Solar Radiation	Licor	none	LI-200	PY19983
21	6/10/2013	Solar Radiation Translator	RM Young	none	70101-X	none
22	6/10/2013	Temperature	RM Young	none	41342	17079
23	6/10/2013	Temperature2meter	RM Young	none	41342	17078
24	6/10/2013	Wind Direction	RM Young	none	AQ05103-5	89123wdr
25	6/10/2013	Wind Speed	RM Young	none	AQ05103-5	89123wsp
26	6/10/2013	Zero air pump	Werther International	none	PC70/4	531391

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2025	ROM406	Eric Hebert	06/10/2013	DAS	Primary

Das Date:	<input type="text" value="6 /10/2013"/>	Audit Date	<input type="text" value="6 /10/2013"/>
Das Time:	<input type="text" value="12:30:00"/>	Audit Time	<input type="text" value="12:30:24"/>
Das Day:	<input type="text" value="161"/>	Audit Day	<input type="text" value="161"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
2	0.0000	0.0000	0.0000	V	V	0.0000
2	0.1000	0.1000	0.1000	V	V	0.0000
2	0.3000	0.3000	0.3000	V	V	0.0000
2	0.5000	0.5000	0.4999	V	V	-0.0001
2	0.7000	0.7000	0.7000	V	V	0.0000
2	0.9000	0.9000	0.8999	V	V	-0.0001
2	1.0000	1.0001	1.0000	V	V	-0.0001
12	0.0000	0.0000	0.0000	V	V	0.0000
12	0.1000	0.1000	0.0998	V	V	-0.0002
12	0.3000	0.3000	0.3000	V	V	0.0000
12	0.5000	0.5000	0.5000	V	V	0.0000
12	0.7000	0.7000	0.6999	V	V	-0.0001
12	0.9000	0.9000	0.9000	V	V	0.0000
12	1.0000	1.0001	1.0000	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403024		ROM406	Eric Hebert	06/10/2013	flow rate	03393

Mfg	Tylan
SN/Owner ID	illegible none
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.32%	0.35%

Cal Factor Zero	0.04
Cal Factor Full Scale	5.46
Rotometer Reading:	3.95

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.05	-0.0150	0.02	l/m	l/m	
primary	leak check	0.000	0.000	-0.05	-0.0150	0.02	l/m	l/m	
primary	test pt 1	0.000	2.998	3.05	2.7380	3.01	l/m	l/m	0.32%
primary	test pt 2	0.000	2.998	3.05	2.7380	3.01	l/m	l/m	0.35%
primary	test pt 3	0.000	3.000	3.05	2.7380	3.01	l/m	l/m	0.28%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	Filter Depth	Condition	- 1.0 cm	Status	fail
Sensor Component	Filter Position	Condition	Poor	Status	fail
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030745086		ROM406	Eric Hebert	06/10/2013	Ozone	none

Slope:	0.99341	Slope:	0.00000
Intercept	0.32985	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
0.4%	0.6%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.32	0.13	0.50	ppb	
primary	2	31.40	31.30	31.12	ppb	-0.58%
primary	3	49.81	49.76	50.02	ppb	0.52%
primary	4	80.17	80.21	80.14	ppb	-0.09%
primary	5	110.10	110.22	109.70	ppb	-0.47%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9995	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.008	Status	pass
Sensor Component	Cell B Freq.	Condition	73.6 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.58 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	538 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	66.1 kHz	Status	Fail
Sensor Component	Cell A Flow	Condition	0.57 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	-0.0002	Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	89123wsp		ROM406	Eric Hebert	06/10/2013	Wind Speed	none

Prop or Cups SN
Prop or Cups Torque to
Prop Correction Fact

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (h"/>
Tfer ID	<input type="text" value="01262"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/13/2010"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (l"/>
Tfer ID	<input type="text" value="01261"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/13/2010"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.05"/>	<input type="text" value="0.00%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.20"/>	<input type="text" value="0.00%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	InputDevice:	Input RPM:	Input m/s:	Output V:	DAS m/s:	Diff/ %Diff:	Difference:
primary	none	0	0.20	0.0000	0.0		-0.20
primary	01262	200	1.02	0.0000	1.0		0.00
primary	01262	400	2.05	0.0000	2.1		0.00
primary	01262	800	4.10	0.0000	4.1		0.00
primary	01262	1200	6.14	0.0000	6.1	0.00%	
primary	01262	2400	12.29	0.0000	12.3	0.00%	
primary	01262	4000	20.48	0.0000	20.5	0.00%	
primary	01262	9400	48.13	0.0000	48.1	0.00%	

Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Prop or Cups Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	89123wdr		ROM406	Eric Hebert	06/10/2013	Wind Direction	none

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/4/2011"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		

DAS 1:	DAS 2:		
Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	<input type="text" value="9.7"/>	<input type="text" value="10.8"/>	<input type="text"/>
Abs Max Er	<input type="text" value="13"/>	<input type="text" value="43"/>	<input type="text"/>

UseDescription:	TferID:	Input Raw:	Linearity	Output V:	Output Deg.:	Difference:	Change:	Error:
primary	01266	0	<input checked="" type="checkbox"/>	0.0000	26	26	88	43
primary	01266	45	<input checked="" type="checkbox"/>	0.0000	60	15	34	-11
primary	01266	90	<input checked="" type="checkbox"/>	0.0000	101	11	41	-4
primary	01266	135	<input checked="" type="checkbox"/>	0.0000	140	5	39	-6
primary	01266	180	<input checked="" type="checkbox"/>	0.0000	180	0	40	-5
primary	01266	225	<input checked="" type="checkbox"/>	0.0000	220	5	40	-5
primary	01266	270	<input checked="" type="checkbox"/>	0.0000	258	12	38	-7
primary	01266	315	<input checked="" type="checkbox"/>	0.0000	298	17	40	-5
primary	01265	96	<input type="checkbox"/>	0.0000	104	8		8
primary	01265	236	<input type="checkbox"/>	0.0000	228	8		8
primary	01265	276	<input type="checkbox"/>	0.0000	263	13		13

Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text" value="See comments"/>	Status	<input type="text" value="pass"/>

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	17079		ROM406	Eric Hebert	06/10/2013	Temperature	none

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.10	0.10		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.13	0.25	0.0000	0.16	C	-0.09
primary	Temp Mid Range	25.40	25.34	0.0000	25.44	C	0.1
primary	Temp High Range	48.65	48.42	0.0000	48.52	C	0.1

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

2 Meter Temperature Data For

Calc. Difference

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	17078	ROM406	Eric Hebert	06/10/2013	Temperature2meter	none

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.11	0.2		

UseDescription:	Test type:	InputTmpRaw	InputTmpCorrected:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Rang	0.13	0.25	0.0000	0.45 C		0.2
primary	Temp Mid Rang	25.40	25.34	0.0000	25.48 C		0.14
primary	Temp High Ran	48.65	48.42	0.0000	48.42 C		0

Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Rotronic	56091		ROM406	Eric Hebert	06/10/2013	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	124432	Tfer Desc.	Hygroclip
Tfer ID	01225		
Slope	1.00000	Intercept	0.00000
Cert Date	1/29/2013	CorrCoff	1.00000

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	0.8	4.2		
Abs Max Er	1.0	4.2		

UseDesc.:	Test type:	Device:	Input RH:	GTL Raw:	RH Corr.:	DAS Volts:	DAS %RH:	Difference:
primary	RH Low Range	Hygroclip	32.8	0.0	32.8	0.3375	33.8	1.0
primary	RH Low Range	Hygroclip	52.9	0.0	52.9	0.5232	52.3	-0.6
primary	RH High Range	Hygroclip	93.6	0.0	93.6	0.8935	89.4	-4.2

Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	illegible		ROM406	Eric Hebert	06/10/2013	Precipitation	01620

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.0%	0.0%		

Mfg	PMP	Parameter	Precipitation
Serial Number	EW-06134-50	Tfer Desc.	250ml graduate
Tfer ID	01250		
Slope	1.00000	Intercept	0.00000
Cert Date	9/5/2005	CorrCoff	1.00000

UseDesc.	Test type:	TferVolume:	Iteration:	TimePerTip:	Eq.Ht:	DAS eng:	Eq.HtUnit:	OSE Unit:	TferUnits:	PctDifference
primary	tip check	10 manual	1	2 sec	1.00	1.00	mm	mm	ml	
primary	test 1	231.5	1	8 sec	5.00	5.00	mm	mm	ml	0.0%
primary	test 2	231.5	2	10 sec	5.00	5.00	mm	mm	ml	0.0%

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sensor Heater	Condition	Functioning	Status	pass
Sensor Component	Properly Sited	Condition	See comments	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Not installed	Status	Fail
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Not installed	Status	Fail

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8814 (s/n 3062-1)"/>	<input type="text" value="896 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	ROM406	Eric Hebert	06/10/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
2.58	4.47		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	19.11	19.09	0.000	22.0	C	2.91
primary	Temp Mid Range	21.38	21.35	0.000	21.7	C	0.37
primary	Temp Mid Range	17.22	17.22	0.000	21.7	C	4.47

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	ROM406	Eric Hebert	06/10/2013	Filter Position	Tylan	1578	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.								
Ozone	ROM406	Eric Hebert	06/10/2013	Cell B Freq.	ThermoElectron	3779	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	ROM406	Eric Hebert	06/10/2013	Cell A Freq.	ThermoElectron	3779	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Precipitation	ROM406	Eric Hebert	06/10/2013	Properly Sited	Climatronics	3769	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Objects violate the 45 degree rule for the tipping bucket rain gage.								
Shelter Temperature	ROM406	Eric Hebert	06/10/2013	Accuracy Mid Ra	ARS	2274	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The shelter temperature is going outside CFR requirements for pollutant monitor operation.								

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator is doing a very good job performing the site duties and expressed an interest in trying to improve any deficiencies. The sample flow rate systems for both the dry deposition and ozone sample trains were explained during the audit at the request of the site operator.

2 Parameter: SiteOpsProcedures

Mercury thermometer was removed from the shelter during the site audit. The site operator has requested additional training from ARS.

3 Parameter: ShelterCleanNotes

The shelter is clean, neat, organized, and well maintained.

4 Parameter: MetSensorComme

The tipping bucket rain gage and solar radiation sensor have been moved to the roof of the shelter since the previous audit visit. Both temperature sensor shields have been replaced with new models.

5 Parameter: MetOpMaintCom

The wind direction sensor is exhibiting the symptoms of potentiometer failure. Wind direction data quality are being impacted by this condition.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Longs Peak"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="08-069-0007"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="40.2778"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-105.5453"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="2743"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(970) 586-8520"/>	Audit Latitude	<input type="text" value="40.278129"/>
Site Address 1	<input type="text" value="High Peak Camp"/>	Audit Longitude	<input type="text" value="-105.545635"/>
Site Address 2	<input type="text" value="Route 7"/>	Audit Elevation	<input type="text" value="2742"/>
County	<input type="text" value="Larimer"/>	Audit Declination	<input type="text" value="9.0"/>
City, State	<input type="text" value="Estes Park, CO"/>		
Zip Code	<input type="text" value="80517"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected July 2012"/>
Time Zone	<input type="text" value="Mountain"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8814 (s/n 3062-1)"/>	Shelter Size <input type="text" value="896 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is clean, neat, organized, and well maintained."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID Technician Site Visit Date

- | | | | |
|----|--|-------------------------------------|----------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | 45 degree rule |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The tipping bucket rain gage and solar radiation sensor have been moved to the roof of the shelter since the previous audit visit. Both temperature sensor shields have been replaced with new models.

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- | | | | |
|---|--|-------------------------------------|----------------------------|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input type="checkbox"/> | Wind direction malfucntion |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | |

Parameter	Manufacturer	Model	S/N	Client ID
Met tower	Rohn	unknown	none	none
Relative Humidity	Rotronic	MP 601A	56091	none
Precipitation	Climatronics	100508-2	illegible	01620
Solar Radiation	Licor	LI-200	PY19983	none
Wind Direction	RM Young	AQ05103-5	89123wdr	none
Wind Speed	RM Young	AQ05103-5	89123wsp	none
Temperature	RM Young	41342	17079	none
Temperature2meter	RM Young	41342	17078	none
Shield (10 meter)	RM Young	unknown	none	none
Shield (2 meter)	RM Young	unknown	none	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The wind direction sensor is exhibiting the symptoms of potentiometer failure. Wind direction data quality are being impacted by this condition.

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	illegible
Filter pack flow pump	Thomas	107CAB18	0493002494	02978
Zero air pump	Werther International	PC70/4	531391	none
MFC power supply	Tylan	RO-32	illegible	none
Ozone	ThermoElectron Inc	49i A3NAA	1030745086	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Toshiba	Terca	unknown	none
DAS	Environmental Sys Corp	8816	2025	90535
Modem	US Robotics	33.6 fax modem	unknown	none
Printer	Hewlett Packard	842C	unknown	none
Solar Radiation Translator	RM Young	70101-X	none	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="June 2000"/>	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text" value="Not current"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|------------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | Filter changed various times |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input checked="" type="checkbox"/> | |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | no longer required |
| 4 | Are general observations being made and recorded? How? | <input checked="" type="checkbox"/> | SSRF |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | Clean gloves on and off |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is doing a very good job performing the site duties and expressed an interest in trying to improve any deficiencies. The sample flow rate systems for both the dry deposition and ozone sample trains were explained during the audit at the request of the site operator.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>GTH161-Eric Hebert-06/12/2013</i>						
1	6/12/2013	Computer	Dell	000251	D520	5HFNHB1
2	6/12/2013	DAS	Campbell	000416	CR3000	2513
3	6/12/2013	Elevation	Elevation	None	1	None
4	6/12/2013	Filter pack flow pump	Thomas	02751	107CAB18	1192001884
5	6/12/2013	flow rate	Tylan	000171	FC280SAV	AW04423004
6	6/12/2013	Infrastructure	Infrastructure	none	none	none
7	6/12/2013	MFC power supply	MACTEC	06044	none	none
8	6/12/2013	Modem	Raven	06589	H4223-C	0844321356
9	6/12/2013	Ozone	ThermoElectron Inc	000744	49i A1NAA	1105347324
10	6/12/2013	Ozone Standard	ThermoElectron Inc	000443	49i A3NAA	CM08200019
11	6/12/2013	Sample Tower	Aluma Tower	03564	A	none
12	6/12/2013	Shelter Temperature	Campbell	none	107-L	none
13	6/12/2013	Siting Criteria	Siting Criteria	None	1	None
14	6/12/2013	Temperature	RM Young	06120	41342VC	11742
15	6/12/2013	Zero air pump	Werther International	06927	P 70/4	000836211

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2513	GTH161	Eric Hebert	06/12/2013	DAS	Primary

Das Date:	<input type="text" value="6 /13/2013"/>	Audit Date	<input type="text" value="6 /13/2013"/>
Das Time:	<input type="text" value="8:56:10"/>	Audit Time	<input type="text" value="8:56:10"/>
Das Day:	<input type="text" value="164"/>	Audit Day	<input type="text" value="164"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/27/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.0999	V	V	-0.0001
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5000	0.5000	V	V	0.0000
7	0.7000	0.7001	0.6999	V	V	-0.0002
7	0.9000	0.9001	0.8999	V	V	-0.0002
7	1.0000	1.0001	0.9999	V	V	-0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW04423004		GTH161	Eric Hebert	06/12/2013	flow rate	000171

Mfg	MACTEC	
SN/Owner ID	none	06044
Parameter	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2013	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
2.16%	2.23%

Cal Factor Zero	-0.09
Cal Factor Full Scale	1.01
Rotometer Reading:	3.6

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.05	0.046	-0.04	l/m	l/m	
primary	leak check	0.000	0.000	0.05	0.046	-0.04	l/m	l/m	
primary	test pt 1	0.000	2.936	2.81	2.808	3.00	l/m	l/m	2.17%
primary	test pt 2	0.000	2.935	2.81	2.808	3.00	l/m	l/m	2.23%
primary	test pt 3	0.000	2.939	2.81	2.808	3.00	l/m	l/m	2.07%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347324		GTH161	Eric Hebert	06/12/2013	Ozone	000744

Slope:	0.93953	Slope:	0.00000
Intercept	0.44137	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
5.4%	5.8%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	-0.15	0.43	ppb	
primary	2	29.75	29.64	27.94	ppb	-5.74%
primary	3	49.75	49.70	47.16	ppb	-5.11%
primary	4	79.85	79.88	75.90	ppb	-4.98%
primary	5	109.80	109.92	103.50	ppb	-5.84%

Sensor Component	Cell B Noise	Condition	1.5 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	3 %	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	0.988	Status	pass
Sensor Component	Cell B Freq.	Condition	99.0 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.59 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.3 C	Status	pass
Sensor Component	Cell A Pressure	Condition	522 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	90.9 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.57 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	11742		GTH161	Eric Hebert	06/12/2013	Temperature	06120

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.13	0.21		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.04	0.08	0.000	0.3	C	0.21
primary	Temp Mid Range	23.81	23.76	0.000	23.8	C	0.03
primary	Temp High Range	45.88	45.67	0.000	45.5	C	-0.14

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-12)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	GTH161	Eric Hebert	06/12/2013	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.47	1.11		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00732	Intercept	-0.12380
Cert Date	1/12/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	19.94	19.92	0.000	21.0	C	1.11
primary	Temp Mid Range	21.94	21.90	0.000	21.8	C	-0.12
primary	Temp Mid Range	22.72	22.68	0.000	22.5	C	-0.19

Field Systems Comments

1 Parameter: SiteOpsProcComm

Due to the remote location of the site, it can take up to a week to return the filter sample to the lab after it is removed from the tower in the winter. The site operator is transferring the filter bag and caps from the new filter to the removed filter. There are no clean bags and spare caps on-site. It was discussed that the bags and caps are intended to stay with each filter and not be transferred from one to the next.

2 Parameter: DasComments

There is a new sample tower on-site to be installed in the near future.

3 Parameter: SiteOpsProcedures

The site operator is new and has not received formal training. He has been provided with written instructions prepared by the previous site operator. Site operation has improved since the previous site audit visit.

4 Parameter: ShelterCleanNotes

Some floor tiles are damaged.

5 Parameter: MetSensorComme

The temperature sensor has been moved to the sample tower and mounted in a naturally aspirated shield facing south and over the shelter roof. The met tower has been removed.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Gothic"/>
Operating Group	<input type="text" value="RMBL"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="08-051-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="38.9573"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-106.9854"/>
Land Use	<input type="text" value="mountain meadow, woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="2926"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="10.75"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="2/23/2006"/>
Site Telephone	<input type="text" value="(970) 349-5691"/>	Audit Latitude	<input type="text" value="38.95627"/>
Site Address 1	<input type="text" value="RMBL"/>	Audit Longitude	<input type="text" value="-106.98587"/>
Site Address 2	<input type="text" value="Gothic"/>	Audit Elevation	<input type="text" value="2915"/>
County	<input type="text" value="Gunnison"/>	Audit Declination	<input type="text" value="9.6"/>
City, State	<input type="text" value="Crested Butte, CO"/>		
Zip Code	<input type="text" value="81224"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Nov 1987"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2149-12)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="Some floor tiles are damaged."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Gunnison take route 135 north to Crested Butte. Continue through town to Mount Crested Butte. Continue through town past the fire station and the road maintenance facility onto the dirt road to Gothic. Continue approximately three miles and park at the visitor area at the bottom of the hill below the site. The site is approximately 200 meters on the path up the hill.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|--------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input type="checkbox"/> | South |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input type="checkbox"/> | Over shelter |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor has been moved to the sample tower and mounted in a naturally aspirated shield facing south and over the shelter roof. The met tower has been removed.

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|---|--|-------------------------------------|-----|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | N/A |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342VC	11742	06120

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	A	none	03564
MFC power supply	MACTEC	none	none	06044
Ozone	ThermoElectron Inc	49i A1NAA	1105347324	000744
Filter pack flow pump	Thomas	107CAB18	1192001884	02751
Zero air pump	Werther International	P 70/4	000836211	06927

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
- 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
- 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
- 4 Are the signal connections protected from the weather and well maintained?
- 5 Are the signal leads connected to the correct DAS channel?
- 6 Are the DAS, sensor translators, and shelter properly grounded?
- 7 Does the instrument shelter have a stable power source?
- 8 Is the instrument shelter temperature controlled?

9 Is the met tower stable and grounded?

10 Is the sample tower stable and grounded?

11 Tower comments?

Stable	Grounded
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Tower does not have ground rod but is bolted to shelter.

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	5HFNHB1	000251
DAS	Campbell	CR3000	2513	000416
Modem	Raven	H4223-C	0844321356	06589

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is a new sample tower on-site to be installed in the near future.

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is new and has not received formal training. He has been provided with written instructions prepared by the previous site operator. Site operation has improved since the previous site audit visit.

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Due to the remote location of the site, it can take up to a week to return the filter sample to the lab after it is removed from the tower in the winter. The site operator is transferring the filter bag and caps from the new filter to the removed filter. There are no clean bags and spare caps on-site. It was discussed that the bags and caps are intended to stay with each filter and not be transferred from one to the next.

APPENDIX B

CASTNET Site Spot Report Forms

EEMS Spot Report

Data Compiled: 7/11/2013 3:02:18 PM

Site Visit Date Site Technician

04/01/2013 CHA467 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99085	unitless	P
2	Ozone Intercept	P	0	5	4	0.45247	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	0.3	%	P
5	Ozone % difference max	P	7	10	4	0.5	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** System Memo **CommentCode** 178

Stainless steel fittings are connected to Teflon fittings on the ozone analyzer. This can cause leaks and premature failure of the fittings.

2 **Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/11/2013 7:29:05 PM

SiteVisitDate	Site	Technician
04/02/2013	PET427	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99254	unitless	P
2	Ozone Intercept	P	0	5	4	0.63847	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.5	%	P
5	Ozone % difference max	P	7	10	4	1.1	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/11/2013 7:39:36 PM

SiteVisitDate	Site	Technician
04/04/2013	GRC474	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00765	unitless	P
2	Ozone Intercept	P	0	5	4	-1.00446	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	1.1	%	P
5	Ozone % difference max	P	7	10	4	2.7	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/11/2013 7:49:36 PM

Site Visit Date Site Technician

04/08/2013 JOT403 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.95679	unitless	P
2	Ozone Intercept	P	0	5	4	1.01348	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99982	unitless	P
4	Ozone % difference avg	P	7	10	4	2.1	%	P
5	Ozone % difference max	P	7	10	4	4.3	%	P

EEMS Spot Report

Data Compiled: 7/11/2013 9:19:49 PM

Site Visit Date Site Technician

04/11/2013 PIN414 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.01	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.03	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	4	0.3	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	4	0.3	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.45	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.5	g-cm	Fail
7	Wind Direction Input Deg True average error (de	P	2	5	5	3.4	degrees	P
8	Wind Direction Input Deg True max error (deg)	P	2	5	5	6	degrees	Fail
9	Wind Direction Linearity average error (deg)	P	2	5	8	2.2	degrees	P
10	Wind Direction Linearity max error (deg)	P	2	5	8	6	degrees	Fail
11	Wind Direction Torque average error	P	2	20	1	8	g-cm	P
12	Wind Direction Torque max error	P	2	20	1	8	g-cm	P
13	Temperature average error	P	4	0.5	3	0.08	c	P
14	Temperature max error	P	4	0.5	3	0.11	c	P
15	Relative Humidity average above 85%	P	6	10	1	4.0	%	P
16	Relative Humidity max above 85%	P	6	10	1	4.0	%	P
17	Relative Humidity average below 85%	P	6	10	2	2.5	%	P
18	Relative Humidity max below 85%	P	6	10	2	4.2	%	P
19	Solar Radiation % diff of avg	P	9	10	27	9.42	%	P
20	Solar Radiation % diff of max STD value	P	9	10	27	9.00	%	P
21	Precipitation average % difference	P	1	10	2	2.0	%	P
22	Precipitation max % difference	P	1	10	2	4.0	%	P
23	Ozone Slope	P	0	1.1	4	0.98686	unitless	P
24	Ozone Intercept	P	0	5	4	0.13471	ppb	P
25	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
26	Ozone % difference avg	P	7	10	4	1.1	%	P
27	Ozone % difference max	P	7	10	4	1.7	%	P
28	Flow Rate average % difference	P	10	5	3	0.10	%	P
29	Flow Rate max % difference	P	10	5	3	0.14	%	P
30	DAS Time maximum error	P	0	5	1	0.67	min	P
31	DAS Voltage average error	P	9	0.003	28	0.0001	V	P
32	DAS Voltage average error	P	2	0.003	28	0.0003	V	P
33	Shelter Temperature average error	P	5	1	9	1.28	c	Fail
34	Shelter Temperature max error	P	5	1	9	2.09	c	Fail

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Precipitation **SensorComponent:** Properly Sited **CommentCode** 193
Objects violate the 45 degree rule for the tipping bucket rain gage.
- Parameter:** Precipitation **SensorComponent:** Sensor Heater **CommentCode** 107
The tipping bucket rain gauge heater is not functioning.
- Parameter:** Wind Direction **SensorComponent:** Condition **CommentCode** 147
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.

Field Systems Comments

- Parameter:** SiteOpsProcComm
The site operator reported that the flow pump is routinely turned on while the tower is down after the dry deposition filter is installed. She reported that she was instructed by ARS to operate the flow pump while the tower was in the down position to check for proper filter pack installation. It was discussed that this is not a proper check of filter installation since air flow could be going through the connector with the connector completely locked in place. The operator reported that the plastic bag is used to handle the filter and that gloves are not used. The site operator reported that the ozone inlet filter is changed while the dry deposition filter is still installed and exposed on the tower.
- Parameter:** SiteOpsProcedures
The site operator reviews data each week to ensure proper operation of sensors and instruments.
- Parameter:** ShelterCleanNotes
Shelter has some loose tiles and signs of a leak in the SW corner. It is somewhat cluttered with equipment that is unused and some that requires installation. The lighting is poor.

EEMS Spot Report

Data Compiled: 7/11/2013 9:31:58 PM

Site Visit Date Site Technician

04/16/2013 GRB411 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.0428	unitless	P
2	Ozone Intercept	P	0	5	4	-0.30416	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	3.5	%	P
5	Ozone % difference max	P	7	10	4	4.1	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/11/2013 9:48:03 PM

SiteVisitDate	Site	Technician
04/18/2013	MEV405	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00093	unitless	P
2	Ozone Intercept	P	0	5	4	-0.68617	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.4	%	P
5	Ozone % difference max	P	7	10	4	3.2	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/11/2013 10:01:49 PM

SiteVisitDate	Site	Technician
04/19/2013	CAN407	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97307	unitless	P
2	Ozone Intercept	P	0	5	4	0.93607	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	1.3	%	P
5	Ozone % difference max	P	7	10	4	1.9	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode** 94

The cooling fan dust cover for the ozone analyzer is clogged with dust and restricting air flow. This is increasing the internal ozone analyzer temperature. This could lead to premature failure of components including the ozone sample pump.

2 **Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

3 **Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/13/2013 12:19:30 PM

SiteVisitDate	Site	Technician
04/22/2013	DCP114	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.13	c	P
2	Temperature max error	P	4	0.5	12	0.15	c	P
3	Ozone Slope	P	0	1.1	4	0.99126	unitless	P
4	Ozone Intercept	P	0	5	4	0.91544	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	0.8	%	P
7	Ozone % difference max	P	7	10	4	2.4	%	P
8	Flow Rate average % difference	P	10	5	2	1.64	%	P
9	Flow Rate max % difference	P	10	5	2	1.7	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	0.11	c	P
13	Shelter Temperature max error	P	5	1	9	0.12	c	P

Field Performance Comments

- 1 **Parameter:** Temperature **SensorComponent:** Blower **CommentCode** 26
The forced-air blower for the shield is not functioning.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm
The site operator is following procedures and doing a very good job with filter handling.
- 2 **Parameter:** DasComments
One leg of the meteorological sensor tower is damaged and has a hole near the midpoint of the tower.
- 3 **Parameter:** SiteOpsProcedures
The ozone inlet filter is replaced and the sample line is leak-tested every two weeks.
- 4 **Parameter:** SitingCriteriaCom
The site is located in a wooded thicket within a state park. The area surrounding the park is almost completely intensive agriculture. The site may not be regionally representative.
- 5 **Parameter:** ShelterCleanNotes
The shelter is currently in fair condition. There are loose floor tiles. There are signs of rodent infestation.
- 6 **Parameter:** MetOpMaintCom
The blower for the aspirated temperature sensor shield is not functioning. This will affect sensor accuracy and data quality.

EEMS Spot Report

Data Compiled: 7/27/2013 12:33:22 PM

Site Visit Date	Site	Technician
04/25/2013	SAN189	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.11	c	P
2	Temperature max error	P	4	0.5	6	0.24	c	P
3	Ozone Slope	P	0	1.1	4	0.95175	unitless	P
4	Ozone Intercept	P	0	5	4	1.21042	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99993	unitless	P
6	Ozone % difference avg	P	7	10	4	3.0	%	P
7	Ozone % difference max	P	7	10	4	3.6	%	P
8	Flow Rate average % difference	P	10	5	6	1.12	%	P
9	Flow Rate max % difference	P	10	5	6	1.15	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	21	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	0.34	c	P
13	Shelter Temperature max error	P	5	1	9	0.65	c	P

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator was observed to be not completely familiar with all aspects of CASTNET site operation. Additional training is recommended. Flow rate leak checks are not performed although they are reported. The initial and final flow rates are not recorded correctly. These observations were reported following the previous audit.

2 Parameter: SiteOpsProcedures

CASTNET procedures including filter pack leak check and filter pack final flow rate are not being performed correctly. Additional training is recommended.

3 Parameter: ShelterCleanNotes

The shelter is in very good condition, however somewhat cluttered.

EEMS Spot Report

Data Compiled: 7/27/2013 1:05:28 PM

Site Visit Date	Site	Technician
04/26/2013	KNZ184	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.17	c	P
2	Temperature max error	P	4	0.5	3	0.19	c	P
3	Flow Rate average % difference	P	10	5	2	0.08	%	P
4	Flow Rate max % difference	P	10	5	2	0.13	%	P
5	DAS Time maximum error	P	0	5	1	0.00	min	P
6	DAS Voltage average error	P	7	0.003	28	0.0000	V	P
7	Shelter Temperature average error	P	5	1	9	0.93	c	P
8	Shelter Temperature max error	P	5	1	9	1.17	c	Fail

Field Systems Comments

1 Parameter: SiteOpsProcComm

One clean glove is used to handle the filter for removal and installation.

2 Parameter: SiteOpsProcedures

Ozone monitor not operating.

3 Parameter: SitingCriteriaCom

The site is located at a Long Term Ecological Research site operated by KSU.

4 Parameter: ShelterCleanNotes

The shelter is very clean, neat, well organized and well maintained.

5 Parameter: PollAnalyzerCom

By request of the Kansas Department of Health and Environment, the site ozone monitor was not operating at the time of the site audit.

EEMS Spot Report

Data Compiled: 7/27/2013 3:32:43 PM

Site Visit Date Site Technician

05/01/2013 YOS404 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.02	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.03	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	4	0.7	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	4	0.8	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.30	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.3	g-cm	P
7	Wind Direction Input Deg True average error (de	P	2	5	4	10.8	degrees	Fail
8	Wind Direction Input Deg True max error (deg)	P	2	5	4	13	degrees	Fail
9	Wind Direction Linearity average error (deg)	P	2	5	8	1.5	degrees	P
10	Wind Direction Linearity max error (deg)	P	2	5	8	4	degrees	P
11	Wind Direction Torque average error	P	2	20	1	8	g-cm	P
12	Wind Direction Torque max error	P	2	20	1	8	g-cm	P
13	Temperature average error	P	4	0.5	3	0.05	c	P
14	Temperature max error	P	4	0.5	3	0.12	c	P
15	Relative Humidity average above 85%	P	6	10	2	2.1	%	P
16	Relative Humidity max above 85%	P	6	10	2	2.1	%	P
17	Relative Humidity average below 85%	P	6	10	4	3.3	%	P
18	Relative Humidity max below 85%	P	6	10	4	4.3	%	P
19	Solar Radiation % diff of avg	P	9	10	8	3.82	%	P
20	Solar Radiation % diff of max STD value	P	9	10	8	4.8	%	P
21	Precipitation average % difference	P	1	10	2	3.0	%	P
22	Precipitation max % difference	P	1	10	2	4.0	%	P
23	Ozone Slope	P	0	1.1	4	1.00354	unitless	P
24	Ozone Intercept	P	0	5	4	-0.98519	ppb	P
25	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
26	Ozone % difference avg	P	7	10	4	1.3	%	P
27	Ozone % difference max	P	7	10	4	1.9	%	P
28	Flow Rate average % difference	P	10	5	6	3.14	%	P
29	Flow Rate max % difference	P	10	5	6	3.22	%	P
30	DAS Time maximum error	P	0	5	1	1.4	min	P
31	DAS Voltage average error	P	15	0.003	21	0.0001	V	P
32	DAS Voltage average error	P	6	0.003	21	0.0000	V	P
33	Shelter Temperature average error	P	5	1	9	2.83	c	Fail
34	Shelter Temperature max error	P	5	1	9	3.6	c	Fail

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode** 71
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Wind Direction **SensorComponent:** Vane Condition **CommentCode** 211
The wind direction vane is slightly bent and could be causing additional bias in wind direction measurements.
- Parameter:** Wind Direction **SensorComponent:** Condition **CommentCode** 147
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.
- Parameter:** Wind Speed **SensorComponent:** Condition **CommentCode** 147
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.

Field Systems Comments

- Parameter:** ShelterCleanNotes
The site is neat, clean, and well organized.
- Parameter:** PollAnalyzerCom
The DAS full scale and zero factors for the ozone channel are set to 497 and -3 respectively. The usual settings are 500 and 0. This may not be a problem but it does contribute to the error observed during the ozone accuracy check. It is possible that polled data at the central polling station have different factors.

EEMS Spot Report

Data Compiled: 7/27/2013 4:51:57 PM

Site Visit Date Site Technician

05/03/2013 SEK430 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.07	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.19	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	4	0.2	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	4	0.5	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.40	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.4	g-cm	P
7	Wind Direction Input Deg True average error (de	P	2	5	4	2.8	degrees	P
8	Wind Direction Input Deg True max error (deg)	P	2	5	4	5	degrees	P
9	Wind Direction Linearity average error (deg)	P	2	5	8	1.8	degrees	P
10	Wind Direction Linearity max error (deg)	P	2	5	8	3	degrees	P
11	Wind Direction Torque average error	P	2	20	1	14	g-cm	P
12	Wind Direction Torque max error	P	2	20	1	14	g-cm	P
13	Temperature average error	P	4	0.5	9	0.13	c	P
14	Temperature max error	P	4	0.5	9	0.21	c	P
15	Relative Humidity average above 85%	P	6	10	1	2.0	%	P
16	Relative Humidity max above 85%	P	6	10	1	2.0	%	P
17	Relative Humidity average below 85%	P	6	10	2	2.0	%	P
18	Relative Humidity max below 85%	P	6	10	2	2.9	%	P
19	Solar Radiation % diff of avg	P	9	10	6	1.73	%	P
20	Solar Radiation % diff of max STD value	P	9	10	6	2.2	%	P
21	Precipitation average % difference	P	1	10	2	4.7	%	P
22	Precipitation max % difference	P	1	10	2	5.5	%	P
23	Ozone Slope	P	0	1.1	4	0.98730	unitless	P
24	Ozone Intercept	P	0	5	4	0.82037	ppb	P
25	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
26	Ozone % difference avg	P	7	10	4	0.9	%	P
27	Ozone % difference max	P	7	10	4	2.4	%	P
28	Flow Rate average % difference	P	10	5	6	0.20	%	P
29	Flow Rate max % difference	P	10	5	6	0.31	%	P
30	DAS Time maximum error	P	0	5	1	0.33	min	P
31	DAS Voltage average error	P	9	0.003	28	0.0002	V	P
32	DAS Voltage average error	P	2	0.003	28	0.0002	V	P
33	Shelter Temperature average error	P	5	1	9	1.42	c	Fail
34	Shelter Temperature max error	P	5	1	9	1.5	c	Fail

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode** 71
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.
- Parameter:** Precipitation **SensorComponent:** Sensor Heater **CommentCode** 107
The tipping bucket rain gauge heater is not functioning.
- Parameter:** Precipitation **SensorComponent:** Properly Sited **CommentCode** 193
Objects violate the 45 degree rule for the tipping bucket rain gage.
- Parameter:** Temperature **SensorComponent:** Blower **CommentCode** 26
The forced-air blower for the shield is not functioning.

Field Systems Comments

- Parameter:** SitingCriteriaCom
The site is a wooded area with spaced trees on three sides and a steep drop in elevation on the west side. Although not strictly conforming to siting criteria it is elevated in a wide valley and representative of the area. Some trees have been trimmed since the previous site audit. Trees are still within 5 meters, however none are higher than the CASTNET sample inlets.
- Parameter:** ShelterCleanNotes
The shelter is aging but is in fair condition and kept clean, neat, and well organized.
- Parameter:** MetSensorComme
The rain gauge is mounted near the tower.
- Parameter:** MetOpMaintCom
The temperature sensor aspirated shield blower is not functioning which will impact temperature data accuracy.

EEMS Spot Report

Data Compiled: 7/27/2013 11:01:13 PM

Site Visit Date Site Technician

05/07/2013 LAV410 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	8	0.01	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	8	0.03	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	8	0.1	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	8	0.3	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.30	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.3	g-cm	P
7	Wind Direction Input Deg True average error (de	P	2	5	8	3.2	degrees	P
8	Wind Direction Input Deg True max error (deg)	P	2	5	8	5	degrees	P
9	Wind Direction Linearity average error (deg)	P	2	5	16	2.0	degrees	P
10	Wind Direction Linearity max error (deg)	P	2	5	16	4	degrees	P
11	Wind Direction Torque average error	P	2	20	1	8	g-cm	P
12	Wind Direction Torque max error	P	2	20	1	10	g-cm	P
13	Temperature average error	P	4	0.5	3	0.15	c	P
14	Temperature max error	P	4	0.5	3	0.34	c	P
15	Relative Humidity average above 85%	P	6	10	2	1.0	%	P
16	Relative Humidity max above 85%	P	6	10	2	1.0	%	P
17	Relative Humidity average below 85%	P	6	10	4	8.0	%	P
18	Relative Humidity max below 85%	P	6	10	4	11.4	%	Fail
19	Solar Radiation % diff of avg	P	9	10	18	9.72	%	P
20	Solar Radiation % diff of max STD value	P	9	10	18	11.4	%	Fail
21	Precipitation average % difference	P	1	10	2	3.0	%	P
22	Precipitation max % difference	P	1	10	2	4.0	%	P
23	Ozone Slope	P	0	1.1	4	0.98219	unitless	P
24	Ozone Intercept	P	0	5	4	1.20291	ppb	P
25	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
26	Ozone % difference avg	P	7	10	4	1.0	%	P
27	Ozone % difference max	P	7	10	4	2.1	%	P
28	Flow Rate average % difference	P	10	5	6	1.13	%	P
29	Flow Rate max % difference	P	10	5	6	1.26	%	P
30	DAS Time maximum error	P	0	5	1	0.15	min	P
31	DAS Voltage average error	P	9	0.003	28	0.0001	V	P
32	DAS Voltage average error	P	2	0.003	28	0.0000	V	P
33	Shelter Temperature average error	P	5	1	9	1.27	c	Fail
34	Shelter Temperature max error	P	5	1	9	1.68	c	Fail

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode** 71
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.
- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Precipitation **SensorComponent:** System Memo **CommentCode** 100
The edge of the tipping bucket funnel rests on the pipe that supports the rain gauge. This causes the funnel to be out of level.
- Parameter:** Precipitation **SensorComponent:** Properly Sited **CommentCode** 193
Objects violate the 45 degree rule for the tipping bucket rain gage.
- Parameter:** Wind Direction **SensorComponent:** Condition **CommentCode** 147
The upper and lower sections of the wind sensor body are loose. This condition will cause premature failure of the sensor and can affect data accuracy.
- Parameter:** Wind Speed **SensorComponent:** Prop or Cups Con **CommentCode** 145
Both set screws are stripped.

Field Systems Comments

- Parameter:** SiteOpsProcedures
The ozone inlet filter is changed and the sample line conditioned every two weeks.
- Parameter:** DocumentationCo
The most recent calibration and verification results are not available on-site.
- Parameter:** ShelterCleanNotes
The inside equipment is located in room within the fire station, clean, neat, and organized.
- Parameter:** SitingCriteriaCom
The site is located at the end of a park service facility parking lot, in a fire station. The tree line is near the building, but the prevailing wind direction is from the clearing. Tree height above the sample inlet is not twice as far away as it is high above the inlet.
- Parameter:** MetSensorComme
The rain gauge funnel is contacting the tipping bucket mounting post causing it to be 1/2 bubble off level. Objects violate the 45 degree rule.
- Parameter:** MetOpMaintCom
The signal cables are showing signs of wear.

EEMS Spot Report

Data Compiled: 7/27/2013 11:52:39 PM

SiteVisitDate	Site	Technician
05/08/2013	OXF122	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.44	c	P
2	Temperature max error	P	4	0.5	6	0.97	c	Fail
3	Ozone Slope	P	0	1.1	4	0.99852	unitless	P
4	Ozone Intercept	P	0	5	4	0.14735	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99992	unitless	P
6	Ozone % difference avg	P	7	10	4	0.7	%	P
7	Ozone % difference max	P	7	10	4	1.7	%	P
8	Flow Rate average % difference	P	10	5	2	0.12	%	P
9	Flow Rate max % difference	P	10	5	2	0.20	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0000	V	P
12	Shelter Temperature average error	P	5	1	9	0.45	c	P
13	Shelter Temperature max error	P	5	1	9	0.52	c	P

SiteVisitDate	Site	Technician
05/08/2013	OXF122	Sandy Grenville

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

Due to the high operator turn-over rate, the operators are unfamiliar with some minor aspects of site operation.

2 **Parameter:** DasComments

The met tower is operated by the university and the temperature sensor has been moved to the sample tower in a naturally aspirated shield.

3 **Parameter:** SitingCriteriaCom

The site is located in university agriculture research facility.

4 **Parameter:** ShelterCleanNotes

The shelter roof is in poor condition with several leaks.

EEMS Spot Report

Data Compiled: 7/28/2013 12:13:50 AM

SiteVisitDate	Site	Technician
05/09/2013	QAK172	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.17	c	P
2	Temperature max error	P	4	0.5	3	0.22	c	P
3	Ozone Slope	P	0	1.1	4	0.99551	unitless	P
4	Ozone Intercept	P	0	5	4	0.61213	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
6	Ozone % difference avg	P	7	10	4	0.8	%	P
7	Ozone % difference max	P	7	10	4	1.3	%	P
8	Flow Rate average % difference	P	10	5	6	2.43	%	P
9	Flow Rate max % difference	P	10	5	6	2.47	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	0.61	c	P
13	Shelter Temperature max error	P	5	1	9	0.81	c	P

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator is doing an excellent job maintaining the site.

2 Parameter: ShelterCleanNotes

The shelter is in good condition. It is clean, well organized, and well maintained.

EEMS Spot Report

Data Compiled: 7/28/2013 12:35:32 AM

Site Visit Date Site Technician

05/12/2013 PND165 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.05	c	P
2	Temperature max error	P	4	0.5	6	0.14	c	P
3	Ozone Slope	P	0	1.1	4	0.95790	unitless	P
4	Ozone Intercept	P	0	5	4	0.02026	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	4.1	%	P
7	Ozone % difference max	P	7	10	4	4.4	%	P
8	Flow Rate average % difference	P	10	5	6	1.02	%	P
9	Flow Rate max % difference	P	10	5	6	1.36	%	P
10	DAS Time maximum error	P	0	5	1	0.08	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	1.43	c	Fail
13	Shelter Temperature max error	P	5	1	9	2.26	c	Fail

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator uses the filter bag received with the new filter to send the filter removed from the tower back to the lab. There is no bag for the sample filter on site for storing the filter when it is removed from the tower.

2 Parameter: DasComments

Both the heat and the air conditioner are running simultaneously.

3 Parameter: DocumentationCo

General site observations are not being recorded on the SSRF. The purpose for recording the general observations was discussed with the site operator.

4 Parameter: ShelterCleanNotes

The shelter is well maintained.

EEMS Spot Report

Data Compiled: 7/28/2013 2:48:21 PM

SiteVisitDate	Site	Technician
05/12/2013	PNF126	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.06946	unitless	P
2	Ozone Intercept	P	0	5	4	-0.38181	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99993	unitless	P
4	Ozone % difference avg	P	7	10	4	6.6	%	P
5	Ozone % difference max	P	7	10	4	7.5	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/28/2013 12:57:44 AM

Site Visit Date Site Technician

05/14/2013 CNT169 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.10	c	P
2	Temperature max error	P	4	0.5	3	0.17	c	P
3	Ozone Slope	P	0	1.1	4	0.95862	unitless	P
4	Ozone Intercept	P	0	5	4	0.26392	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	3.5	%	P
7	Ozone % difference max	P	7	10	4	4.1	%	P
8	Flow Rate average % difference	P	10	5	6	5.76	%	Fail
9	Flow Rate max % difference	P	10	5	6	6.13	%	Fail
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	0.69	c	P
13	Shelter Temperature max error	P	5	1	9	0.99	c	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 **Parameter:** DasComments

The sample tower has been replaced and the met tower removed since the previous site audit visit.

2 **Parameter:** SiteOpsProcedures

The ozone inlet filter is changed once each month and the ozone sample line is leak tested every two weeks.

3 **Parameter:** ShelterCleanNotes

The shelter is dirty. Some floor tiles have been repaired since the previous audit visit.

EEMS Spot Report

Data Compiled: 7/28/2013 2:45:14 PM

Site Visit Date Site Technician

05/18/2013 MCK231 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97219	unitless	P
2	Ozone Intercept	P	0	5	4	0.30066	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99970	unitless	P
4	Ozone % difference avg	P	7	10	4	2.7	%	P
5	Ozone % difference max	P	7	10	4	5.4	%	P

EEMS Spot Report

Data Compiled: 7/28/2013 12:31:17 PM

Site Visit Date Site Technician

06/06/2013 YEL408 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	8	0.08	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	8	0.13	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	8	1.1	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	8	1.6	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.30	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.3	g-cm	P
7	Wind Direction Input Deg True average error (de	P	2	5	8	9.5	degrees	Fail
8	Wind Direction Input Deg True max error (deg)	P	2	5	8	13	degrees	Fail
9	Wind Direction Linearity average error (deg)	P	2	5	16	1.2	degrees	P
10	Wind Direction Linearity max error (deg)	P	2	5	16	5	degrees	P
11	Wind Direction Torque average error	P	2	20	1	8	g-cm	P
12	Wind Direction Torque max error	P	2	20	1	8	g-cm	P
13	Temperature average error	P	4	0.5	9	0.05	c	P
14	Temperature max error	P	4	0.5	9	0.11	c	P
15	Relative Humidity average above 85%	P	6	10	2	0.9	%	P
16	Relative Humidity max above 85%	P	6	10	2	0.9	%	P
17	Relative Humidity average below 85%	P	6	10	4	2.2	%	P
18	Relative Humidity max below 85%	P	6	10	4	2.8	%	P
19	Solar Radiation % diff of avg	P	9	10	15	1.35	%	P
20	Solar Radiation % diff of max STD value	P	9	10	15	1.3	%	P
21	Precipitation average % difference	P	1	10	2	3.0	%	P
22	Precipitation max % difference	P	1	10	2	4.0	%	P
23	Ozone Slope	P	0	1.1	4	1.02906	unitless	P
24	Ozone Intercept	P	0	5	4	-0.33928	ppb	P
25	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
26	Ozone % difference avg	P	7	10	4	1.9	%	P
27	Ozone % difference max	P	7	10	4	2.8	%	P
28	Flow Rate average % difference	P	10	5	6	0.48	%	P
29	Flow Rate max % difference	P	10	5	6	0.87	%	P
30	DAS Time maximum error	P	0	5	1	0.52	min	P
31	DAS Voltage average error	P	16	0.003	35	0.0003	V	P
32	DAS Voltage average error	P	2	0.003	35	0.0001	V	P
33	Shelter Temperature average error	P	5	1	12	1.68	c	Fail
34	Shelter Temperature max error	P	5	1	12	2.06	c	Fail

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode** 71
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.
- Parameter:** Precipitation **SensorComponent:** Properly Sited **CommentCode** 193
Objects violate the 45 degree rule for the tipping bucket rain gage.
- Parameter:** Wind Speed **SensorComponent:** System Memo **CommentCode** 212
The external heater that wraps around the sensor was found to be impeding the rotation of the sensor shaft. This condition impacts data accuracy. The condition was corrected during the sensor audit.

Field Systems Comments

- Parameter:** SiteOpsProcComm
Gloves are no longer used to handle the filter pack.
- Parameter:** SitingCriteriaCom
The site is located at the edge of a tree line. The trees close to the inlet are approximately 5 meters tall. Trees taller than 10 meters are 15 meters from the inlet.
- Parameter:** ShelterCleanNotes
The shelter is organized and well maintained.
- Parameter:** PollAnalyzerCom
The shelter and sample tower are located at the edge of the tree line and mountain slope. Small trees are encroaching on the sample tower. Taller trees are 10 to 15 meters from the sample tower.

EEMS Spot Report

Data Compiled: 7/28/2013 1:02:30 PM

Site Visit Date Site Technician

06/10/2013 ROM206 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.08	c	P
2	Temperature max error	P	4	0.5	9	0.12	c	P
3	Ozone Slope	P	0	1.1	4	0.99603	unitless	P
4	Ozone Intercept	P	0	5	4	0.31352	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	0.5	%	P
7	Ozone % difference max	P	7	10	4	0.8	%	P
8	Flow Rate average % difference	P	10	5	3	0.78	%	P
9	Flow Rate max % difference	P	10	5	3	0.94	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	0.52	c	P
13	Shelter Temperature max error	P	5	1	9	0.54	c	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

- Parameter:** ShelterCleanNotes
The shelter is clean, neat, and well organized. There are signs of previous roof leaks, but they have been repaired. The floor and counter top have been replaced.
- Parameter:** MetSensorComme
The temperature sensor has been removed from the met tower and mounted in a naturally aspirated shield on the sample tower.

EEMS Spot Report

Data Compiled: 7/28/2013 2:01:22 PM

Site Visit Date Site Technician

06/10/2013 ROM406 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature 2 meter average error	P	5	0.5	3	0.11	c	P
2	Temperature 2 meter max error	P	5	0.5	3	0.20	c	P
3	Wind Speed average error below 5 m/s in m/s	P	3	0.5	4	0.05	m/s	P
4	Wind Speed max error below 5 m/s in m/s	P	3	0.5	4	0.20	m/s	P
5	Wind Speed average % difference above 5 m/s	P	3	5	4	0.0	%	P
6	Wind Speed max % difference above 5 m/s	P	3	5	4	0.0	%	P
7	Wind Speed Torque average error	P	3	0.5	1	0.30	g-cm	P
8	Wind Speed Torque max error	P	3	0.5	1	0.3	g-cm	P
9	Wind Direction Input Deg True average error (de	P	2	5	3	9.7	degrees	Fail
10	Wind Direction Input Deg True max error (deg)	P	2	5	3	13	degrees	Fail
11	Wind Direction Linearity average error (deg)	P	2	5	8	10.8	degrees	Fail
12	Wind Direction Linearity max error (deg)	P	2	5	8	43	degrees	Fail
13	Wind Direction Torque average error	P	2	20	1	14	g-cm	P
14	Wind Direction Torque max error	P	2	20	1	15	g-cm	P
15	Temperature average error	P	4	0.5	3	0.10	c	P
16	Temperature max error	P	4	0.5	3	0.10	c	P
17	Relative Humidity average above 85%	P	6	10	2	4.2	%	P
18	Relative Humidity max above 85%	P	6	10	2	4.2	%	P
19	Relative Humidity average below 85%	P	6	10	4	0.8	%	P
20	Relative Humidity max below 85%	P	6	10	4	1.0	%	P
21	Solar Radiation % diff of avg	P	9	10	10	3.05	%	P
22	Solar Radiation % diff of max STD value	P	9	10	10	7.1	%	P
23	Precipitation average % difference	P	1	10	2	0.0	%	P
24	Precipitation max % difference	P	1	10	2	0.0	%	P
25	Ozone Slope	P	0	1.1	4	0.99341	unitless	P
26	Ozone Intercept	P	0	5	4	0.32985	ppb	P
27	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
28	Ozone % difference avg	P	7	10	4	0.4	%	P
29	Ozone % difference max	P	7	10	4	0.6	%	P
30	Flow Rate average % difference	P	10	5	6	0.32	%	P
31	Flow Rate max % difference	P	10	5	6	0.35	%	P
32	DAS Time maximum error	P	0	5	1	0.40	min	P
33	DAS Voltage average error	P	12	0.003	35	0.0001	V	P
34	DAS Voltage average error	P	2	0.003	35	0.0000	V	P

SiteVisitDate Site Technician

06/10/2013	ROM406	Eric Hebert							
35	Shelter Temperature average error	P	5	1	12	2.58	c	Fail	
36	Shelter Temperature max error	P	5	1	12	4.47	c	Fail	

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode** 71
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.
- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Precipitation **SensorComponent:** Properly Sited **CommentCode** 193
Objects violate the 45 degree rule for the tipping bucket rain gage.
- Parameter:** Shelter Temperatur **SensorComponent:** Accuracy Mid Ran **CommentCode** 213
The shelter temperature is going outside CFR requirements for pollutant monitor operation.

Field Systems Comments

- Parameter:** SiteOpsProcComm
The site operator is doing a very good job performing the site duties and expressed an interest in trying to improve any deficiencies. The sample flow rate systems for both the dry deposition and ozone sample trains were explained during the audit at the request of the site operator.
- Parameter:** SiteOpsProcedures
Mercury thermometer was removed from the shelter during the site audit. The site operator has requested additional training from ARS.
- Parameter:** ShelterCleanNotes
The shelter is clean, neat, organized, and well maintained.
- Parameter:** MetSensorComme
The tipping bucket rain gage and solar radiation sensor have been moved to the roof of the shelter since the previous audit visit. Both temperature sensor shields have been replaced with new models.
- Parameter:** MetOpMaintCom
The wind direction sensor is exhibiting the symptoms of potentiometer failure. Wind direction data quality are being impacted by this condition.

EEMS Spot Report

Data Compiled: 7/28/2013 2:27:29 PM

Site Visit Date Site Technician

06/12/2013 GTH161 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.13	c	P
2	Temperature max error	P	4	0.5	9	0.21	c	P
3	Ozone Slope	P	0	1.1	4	0.93953	unitless	P
4	Ozone Intercept	P	0	5	4	0.44137	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
6	Ozone % difference avg	P	7	10	4	5.4	%	P
7	Ozone % difference max	P	7	10	4	5.8	%	P
8	Flow Rate average % difference	P	10	5	6	2.15	%	P
9	Flow Rate max % difference	P	10	5	6	2.23	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	28	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	0.47	c	P
13	Shelter Temperature max error	P	5	1	9	1.11	c	Fail

Field Systems Comments

1 Parameter: SiteOpsProcComm

Due to the remote location of the site, it can take up to a week to return the filter sample to the lab after it is removed from the tower in the winter. The site operator is transferring the filter bag and caps from the new filter to the removed filter. There are no clean bags and spare caps on-site. It was discussed that the bags and caps are intended to stay with each filter and not be transferred from one to the next.

2 Parameter: DasComments

There is a new sample tower on-site to be installed in the near future.

3 Parameter: SiteOpsProcedures

The site operator is new and has not received formal training. He has been provided with written instructions prepared by the previous site operator. Site operation has improved since the previous site audit visit.

4 Parameter: ShelterCleanNotes

Some floor tiles are damaged.

5 Parameter: MetSensorComme

The temperature sensor has been moved to the sample tower and mounted in a naturally aspirated shield facing south and over the shelter roof. The met tower has been removed.

EEMS Spot Report

Data Compiled: 7/28/2013 2:47:00 PM

SiteVisitDate	Site	Technician
06/15/2013	DEN417	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99826	unitless	P
2	Ozone Intercept	P	0	5	4	1.06287	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.9	%	P
5	Ozone % difference max	P	7	10	4	4.1	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/28/2013 2:49:22 PM

SiteVisitDate	Site	Technician
06/17/2013	MOR409	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97890	unitless	P
2	Ozone Intercept	P	0	5	4	-0.66252	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99992	unitless	P
4	Ozone % difference avg	P	7	10	4	3.5	%	P
5	Ozone % difference max	P	7	10	4	5.3	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

APPENDIX C

CASTNET Ozone Performance Evaluation Forms

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CHA467-Eric Hebert-04/01/2013

1	4/1/2013	Computer	Gateway	none	Solo	B2509462726
2	4/1/2013	DAS	Environmental Sys Corp	90611	8816	2613
3	4/1/2013	Modem	US Robotics	09615	56k	unknown
4	4/1/2013	Ozone	ThermoElectron Inc	none	49i A3NAA	CM08460007
5	4/1/2013	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130450193
6	4/1/2013	Printer	Hewlett Packard	none	5610	Unknown
7	4/1/2013	Sample Tower	Aluma Tower	03566	A	none
8	4/1/2013	Zero air pump	Werther International	none	PC70/4	000665785

Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	CM08460007	CHA467	Eric Hebert	04/01/2013	Ozone	none

Slope:	0.99085	Slope:	0.00000
Intercept	0.45247	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
0.3%	0.6%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	-0.15	0.38	ppb	
primary	2	25.72	25.60	25.62	ppb	0.08%
primary	3	56.23	56.20	56.35	ppb	0.27%
primary	4	86.17	86.22	85.75	ppb	-0.55%
primary	5	107.58	107.69	107.20	ppb	-0.46%

Sensor Component	Cell B Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9960	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.1	Status	pass
Sensor Component	Span	Condition	1.055	Status	pass
Sensor Component	Cell B Freq.	Condition	78.9 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Poor	Status	Fail
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	39.2 C	Status	pass
Sensor Component	Cell A Pressure	Condition	627 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	81.3 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0002	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
-----------	------	------------	-----------	-----------	-----	------------	--------	---------

Ozone	CHA467	Eric Hebert	04/01/2013	System Memo	ThermoElectron	3564	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-------	--------	-------------	------------	-------------	----------------	------	--------------------------	-------------------------------------

Stainless steel fittings are connected to Teflon fittings on the ozone analyzer. This can cause leaks and premature failure of the fittings.

Ozone	CHA467	Eric Hebert	04/01/2013	Cell B Freq.	ThermoElectron	3564	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-------	--------	-------------	------------	--------------	----------------	------	--------------------------	-------------------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

PET427-Eric Hebert-04/02/2013

1	4/2/2013	Computer	Gateway	none	Solo	B2500212709
2	4/2/2013	DAS	Environmental Sys Corp	90641	8816	2526
3	4/2/2013	Modem	US Robotics	none	56k	unknown
4	4/2/2013	Ozone	ThermoElectron Inc	none	49i A3NAA	1211052490
5	4/2/2013	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1015543061
6	4/2/2013	Sample Tower	Aluma Tower	none	B	none

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1211052490		PET427	Eric Hebert	04/02/2013	Ozone	none

Slope:	0.99254	Slope:	0.00000
Intercept	0.63847	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
0.5%	1.1%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.06	-0.12	0.42	ppb	
primary	2	36.16	36.07	36.48	ppb	1.14%
primary	3	54.32	54.28	54.70	ppb	0.77%
primary	4	77.85	77.88	77.87	ppb	-0.01%
primary	5	105.70	105.81	105.60	ppb	-0.20%

Sensor Component	Cell B Noise	Condition	2.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9998	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.033	Status	pass
Sensor Component	Cell B Freq.	Condition	78.9 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	608 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	77.7 kHz	Status	Fail
Sensor Component	Cell A Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0001	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
-----------	------	------------	-----------	-----------	-----	------------	--------	---------

Ozone	PET427	Eric Hebert	04/02/2013	Cell B Freq.	ThermoElectron	3729	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Ozone	PET427	Eric Hebert	04/02/2013	Cell A Freq.	ThermoElectron	3729	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

GRC474-Eric Hebert-04/04/2013

1	4/4/2013	Computer	Gateway	none	Solo	B2500251337
2	4/4/2013	DAS	Environmental Sys Corp	90602	8816	2270
3	4/4/2013	Modem	US Robotics	none	33.6 sportster	unknown
4	4/4/2013	Ozone	ThermoElectron Inc	none	49i A3NAA	1023943902
5	4/4/2013	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130450192
6	4/4/2013	Printer	Hewlett Packard	none	842C	unknown
7	4/4/2013	Sample Tower	Aluma Tower	03570	B	none
8	4/4/2013	Zero air pump	Werther International	none	PC70/4	531380

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1023943902		GRC474	Eric Hebert	04/04/2013	Ozone	none

Slope:	1.00765	Slope:	0.00000
Intercept	-1.00446	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
1.1%	2.7%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	-0.15	-1.17	ppb	
primary	2	27.77	27.66	26.91	ppb	-2.71%
primary	3	56.06	56.03	55.39	ppb	-1.14%
primary	4	83.12	83.16	82.85	ppb	-0.37%
primary	5	107.99	108.10	107.90	ppb	-0.19%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9999	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	1.6	Status	pass
Sensor Component	Span	Condition	1.040	Status	pass
Sensor Component	Cell B Freq.	Condition	103.7 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.61 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	40.1 C	Status	Fail
Sensor Component	Cell A Pressure	Condition	594 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	114.3 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.61 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0002	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	GRC474	Eric Hebert	04/04/2013	Cell A Tmp.	ThermoElectron	3570	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

JOT403-Eric Hebert-04/08/2013

1	4/8/2013	Computer	Hewlett Packard	none	8460p	CNU1360668
2	4/8/2013	DAS	Environmental Sys Corp	90599	8816	2271
3	4/8/2013	Modem	US Robotics	none	56k	unknown
4	4/8/2013	Ozone	ThermoElectron Inc	none	49i A3NAA	CM08460006
5	4/8/2013	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1211052489
6	4/8/2013	Printer	Hewlett Packard	none	842C	unknown
7	4/8/2013	Sample Tower	Aluma Tower	923310	B	none
8	4/8/2013	Zero air pump	Werther International	none	PC70/4	606491

Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	CM08460006	JOT403	Eric Hebert	04/08/2013	Ozone	none

Slope:	0.95679	Slope:	0.00000
Intercept	1.01348	Intercept	0.00000
CorrCoff	0.99982	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.1%	4.3%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.16	-0.02	0.60	ppb	
primary	2	26.16	26.04	25.98	ppb	-0.23%
primary	3	55.43	55.40	54.35	ppb	-1.90%
primary	4	81.93	81.97	80.44	ppb	-1.87%
primary	5	102.85	102.95	98.53	ppb	-4.29%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	10.0018	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.8	Status	pass
Sensor Component	Span	Condition	1.001	Status	pass
Sensor Component	Cell B Freq.	Condition	99.3 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	31.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	643 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	101.0 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	-0.0003	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

GRB411-Eric Hebert-04/16/2013

1	4/16/2013	Computer	Gateway	none	Solo	B2500130064
2	4/16/2013	DAS	Environmental Sys Corp	90635	8816	2507
3	4/16/2013	Modem	US Robotics	none	V.92	unknown
4	4/16/2013	Ozone	ThermoElectron Inc	90565	49C	49C-59285-322
5	4/16/2013	Ozone Standard	ThermoElectron Inc	90570	49C	49C-59301-322
6	4/16/2013	Printer	Hewlett Packard	none	842C	unknown
7	4/16/2013	Sample Tower	Aluma Tower	none	B	AT-5381-F9-2
8	4/16/2013	Zero air pump	Werther International	90722	TT70/4E	507782

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-59285-322		GRB411	Eric Hebert	04/16/2013	Ozone	90565

Slope:	1.04280	Slope:	0.00000
Intercept	-0.30416	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.5%	4.1%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.18	0.00	-0.09	ppb	
primary	2	28.42	28.31	28.98	ppb	2.37%
primary	3	54.04	54.00	55.94	ppb	3.59%
primary	4	81.75	81.79	84.95	ppb	3.86%
primary	5	104.98	105.08	109.40	ppb	4.11%

Sensor Component	Cell B Noise	Condition	1.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9995	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.6	Status	pass
Sensor Component	Span	Condition	1.044	Status	pass
Sensor Component	Cell B Freq.	Condition	66.4 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.3 C	Status	pass
Sensor Component	Cell A Pressure	Condition	573 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	69.3 kHz	Status	Fail
Sensor Component	Cell A Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0008	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	GRB411	Eric Hebert	04/16/2013	Cell B Freq.	ThermoElectron	1577	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	GRB411	Eric Hebert	04/16/2013	Cell A Freq.	ThermoElectron	1577	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

MEV405-Eric Hebert-04/18/2013

1	4/18/2013	Computer	Gateway	none	450SX4	unknown
2	4/18/2013	DAS	Environmental Sys Corp	90613	8816	2616
3	4/18/2013	Modem	US Robotics	none	56k fax modem	unknown
4	4/18/2013	Ozone	ThermoElectron Inc	none	49C	0425208058
5	4/18/2013	Ozone Standard	ThermoElectron Inc	none	49C	0425208055
6	4/18/2013	Printer	Hewlett Packard	none	842C	unknown
7	4/18/2013	Sample Tower	Aluma Tower	illegible	B	none
8	4/18/2013	Zero air pump	Werther International	none	PC40/4	526289

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	0425208058		MEV405	Eric Hebert	04/18/2013	Ozone	none

Slope:	1.00093	Slope:	0.00000
Intercept	-0.68617	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.4%	3.2%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.05	-0.13	-0.63	ppb	
primary	2	27.24	27.13	26.27	ppb	-3.17%
primary	3	52.32	52.28	51.73	ppb	-1.05%
primary	4	81.47	81.51	80.57	ppb	-1.15%
primary	5	108.61	108.73	108.40	ppb	-0.30%

Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	1.0003	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Moderately clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	1.0	Status	pass
Sensor Component	Span	Condition	1.030	Status	pass
Sensor Component	Cell B Freq.	Condition	86.4 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.60 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	572 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	62.2 kHz	Status	Fail
Sensor Component	Cell A Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0003	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	MEV405	Eric Hebert	04/18/2013	Cell A Freq.	ThermoElectron	418	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-------	--------	-------------	------------	--------------	----------------	-----	--------------------------	-------------------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CAN407-Eric Hebert-04/19/2013

1	4/19/2013	Computer	Gateway	none	Solo	unknown
2	4/19/2013	DAS	Environmental Sys Corp	09638	8816	2523
3	4/19/2013	Modem	US Robotics	none	56k	unknown
4	4/19/2013	Ozone	ThermoElectron Inc	none	49C	0425208057
5	4/19/2013	Ozone Standard	ThermoElectron Inc	90567	49C	49C-59283-322
6	4/19/2013	Printer	Hewlett Packard	none	842C	unknown
7	4/19/2013	Sample Tower	Aluma Tower	illegible	B	none
8	4/19/2013	Zero air pump	Twin Tower Engineering	none	TT70/4E	526292

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	0425208057		CAN407	Eric Hebert	04/19/2013	Ozone	none

Slope:	0.97307	Slope:	0.00000
Intercept	0.93607	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.3%	1.9%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.02	-0.20	1.03	ppb	
primary	2	27.49	27.38	27.10	ppb	-1.02%
primary	3	55.52	55.49	54.92	ppb	-1.03%
primary	4	82.24	82.28	81.31	ppb	-1.18%
primary	5	108.28	108.39	106.30	ppb	-1.93%

Sensor Component	Cell B Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9996	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.040	Status	pass
Sensor Component	Cell B Freq.	Condition	57.3 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.59 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	40.3 C	Status	Fail
Sensor Component	Cell A Pressure	Condition	615 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	92.2 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.57 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	-0.0005	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	CAN407	Eric Hebert	04/19/2013	Cell A Tmp.	ThermoElectron	216	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The cooling fan dust cover for the ozone analyzer is clogged with dust and restricting air flow. This is increasing the internal ozone analyzer temperature. This could lead to premature failure of components including the ozone sample pump.								
Ozone	CAN407	Eric Hebert	04/19/2013	Cell A Tmp.	ThermoElectron	216	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	CAN407	Eric Hebert	04/19/2013	Cell B Freq.	ThermoElectron	216	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

PNF126-Sandy Grenville-05/12/2013

1	5/12/2013	Computer	Dell	000264	D520	unknown
2	5/12/2013	DAS	Campbell	000346	CR3000	2125
3	5/12/2013	Modem	Raven	06597	V4221-V	0844349884
4	5/12/2013	Ozone	ThermoElectron Inc	000618	49i A1NAA	1009241789
5	5/12/2013	Ozone Standard	ThermoElectron Inc	000512	49i A3NAA	0922236890
6	5/12/2013	Sample Tower	Aluma Tower	000178	B	none
7	5/12/2013	Zero air pump	Werther International	06886	C 70/4	000815259

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241789		PNF126	Sandy Grenville	05/12/2013	Ozone	000618

Slope:	1.06946	Slope:	0.00000
Intercept	-0.38181	Intercept	0.00000
CorrCoff	0.99993	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
6.6%	7.5%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00308	Intercept	-0.17961
Cert Date	4/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.00	0.17	-0.54	ppb	
primary	2	29.80	29.88	32.13	ppb	7.53%
primary	3	50.50	50.52	53.34	ppb	5.58%
primary	4	81.00	80.93	86.70	ppb	7.13%
primary	5	100.20	100.07	106.20	ppb	6.13%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.30	Status	pass
Sensor Component	Span	Condition	1.017	Status	pass
Sensor Component	Cell B Freq.	Condition	93.2 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.000	Status	fail
Sensor Component	Cell A Tmp.	Condition	31.9 C	Status	pass
Sensor Component	Cell A Pressure	Condition	642 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	82.8 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	1.37 lpm	Status	fail
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	PNF126	Sandy Grenville	05/12/2013	Cell B Flow	ThermoElectron	3364	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	PNF126	Sandy Grenville	05/12/2013	Cell A Flow	ThermoElectron	3364	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

MCK231-Eric Hebert-05/18/2013

1	5/18/2013	Computer	Dell	000458	D530	unknown
2	5/18/2013	DAS	Campbell	000359	CR3000	2137
3	5/18/2013	Modem	Raven	06476	H4222-C	0808311140
4	5/18/2013	Ozone	ThermoElectron Inc	000723	49i A1NAA	1105347327
5	5/18/2013	Ozone Standard	ThermoElectron Inc	000439	49i A3NAA	CM08200015
6	5/18/2013	Zero air pump	Werther International	06924	C 70/4	000836205

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347327		MCK231	Eric Hebert	05/18/2013	Ozone	000723

Slope:	0.97219	Slope:	0.00000
Intercept	0.30066	Intercept	0.00000
CorrCoff	0.99970	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.7%	5.4%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	0.99720	Intercept	0.18428
Cert Date	1/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.17	-0.35	-0.11	ppb	
primary	2	30.01	29.90	28.30	ppb	-5.35%
primary	3	54.88	54.84	55.07	ppb	0.42%
primary	4	83.75	83.80	82.30	ppb	-1.79%
primary	5	109.06	109.18	105.60	ppb	-3.28%

Sensor Component	Cell B Noise	Condition	1.4 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.3	Status	pass
Sensor Component	Span	Condition	1.005	Status	pass
Sensor Component	Cell B Freq.	Condition	95.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	31.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	703 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	94.8 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

DEN417-Sandy Grenville-06/15/2013

1	6/15/2013	Computer	Gateway	none	Solo	2500251309
2	6/15/2013	DAS	Environmental Sys Corp	90600	8816	2274
3	6/15/2013	Modem	US Robotics	none	33.6 fax modem	unknown
4	6/15/2013	Ozone	ThermoElectron Inc	90778	49C	49C-77033-384
5	6/15/2013	Ozone Standard	ThermoElectron Inc	90831	49C	0520012325
6	6/15/2013	Printer	Hewlett Packard	none	840C	unknown
7	6/15/2013	Sample Tower	Aluma Tower	none	B	AT-71102-7I-5
8	6/15/2013	Zero air pump	Werther International	none	PC 70/4	626281

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-77033-384		DEN417	Sandy Grenville	06/15/2013	Ozone	90778

Slope:	0.99826	Slope:	0.00000
Intercept	1.06287	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.9%	4.1%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00308	Intercept	-0.17961
Cert Date	4/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.23	-0.05	1.00	ppb	
primary	2	30.47	30.55	31.79	ppb	4.06%
primary	3	49.66	49.68	50.50	ppb	1.65%
primary	4	80.50	80.43	81.00	ppb	0.71%
primary	5	99.95	99.82	101.00	ppb	1.18%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.7	Status	pass
Sensor Component	Span	Condition	1.021	Status	pass
Sensor Component	Cell B Freq.	Condition	76.7 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	695 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	92.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	DEN417	Sandy Grenville	06/15/2013	Cell B Freq.	ThermoElectron	623	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-------	--------	-----------------	------------	--------------	----------------	-----	--------------------------	-------------------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

MOR409-Sandy Grenville-06/17/2013

1	6/17/2013	DAS	Environmental Sys Corp	90652	8816	2565
2	6/17/2013	Modem	US Robotics	none	14.4 fax modem	7643
3	6/17/2013	Ozone	ThermoElectron Inc	90608	49C	49C-61987-333
4	6/17/2013	Ozone Standard	ThermoElectron Inc	none	49C	49C-74537-376
5	6/17/2013	Sample Tower	Aluma Tower	none	B	none
6	6/17/2013	Zero air pump	Werther International	none	PC70/4	585572

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-61987-333		MOR409	Sandy Grenville	06/17/2013	Ozone	90608

Slope:	0.97890	Slope:	0.00000
Intercept	-0.66252	Intercept	0.00000
CorrCoff	0.99992	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
3.5%	5.3%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00308	Intercept	-0.17961
Cert Date	4/2/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.14	0.31	-0.16	ppb	
primary	2	32.36	32.43	30.71	ppb	-5.30%
primary	3	52.52	52.53	51.14	ppb	-2.65%
primary	4	82.40	82.32	79.25	ppb	-3.73%
primary	5	102.04	101.90	99.55	ppb	-2.31%

Sensor Component	Cell B Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	1.4	Status	pass
Sensor Component	Span	Condition	1.131	Status	pass
Sensor Component	Cell B Freq.	Condition	58.9 kHz	Status	Fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.78 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	705 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	89.6 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.56 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	MOR409	Sandy Grenville	06/17/2013	Cell B Freq.	ThermoElectron	1389	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-------	--------	-----------------	------------	--------------	----------------	------	--------------------------	-------------------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.