
2014 – 1st Quarter Report
Support for Conducting Systems &
Performance Audits of CASTNET Sites and
NADP Monitoring Stations

EPA Contract No. EPW12019

Prepared for:

U. S. Environmental Protection Agency

Prepared by:



1128 NW 39th Drive
Gainesville, FL 32605

May 2016

Table of Contents

1.0 CASTNET Quarterly Report.....	1-1
1.1 Introduction.....	1-1
1.2 Project Objectives	1-1
1.3 CASTNET Sites Visited First Quarter 2014.....	1-4
1.4 Audit Results.....	1-5
2.0 NADP Quarterly Report	2-1
2.1 Introduction.....	2-1
2.2 Project Objectives	2-1
2.3 NADP Sites Visited First Quarter 2014.....	2-2
2.4 Survey Results.....	2-3

List of Appendices

Appendix A	CASNET Audit Report Forms
Appendix B	CASTNET Site Spot Report Forms
Appendix C	CASTNET Ozone Performance Evaluation Forms

List of Tables

Table 1.	Performance Audit Challenge and Acceptance Criteria	1-2
Table 2.	Site Audit Visits	1-4
Table 3.	Sites Ozone PE Visits	1-4
Table 4.	Sites Surveyed	2-2

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialist, Inc.
ASTM	American Society for Testing and Materials
CASTNET	Clean Air Status and Trends Network
DAS	data acquisition system
DC	direct current
deg	degree
DVM	digital voltmeter
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSAD	Field Site Audit Database
GPS	geographical positioning system
lpm	liters per minute
MLM	Multilayer Model
m/s	meters per second
mv	milivolt
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
QAPP	Quality Assurance Project Plan
SOP	standard operating procedure
TEI	Thermo Environmental Instruments
USNO	United States Naval Observatory
V	volts
WRR	World Radiation Reference

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program developed under mandate of the 1990 Clean Air Act Amendments. Each site in the network measures acidic gases and particles and other forms of atmospheric pollution using a continuous collection filter aggregated over a one week period. Hourly averages of surface ozone concentrations and selected meteorological variables are also measured.

Site measurements are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and effects research.

CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and model-estimated deposition velocities. Currently, the National Oceanic and Atmospheric Administration's multilayer inferential model (NOAA-MLM) described by Meyers et al. [1998] is used to derive deposition velocity estimates.

As of May 2016, the network is comprised of 94 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), the Bureau of Land Management (BLM), Environment Canada, and several independent partners. AMEC is responsible for operating the EPA and Environment Canada sponsored sites, and Air Resource Specialist, Inc. (ARS) is responsible for operating the NPS and BLM sponsored sites.

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all evaluated variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1. Only four EPA sponsored sites that are operated by AMEC continue to operate meteorological sensors. Those sites are BEL116, BVL30, CHE185,

and PAL190. Five sites sponsored by EPA and operated by the BLM in WY also operate meteorological sensors and are BAS601, NEC602, BUF603, SHE604, and FOR605.

Some or all of the additional monitored variables, NO_y, CO, and SO₂ have been added to the EPA sponsored sites BVL130, HWF187, PND165, PNF126, and BEL116. No sites that measure these variables were audited in first quarter 2014.

Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	≤ ±10.0% of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	≤ ±10.0% RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	≤ ±10.0% of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	≤ ± 0.5° C
Temperature Difference	Accuracy	Comparison to station temperature sensor	≤ ± 0.50° C
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	≤ ±5° from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	≤ ±5° mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	≤ ±0.5 mps below 5.0 mps input; ≤ ±5.0% of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	≤ ± 5.0% of designated rate
Ozone	Slope	Linear regression of multi-	0.9000 ≤ m ≤ 1.1000

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Ozone	Intercept	point test gas concentration as measured with a certified transfer standard	$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003 \text{ VDC}$

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, and certified as current.

Site systems audits are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 CASTNET Sites Visited First Quarter 2014

This report consists of the systems and performance and other audit results from the CASTNET sites visited during the first quarter (January through March) of 2014. The locations and dates of the audits are presented in Table 2.

Table 2. Site Audit Visits

Site ID	Audit Type	Sponsor Agency	Site Location	Visit dates
IRL141	Without met	EPA	Indian River Lagoon	2/13/2014
SUM156	Without met	EPA	Sumatra	2/11/2014
GAS153	Without met	EPA	Georgia Station	3/4/2014
SND152	Without met	EPA	Sand Mountain	3/5/2014
SPD111	Without met	EPA	Speedwell	3/31/2014
COW137	Without met	EPA	Coweeta	3/26/2014
ESP127	Without met	EPA	Edgar Evins	3/27/2014

In addition to the sites listed in Table 2 that were visited for complete audits, the sites listed in Table 3 were visited to conduct Through-The-Probe (TTP) ozone Performance Evaluations (PE).

Table 3. Site Ozone PE Visits

Site ID	Sponsor Agency	Site Location	Visit dates
ALC188	EPA	Alabama-Coushatta	3/12/2014
BBE401	NPS	Big Bend NP	3/20/2014
CAD150	EPA	Caddo Valley	2/25/2014
CDZ171	EPA	Cadiz	3/28/2014
CHE185	EPA	Cherokee Nation	2/26/2014
CKT136	EPA	Crockett	3/31/2014
CVL151	EPA	Coffeeville	2/28/2014
MAC426	NPS	Mammoth Cave NP	3/28/2014
MCK131	EPA	Mackville	3/30/2014
MCK231	EPA	Mackville (precision site)	3/30/2014
PAL190	EPA	Palo Duro	3/25/2014

1.4 Audit Results

The observations and results of the systems and performance audits are included in Appendix A, *Audit Report Forms* by site, arranged by audit date.

Photographs of site conditions are included within each systems report where necessary.

Copies of the spot reports that were sent immediately following the audit of each site are included as Appendix B, *Site Spot Report Forms*.

The Ozone PE results and observations are included in Appendix C, *Ozone Performance Evaluation Forms*.

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates three precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The Atmospheric Integrated Research Monitoring Network (AIRMoN) began operation in 1992 and currently measures event based precipitation events at 6 sites. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from more than 100 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry.

The NADP Program Office operates and administers the three precipitation chemistry networks (NTN, MDN and AIRMoN), two atmospheric concentration networks (AMNet and AMoN), two analytical laboratories (the Central Analytical Laboratory (CAL) located at the University of Illinois/Illinois State Water Survey and the Mercury Analytical Laboratory (HAL) located at Eurofins, and the network equipment depot (NED).

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the site instruments and operations. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 NADP Sites Visited First Quarter 2014

This report covers the results from the NADP sites surveyed during the first quarter (January through March) of 2014. The station names and dates of the surveys are presented in Table 4.

Table 4. Sites Surveyed

Side ID	Network	Survey Date	Station Name
AL03	MDN/NTN	2/24/2014	Centreville
AL10	NTN	2/24/2014	Black Belt Research & Extension Center
AR02	NTN	2/25/2014	Warren 2WSW
AR03	NTN/AMoN	2/25/2014	Caddo Valley
AR16	NTN	2/27/2014	Buffalo National River-Buffalo Point
AR27	NTN	2/26/2014	Fayetteville
LA30	NTN	2/18/2014	Southeast Research Station
MS22	MDN	2/20/2014	Oak Grove
MS30	NTN/AMoN	2/28/2014	Coffeeville
OK99	MDN	2/27/2014	Cherokee Nation
AL99	AMoN/NTN	3/5/2014	Sand Mountain Research & Extension Center
GA41	AMoN/NTN	3/4/2014	Georgia Station
MS10	NTN	3/8/2014	Clinton
MS19	NTN	3/6/2014	Newton
TX02	NTN	3/24/2014	Muleshoe National Wildlife Refuge
TX03	NTN	3/17/2014	Beeville
TX04	NTN	3/20/2014	Big Bend National Park
TX10	NTN	3/13/2014	Attwater Prairie Chicken
TX16	NTN	3/18/2014	Sonora
TX21	MDN	3/11/2014	Longview
TX21	NTN	3/11/2014	Longview
TX43	AMoN/NTN	3/25/2014	Canonceta
TX56	NTN	3/10/2014	LBJ Grassland

2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to EEMS' server where the NADP PO and the U.S. EPA POs can access them and download them as needed by login into the server site.

Given the volume of data generated, and the fact that data is distributed and/or is available through EEMS' server, no NADP site survey results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>SUM156-Eric Hebert-02/11/2014</i>						
1	2/11/2014	Computer	Dell	000323	D520	unknown
2	2/11/2014	DAS	Campbell	000335	CR3000	2114
3	2/11/2014	Elevation	Elevation	None	1	None
4	2/11/2014	Filter pack flow pump	Thomas	00235	107CA18	00688001783
5	2/11/2014	Flow Rate	Apex	000665	AXMC105LPMDPCV	54762
6	2/11/2014	Infrastructure	Infrastructure	none	none	none
7	2/11/2014	Ozone	ThermoElectron Inc	000724	49i A1NAA	1105347328
8	2/11/2014	Ozone Standard	ThermoElectron Inc	000447	49i A3NAA	CM08200023
9	2/11/2014	Sample Tower	Aluma Tower	03542	A	none
10	2/11/2014	Shelter Temperature	Campbell	none	107-L	none
11	2/11/2014	Siting Criteria	Siting Criteria	None	1	None
12	2/11/2014	Temperature	RM Young	05043	41342VO	9639
13	2/11/2014	UPS	APC	06792	RS900	unknown
14	2/11/2014	Zero air pump	Werther International	06876	C 70/4	000814286

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2114	SUM156	Eric Hebert	02/11/2014	DAS	Primary

Das Date:	<input type="text" value="2 /11/2014"/>	Audit Date	<input type="text" value="2 /11/2014"/>
Das Time:	<input type="text" value="11:25:54"/>	Audit Time	<input type="text" value="11:25:53"/>
Das Day:	<input type="text" value="42"/>	Audit Day	<input type="text" value="42"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5001	0.5000	V	V	-0.0001
7	0.7000	0.7001	0.6999	V	V	-0.0002
7	0.9000	0.9001	0.8999	V	V	-0.0002
7	1.0000	1.0002	1.0000	V	V	-0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54762		SUM156	Eric Hebert	02/11/2014	Flow Rate	000665

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		

DAS 1:	DAS 2:	Cal Factor Zero	-0.003
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.996
2.34%	2.37%	Rotometer Reading:	1.3

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.00	l/m	l/m	
primary	test pt 1	0.000	1.535	0.00	0.000	1.50	l/m	l/m	-2.31%
primary	test pt 2	0.000	1.536	0.00	0.000	1.50	l/m	l/m	-2.33%
primary	test pt 3	0.000	1.536	0.00	0.000	1.50	l/m	l/m	-2.37%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347328		SUM156	Eric Hebert	02/11/2014	Ozone	000724

Slope:	0.98734	Slope:	0.00000
Intercept	-0.66673	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.7%	4.0%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00561	Intercept	0.21973
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.27	0.04	-0.56	ppb	
primary	2	25.88	25.51	24.48	ppb	-4.04%
primary	3	52.47	51.95	50.60	ppb	-2.60%
primary	4	84.83	84.13	82.30	ppb	-2.18%
primary	5	110.60	109.76	107.80	ppb	-1.79%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.30	Status	pass
Sensor Component	Span	Condition	0.999	Status	pass
Sensor Component	Cell B Freq.	Condition	110.0 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.4 C	Status	pass
Sensor Component	Cell A Pressure	Condition	736 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	101.9 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	9639		SUM156	Eric Hebert	02/11/2014	Temperature	05043

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.07	0.13		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.10	0.13	0.000	0.3	C	0.13
primary	Temp Mid Range	20.58	20.71	0.000	20.7	C	-0.02
primary	Temp High Range	47.86	47.85	0.000	47.8	C	-0.07

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	SUM156	Eric Hebert	02/11/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.43	0.67		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	24.60	24.71	0.000	25.3	C	0.59
primary	Temp Mid Range	25.62	25.72	0.000	25.7	C	-0.03
primary	Temp Mid Range	26.77	26.87	0.000	26.2	C	-0.67

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	SUM156	Eric Hebert	02/11/2014	Moisture Present	Apex	3534	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

1 Parameter: DasComments

The meteorological tower has been removed. The temperature sensor is mounted in a naturally aspirated shield on the sample tower.

2 Parameter: SitingCriteriaCom

The site is surrounded by pine trees on land managed by the forest service. A few trees are now 17 meters tall and within 17 meters of the sample tower. Most trees are 30 meters from the sample tower.

3 Parameter: ShelterCleanNotes

The shelter is clean and well organized.. The site operator does an excellent job of organizing and maintaining the site.

4 Parameter: PollAnalyzerCom

There is water in the flow tubing outside the shelter. Trees to the north are less than 20 meters from the sample inlets.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA/USFS"/>	USGS Map	<input type="text" value="Sumatra"/>
Operating Group	<input type="text" value="USFS/private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="12-077-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="wetlands, woodland - evergreen"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="flat"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(850) 670-8376"/>	Audit Latitude	<input type="text" value="30.110226"/>
Site Address 1	<input type="text" value="Rt 65"/>	Audit Longitude	<input type="text" value="-84.99038"/>
Site Address 2	<input type="text" value="Apalachicola National Forest"/>	Audit Elevation	<input type="text" value="16"/>
County	<input type="text" value="Liberty"/>	Audit Declination	<input type="text" value="-3"/>
City, State	<input type="text" value="Bristol, FL"/>		
Zip Code	<input type="text" value="32321"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Nov 1992"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text" value="none"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text" value="none"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/> Model <input type="text" value="8810"/>	Shelter Size	<input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes	<input type="text" value="The shelter is clean and well organized.. The site operator does an excellent job of organizing and maintaining the site."/>	
Site OK <input checked="" type="checkbox"/>	Notes	<input type="text"/>	
Driving Directions	<input type="text" value="From Tallahassee take Hwy 20 west about 25 miles to Hosford. Turn left (south) on Hwy 65 at the intersection in Hosford. Continue about 22 miles on Hwy 65 past Wilma. Turn right on a dirt road and bear left continuing south parallel to Hwy 65. The site will be visible on the right."/>		

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	17 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is surrounded by pine trees on land managed by the forest service. A few trees are now 17 meters tall and within 17 meters of the sample tower. Most trees are 30 meters from the sample tower.

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean? Moderately clean
- 4 Are the aspirated motors working? N/A
- 5 Is the solar radiation sensor's lens clean and free of scratches? N/A
- 6 Is the surface wetness sensor grid clean and undamaged? N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained? Signs of wear
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342VO	9639	05043

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? Trees 17 meters

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 15 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions? Moisture in tubing only
- 7 Is the zero air supply desiccant unsaturated? 70 % saturated
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	A	none	03542
Ozone	ThermoElectron Inc	49i A1NAA	1105347328	000724
Filter pack flow pump	Thomas	107CA18	00688001783	00235
Zero air pump	Werther International	C 70/4	000814286	06876

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is water in the flow tubing outside the shelter. Trees to the north are less than 20 meters from the sample inlets.

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000323
DAS	Campbell	CR3000	2114	000335
UPS	APC	RS900	unknown	06792

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower has been removed. The temperature sensor is mounted in a naturally aspirated shield on the sample tower.

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2010	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	2/5/2014	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|--------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | Filter changed morinings |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input checked="" type="checkbox"/> | |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | No longer required |
| 4 | Are general observations being made and recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook, call-in |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | Clean gloves on and off |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>IRL141-Eric Hebert-02/13/2014</i>						
1	2/13/2014	Computer	Dell	000295	D520	HF974A02
2	2/13/2014	DAS	Campbell	000340	CR3000	2119
3	2/13/2014	Elevation	Elevation	None	1	None
4	2/13/2014	Filter pack flow pump	Thomas	00085	107CA110	71488
5	2/13/2014	Flow Rate	Apex	000598	AXMC105LPMPCV	unknown
6	2/13/2014	Infrastructure	Infrastructure	none	none	none
7	2/13/2014	Modem	Raven	06384	H4222-C	0802310499
8	2/13/2014	Ozone	ThermoElectron Inc	000729	49i A1NAA	1105347323
9	2/13/2014	Ozone Standard	ThermoElectron Inc	000446	49i A3NAA	CM08200022
10	2/13/2014	Sample Tower	Aluma Tower	000020	B	AT-61152-A-H8-F
11	2/13/2014	Shelter Temperature	Campbell	none	107-L	none
12	2/13/2014	Siting Criteria	Siting Criteria	None	1	None
13	2/13/2014	Temperature	RM Young	illegible	41342VC	14804
14	2/13/2014	UPS	APC	06790	RS900	unknown
15	2/13/2014	Zero air pump	Werther International	06898	C 70/4	000821905

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2119	IRL141	Eric Hebert	02/13/2014	DAS	Primary

Das Date:	<input type="text" value="2 /13/2014"/>	Audit Date	<input type="text" value="2 /13/2014"/>
Das Time:	<input type="text" value="12:13:58"/>	Audit Time	<input type="text" value="12:13:57"/>
Das Day:	<input type="text" value="44"/>	Audit Day	<input type="text" value="44"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0000"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0000"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.1000	V	V	0.0000
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5000	0.5000	V	V	0.0000
7	0.7000	0.7000	0.7000	V	V	0.0000
7	0.9000	0.9001	0.8999	V	V	-0.0002
7	1.0000	1.0001	1.0000	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		IRL141	Eric Hebert	02/13/2014	Flow Rate	000598

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		

DAS 1:	DAS 2:	Cal Factor Zero	-0.017
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.99
0.92%	1.06%	Rotometer Reading:	1.4

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	-0.01	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.05	l/m	l/m	
primary	test pt 1	0.000	1.516	1.51	0.000	1.50	l/m	l/m	-1.06%
primary	test pt 2	0.000	1.516	1.51	0.000	1.50	l/m	l/m	-1.03%
primary	test pt 3	0.000	1.520	1.51	0.000	1.51	l/m	l/m	-0.68%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	Filter Depth	Condition	0.000	Status	pass
Sensor Component	Filter Position	Condition	Fair	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	6.0 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347323		IRL141	Eric Hebert	02/13/2014	Ozone	000729

Slope:	0.99726	Slope:	0.00000
Intercept	0.41844	Intercept	0.00000
CorrCoff	0.99988	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.3%	3.6%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00561	Intercept	0.21973
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.24	0.02	-0.25	ppb	
primary	2	33.09	32.68	33.87	ppb	3.64%
primary	3	62.41	61.84	62.40	ppb	0.91%
primary	4	85.15	84.45	84.60	ppb	0.18%
primary	5	99.78	99.00	98.70	ppb	-0.30%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.025	Status	pass
Sensor Component	Cell B Freq.	Condition	100.4 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	732 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.4 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	109.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.78 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14804		IRL141	Eric Hebert	02/13/2014	Temperature	illegible

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.06	0.06		

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	-0.03	0.20	0.000	0.2	C	-0.05
primary	Temp Mid Range	25.19	25.29	0.000	25.2	C	-0.06
primary	Temp High Range	48.10	48.09	0.000	48.0	C	-0.06

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	IRL141	Eric Hebert	02/13/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.83	1.01		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	26.85	26.95	0.000	26.3	C	-0.64
primary	Temp Mid Range	28.08	28.17	0.000	27.2	C	-1.01
primary	Temp Mid Range	20.39	20.52	0.000	21.4	C	0.83

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator is doing an excellent job of handling and changing the filter pack.

2 Parameter: SitingCriteriaCom

The expanded roadway and parking lots were observed to have several vehicles traveling and parking including motor homes, during the audit visit. Sebastian has an estimated population of 18,000. The park operates a boat ramp with vehicle parking near the site. The site is surrounded on three sides by boat traffic using the ramp.

3 Parameter: ShelterCleanNotes

The shelter is clean and well organized.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA/SJRWMD"/>	USGS Map	<input type="text" value="Sebastian"/>
Operating Group	<input type="text" value="IRC Health Dept"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="12-061-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="coastal"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="flat"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(772) 538-2365"/>	Audit Latitude	<input type="text" value="27.849215"/>
Site Address 1	<input type="text" value="Sebastian Inlet State Park"/>	Audit Longitude	<input type="text" value="-80.455595"/>
Site Address 2	<input type="text" value="9700 South A1A"/>	Audit Elevation	<input type="text" value="2"/>
County	<input type="text" value="Indian River"/>	Audit Declination	<input type="text" value="-5.8"/>
City, State	<input type="text" value="Melbourne Beach, FL"/>		
Zip Code	<input type="text" value="32951"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	5 to 10 km	<input type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m	100 m	<input type="checkbox"/>
Small parking lot	100 m	10 - 20 m	<input type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The expanded roadway and parking lots were observed to have several vehicles traveling and parking including motor homes, during the audit visit. Sebastian has an estimated population of 18,000. The park operates a boat ramp with vehicle parking near the site. The site is surrounded on three sides by boat traffic using the ramp.

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches? N/A
- 6 Is the surface wetness sensor grid clean and undamaged? N/A
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained? Signs of wear
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342VC	14804	illegible

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID Technician Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 15 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 15 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions? Moisture in tubing only
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	AT-61152-A-H8-F	000020
Ozone	ThermoElectron Inc	49i A1NAA	1105347323	000729
Filter pack flow pump	Thomas	107CA110	71488	00085
Zero air pump	Werther International	C 70/4	000821905	06898

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	HF974A02	000295
DAS	Campbell	CR3000	2119	000340
Modem	Raven	H4222-C	0802310499	06384
UPS	APC	RS900	unknown	06790

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID Technician Site Visit Date

Site operation procedures

- | | | | |
|---|--|-------------------------------------|--------------------------|
| 1 | Is the filter pack being changed every Tuesday as scheduled? | <input checked="" type="checkbox"/> | Filter changed morinings |
| 2 | Are the Site Status Report Forms being completed and filed correctly? | <input checked="" type="checkbox"/> | |
| 3 | Are data downloads and backups being performed as scheduled? | <input type="checkbox"/> | No longer required |
| 4 | Are general observations being made and recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook |
| 5 | Are site supplies on-hand and replenished in a timely fashion? | <input checked="" type="checkbox"/> | |
| 6 | Are sample flow rates recorded? How? | <input checked="" type="checkbox"/> | SSRF, logbook, call-in |
| 7 | Are samples sent to the lab on a regular schedule in a timely fashion? | <input checked="" type="checkbox"/> | |
| 8 | Are filters protected from contamination during handling and shipping? How? | <input checked="" type="checkbox"/> | Clean gloves on and off |
| 9 | Are the site conditions reported regularly to the field operations manager or staff? | <input checked="" type="checkbox"/> | |

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> <input type="text"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is doing an excellent job of handling and changing the filter pack.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>GAS153-Eric Hebert-03/04/2014</i>						
1	3/4/2014	Computer	Dell	000295	D520	HF974A02
2	3/4/2014	DAS	Campbell	000635	CR3000	4934
3	3/4/2014	Elevation	Elevation	None	1	None
4	3/4/2014	Filter pack flow pump	Thomas	04858	107CAB18	608102A
5	3/4/2014	Flow Rate	Apex	000643	AXMC105LPMDPCV	unknown
6	3/4/2014	Infrastructure	Infrastructure	none	none	none
7	3/4/2014	Modem	Raven	06805	H4222-C	0934411884
8	3/4/2014	Ozone	ThermoElectron Inc	000705	49i A1NAA	1030244807
9	3/4/2014	Ozone Standard	ThermoElectron Inc	000697	49i A3NAA	1030244814
10	3/4/2014	Sample Tower	Aluma Tower	000138	B	none
11	3/4/2014	Shelter Temperature	Campbell	none	107-L	none
12	3/4/2014	Siting Criteria	Siting Criteria	None	1	None
13	3/4/2014	Temperature	RM Young	04319	41342	4038
14	3/4/2014	UPS	APC	missing	BP6505	NB0009260535
15	3/4/2014	Zero air pump	Werther International	06865	C 70/4	000814277

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	4934	GAS153	Eric Hebert	03/04/2014	DAS	Primary

Das Date:	<input type="text" value="3 /4 /2014"/>	Audit Date	<input type="text" value="3 /4 /2014"/>
Das Time:	<input type="text" value="10:17:00"/>	Audit Time	<input type="text" value="10:17:01"/>
Das Day:	<input type="text" value="63"/>	Audit Day	<input type="text" value="63"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0001	0.0000	V	V	0.0001
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5000	0.5001	V	V	0.0001
7	0.7000	0.7001	0.7001	V	V	0.0000
7	0.9000	0.9001	0.9002	V	V	0.0001
7	1.0000	1.0001	1.0002	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		GAS153	Eric Hebert	03/04/2014	Flow Rate	000643

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	-0.036
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0.97
2.62%	2.86%	Rotometer Reading:	1.5

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.000	-0.04	l/m	l/m	
primary	leak check	0.000	0.000	0.19	0.000	0.17	l/m	l/m	
primary	test pt 1	0.000	1.544	1.53	0.000	1.50	l/m	l/m	-2.86%
primary	test pt 2	0.000	1.544	1.53	0.000	1.51	l/m	l/m	-2.17%
primary	test pt 3	0.000	1.544	1.53	0.000	1.50	l/m	l/m	-2.83%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	3.0 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244807		GAS153	Eric Hebert	03/04/2014	Ozone	000705

Slope:	1.02217	Slope:	0.00000
Intercept	-0.44253	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.3%	1.9%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.56	0.76	0.37	ppb	
primary	2	28.45	28.45	28.63	ppb	0.63%
primary	3	50.05	49.90	50.55	ppb	1.30%
primary	4	77.27	76.93	78.12	ppb	1.55%
primary	5	110.32	109.75	111.80	ppb	1.87%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.004	Status	pass
Sensor Component	Cell B Freq.	Condition	96.4 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.73 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	28.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	727 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	94.3 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Not functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4038		GAS153	Eric Hebert	03/04/2014	Temperature	04319

DAS 1:	DAS 2:
Abs Avg Err	Abs Max Er
Abs Avg Err	Abs Max Er

Mfg	Eutechnics	Parameter	Temperature
Serial Number	01D102193	Tfer Desc.	RTD translator
Tfer ID	01231		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000
Mfg	Eutechnics	Parameter	Temperature
Serial Number	01H0060	Tfer Desc.	RTD probe
Tfer ID	01230		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000

0.12	0.25		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.05	0.11	0.000	0.0	C	-0.11
primary	Temp Mid Range	15.83	15.87	0.000	15.6	C	-0.25
primary	Temp High Range	48.56	48.55	0.000	48.5	C	-0.01

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	GAS153	Eric Hebert	03/04/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.09	0.10		

Mfg	Eutechnics	Parameter	Shelter Temperatur
Serial Number	01D102193	Tfer Desc.	RTD translator
Tfer ID	01231		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000
Mfg	Eutechnics	Parameter	Shelter Temperatur
Serial Number	01H0060	Tfer Desc.	RTD probe
Tfer ID	01230		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	18.26	18.29	0.000	18.4	C	0.08
primary	Temp Mid Range	17.07	17.10	0.000	17.0	C	-0.1

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	GAS153	Eric Hebert	03/04/2014	Moisture Present	Apex	3978	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone sample train is tested for leaks every two weeks.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Hollonville"/>
Operating Group	<input type="text" value="UGA"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="13-231-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="agriculture, woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(770) 229-8542"/>	Audit Latitude	<input type="text" value="33.181173"/>
Site Address 1	<input type="text" value="Bledsoe Farm, GA Experiment Station"/>	Audit Longitude	<input type="text" value="-84.410054"/>
Site Address 2	<input type="text" value="1913 Jackson road"/>	Audit Elevation	<input type="text" value="265"/>
County	<input type="text" value="Pike"/>	Audit Declination	<input type="text" value="-4"/>
City, State	<input type="text" value="Williamson, GA"/>		
Zip Code	<input type="text" value="30292"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From I-75 take exit 205 (Rt 16) west to Griffin. Continue west through Griffin to 19/41 south. Turn south on 19/41 and take the next exit (Rt 362) west toward Williamson. Continue 7.2 miles on 362 through Williamson. Bear right on the dirt road marked Blanton Mill Road, approximately 0.9 miles to the gated Bledsoe Farm on the right. The site is past the farm office and sheds on the north side of the farm.

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID

Technician

Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

N/A
N/A
N/A

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	4038	04319

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	000138
Ozone	ThermoElectron Inc	49i A1NAA	1030244807	000705
Filter pack flow pump	Thomas	107CAB18	608102A	04858
Zero air pump	Werther International	C 70/4	000814277	06865

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	HF974A02	000295
DAS	Campbell	CR3000	4934	000635
Modem	Raven	H4222-C	0934411884	06805
UPS	APC	BP6505	NB0009260535	missing

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters? Unknown
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>SND152-Eric Hebert-03/05/2014</i>						
1	3/5/2014	Computer	Dell	000255	D520	unknown
2	3/5/2014	DAS	Campbell	000357	CR3000	2135
3	3/5/2014	Elevation	Elevation	None	1	None
4	3/5/2014	Filter pack flow pump	Thomas	04855	107CAB18	060300020200
5	3/5/2014	Flow Rate	Apex	000555	AXMC105LPMDPCV	illegible
6	3/5/2014	Infrastructure	Infrastructure	none	none	none
7	3/5/2014	Modem	Raven	06458	V4221-V	0808337422
8	3/5/2014	Ozone	ThermoElectron Inc	000725	49i A1NAA	1106347326
9	3/5/2014	Ozone Standard	ThermoElectron Inc	000215	49i A3NAA	0622717856
10	3/5/2014	Sample Tower	Aluma Tower	000148	B	none
11	3/5/2014	Shelter Temperature	Campbell	none	107-L	none
12	3/5/2014	Siting Criteria	Siting Criteria	None	1	None
13	3/5/2014	Temperature	RM Young	06405	41342	14038
14	3/5/2014	Zero air pump	Werther International	06867	C 70/4	000814279

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2135	SND152	Eric Hebert	03/05/2014	DAS	Primary

Das Date:	<input type="text" value="3 /5 /2014"/>	Audit Date	<input type="text" value="3 /5 /2014"/>
Das Time:	<input type="text" value="10:48:32"/>	Audit Time	<input type="text" value="10:48:30"/>
Das Day:	<input type="text" value="64"/>	Audit Day	<input type="text" value="64"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0003"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0001	0.0000	V	V	0.0001
7	0.1000	0.0999	0.0996	V	V	-0.0003
7	0.3000	0.3000	0.3000	V	V	0.0000
7	0.5000	0.5000	0.5001	V	V	0.0001
7	0.7000	0.7000	0.7001	V	V	0.0001
7	0.9000	0.9001	0.9002	V	V	0.0001
7	1.0000	1.0001	1.0002	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		SND152	Eric Hebert	03/05/2014	Flow Rate	000555

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	-0.02
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1
0.26%	0.47%	Rotometer Reading:	1.45

UseDescription:	Test type:	Input l/m:	Input STP:	MfcDisp.:	OutputSignal:	Output S E:	InputUnit:	OutputSignal:	PctDifference:
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	test pt 1	0.000	1.511	1.50	0.000	1.51	l/m	l/m	-0.05%
primary	test pt 2	0.000	1.517	1.50	0.000	1.51	l/m	l/m	-0.47%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1106347326		SND152	Eric Hebert	03/05/2014	Ozone	000725

Slope:	1.00529	Slope:	0.00000
Intercept	-0.52037	Intercept	0.00000
CorrCoff	0.99982	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.3%	1.9%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.47	0.67	0.00	ppb	
primary	2	28.51	28.51	27.97	ppb	-1.89%
primary	3	49.64	49.50	49.04	ppb	-0.93%
primary	4	76.80	76.46	77.67	ppb	1.58%
primary	5	108.51	107.95	107.20	ppb	-0.69%

Sensor Component	Cell B Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	0.994	Status	pass
Sensor Component	Cell B Freq.	Condition	92.6 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	31.1 C	Status	pass
Sensor Component	Cell A Pressure	Condition	701 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	96.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14038		SND152	Eric Hebert	03/05/2014	Temperature	06405

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er

Mfg	Eutechnics	Parameter	Temperature
Serial Number	01D102193	Tfer Desc.	RTD translator
Tfer ID	01231		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000
Mfg	Eutechnics	Parameter	Temperature
Serial Number	01H0060	Tfer Desc.	RTD probe
Tfer ID	01230		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000

0.24	0.34		
------	------	--	--

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Low Range	0.05	0.11	0.000	0.3	C	0.16
primary	Temp Mid Range	24.42	24.44	0.000	24.2	C	-0.23
primary	Temp High Range	44.95	44.95	0.000	44.6	C	-0.34

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	SND152	Eric Hebert	03/05/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.38	0.70		

Mfg	Eutechnics	Parameter	Shelter Temperatur
Serial Number	01D102193	Tfer Desc.	RTD translator
Tfer ID	01231		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000
Mfg	Eutechnics	Parameter	Shelter Temperatur
Serial Number	01H0060	Tfer Desc.	RTD probe
Tfer ID	01230		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000

UseDesc.:	Test type:	InputTmpRaw	InputTmpCorr.:	OutputTmpSignal:	OutputSignalEng:	OSE Unit:	Difference:
primary	Temp Mid Range	17.29	17.32	0.000	17.3	C	-0.06
primary	Temp Mid Range	23.69	23.72	0.000	23.0	C	-0.7

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** DasComments

The sample tower is leaning approximately 10 degrees from vertical.

2 **Parameter:** SitingCriteriaCom

The site is located on an active research farm with cattle and poultry. Cattle are fed within 100 meters of the site. A Climate Reference Network site is located on the farm on the south side of Hwy 68 which is a better location for the CASTNET site.

3 **Parameter:** ShelterCleanNotes

The shelter is kept clean, neat, and very well organized.

4 **Parameter:** MetOpMaintCom

The temperature sensor signal cable is beginning to show signs of wear.

Field Systems Data Form

F-02058-1500-S1-rev001

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Crossville"/>
Operating Group	<input type="text" value="Auburn Univ./private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="01-049-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, PM10"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet,"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="Agriculture, Dairy"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="plateau, gently rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(256) 528-7175"/>	Audit Latitude	<input type="text" value="34.289001"/>
Site Address 1	<input type="text" value="Sand Mountain Research & Extension"/>	Audit Longitude	<input type="text" value="-85.970065"/>
Site Address 2	<input type="text" value="13112 Hwy 68"/>	Audit Elevation	<input type="text" value="349"/>
County	<input type="text" value="DeKalb"/>	Audit Declination	<input type="text" value="-3"/>
City, State	<input type="text" value="Crossville, AL"/>		
Zip Code	<input type="text" value="35962"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is kept clean, neat, and very well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="From I-59 take exit 205, Highway 68, west toward Crossville. The site is on the right at the Sand Mountain Research and Extension Station just at the east edge of Crossville. The combination to the gate lock is 22-32-10."/>		

Field Systems Data Form

F-02058-1500-S2-rev001

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m	100 m	<input type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located on an active research farm with cattle and poultry. Cattle are fed within 100 meters of the site. A Climate Reference Network site is located on the farm on the south side of Hwy 68 which is a better location for the CASTNET site.

Field Systems Data Form

F-02058-1500-S3-rev001

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev001

Site ID Technician Site Visit Date

- | | | | |
|---|--|-------------------------------------|---------------|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input checked="" type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input checked="" type="checkbox"/> | |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input checked="" type="checkbox"/> | N/A |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input checked="" type="checkbox"/> | N/A |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input checked="" type="checkbox"/> | Signs of wear |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input checked="" type="checkbox"/> | N/A |

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	14038	06405

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor signal cable is beginning to show signs of wear.

Field Systems Data Form

F-02058-1500-S5-rev001

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube. 1/4 teflon by 12 meters
- 4 Describe dry dep sample tube. 3/8 teflon by 12 meters
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location) At inlet only
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean? Clean and dry

Parameter	Manufacturer	Model	S/N	Client ID
Sample Tower	Aluma Tower	B	none	000148
Ozone	ThermoElectron Inc	49i A1NAA	1106347326	000725
Zero air pump	Werther International	C 70/4	000814279	06867
Filter pack flow pump	Thomas	107CAB18	060300020200	04855

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev001

Site ID Technician Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
 - 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
 - 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Met sensors only
 - 4 Are the signal connections protected from the weather and well maintained?
 - 5 Are the signal leads connected to the correct DAS channel?
 - 6 Are the DAS, sensor translators, and shelter properly grounded?
 - 7 Does the instrument shelter have a stable power source?
 - 8 Is the instrument shelter temperature controlled?
- Stable**

Grounded
- 9 Is the met tower stable and grounded?
- 10 Is the sample tower stable and grounded?
- 11 Tower comments?

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000255
DAS	Campbell	CR3000	2135	000357
Modem	Raven	V4221-V	0808337422	06458

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev001

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- Is the station log properly completed during every site visit?
- Are the Site Status Report Forms being completed and current?
- Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev001

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>COW137-Sandy Grenville-03/26/2014</i>						
1	3/26/2014	Computer	Dell	000261	D520	23FNHB1
2	3/26/2014	DAS	Campbell	000401	CR3000	2529
3	3/26/2014	Elevation	Elevation	None	1	None
4	3/26/2014	Filter pack flow pump	Thomas	02758	107CAB18	001871
5	3/26/2014	Flow Rate	Apex	000652	AXMC105LPMPCV	54771
6	3/26/2014	Infrastructure	Infrastructure	none	none	none
7	3/26/2014	Modem	Raven	06806	V4221-V	0936444095
8	3/26/2014	Ozone	ThermoElectron Inc	000726	49i A1NAA	1105347314
9	3/26/2014	Ozone Standard	ThermoElectron Inc	000441	49i A3NAA	CM08200017
10	3/26/2014	Sample Tower	Aluma Tower	03499	A	none
11	3/26/2014	Shelter Temperature	Campbell	none	107-L	none
12	3/26/2014	Siting Criteria	Siting Criteria	None	1	None
13	3/26/2014	Temperature	Climatronics	06693	100093	missing
14	3/26/2014	UPS	APC	none	650	unknown
15	3/26/2014	Zero air pump	Werther International	06878	C 70/4	000815254

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2529	COW137	Sandy Grenville	03/26/2014	DAS	Primary

Das Date:	<input type="text" value="3 /26/2014"/>	Audit Date	<input type="text" value="3 /26/2014"/>
Das Time:	<input type="text" value="15:11:56"/>	Audit Time	<input type="text" value="15:11:57"/>
Das Day:	<input type="text" value="85"/>	Audit Day	<input type="text" value="85"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2998	0.2998	V	V	0.0000
7	0.5000	0.4997	0.4996	V	V	-0.0001
7	0.7000	0.6996	0.6995	V	V	-0.0001
7	0.9000	0.8995	0.8994	V	V	-0.0001
7	1.0000	0.9994	0.9993	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54771		COW137	Sandy Grenville	03/26/2014	Flow Rate	000652

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1.01
2.04%	2.04%	Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	test pt 1	1.495	1.470	1.49	0.000	1.50	l/m	l/m	2.04%
primary	test pt 2	1.492	1.470	1.49	0.000	1.50	l/m	l/m	2.04%
primary	test pt 3	1.493	1.470	1.49	0.000	1.50	l/m	l/m	2.04%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	170 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347314		COW137	Sandy Grenville	03/26/2014	Ozone	000726

Slope:	1.01997	Slope:	0.00000
Intercept	0.24297	Intercept	0.00000
CorrCoff	0.99994	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
2.1%	2.8%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.05	0.16	0.85	ppb	
primary	2	31.27	31.24	31.86	ppb	1.98%
primary	3	50.15	50.03	50.87	ppb	1.68%
primary	4	79.55	79.30	80.80	ppb	1.89%
primary	5	101.26	100.91	103.70	ppb	2.76%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	1.020	Status	pass
Sensor Component	Cell B Freq.	Condition	99 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	29.9 C	Status	pass
Sensor Component	Cell A Pressure	Condition	683.1 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	108 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.77 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Not functioning	Status	Fail
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	missing		COW137	Sandy Grenville	03/26/2014	Temperature	06693

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.08	0.11		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.58	0.73	0.000	0.6	C	-0.11
primary	Temp Mid Range	24.89	24.97	0.000	24.9	C	-0.04
primary	Temp High Range	49.14	49.15	0.000	49.1	C	-0.09

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	COW137	Sandy Grenville	03/26/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.46	0.65		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	21.19	21.28	0.000	21.0	C	-0.27
primary	Temp Mid Range	21.44	21.53	0.000	21.1	C	-0.47
primary	Temp Mid Range	23.37	23.45	0.000	22.8	C	-0.65

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: DasComments

One leg of the meteorological tower has two holes.

2 Parameter: SitingCriteriaCom

Construction was completed on new building with a parking lot, in October 2004. The parking area is within 60 meters of the site.

3 Parameter: ShelterCleanNotes

The shelter is in fair condition with some rot near the air conditioner and in the corners. It has degraded since the previous audit. It was reported that the roof leaks. The shelter is kept very clean, neat, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA/USFS"/>	USGS Map	<input type="text" value="Prentiss"/>
Operating Group	<input type="text" value="USFS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="37-113-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="8283697919"/>	Audit Latitude	<input type="text" value="35.060527"/>
Site Address 1	<input type="text" value="Southeastern Forest Experiment Statio"/>	Audit Longitude	<input type="text" value="-83.43034"/>
Site Address 2	<input type="text" value="3160 Coweeta Lab Road"/>	Audit Elevation	<input type="text" value="683"/>
County	<input type="text" value="Macon"/>	Audit Declination	<input type="text" value="-5.1"/>
City, State	<input type="text" value=", NC"/>		
Zip Code	<input type="text" value="28763"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes	<input type="text" value="The shelter is in fair condition with some rot near the air conditioner and in the corners. It has degraded since the previous audit. It was reported that the roof leaks. The shelter is kept very clean, neat, and well organized."/>	
Site OK <input checked="" type="checkbox"/>	Notes	<input type="text"/>	
Driving Directions	<input type="text"/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m	60 m	<input type="checkbox"/>
Tree line	50 m	40 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Construction was completed on new building with a parking lot, in October 2004. The parking area is within 60 meters of the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 3 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	23FNHB1	000261
DAS	Campbell	CR3000	2529	000401
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	001871	02758
Flow Rate	Apex	AXMC105LPMDPC	54771	000652
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0936444095	06806
Ozone	ThermoElectron Inc	49i A1NAA	1105347314	000726
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200017	000441
Sample Tower	Aluma Tower	A	none	03499
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	Climatronics	100093	missing	06693
UPS	APC	650	unknown	none
Zero air pump	Werther International	C 70/4	000815254	06878

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ESP127-Sandy Grenville-03/27/2014

1	3/27/2014	Computer	Dell	000322	D520	unknown
2	3/27/2014	DAS	Campbell	illegible	CR3000	3817
3	3/27/2014	Elevation	Elevation	None	1	None
4	3/27/2014	Filter pack flow pump	Thomas	02975	107CAB18	0493002476
5	3/27/2014	Flow Rate	Apex	000642	AXMC105LPMDPCV	54755
6	3/27/2014	Infrastructure	Infrastructure	none	none	none
7	3/27/2014	Modem	Raven	06606	H4223-C	0844355622
8	3/27/2014	Ozone	ThermoElectron Inc	000622	49i A1NAA	1009241785
9	3/27/2014	Ozone Standard	ThermoElectron Inc	000687	49i A3NAA	1030244809
10	3/27/2014	Sample Tower	Aluma Tower	03550	A	none
11	3/27/2014	Shelter Temperature	Campbell	none	107-L	none
12	3/27/2014	Siting Criteria	Siting Criteria	None	1	None
13	3/27/2014	Temperature	Climatronics	06692	100093	none
14	3/27/2014	Zero air pump	Werther International	06909	C 70/4	000829161

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	3817	ESP127	Sandy Grenville	03/27/2014	DAS	Primary

Das Date:	<input type="text" value="3 /27/2014"/>	Audit Date	<input type="text" value="3 /27/2014"/>
Das Time:	<input type="text" value="15:04:01"/>	Audit Time	<input type="text" value="15:04:01"/>
Das Day:	<input type="text" value="86"/>	Audit Day	<input type="text" value="86"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2997	0.2998	V	V	0.0001
7	0.5000	0.4996	0.4997	V	V	0.0001
7	0.7000	0.6996	0.6996	V	V	0.0000
7	0.9000	0.8995	0.8994	V	V	-0.0001
7	1.0000	0.9994	0.9993	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54755		ESP127	Sandy Grenville	03/27/2014	Flow Rate	000642

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:	Cal Factor Zero	0.04
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1.02
0.45%	0.67%	Rotometer Reading:	1.4

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.03	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.06	l/m	l/m	
primary	test pt 1	1.529	1.500	1.50	0.000	1.51	l/m	l/m	0.67%
primary	test pt 2	1.534	1.510	1.50	0.000	1.51	l/m	l/m	0.00%
primary	test pt 3	1.530	1.500	1.50	0.000	1.51	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.25 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.75 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	350 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241785		ESP127	Sandy Grenville	03/27/2014	Ozone	000622

Slope:	0.99644	Slope:	0.00000
Intercept	0.52675	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
0.4%	0.8%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	0.14	0.88	ppb	
primary	2	30.68	30.65	30.90	ppb	0.82%
primary	3	50.19	50.07	50.15	ppb	0.16%
primary	4	80.03	79.77	80.20	ppb	0.54%
primary	5	102.36	102.00	102.20	ppb	0.20%

Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.1	Status	pass
Sensor Component	Span	Condition	1.007	Status	pass
Sensor Component	Cell B Freq.	Condition	102.2 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.4 C	Status	pass
Sensor Component	Cell A Pressure	Condition	704 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	88.8 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	none		ESP127	Sandy Grenville	03/27/2014	Temperature	06692

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.09	0.15		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	1.03	1.18	0.000	1.0	C	-0.15
primary	Temp Mid Range	25.30	25.38	0.000	25.3	C	-0.13
primary	Temp High Range	47.95	47.96	0.000	48.0	C	0

Sensor Component	Shield	Condition	Dirty	Status	Fail
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ESP127	Sandy Grenville	03/27/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.21	0.31		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.40	22.49	0.000	22.3	C	-0.21
primary	Temp Mid Range	21.90	21.99	0.000	22.3	C	0.31
primary	Temp Mid Range	23.40	23.48	0.000	23.6	C	0.12

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** DasComments

The site operator must use a chair to stand on when accessing the sample tower filter pack enclosure due to obstructions when lowering the sample tower.

2 **Parameter:** ShelterCleanNotes

The shelter is in poor condition with rot at the bottom of walls and floor. Some paneling is loose.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Silver Point"/>
Operating Group	<input type="text" value="private, TN DEC"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="47-041-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="rolling - complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(615) 597-6556"/>	Audit Latitude	<input type="text" value="36.03893"/>
Site Address 1	<input type="text" value="Craft Center Rd."/>	Audit Longitude	<input type="text" value="-85.73305"/>
Site Address 2	<input type="text" value="Hurricane Bridge"/>	Audit Elevation	<input type="text" value="302"/>
County	<input type="text" value="DeKalb"/>	Audit Declination	<input type="text" value="-3.5"/>
City, State	<input type="text" value="Smithville, TN"/>		
Zip Code	<input type="text" value="37166"/>	Present	
Time Zone	<input type="text" value="Central"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input type="checkbox"/>	Notes <input type="text" value="The shelter is in poor condition with rot at the bottom of walls and floor. Some paneling is loose."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
- 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
- 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
- 4 Are the signal connections protected from the weather and well maintained?
- 5 Are the signal leads connected to the correct DAS channel?
- 6 Are the DAS, sensor translators, and shelter properly grounded?
- 7 Does the instrument shelter have a stable power source?
- 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 10 Is the sample tower stable and grounded?

<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
-------------------------------------	-------------------------------------
- 11 Tower comments?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator must use a chair to stand on when accessing the sample tower filter pack enclosure due to obstructions when lowering the sample tower.

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters? Unknown
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000322
DAS	Campbell	CR3000	3817	illegible
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	0493002476	02975
Flow Rate	Apex	AXMC105LPMDPC	54755	000642
Infrastructure	Infrastructure	none	none	none
Modem	Raven	H4223-C	0844355622	06606
Ozone	ThermoElectron Inc	49i A1NAA	1009241785	000622
Ozone Standard	ThermoElectron Inc	49i A3NAA	1030244809	000687
Sample Tower	Aluma Tower	A	none	03550
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	Climatronics	100093	none	06692
Zero air pump	Werther International	C 70/4	000829161	06909

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

SPD111-Sandy Grenville-03/31/2014

1	3/31/2014	Computer	Dell	000265	D520	unknown
2	3/31/2014	DAS	Campbell	000342	CR3000	2121
3	3/31/2014	Elevation	Elevation	None	1	None
4	3/31/2014	Filter pack flow pump	Thomas	04861	107CAB18	00019997
5	3/31/2014	Flow Rate	Apex	000459	AXMC105LPMDPCV	40577
6	3/31/2014	Infrastructure	Infrastructure	none	none	none
7	3/31/2014	Modem	Raven	06463	V4221-V	0808337428
8	3/31/2014	Ozone	ThermoElectron Inc	000676	49i A1NAA	1030244794
9	3/31/2014	Ozone Standard	ThermoElectron Inc	000515	49i A3NAA	0922236891
10	3/31/2014	Sample Tower	Aluma Tower	03548	A	none
11	3/31/2014	Shelter Temperature	Campbell	none	107-L	none
12	3/31/2014	Siting Criteria	Siting Criteria	None	1	None
13	3/31/2014	Temperature	RM Young	04314	41342	4011
14	3/31/2014	UPS	APC	06096	RS800	080331133278
15	3/31/2014	Zero air pump	Werther International	06918	C 70/4	000829138

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2121	SPD111	Sandy Grenville	03/31/2014	DAS	Primary

Das Date:	<input type="text" value="3 /31/2014"/>	Audit Date:	<input type="text" value="3 /31/2014"/>
Das Time:	<input type="text" value="17:22:09"/>	Audit Time:	<input type="text" value="17:22:09"/>
Das Day:	<input type="text" value="90"/>	Audit Day:	<input type="text" value="90"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0003"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="4000392"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01321"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.0999	V	V	-0.0001
7	0.3000	0.2998	0.2997	V	V	-0.0001
7	0.5000	0.4997	0.4996	V	V	-0.0001
7	0.7000	0.6996	0.6993	V	V	-0.0003
7	0.9000	0.8994	0.8995	V	V	0.0001
7	1.0000	0.9994	0.9993	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	40577		SPD111	Sandy Grenville	03/31/2014	Flow Rate	000459

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.44%	0.66%

Cal Factor Zero	-0.04
Cal Factor Full Scale	0.97
Rotometer Reading:	1.6

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.03	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.03	l/m	l/m	
primary	test pt 1	1.524	1.500	1.53	0.000	1.50	l/m	l/m	0.00%
primary	test pt 2	1.533	1.510	1.53	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 3	1.539	1.510	1.53	0.000	1.50	l/m	l/m	-0.66%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244794	SPD111	Sandy Grenville	03/31/2014	Ozone	000676

Slope:	1.00976	Slope:	0.00000
Intercept	0.27889	Intercept	0.00000
CorrCoff	0.99982	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
1.7%	2.5%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.04	0.15	0.02	ppb	
primary	2	30.54	30.51	30.99	ppb	1.57%
primary	3	52.03	51.90	53.22	ppb	2.54%
primary	4	81.12	80.86	82.90	ppb	2.52%
primary	5	103.77	103.41	103.70	ppb	0.28%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	1.021	Status	pass
Sensor Component	Cell B Freq.	Condition	101.3 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	32.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	701.8 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	101.8 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.60 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4011		SPD111	Sandy Grenville	03/31/2014	Temperature	04314

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.14	0.26		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.71	0.86	0.000	0.6	C	-0.26
primary	Temp Mid Range	25.94	26.02	0.000	25.9	C	-0.08
primary	Temp High Range	49.41	49.42	0.000	49.4	C	-0.07

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	SPD111	Sandy Grenville	03/31/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.23	0.26		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	21.91	22.00	0.000	21.7	C	-0.26
primary	Temp Mid Range	22.02	22.11	0.000	21.9	C	-0.21
primary	Temp Mid Range	22.19	22.28	0.000	22.1	C	-0.23

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** DasComments

One leg of the meteorological tower is split.

2 **Parameter:** SitingCriteriaCom

The site is in a pasture with as many as 75 cattle. The cattle are fed within 100 meters of the site. When the site is visited the cattle approach to within 10 meters of the site.

3 **Parameter:** ShelterCleanNotes

The shelter is in good condition. The shelter is clean, neat, well organized and well maintained, however the floor is beginning to buckle.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map
 Operating Group Map Scale
 AQS # Map Date

Meteorological Type
 Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude
 Land Use QAPP Elevation Meters

Terrain QAPP Declination
 Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude
 Site Address 1 Audit Longitude

Site Address 2
 County Audit Elevation
 City, State Audit Declination

Zip Code Present
 Time Zone Fire Extinguisher

Primary Operator First Aid Kit
 Primary Op. Phone # Safety Glasses

Primary Op. E-mail Safety Hard Hat
 Backup Operator Climbing Belt

Backup Op. Phone # Security Fence
 Backup Op. E-mail Secure Shelter

Stable Entry Step
 Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m	100 m	<input type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is in a pasture with as many as 75 cattle. The cattle are fed within 100 meters of the site. When the site is visited the cattle approach to within 10 meters of the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|----------------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | one leg of met tower split | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000265
DAS	Campbell	CR3000	2121	000342
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	00019997	04861
Flow Rate	Apex	AXMC105LPMDPC	40577	000459
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0808337428	06463
Ozone	ThermoElectron Inc	49i A1NAA	1030244794	000676
Ozone Standard	ThermoElectron Inc	49i A3NAA	0922236891	000515
Sample Tower	Aluma Tower	A	none	03548
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	4011	04314
UPS	APC	RS800	080331133278	06096
Zero air pump	Werther International	C 70/4	000829138	06918

APPENDIX B

CASTNET Site Spot Report Forms

EEMS Spot Report

Data Compiled: 4/3/2014 11:37:13 PM

Site Visit Date Site Technician

03/12/2014 ALC188 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00006	unitless	P
2	Ozone Intercept	P	0	5	4	-0.63109	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99996	unitless	P
4	Ozone % difference avg	P	7	10	4	1.7	%	P
5	Ozone % difference max	P	7	10	4	4.3	%	P

EEMS Spot Report

Data Compiled: 4/11/2014 5:07:30 PM

Site Visit Date Site Technician

03/20/2014 BBE401 Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02051	unitless	P
2	Ozone Intercept	P	0	5	4	-0.35549	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.5	%	P
5	Ozone % difference max	P	7	10	4	2.0	%	P

EEMS Spot Report

Data Compiled: 4/11/2014 4:56:01 PM

SiteVisitDate	Site	Technician
02/25/2014	CAD150	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02516	unitless	P
2	Ozone Intercept	P	0	5	4	-0.20051	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	2.1	%	P
5	Ozone % difference max	P	7	10	4	2.4	%	P

EEMS Spot Report

Data Compiled: 4/5/2014 1:48:46 PM

Site Visit Date	Site	Technician
03/28/2014	CDZ171	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99413	unitless	P
2	Ozone Intercept	P	0	5	4	-0.51849	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
4	Ozone % difference avg	P	7	10	4	1.9	%	P
5	Ozone % difference max	P	7	10	4	3.5	%	P

EEMS Spot Report

Data Compiled: 4/11/2014 4:36:31 PM

Site Visit Date	Site	Technician
02/26/2014	CHE185	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02487	unitless	P
2	Ozone Intercept	P	0	5	4	-0.19321	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99982	unitless	P
4	Ozone % difference avg	P	7	10	4	2.4	%	P
5	Ozone % difference max	P	7	10	4	4.2	%	P

EEMS Spot Report

Data Compiled: 4/5/2014 2:29:24 PM

Site Visit Date	Site	Technician
03/31/2014	CKT136	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99303	unitless	P
2	Ozone Intercept	P	0	5	4	-0.34168	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.5	%	P
5	Ozone % difference max	P	7	10	4	2.2	%	P

EEMS Spot Report

Data Compiled: 5/2/2016 6:01:41 PM

Site Visit Date	Site	Technician
03/26/2014	COW137	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.08	c	P
2	Temperature max error	P	4	0.5	3	0.11	c	P
3	Ozone Slope	P	0	1.1	4	1.01997	unitless	P
4	Ozone Intercept	P	0	5	4	0.24297	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
6	Ozone % difference avg	P	7	10	4	2.1	%	P
7	Ozone % difference max	P	7	10	4	2.8	%	P
8	Flow Rate average % difference	P	10	5	3	2.04	%	P
9	Flow Rate max % difference	P	10	5	3	2.04	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	49	0.0001	V	P

Field Systems Comments

1 Parameter: DasComments

One leg of the meteorological tower has two holes.

2 Parameter: SitingCriteriaCom

Construction was completed on new building with a parking lot, in October 2004. The parking area is within 60 meters of the site.

3 Parameter: ShelterCleanNotes

The shelter is in fair condition with some rot near the air conditioner and in the corners. It has degraded since the previous audit. It was reported that the roof leaks. The shelter is kept very clean, neat, and well organized.

EEMS Spot Report

Data Compiled: 4/11/2014 4:46:24 PM

SiteVisitDate	Site	Technician
02/28/2014	CVL151	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00749	unitless	P
2	Ozone Intercept	P	0	5	4	-0.67428	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	0.7	%	P
5	Ozone % difference max	P	7	10	4	2.0	%	P

EEMS Spot Report

Data Compiled: 5/2/2016 6:59:11 PM

Site Visit Date	Site	Technician
03/27/2014	ESP127	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.09	c	P
2	Temperature max error	P	4	0.5	6	0.15	c	P
3	Ozone Slope	P	0	1.1	4	0.99644	unitless	P
4	Ozone Intercept	P	0	5	4	0.52675	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	0.4	%	P
7	Ozone % difference max	P	7	10	4	0.8	%	P
8	Flow Rate average % difference	P	10	5	4	0.44	%	P
9	Flow Rate max % difference	P	10	5	4	0.67	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	49	0.0001	V	P

Field Systems Comments

1 Parameter: DasComments

The site operator must use a chair to stand on when accessing the sample tower filter pack enclosure due to obstructions when lowering the sample tower.

2 Parameter: ShelterCleanNotes

The shelter is in poor condition with rot at the bottom of walls and floor. Some paneling is loose.

EEMS Spot Report

Data Compiled: 8/9/2014 4:05:00 PM

Site Visit Date Site Technician

03/04/2014 GAS153 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.12	c	P
2	Temperature max error	P	4	0.5	12	0.25	c	P
3	Ozone Slope	P	0	1.1	4	1.02217	unitless	P
4	Ozone Intercept	P	0	5	4	-0.44253	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.3	%	P
7	Ozone % difference max	P	7	10	4	1.9	%	P
8	Flow Rate average % difference	P	10	5	2	2.62	%	P
9	Flow Rate max % difference	P	10	5	2	2.86	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	21	0.0001	V	P
12	Shelter Temperature average error	P	5	1	6	0.09	c	P
13	Shelter Temperature max error	P	5	1	6	0.10	c	P

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 72
The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcedures
The ozone sample train is tested for leaks every two weeks.

EEMS Spot Report

Data Compiled: 8/9/2014 3:04:58 PM

Site Visit Date Site Technician

02/13/2014 IRL141 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.06	c	P
2	Temperature max error	P	4	0.5	3	0.06	c	P
3	Ozone Slope	P	0	1.1	4	0.99726	unitless	P
4	Ozone Intercept	P	0	5	4	0.41844	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99988	unitless	P
6	Ozone % difference avg	P	7	10	4	1.3	%	P
7	Ozone % difference max	P	7	10	4	3.6	%	P
8	Flow Rate average % difference	P	10	5	4	0.92	%	P
9	Flow Rate max % difference	P	10	5	4	1.06	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	35	0.0000	V	P
12	Shelter Temperature average error	P	5	1	9	0.83	c	P
13	Shelter Temperature max error	P	5	1	9	1.01	c	Fail

Field Systems Comments

1 Parameter: SiteOpsProcComm

The site operator is doing an excellent job of handling and changing the filter pack.

2 Parameter: SitingCriteriaCom

The expanded roadway and parking lots were observed to have several vehicles traveling and parking including motor homes, during the audit visit. Sebastian has an estimated population of 18,000. The park operates a boat ramp with vehicle parking near the site. The site is surrounded on three sides by boat traffic using the ramp.

3 Parameter: ShelterCleanNotes

The shelter is clean and well organized.

EEMS Spot Report

Data Compiled: 4/5/2014 1:38:22 PM

Site Visit Date	Site	Technician
03/28/2014	MAC426	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01804	unitless	P
2	Ozone Intercept	P	0	5	4	-0.31284	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.1	%	P
5	Ozone % difference max	P	7	10	4	1.7	%	P

EEMS Spot Report

Data Compiled: 4/5/2014 2:11:58 PM

Site Visit Date	Site	Technician
03/30/2014	MCK131	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00752	unitless	P
2	Ozone Intercept	P	0	5	4	0.11721	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	1.2	%	P
5	Ozone % difference max	P	7	10	4	2.6	%	P

EEMS Spot Report

Data Compiled: 4/5/2014 2:20:56 PM

Site Visit Date	Site	Technician
03/30/2014	MCK231	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01159	unitless	P
2	Ozone Intercept	P	0	5	4	-0.35351	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	0.8	%	P
5	Ozone % difference max	P	7	10	4	1.2	%	P

EEMS Spot Report

Data Compiled: 4/11/2014 5:17:48 PM

Site Visit Date	Site	Technician
03/25/2014	PAL190	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99016	unitless	P
2	Ozone Intercept	P	0	5	4	-0.24018	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.6	%	P
5	Ozone % difference max	P	7	10	4	2.3	%	P

EEMS Spot Report

Data Compiled: 8/10/2014 10:54:16 AM

Site Visit Date Site Technician

03/05/2014 SND152 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.24	c	P
2	Temperature max error	P	4	0.5	3	0.34	c	P
3	Ozone Slope	P	0	1.1	4	1.00529	unitless	P
4	Ozone Intercept	P	0	5	4	-0.52037	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99982	unitless	P
6	Ozone % difference avg	P	7	10	4	1.3	%	P
7	Ozone % difference max	P	7	10	4	1.9	%	P
8	Flow Rate average % difference	P	10	5	1	0.26	%	P
9	Flow Rate max % difference	P	10	5	1	0.47	%	P
10	DAS Time maximum error	P	0	5	1	0.03	min	P
11	DAS Voltage average error	P	7	0.003	35	0.0001	V	P
12	Shelter Temperature average error	P	5	1	6	0.38	c	P
13	Shelter Temperature max error	P	5	1	6	0.70	c	P

Field Systems Comments

1 Parameter: DasComments

The sample tower is leaning approximately 10 degrees from vertical.

2 Parameter: SitingCriteriaCom

The site is located on an active research farm with cattle and poultry. Cattle are fed within 100 meters of the site. A Climate Reference Network site is located on the farm on the south side of Hwy 68 which is a better location for the CASTNET site.

3 Parameter: ShelterCleanNotes

The shelter is kept clean, neat, and very well organized.

4 Parameter: MetOpMaintCom

The temperature sensor signal cable is beginning to show signs of wear.

EEMS Spot Report

Data Compiled: 5/2/2016 7:30:07 PM

Site Visit Date	Site	Technician
03/31/2014	SPD111	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.14	c	P
2	Temperature max error	P	4	0.5	12	0.26	c	P
3	Ozone Slope	P	0	1.1	4	1.00976	unitless	P
4	Ozone Intercept	P	0	5	4	0.27889	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99982	unitless	P
6	Ozone % difference avg	P	7	10	4	1.7	%	P
7	Ozone % difference max	P	7	10	4	2.5	%	P
8	Flow Rate average % difference	P	10	5	8	0.44	%	P
9	Flow Rate max % difference	P	10	5	8	0.66	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	49	0.0001	V	P

Field Systems Comments

1 Parameter: DasComments

One leg of the meteorological tower is split.

2 Parameter: SitingCriteriaCom

The site is in a pasture with as many as 75 cattle. The cattle are fed within 100 meters of the site. When the site is visited the cattle approach to within 10 meters of the site.

3 Parameter: ShelterCleanNotes

The shelter is in good condition. The shelter is clean, neat, well organized and well maintained, however the floor is beginning to buckle.

EEMS Spot Report

Data Compiled: 8/9/2014 2:03:24 PM

Site Visit Date Site Technician

02/11/2014 SUM156 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.07	c	P
2	Temperature max error	P	4	0.5	6	0.13	c	P
3	Ozone Slope	P	0	1.1	4	0.98734	unitless	P
4	Ozone Intercept	P	0	5	4	-0.66673	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	2.6	%	P
7	Ozone % difference max	P	7	10	4	4.0	%	P
8	Flow Rate average % difference	P	10	5	3	2.34	%	P
9	Flow Rate max % difference	P	10	5	3	2.37	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	35	0.0001	V	P
12	Shelter Temperature average error	P	5	1	9	0.43	c	P
13	Shelter Temperature max error	P	5	1	9	0.67	c	P

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 72
The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1 **Parameter:** DasComments
The meteorological tower has been removed. The temperature sensor is mounted in a naturally aspirated shield on the sample tower.
- 2 **Parameter:** SitingCriteriaCom
The site is surrounded by pine trees on land managed by the forest service. A few trees are now 17 meters tall and within 17 meters of the sample tower. Most trees are 30 meters from the sample tower.
- 3 **Parameter:** ShelterCleanNotes
The shelter is clean and well organized.. The site operator does an excellent job of organizing and maintaining the site.
- 4 **Parameter:** PollAnalyzerCom
There is water in the flow tubing outside the shelter. Trees to the north are less than 20 meters from the sample inlets.

APPENDIX C

CASTNET Ozone Performance Evaluation Forms

EEMS Spot Report

Data Compiled: 4/11/2014 4:56:01 PM

SiteVisitDate	Site	Technician
02/25/2014	CAD150	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02516	unitless	P
2	Ozone Intercept	P	0	5	4	-0.20051	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	2.1	%	P
5	Ozone % difference max	P	7	10	4	2.4	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241792		CAD150	Sandy Grenville	02/25/2014	Ozone	000624

Slope:	1.02516	Slope:	0.00000
Intercept	-0.20051	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.1%	2.4%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.53	0.64	0.46	ppb	
primary	2	31.55	31.52	32.08	ppb	1.78%
primary	3	50.86	50.74	51.91	ppb	2.31%
primary	4	80.88	80.62	82.30	ppb	2.08%
primary	5	100.06	99.71	102.10	ppb	2.40%

Sensor Component	Cell B Noise	Condition	1.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	1.037	Status	pass
Sensor Component	Cell B Freq.	Condition	100.3 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	31.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	737.5 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	103.6 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CAD150-Sandy Grenville-02/25/2014

1	2/25/2014	DAS	Campbell	000421	CR3000	2530
2	2/25/2014	Ozone	ThermoElectron Inc	000624	49i A1NAA	1009241792
3	2/25/2014	Ozone Standard	ThermoElectron Inc	000495	49i A3NAA	0622717849
4	2/25/2014	Zero air pump	Werther International	06885	C 70/4	000814270

EEMS Spot Report

Data Compiled: 4/11/2014 4:36:31 PM

Site Visit Date	Site	Technician
02/26/2014	CHE185	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02487	unitless	P
2	Ozone Intercept	P	0	5	4	-0.19321	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99982	unitless	P
4	Ozone % difference avg	P	7	10	4	2.4	%	P
5	Ozone % difference max	P	7	10	4	4.2	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Monitor Labs, Inc.	191		CHE185	Sandy Grenville	02/26/2014	Ozone	54901

Slope:	1.02487	Slope:	0.00000
Intercept	-0.19321	Intercept	0.00000
CorrCoff	0.99982	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.4%	4.2%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.05	0.16	0.01	ppb	
primary	2	30.04	30.01	29.67	ppb	-1.13%
primary	3	50.78	50.66	52.78	ppb	4.18%
primary	4	82.49	82.22	84.45	ppb	2.71%
primary	5	100.14	99.79	101.50	ppb	1.71%

Sensor Component	Cell B Noise	Condition	0.22 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.06	Status	pass
Sensor Component	Span	Condition	1.079	Status	pass
Sensor Component	Cell B Freq.	Condition		Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.5 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	37.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	712 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.22 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition		Status	pass
Sensor Component	Cell A Flow	Condition	0.5 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>CHE185-Sandy Grenville-02/26/2014</i>						
1	2/26/2014	DAS	Environmental Sys Corp	73955	8832	A0656-b
2	2/26/2014	Ozone	Monitor Labs, Inc.	54901	ML9811	191
3	2/26/2014	UPS	Tripplite	none	LRC2400	9743AYOLC615000
4	2/26/2014	Zero air pump	Ecotech	none	8301LC	01-0658

EEMS Spot Report

Data Compiled: 4/11/2014 4:46:24 PM

SiteVisitDate	Site	Technician
02/28/2014	CVL151	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00749	unitless	P
2	Ozone Intercept	P	0	5	4	-0.67428	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	0.7	%	P
5	Ozone % difference max	P	7	10	4	2.0	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244797		CVL151	Sandy Grenville	02/28/2014	Ozone	000698

Slope:	1.00749	Slope:	0.00000
Intercept	-0.67428	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
0.7%	2.0%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	0.14	-0.44	ppb	
primary	2	31.60	31.57	30.95	ppb	-1.96%
primary	3	49.97	49.85	49.56	ppb	-0.58%
primary	4	81.09	80.83	80.90	ppb	0.09%
primary	5	99.74	99.39	99.40	ppb	0.01%

Sensor Component	Cell B Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.30	Status	pass
Sensor Component	Span	Condition	1.02	Status	pass
Sensor Component	Cell B Freq.	Condition	100.8 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.5 C	Status	pass
Sensor Component	Cell A Pressure	Condition	726 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	95.9 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CVL151-Sandy Grenville-02/28/2014

1	2/28/2014	DAS	Campbell	000410	CR3000	2508
2	2/28/2014	Ozone	ThermoElectron Inc	000698	49i A1NAA	1030244797
3	2/28/2014	Ozone Standard	ThermoElectron Inc	000464	49i A3NAA	0622717858
4	2/28/2014	Zero air pump	Werther International	06884	PC70/4	000815263

EEMS Spot Report

Data Compiled: 4/3/2014 11:37:13 PM

Site Visit Date Site Technician

03/12/2014 ALC188 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00006	unitless	P
2	Ozone Intercept	P	0	5	4	-0.63109	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99996	unitless	P
4	Ozone % difference avg	P	7	10	4	1.7	%	P
5	Ozone % difference max	P	7	10	4	4.3	%	P

Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244802	ALC188	Eric Hebert	03/12/2014	Ozone	000689

Slope:	1.00006	Slope:	0.00000
Intercept	-0.63109	Intercept	0.00000
CorrCoff	0.99996	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
1.7%	4.3%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.58	0.78	0.51	ppb	
primary	2	26.99	27.00	25.85	ppb	-4.26%
primary	3	47.52	47.39	46.69	ppb	-1.48%
primary	4	75.22	74.90	74.51	ppb	-0.52%
primary	5	103.96	103.43	102.80	ppb	-0.61%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.015	Status	pass
Sensor Component	Cell B Freq.	Condition	93.0 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	28.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	731 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	94.5 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ALC188-Eric Hebert-03/12/2014

1	3/12/2014	DAS	Campbell	000422	CR3000	2523
2	3/12/2014	Ozone	ThermoElectron Inc	000689	49i A1NAA	1030244802
3	3/12/2014	Ozone Standard	ThermoElectron Inc	000363	49i A3NAA	0726124691
4	3/12/2014	Zero air pump	Werther International	06940	C 70/4	000821897

EEMS Spot Report

Data Compiled: 4/11/2014 5:07:30 PM

SiteVisitDate	Site	Technician
03/20/2014	BBE401	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.02051	unitless	P
2	Ozone Intercept	P	0	5	4	-0.35549	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.5	%	P
5	Ozone % difference max	P	7	10	4	2.0	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-58468-318		BBE401	Alison Ray	03/20/2014	Ozone	90517

Slope:	1.02051	Slope:	0.00000
Intercept	-0.35549	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
1.5%	2.0%

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.45	0.65	0.21	ppb	
primary	2	33.13	33.10	33.58	ppb	1.45%
primary	3	45.07	44.96	45.45	ppb	1.09%
primary	4	82.65	82.27	83.88	ppb	1.96%
primary	5	94.83	94.37	95.69	ppb	1.40%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.018	Status	pass
Sensor Component	Cell B Freq.	Condition	87 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	38.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	659.6 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	91 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

BBE401-Alison Ray-03/20/2014

1	3/20/2014	DAS	Environmental Sys Corp	90665	8816	2689
2	3/20/2014	Ozone	ThermoElectron Inc	90517	49C	49C-58468-318
3	3/20/2014	Ozone Standard	ThermoElectron Inc	90832	49C	520012326
4	3/20/2014	Zero air pump	Werther International	none	C 70/4	606499

EEMS Spot Report

Data Compiled: 4/11/2014 5:17:48 PM

SiteVisitDate	Site	Technician
03/25/2014	PAL190	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99016	unitless	P
2	Ozone Intercept	P	0	5	4	-0.24018	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.6	%	P
5	Ozone % difference max	P	7	10	4	2.3	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347322		PAL190	Alison Ray	03/25/2014	Ozone	000733

Slope:	0.99016	Slope:	0.00000
Intercept	-0.24018	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.6%	2.3%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	0.23	0.13	ppb	
primary	2	33.45	33.42	32.64	ppb	-2.33%
primary	3	51.67	51.51	50.72	ppb	-1.53%
primary	4	79.81	79.45	78.52	ppb	-1.17%
primary	5	98.06	97.58	96.40	ppb	-1.21%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.1	Status	pass
Sensor Component	Span	Condition	1.005	Status	pass
Sensor Component	Cell B Freq.	Condition	97.6 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	27.4 C	Status	pass
Sensor Component	Cell A Pressure	Condition	657.6 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	90.5 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

PAL190-Alison Ray-03/25/2014

1	3/25/2014	DAS	Campbell	000347	CR3000	2126
2	3/25/2014	Ozone	ThermoElectron Inc	000733	49i A1NAA	1105347322
3	3/25/2014	Ozone Standard	ThermoElectron Inc	000214	49i A3NAA	0622717855
4	3/25/2014	Zero air pump	Werther International	06929	C 70/4	000829173

EEMS Spot Report

Data Compiled: 4/5/2014 1:48:46 PM

Site Visit Date	Site	Technician
03/28/2014	CDZ171	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99413	unitless	P
2	Ozone Intercept	P	0	5	4	-0.51849	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
4	Ozone % difference avg	P	7	10	4	1.9	%	P
5	Ozone % difference max	P	7	10	4	3.5	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347320		CDZ171	Sandy Grenville	03/28/2014	Ozone	000727

Slope:	0.99413	Slope:	0.00000
Intercept	-0.51849	Intercept	0.00000
CorrCoff	0.99995	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.9%	3.5%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.31	0.42	0.26	ppb	
primary	2	32.20	32.16	31.03	ppb	-3.51%
primary	3	50.81	50.69	49.57	ppb	-2.21%
primary	4	80.50	80.24	79.64	ppb	-0.75%
primary	5	100.28	99.93	98.80	ppb	-1.13%

Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.007	Status	pass
Sensor Component	Cell B Freq.	Condition	89.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	714.3 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	91.8 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CDZ171-Sandy Grenville-03/28/2014

1	3/28/2014	DAS	Campbell	000352	CR3000	2130
2	3/28/2014	Ozone	ThermoElectron Inc	000727	49i A1NAA	1105347320
3	3/28/2014	Ozone Standard	ThermoElectron Inc	000544	49i A3NAA	0929938242
4	3/28/2014	UPS	APC	06793	RS900	unknown
5	3/28/2014	Zero air pump	Werther International	06899	PC70/4	000821902

EEMS Spot Report

Data Compiled: 4/5/2014 1:38:22 PM

Site Visit Date	Site	Technician
03/28/2014	MAC426	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01804	unitless	P
2	Ozone Intercept	P	0	5	4	-0.31284	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	1.1	%	P
5	Ozone % difference max	P	7	10	4	1.7	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	CM08460049		MAC426	Sandy Grenville	03/28/2014	Ozone	none

Slope:	1.01804	Slope:	0.00000
Intercept	-0.31284	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
1.1%	1.7%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	0.14	-0.03	ppb	
primary	2	29.81	29.78	30.11	ppb	1.11%
primary	3	50.79	50.67	50.82	ppb	0.30%
primary	4	80.34	80.08	81.25	ppb	1.46%
primary	5	99.87	99.52	101.17	ppb	1.66%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.2	Status	pass
Sensor Component	Span	Condition	1.016	Status	pass
Sensor Component	Cell B Freq.	Condition	106.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	729.4 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	88.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

MAC426-Sandy Grenville-03/28/2014

1	3/28/2014	DAS	Environmental Sys Corp	3027	8832	A3027
2	3/28/2014	Ozone	ThermoElectron Inc	none	49i A3NAA	CM08460049
3	3/28/2014	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1030745084
4	3/28/2014	UPS	APC	none	XS1500	unkown
5	3/28/2014	Zero air pump	Werther International	none	PC70/4	000665778

EEMS Spot Report

Data Compiled: 4/5/2014 2:11:58 PM

Site Visit Date	Site	Technician
03/30/2014	MCK131	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00752	unitless	P
2	Ozone Intercept	P	0	5	4	0.11721	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	1.2	%	P
5	Ozone % difference max	P	7	10	4	2.6	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347327		MCK131	Sandy Grenville	03/30/2014	Ozone	000723

Slope:	1.00752	Slope:	0.00000
Intercept	0.11721	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
1.2%	2.6%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.03	0.14	0.14	ppb	
primary	2	31.04	31.01	31.81	ppb	2.58%
primary	3	51.03	50.91	51.00	ppb	0.18%
primary	4	80.79	80.53	81.30	ppb	0.96%
primary	5	100.25	99.90	100.80	ppb	0.90%

Sensor Component	Cell B Noise	Condition	1.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.3	Status	pass
Sensor Component	Span	Condition	1.031	Status	pass
Sensor Component	Cell B Freq.	Condition	110.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.73 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	31.3 C	Status	pass
Sensor Component	Cell A Pressure	Condition	726.2 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.4 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	102.8 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

MCK131-Sandy Grenville-03/30/2014

1	3/30/2014	DAS	Campbell	000429	CR3000	2535
2	3/30/2014	Ozone	ThermoElectron Inc	000723	49i A1NAA	1105347327
3	3/30/2014	Ozone Standard	ThermoElectron Inc	000366	49i A3NAA	0726124895
4	3/30/2014	Zero air pump	Werther International	06912	PC70/4	000829177

EEMS Spot Report

Data Compiled: 4/5/2014 2:20:56 PM

Site Visit Date	Site	Technician
03/30/2014	MCK231	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01159	unitless	P
2	Ozone Intercept	P	0	5	4	-0.35351	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	0.8	%	P
5	Ozone % difference max	P	7	10	4	1.2	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347318		MCK231	Sandy Grenville	03/30/2014	Ozone	000739

Slope:	1.01159	Slope:	0.00000
Intercept	-0.35351	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
0.8%	1.2%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.13	0.24	0.10	ppb	
primary	2	31.04	31.01	30.65	ppb	-1.16%
primary	3	51.54	51.41	51.64	ppb	0.45%
primary	4	81.03	80.77	81.60	ppb	1.03%
primary	5	100.82	100.47	101.20	ppb	0.73%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	1.015	Status	pass
Sensor Component	Cell B Freq.	Condition	89.2 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.74 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.2 C	Status	pass
Sensor Component	Cell A Pressure	Condition	705.8 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	93.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

MCK231-Sandy Grenville-03/30/2014

1	3/30/2014	DAS	Campbell	000359	CR3000	2137
2	3/30/2014	Ozone	ThermoElectron Inc	000739	49i A1NAA	1105347318
3	3/30/2014	Ozone Standard	ThermoElectron Inc	000369	49i A3NAA	0726124890
4	3/30/2014	Zero air pump	Werther International	06924	C 70/4	000836205

EEMS Spot Report

Data Compiled: 4/5/2014 2:29:24 PM

Site Visit Date	Site	Technician
03/31/2014	CKT136	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99303	unitless	P
2	Ozone Intercept	P	0	5	4	-0.34168	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.5	%	P
5	Ozone % difference max	P	7	10	4	2.2	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241780		CKT136	Sandy Grenville	03/31/2014	Ozone	000617

Slope:	0.99303	Slope:	0.00000
Intercept	-0.34168	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg % Dif
A Max % Di	A Max % Di
1.5%	2.2%

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.02	0.13	-0.05	ppb	
primary	2	31.31	31.28	30.58	ppb	-2.24%
primary	3	52.54	52.41	51.51	ppb	-1.72%
primary	4	82.03	81.77	81.00	ppb	-0.94%
primary	5	100.36	100.01	99.00	ppb	-1.01%

Sensor Component	Cell B Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	1.008	Status	pass
Sensor Component	Cell B Freq.	Condition	113.7 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.64 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	711.5 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	98.2 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CKT136-Sandy Grenville-03/31/2014

1	3/31/2014	DAS	Campbell	000354	CR3000	2132
2	3/31/2014	Ozone	ThermoElectron Inc	000617	49i A1NAA	1009241780
3	3/31/2014	Ozone Standard	ThermoElectron Inc	000433	49i A3NAA	CM08200009
4	3/31/2014	Zero air pump	Werther International	06902	PC70/4	000829157