
2014 – 3rd Quarter Report
Support for Conducting Systems &
Performance Audits of CASTNET Sites and
NADP Monitoring Stations

EPA Contract No. EPW12019

Prepared for:

U. S. Environmental Protection Agency

Prepared by:



1128 NW 39th Drive
Gainesville, FL 32605

May 2016

Table of Contents

1.0 CASTNET Quarterly Report.....	1-1
1.1 Introduction.....	1-1
1.2 Project Objectives	1-1
1.3 CASTNET Sites Visited Third Quarter 2014	1-4
1.4 Audit Results.....	1-6
2.0 NADP Quarterly Report	2-1
2.1 Introduction.....	2-1
2.2 Project Objectives	2-1
2.3 Sites Visited Third Quarter 2014	2-2
2.4 Survey Results.....	2-3

List of Appendices

Appendix A	CASNTET Audit Report Forms
Appendix B	CASTNET Site Spot Report Forms
Appendix C	CASTNET Ozone Performance Evaluation Forms

List of Tables

Table 1.	Performance Audit Challenge and Acceptance Criteria	1-2
Table 2.	Site Audit Visits	1-4
Table 3.	Site TTP Pollutant Monitor PE Audit Visits.....	1-5
Table 4.	Sites Surveyed – Third Quarter 2014	2-2

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialist, Inc.
ASTM	American Society for Testing and Materials
CASTNET	Clean Air Status and Trends Network
DAS	data acquisition system
DC	direct current
deg	degree
DVM	digital voltmeter
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSAD	Field Site Audit Database
GPS	geographical positioning system
lpm	liters per minute
MLM	Multilayer Model
m/s	meters per second
mv	milivolt
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
QAPP	Quality Assurance Project Plan
SOP	standard operating procedure
TEI	Thermo Environmental Instruments
USNO	United States Naval Observatory
V	volts
WRR	World Radiation Reference

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program developed under mandate of the 1990 Clean Air Act Amendments. Each site in the network measures acidic gases and particles and other forms of atmospheric pollution using a continuous collection filter aggregated over a one week period. Hourly averages of surface ozone concentrations and selected meteorological variables are also measured.

Site measurements are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and effects research.

CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and model-estimated deposition velocities. Currently, the National Oceanic and Atmospheric Administration's multilayer inferential model (NOAA-MLM) described by Meyers et al. [1998] is used to derive deposition velocity estimates.

As of May 2016, the network is comprised of 94 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Environment Canada, Bureau of Land Management (BLM) and several independent partners. AMEC is responsible for operating the EPA and Environment Canada sponsored sites, and Air Resource Specialist, Inc. (ARS) is responsible for operating the NPS and BLM sponsored sites.

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all evaluated variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1. Only four EPA sponsored sites that are operated by AMEC continue to operate meteorological sensors. Those sites are BEL116, BVL30, CHE185,

and PAL190. Five new sites sponsored by EPA and operated by the BLM in WY also operate meteorological sensors and are BAS601, NEC602, BUF603, FOR604, and SHE604.

Some or all of the additional monitored variables, NO_y, CO, and SO₂ have been added to the EPA sponsored sites BVL130, HWF187, PND165, PNF126, ROM206, and BEL116. Those variables were audited at the ROM206, PND165, HWF187, and BVL130 stations during third quarter 2014. All of the SO₂ and NO_y results for those audits were found to be within acceptance criteria. The preliminary reports of those results were delivered following the audits and are not included in this report.

Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	≤ ±10.0% of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	≤ ±10.0% RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	≤ ±10.0% of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	≤ ± 0.5° C
Temperature Difference	Accuracy	Comparison to station temperature sensor	≤ ± 0.50° C
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	≤ ±5° from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	≤ ±5° mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	≤ ±0.5 mps below 5.0 mps input; ≤ ±5.0% of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	≤ ± 5.0% of designated rate

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003 \text{ VDC}$

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, and certified as current.

Site systems audits are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.
- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 CASTNET Sites Visited Third Quarter 2014

This report consists of the systems and performance and other audit results from the CASTNET sites visited during the third quarter (July through September) of 2014. The locations and dates of the audits are presented in Table 2.

Table 2. Site Audit Visits

<u>Side ID</u>	<u>Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
ANA115	Without met	EPA	8/19/2014	Ann Arbor
ARE128	Without met	EPA	9/25/2014	Arendtsville
CAT175	Without met	EPA	9/26/2014	Claryville
CTH110	Without met	EPA	9/5/2014	Connecticut Hill
DIN431	Without met	NPS	7/15/2014	Dinosaur NM
EGB181	Without met	EPA	8/28/2014	Egbert, Ontario
FOR605	With met	EPA / BLM	7/21/2014	Fortification Creek
HOX148	Without met	EPA	8/25/2014	Hoxeyville
HWF187	Without met	EPA	9/30/2014	Huntington Wildlife Forest
KEF112	Without met	EPA	9/23/2014	Kane Experimental Forest
MKG113	Without met	EPA	9/20/2014	M.K. Goddard State Park
PSU106	Without met	EPA	9/23/2014	Penn State University
RED004	Flow only	EPA	9/4/2014	Red Lake Nation
SAL133	Without met	EPA	7/19/2014	Salamonie Reservoir
UVL124	Without met	EPA	8/26/2014	Unionville

In addition to the sites listed in Table 2 that were visited for complete audits, the sites listed in Table 3 were visited to conduct Through-The-Probe (TTP) pollutant monitor Performance Evaluations (PE).

Table 3. Site TTP Pollutant Monitor PE Audit Visits

<u>Side ID</u>	<u>Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
ALH157	Ozone PE	EPA	7/22/2014	Alhambra
ANA115	Ozone PE	EPA	9/24/2014	Ann Arbor
BAS601	Ozone PE	EPA / BLM	7/17/2014	Basin
BVL130	Ozone PE	EPA	9/20/2014	Bondville
BVL130	NO _y CO SO ₂	EPA	9/20/2014	Bondville
CNT169	Ozone PE	EPA	8/23/2014	Centennial
GLR468	Ozone PE	NPS	8/23/2014	Glacier NP
GTH161	Ozone PE	EPA	8/21/2014	Gothic
HWF187	NO _y	EPA	9/30/2014	Huntington Wildlife Forest
LRL117	Ozone PE	EPA	9/19/2014	Laurel Hill
NEC602	Ozone PE	EPA / BLM	7/22/2014	New Castle
PND165	Ozone PE	EPA / BLM	7/16/2014	Pinedale
PND165	NO _y	EPA / BLM	7/16/2014	Pinedale
PRK134	Ozone PE	EPA	9/10/2014	Perkinstown
ROM206	Ozone PE	EPA	8/16/2014	Rocky Mountain NP
ROM206	NO _y	EPA	8/16/2014	Rocky Mountain NP
ROM406	Ozone PE	NPS	8/16/2014	Rocky Mountain NP
STK138	Ozone PE	EPA	7/21/2014	Stockton
THR422	Ozone PE	NPS	8/25/2014	Theodore Roosevelt NP
VIN140	Ozone PE	EPA	7/23/2014	Vincennes
VOY413	Ozone PE	NPS	9/8/2014	Voyageurs NP
WNC429	Ozone PE	NPS	7/23/2014	Wind Cave NP
YEL408	Ozone PE	NPS	8/24/2014	Yellowstone NP

1.4 Audit Results

The observations and results of the systems and performance audits are included in Appendix A, *Audit Report Forms* by site, arranged by audit date.

Photographs of site conditions are included within each systems report where necessary.

Copies of the spot reports that were sent immediately following the audit of each site are included as Appendix B, *Site Spot Report Forms*.

The Ozone PE results and observations are included in Appendix C, *Ozone Performance Evaluation Forms*.

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates three precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 200 sites. The Atmospheric Integrated Research Monitoring Network (AIRMoN) began operation in 1992 and currently measures event based precipitation events at 6 sites. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from more than 100 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry.

The NADP Program Office operates and administers the three precipitation chemistry networks (NTN, MDN and AIRMoN), two atmospheric concentration networks (AMNet and AMoN), two analytical laboratories (the Central Analytical Laboratory (CAL) located at the University of Illinois/Illinois State Water Survey and the Mercury Analytical Laboratory (HAL) located at Frontier Global Sciences), and the network equipment depot (NED).

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites along with its operations. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 Sites Visited Third Quarter 2014

This report covers the results from the NADP sites surveyed during the third quarter (July through September) of 2014. The station names and dates of the audits are presented in Table 4.

Table 4. Sites Surveyed – Third Quarter 2014

<u>Side ID</u>	<u>Network</u>	<u>Visit Date</u>	<u>Station Name</u>
IA08	NTN	7/21/2014	Big Springs Fish Hatchery
IL37	AMoN	7/21/2014	Stockton
IL46	AMoN/NTN	7/22/2014	Alhambra
IN20	NTN	7/19/2014	Roush Lake
WY99	NTN	7/22/2014	Newcastle
CO10	NTN	8/21/2014	Gothic
CO15	NTN	8/25/2014	Sand Spring
CO19	NTN	8/27/2014	Rocky Mountain NP-Beaver Meadows
CO97	MDN/NTN	8/26/2014	Buffalo Pass - Summit Lake
MT97	NTN	8/22/2014	Lost Trail Pass
ON07	MDN	8/28/2014	Egbert
SD18	MDN	8/26/2014	Eagle Butte
SD99	NTN	8/27/2014	Huron Well Field
CAN5	NTN	9/3/2014	Frelighsburg
ND08	NTN	9/3/2014	Icelandic State Park
ND11	NTN	9/2/2014	Woodworth
NY01	NTN	9/21/2014	Alfred
NY08	NTN	9/5/2014	Aurora Research Farm
NY20	MDN/NTN/AMoN	9/30/2014	Huntington Wildlife
NY67	AIRMoN	9/5/2014	Ithaca
NY68	MDN/NTN	9/26/2014	Biscuit Brook
NY98	NTN/AMoN	9/29/2014	Whiteface Mountain
PA15	AIRMoN/NTN	9/24/2014	Penn State

<u>Side ID</u>	<u>Network</u>	<u>Visit Date</u>	<u>Station Name</u>
PA18	NTN	9/22/2014	Young Woman's Creek
PA60	NTN	9/24/2014	Valley Forge
PA90	NTN	9/22/2014	Hills Creek State Park
PQ17	MDN	9/1/2014	Chapais
WI35	NTN/AMoN	9/10/2014	Perkinstown
WI37	NTN	9/9/2014	Spooner

2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to EEMS' server where the NADP PO and the U.S. EPA POs can access them and download them as needed by login into the server site.

Given the volume of data generated, and the fact that data is distributed and/or is available through EEMS' server, no survey results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

DIN431-Eric Hebert-07/15/2014

1	7/15/2014	DAS	Environmental Sys Corp	90652	8816	2565
2	7/15/2014	elevation	Elevation	none	none	none
3	7/15/2014	flow rate	Mykrolis	none	FC280SAV-4S	AW902153
4	7/15/2014	Infrastructure	Infrastructure	none	none	none
5	7/15/2014	MFC power supply	Tylan	none	RO-32	FP9706002
6	7/15/2014	Ozone	ThermoElectron Inc	none	49i A3NAA	1211052490
7	7/15/2014	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	1130450194
8	7/15/2014	Shelter Temperature	ARS	none	unknown	none
9	7/15/2014	siting criteria	Siting Criteria	none	none	None
10	7/15/2014	Temperature	RM Young	none	41342	4273

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2565	DIN431	Eric Hebert	07/15/2014	DAS	Primary

Das Date:	<input type="text" value="7/15/2014"/>	Audit Date:	<input type="text" value="7/15/2014"/>
Das Time:	<input type="text" value="13:28:15"/>	Audit Time:	<input type="text" value="13:27:00"/>
Das Day:	<input type="text" value="196"/>	Audit Day:	<input type="text" value="196"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0002"/>	Max Diff:	<input type="text" value="0.0005"/>
		Avg Diff:	<input type="text" value="0.0002"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
2	0.0000	0.0000	0.0000	V	V	0.0000
2	0.1000	0.1000	0.1000	V	V	0.0000
2	0.3000	0.2999	0.2999	V	V	0.0000
2	0.5000	0.5004	0.5006	V	V	0.0002
2	0.7000	0.7002	0.7007	V	V	0.0005
2	0.9000	0.9003	0.9008	V	V	0.0005
2	1.0000	1.0004	1.0009	V	V	0.0005
9	0.0000	-0.0002	-0.0002	V	V	0.0000
9	0.1000	0.0997	0.1000	V	V	0.0003
9	0.3000	0.3001	0.3004	V	V	0.0003
9	0.5000	0.5000	0.5002	V	V	0.0002
9	0.7000	0.7003	0.7004	V	V	0.0001
9	0.9000	0.9003	0.9005	V	V	0.0002
9	1.0000	0.9993	0.9992	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Mykrolis	AW902153		DIN431	Eric Hebert	07/15/2014	flow rate	none

Mfg	Tylan
SN/Owner ID	FP9706002 none
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.24%	0.28%

Cal Factor Zero	0.038
Cal Factor Full Scale	10.92
Rotometer Reading:	3.4

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	-0.05	0.0101	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.05	0.0101	0.01	l/m	l/m	
primary	test pt 1	0.000	2.993	1.35	1.3574	3.00	l/m	l/m	0.20%
primary	test pt 2	0.000	2.991	1.35	1.3574	3.00	l/m	l/m	0.28%
primary	test pt 3	0.000	2.992	1.35	1.3574	3.00	l/m	l/m	0.25%

Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1211052490		DIN431	Eric Hebert	07/15/2014	Ozone	none

Slope:	0.99366	Slope:	0.00000
Intercept	0.33934	Intercept	0.00000
CorrCoff	0.99996	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.9%	2.4%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.32	0.52	0.47	ppb	
primary	2	33.21	33.18	33.99	ppb	2.44%
primary	3	52.94	52.77	52.63	ppb	-0.27%
primary	4	83.46	83.08	82.82	ppb	-0.31%
primary	5	112.74	112.15	111.70	ppb	-0.40%

Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9998	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.024	Status	pass
Sensor Component	Cell B Freq.	Condition	80.0 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.1 C	Status	pass
Sensor Component	Cell A Pressure	Condition	620.9 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	81.9 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0001	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4273		DIN431	Eric Hebert	07/15/2014	Temperature	none

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.44	0.54		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.06	0.29	0.0000	0.7	C	0.37
primary	Temp Mid Range	25.37	25.47	0.0000	25.9	C	0.42
primary	Temp High Range	45.32	45.33	0.0000	45.9	C	0.54

Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	DIN431	Eric Hebert	07/15/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.23	0.49		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.16	25.26	0.000	25.4	C	0.11
primary	Temp Mid Range	24.62	24.73	0.000	25.2	C	0.49
primary	Temp Mid Range	25.32	25.42	0.000	25.3	C	-0.1

Infrastructure Data For

Site ID Technician Site Visit Date

Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Temperature	DIN431	Eric Hebert	07/15/2014	System Memo	RM Young	3992	<input type="checkbox"/>	<input type="checkbox"/>
-------------	--------	-------------	------------	-------------	----------	------	--------------------------	--------------------------

The temperature sensor is mounted directly above the shelter roof.

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator was observed to lower the sample tower and replace the filter pack with the sample pump running and the channel marked as valid. Although gloves were used to handle the filter, they were kept in a pants pocket until needed and many items were touched between handling the filters. The operator was not completely familiar with the CASTNET procedures.

2 **Parameter:** DasComments

All sensors, filter pack, and ozone sample inlet are on a single, crank-down tower.

3 **Parameter:** SiteOpsProcedures

The site operator is not responsible for manual zero/span/precision checks of the ozone analyzer.

4 **Parameter:** DocumentationCo

There is very little documentation of onsite activities. No manual entries in Dataview. The COC section of the SSRF is not being used.

5 **Parameter:** SitingCriteriaCom

A small parking lot for park service employees is located approximately 40 meters north of the site.

6 **Parameter:** ShelterCleanNotes

The shelter is in good condition, clean, and well organized.

7 **Parameter:** MetSensorComme

The ambient temperature sensor is mounted approximately 8 meters from the ground and above the shelter roof.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Dinosaur Quarry"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="49-047-1002"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="40.4373"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-109.3046"/>
Land Use	<input type="text" value="Desert"/>	QAPP Elevation Meters	<input type="text" value="1463"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="10.7"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="40.4373"/>
Site Address 1	<input type="text"/>	Audit Longitude	<input type="text" value="-109.3046"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="1463"/>
County	<input type="text" value="Uintah"/>	Audit Declination	<input type="text" value="10.7"/>
City, State	<input type="text" value="Jensen, UT"/>		
Zip Code	<input type="text" value="84035"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="American Portable B"/>	Model <input type="text" value="A0810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in good condition, clean, and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="Go east on route 40 from Vernal, UT. Turn north on route 149 and follow signs for Dinosaur National Monument."/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	40 m	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|---|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input type="checkbox"/> | Mounted on south of tower, over shelter |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ambient temperature sensor is mounted approximately 8 meters from the ground and above the shelter roof.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

N/A
N/A

Parameter	Manufacturer	Model	S/N	Client ID
Temperature	RM Young	41342	4273	none

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
No
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|---|------------------|-----------------|--------------------------|--------------------------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 11 | Tower comments? | | One tower only | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

All sensors, filter pack, and ozone sample inlet are on a single, crank-down tower.

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text" value="1/20/2014"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current? Flow & observation sections
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is very little documentation of onsite activities. No manual entries in Dataview. The COC section of the SSRF is not being used.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="Not performed"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="Not performed"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="Not performed"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="Not performed"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input type="checkbox"/> Not performed	<input type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> Not performed	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was observed to lower the sample tower and replace the filter pack with the sample pump running and the channel marked as valid. Although gloves were used to handle the filter, they were kept in a pants pocket until needed and many items were touched between handling the filters. The operator was not completely familiar with the CASTNET procedures.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8816	2565	90652
elevation	Elevation	none	none	none
flow rate	Mykrolis	FC280SAV-4S	AW902153	none
Infrastructure	Infrastructure	none	none	none
MFC power supply	Tylan	RO-32	FP9706002	none
Ozone	ThermoElectron Inc	49i A3NAA	1211052490	none
Ozone Standard	ThermoElectron Inc	49i A1NAA	1130450194	none
Shelter Temperature	ARS	unknown	none	none
siting criteria	Siting Criteria	none	None	none
Temperature	RM Young	41342	4273	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>SAL133-Sandy Grenville-07/19/2014</i>						
1	7/19/2014	Computer	Dell	000292	D520	unknown
2	7/19/2014	DAS	Campbell	000351	CR3000	2129
3	7/19/2014	Elevation	Elevation	None	1	None
4	7/19/2014	Filter pack flow pump	Thomas	00765	107CA110	0000141
5	7/19/2014	Flow Rate	Apex	000465	AXMC105LPMDPCV	43974
6	7/19/2014	Infrastructure	Infrastructure	none	none	none
7	7/19/2014	Met tower	Universal Tower	03558	unknown	none
8	7/19/2014	Modem	Raven	06594	V4221-V	0844344486
9	7/19/2014	Ozone	ThermoElectron Inc	000741	49i A1NAA	1105347316
10	7/19/2014	Ozone Standard	ThermoElectron Inc	000372	49i A3NAA	0726124684
11	7/19/2014	Sample Tower	Aluma Tower	none	B	AT-51065-5-G-A
12	7/19/2014	Shelter Temperature	Campbell	none	107-L	none
13	7/19/2014	Siting Criteria	Siting Criteria	None	1	None
14	7/19/2014	Temperature	RM Young	06410	41342	14043
15	7/19/2014	Zero air pump	Werther International	06935	C 70/4	000829172

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2129	SAL133	Sandy Grenville	07/19/2014	DAS	Primary

Das Date:	<input type="text" value="7 /19/2014"/>	Audit Date	<input type="text" value="7 /19/2014"/>
Das Time:	<input type="text" value="17:30:33"/>	Audit Time	<input type="text" value="17:30:34"/>
Das Day:	<input type="text" value="200"/>	Audit Day	<input type="text" value="200"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2998	0.2998	V	V	0.0000
7	0.5000	0.4997	0.4996	V	V	-0.0001
7	0.7000	0.6996	0.6995	V	V	-0.0001
7	0.9000	0.8995	0.8993	V	V	-0.0002
7	1.0000	0.9994	0.9992	V	V	-0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	43974		SAL133	Sandy Grenville	07/19/2014	Flow Rate	000465

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.12%	1.35%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.02
Cal Factor Full Scale	0.97
Rotometer Reading:	1.4

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	-0.01	l/m	l/m	
primary	test pt 1	1.510	1.480	1.54	0.000	1.50	l/m	l/m	1.35%
primary	test pt 2	1.506	1.480	1.54	0.000	1.50	l/m	l/m	1.35%
primary	test pt 3	1.515	1.490	1.54	0.000	1.50	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	200 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347316		SAL133	Sandy Grenville	07/19/2014	Ozone	000741

Slope:	1.01925	Slope:	0.00000
Intercept	-0.35120	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.4%	1.6%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.55	0.66	0.15	ppb	
primary	2	30.65	30.62	31.05	ppb	1.40%
primary	3	50.33	50.21	50.99	ppb	1.55%
primary	4	80.69	80.43	81.40	ppb	1.21%
primary	5	100.53	100.18	101.80	ppb	1.62%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.020	Status	pass
Sensor Component	Cell B Freq.	Condition	96.7 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.54 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	729 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	109.7 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14043		SAL133	Sandy Grenville	07/19/2014	Temperature	06410

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.10	0.18		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.04	0.19	0.000	0.2	C	0
primary	Temp Mid Range	26.02	26.10	0.000	26.0	C	-0.12
primary	Temp High Range	49.32	49.33	0.000	49.2	C	-0.18

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	SAL133	Sandy Grenville	07/19/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.14	0.31		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.60	22.69	0.000	23.0	C	0.31
primary	Temp Mid Range	22.70	22.79	0.000	22.8	C	0.01
primary	Temp Mid Range	22.80	22.89	0.000	23.0	C	0.11

Infrastructure Data For

Site ID Technician Site Visit Date

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is located next to a field usually planted with corn or soy beans.

3 Parameter: ShelterCleanNotes

There is evidence of a leak in the shelter roof, and the condition has deteriorated since the previous audit visit. Only one light is working. There are signs of ants in the shelter.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map
 Operating Group Map Scale
 AQS # Map Date

Meteorological Type

Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude

Land Use QAPP Elevation Meters

Terrain QAPP Declination

Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State Present

Zip Code Fire Extinguisher

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	20 m	<input type="checkbox"/>
Limited agricultural operations	200 m	20 m	<input type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	November 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

FOR605-Eric Hebert-07/21/2014

1	7/21/2014	DAS	Campbell	49922	CR1000	illegible
2	7/21/2014	elevation	Elevation	none	none	none
3	7/21/2014	Flow Rate	AALBORG	none	GFMS-012446	196706-5
4	7/21/2014	Infrastructure	Infrastructure	none	none	none
5	7/21/2014	Precipitation	Vaisala	none	444A	2998
6	7/21/2014	Relative Humidity	Vaisala	none	HMP45AC	C2240042
7	7/21/2014	siting criteria	Siting Criteria	none	none	None
8	7/21/2014	Solar Radiation	Licor	none	LI-200	PY47986
9	7/21/2014	Temperature	Vaisala	none	HMP45AC	C2240042
10	7/21/2014	Wind Direction	Met One	illegible	Illegible	k5192
11	7/21/2014	Wind Speed	Met One	none	014	D3117

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
AALBORG	196706-5		FOR605	Eric Hebert	07/21/2014	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
6.56%	6.82%

Cal Factor Zero	0.33
Cal Factor Full Scale	0.0019
Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.36	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.36	l/m	l/m	
primary	test pt 1	3.080	3.080	0.00	0.000	3.29	l/m	l/m	6.82%
primary	test pt 2	3.079	3.080	0.00	0.000	3.29	l/m	l/m	6.66%
primary	test pt 3	3.081	3.080	0.00	0.000	3.27	l/m	l/m	6.20%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	D3117		FOR605	Eric Hebert	07/21/2014	Wind Speed	none

Mfg	RM Young	Parameter	wind speed
Serial Number	CA04013	Tfer Desc.	wind speed motor (h
Tfer ID	01253		
Slope	1.00000	Intercept	0.00000
Cert Date	1/16/2014	CorrCoff	1.00000

Prop or Cups SN
Prop or Cups Torque to
Prop Correction Fact

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.07"/>	<input type="text" value="0.63%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.17"/>	<input type="text" value="1.26%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	Input Device	Input RPM	Input m/s	Out V	DAS m/s	Diff/ %Diff	Diff	WsM
primary	none	0	0.45	0.0	0.5		0.00	
primary	01253	40	1.67	0.0	1.5		-0.17	
primary	01253	80	2.75	0.0	2.7		-0.10	
primary	01253	140	4.26	0.0	4.3		-0.01	
primary	01253	210	6.07	0.0	6.1	-0.33%		
primary	01253	400	11.11	0.0	11.3	1.26%		
primary	01253	730	19.87	0.0	20.1	0.91%		
primary	01253	1800	48.44	0.0	48.5	0.02%		

Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Prop or Cups Condition	Condition	Good	Status	pass
Sensor Component	Sensor Heater	Condition	N/A	Status	pass
Sensor Component	Torque	Condition		Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	k5192		FOR605	Eric Hebert	07/21/2014	Wind Direction	illegible

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value=""/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01264"/>		
Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="192034"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01270"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/30/2014"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	<input type="text" value="3.5"/>	<input type="text" value=""/>	<input type="text" value=""/>	<input type="text" value=""/>
Abs Max Er	<input type="text" value="5"/>	<input type="text" value=""/>	<input type="text" value=""/>	<input type="text" value=""/>

UseDescription	TferID	Input Raw	Linearity	Output V	Output Deg.	Difference	Change	Error
primary	01270	0	<input type="checkbox"/>	0.000	1	1		1
primary	01270	90	<input type="checkbox"/>	0.000	86	4		4
primary	01270	180	<input type="checkbox"/>	0.000	176	4		4
primary	01270	270	<input type="checkbox"/>	0.000	265	5		5

Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value=""/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text" value=""/>	Status	<input type="text" value="pass"/>

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2240042		FOR605	Eric Hebert	07/21/2014	Temperature	none

DAS 1:	DAS 2:
Abs Avg Err	Abs Max Er
	Abs Avg Err
	Abs Max Er

Mfg	Eutechnics	Parameter	Temperature
Serial Number	01D102193	Tfer Desc.	RTD translator
Tfer ID	01231		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000
Mfg	Eutechnics	Parameter	Temperature
Serial Number	01H0060	Tfer Desc.	RTD probe
Tfer ID	01230		
Slope	1.00133	Intercept	-0.05731
Cert Date	12/27/2013	CorrCoff	1.00000

0.67	1.45		
------	------	--	--

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	4.41	4.46	0.000	5.9	C	1.45
primary	Temp Mid Range	33.72	33.73	0.000	33.5	C	-0.27
primary	Temp High Range	43.63	43.63	0.000	43.9	C	0.29

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2240042		FOR605	Eric Hebert	07/21/2014	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	75296	Tfer Desc.	GTL
Tfer ID	01220		
Slope	1.00000	Intercept	0.00000
Cert Date	1/5/2010	CorrCoff	1.00000

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	3.5	6.5		
Abs Max Er	4.7	6.5		

UseDesc.	Test type	Device	Input RH	GTL Raw	RH Corr.	DAS Volts	DAS %RH	Difference
primary	RH Low Range	GTL	32.8	0.0	32.8	0.000	30.5	-2.3
primary	RH Low Range	GTL	52.9	0.0	52.9	0.000	48.2	-4.7
primary	RH High Range	GTL	93.6	0.0	93.6	0.000	87.1	-6.5

Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Solar Radiation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Licor	PY47986		FOR605	Eric Hebert	07/21/2014	Solar Radiation	none

DAS 1:
% Diff of Avg %Diff of Max **DAS 2:**
%Diff of Avg %Diff of Max

Mfg	RM Young	Parameter	solar radiation
Serial Number		Tfer Desc.	SR transfer transl
Tfer ID	01240		
Slope	1.02678	Intercept	-16.91000
Cert Date	6/14/2014	CorrCoff	0.99800
Mfg	Licor	Parameter	solar radiation
Serial Number		Tfer Desc.	SR transfer sensor
Tfer ID	01241		
Slope	1.02678	Intercept	-16.91000
Cert Date	6/14/2014	CorrCoff	0.99800

2.3% 1.7% 0.0% 0.0%

UseDescription	Measure Date	MeasureTime	Tfer Raw	Tfer Corr	DAS w/m2	PctDifference
primary	7/21/2014	10:00	844	838	814	-2.9%
primary	7/21/2014	11:00	875	868	853	-1.7%

Sensor Component	Sensor Clean	Condition	Clean	Status	pass
Sensor Component	Sensor Level	Condition	Level	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	2998		FOR605	Eric Hebert	07/21/2014	Precipitation	none

DAS 1:

A Avg % Diff: **A Max % Di**

DAS 2:

A Avg %Dif **A Max % Di**

Mfg	<input type="text" value="PMP"/>	Parameter	<input type="text" value="Precipitation"/>
Serial Number	<input type="text" value="EW-06134-50"/>	Tfer Desc.	<input type="text" value="250ml graduate"/>
Tfer ID	<input type="text" value="01250"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="9/5/2005"/>	CorrCoff	<input type="text" value="1.00000"/>

UseDesc.	Test type	TferVolume	Iteration	TimePerTip	Eq.Ht	DAS eng	Eq.HtUnit	OSE Unit	TferUnits	PctDifference
primary	test 1	231.5	1	15 sec	7.25	6.50	mm	mm	ml	-10.3%
primary	test 2	231.5	2	15 sec	7.25	6.60	mm	mm	ml	-9.0%

Sensor Component	<input type="text" value="Gauge Drain Screen"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Funnel Clean"/>	Condition	<input type="text" value="Clean"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Properly Sited"/>	Condition	<input type="text" value="45 degree rule"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Gauge Screen"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Gauge Clean"/>	Condition	<input type="text" value="Dirty"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Level"/>	Condition	<input type="text" value="Level"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Pole type"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	FOR605	Eric Hebert	07/21/2014	System Memo	AALBORG	4202	<input type="checkbox"/>	<input type="checkbox"/>
-----------	--------	-------------	------------	-------------	---------	------	--------------------------	--------------------------

Additional details can be found in the hardcopy of the site audit report.

Temperature	FOR605	Eric Hebert	07/21/2014	System Memo	Vaisala	4198	<input type="checkbox"/>	<input type="checkbox"/>
-------------	--------	-------------	------------	-------------	---------	------	--------------------------	--------------------------

Additional details can be found in the hardcopy of the site audit report.

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The dry deposition sample height is approximately 6 meters and not 10 meters.

2 **Parameter:** DocumentationCo

There is no documentation available at the site since there is no place to store documents. The site does not have a computer or shelter other than the small enclosure. The site operator completes a site checklist which remains in his vehicle. Information from the checklist is later filed at his office.

3 **Parameter:** SitingCriteriaCom

The site is located in a wellfield with oil and gas operations nearby.

4 **Parameter:** ShelterCleanNotes

This is a small footprint site with instruments mounted in enclosure on tripod tower.

5 **Parameter:** MetOpMaintCom

The temperature and relative humidity sensor is a combination sensor which cannot be submersed making it difficult to audit throughout a range of temperatures.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map

Operating Group Map Scale

AQS # Map Date

Meteorological Type

Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude

Land Use QAPP Elevation Meters

Terrain QAPP Declination

Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State Present

Zip Code Fire Extinguisher

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|--------------------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | 45 degree rule violation |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature and relative humidity sensor is a combination sensor which cannot be submersed making it difficult to audit throughout a range of temperatures.

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

N/A
3/8 teflon by 8 meters
N/A
N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>							
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>							
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>							
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>							
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>							
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>							
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>	Solar power						
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>	N/A						
9	Is the met tower stable and grounded?	<input checked="" type="checkbox"/>	<table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded							
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
10	Is the sample tower stable and grounded?	<input checked="" type="checkbox"/>	<table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable		Grounded	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Stable		Grounded							
<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>							
11	Tower comments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is no documentation available at the site since there is no place to store documents. The site does not have a computer or shelter other than the small enclosure. The site operator completes a site checklist which remains in his vehicle. Information from the checklist is later filed at his office.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	Flow section only
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> N/A	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The dry deposition sample height is approximately 6 meters and not 10 meters.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	illegible	49922
elevation	Elevation	none	none	none
Flow Rate	AALBORG	GFMS-012446	196706-5	none
Infrastructure	Infrastructure	none	none	none
Precipitation	Vaisala	444A	2998	none
Relative Humidity	Vaisala	HMP45AC	C2240042	none
siting criteria	Siting Criteria	none	None	none
Solar Radiation	Licor	LI-200	PY47986	none
Temperature	Vaisala	HMP45AC	C2240042	none
Wind Direction	Met One	Illegible	k5192	illegible
Wind Speed	Met One	014	D3117	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ANA115-Eric Hebert-08/19/2014

1	8/19/2014	Computer	Dell	000298	D520	unknown
2	8/19/2014	DAS	Campbell	000338	CR3000	2117
3	8/19/2014	Elevation	Elevation	None	1	None
4	8/19/2014	Filter pack flow pump	Thomas	00209	107CA110	0000124
5	8/19/2014	Flow Rate	Apex	000809	AXMC105LPMDPCV	illegible
6	8/19/2014	Infrastructure	Infrastructure	none	none	none
7	8/19/2014	Met tower	Universal Tower	03555	unknown	none
8	8/19/2014	Modem	Raven	06588	V4221-V	0844352818
9	8/19/2014	Ozone	ThermoElectron Inc	000746	49i A1NAA	1105347315
10	8/19/2014	Ozone Standard	ThermoElectron Inc	000436	49i A3NAA	CM08200012
11	8/19/2014	Ozone Standard	ThermoElectron Inc	000364	49i A3NAA	0726124687
12	8/19/2014	Sample Tower	Aluma Tower	000180	B	none
13	8/19/2014	Shelter Temperature	Campbell	none	107-L	none
14	8/19/2014	Shield (10 meter)	Climatronics	00768	100325	illegible
15	8/19/2014	Siting Criteria	Siting Criteria	None	1	None
16	8/19/2014	Temperature	Climatronics	06708	100093	missing
17	8/19/2014	Zero air pump	Werther International	06933	C 70/4	000836202

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2117	ANA115	Eric Hebert	08/19/2014	DAS	Primary

Das Date: **Audit Date:**
Das Time: **Audit Time:**
Das Day: **Audit Day:**
Low Channel: **High Channel:**
Avg Diff: **Max Diff:** **Avg Diff:** **Max Diff:**

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/22/2014"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		ANA115	Eric Hebert	08/19/2014	Flow Rate	000809

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0
2.04%	2.04%	Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	test pt 1	1.474	1.470	1.47	0.000	1.50	l/m	l/m	2.04%
primary	test pt 2	1.474	1.470	1.47	0.000	1.50	l/m	l/m	2.04%
primary	test pt 3	1.473	1.470	1.47	0.000	1.50	l/m	l/m	2.04%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347315		ANA115	Eric Hebert	08/19/2014	Ozone	000746

Slope:	0.80101	Slope:	0.00000
Intercept	2.22814	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
16.0%	17.9%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	0419606966	Tfer Desc.	Ozone primary stan
Tfer ID	01112		
Slope	1.00928	Intercept	0.11780
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.36	-0.47	1.91	ppb	
primary	2	32.59	32.17	28.06	ppb	-12.78%
primary	3	53.27	52.66	44.13	ppb	-16.20%
primary	4	85.17	84.27	69.91	ppb	-17.04%
primary	5	110.87	109.73	90.10	ppb	-17.89%

Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.016	Status	pass
Sensor Component	Cell B Freq.	Condition	90.3 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.2 C	Status	pass
Sensor Component	Cell A Pressure	Condition	712.7 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	87.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	missing		ANA115	Eric Hebert	08/19/2014	Temperature	06708

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.20	0.28		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	-0.03	0.20	0.000	0.3	C	0.08
primary	Temp Mid Range	25.10	25.21	0.000	25.0	C	-0.24
primary	Temp High Range	47.26	47.26	0.000	47.5	C	0.28

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ANA115	Eric Hebert	08/19/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.12	0.22		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.50	22.62	0.000	22.6	C	0.01
primary	Temp Mid Range	22.20	22.32	0.000	22.5	C	0.22

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>
Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	ANA115	Eric Hebert	08/19/2014	System Memo	Apex	3990	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-----------	--------	-------------	------------	-------------	------	------	--------------------------	-------------------------------------

There is no plastic bag for the installed filter. The operator uses the received bag for the installed filter to ship the removed filter to the lab.

Flow Rate	ANA115	Eric Hebert	08/19/2014	Moisture Present	Apex	3990	<input type="checkbox"/>	<input type="checkbox"/>
-----------	--------	-------------	------------	------------------	------	------	--------------------------	--------------------------

The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

1 Parameter: SiteOpsProcComm

Gloves were not used to change the filter. It was observed that the dry deposition filter was replaced while the sample pump was running with the sample tower lowered. The filter was changed during a rain storm and water entered the filter and sample lines (flow and ozone). The filter can be exposed and sampling from ground level for up to 30 minutes if the ozone leak check is also performed.

2 Parameter: DasComments

The air conditioner thermostat control is by-passed and the air conditioner is running continuously.

3 Parameter: SitingCriteriaCom

Site is confined within a fenced area that is somewhat small. There is available space adjacent to the fenced area that could be utilized to improve the instrument siting.

4 Parameter: ShelterCleanNotes

The shelter is well organized and in fair condition.

5 Parameter: PollAnalyzerCom

Moisture is present in the flow tubing outside of the shelter.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Pinckney"/>
Operating Group	<input type="text" value="University of MI"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="26-161-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet, Hg"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="flat"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(734) 426-0060"/>	Audit Latitude	<input type="text" value="42.416636"/>
Site Address 1	<input type="text" value="8420 Strawberry Lake Rd."/>	Audit Longitude	<input type="text" value="-83.90218"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="266"/>
County	<input type="text" value="Washtenaw"/>	Audit Declination	<input type="text" value="-6.6"/>
City, State	<input type="text" value="Dexter, MI"/>		
Zip Code	<input type="text" value="48130"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is well organized and in fair condition."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Ann Arbor take I-94 west to exit 169 to Dexter, turning right (north) to Dexter. Continue a few miles to the stop sign and turn left. Continue approximately one block to the small park in the center of town and turn right (north). Continue through Dexter, across the railroad tracks and river. Turn left (west) just across the river on Huron River Drive. Continue about 8 miles on Huron River Drive which becomes a dirt road after the intersection of North Territorial Rd. The site is on the left, just past the first sharp turn in the road (to the right) where it becomes Strawberry Lake Road.

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Site is confined within a fenced area that is somewhat small. There is available space adjacent to the fenced area that could be utilized to improve the instrument siting.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	N/A
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Moisture in tubing only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Moisture is present in the flow tubing outside of the shelter.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|--|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | A/C running continuously, thermostat by-passed | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | Sample tower not grounded | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters? Unknown
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Gloves were not used to change the filter. It was observed that the dry deposition filter was replaced while the sample pump was running with the sample tower lowered. The filter was changed during a rain storm and water entered the filter and sample lines (flow and ozone). The filter can be exposed and sampling from ground level for up to 30 minutes if the ozone leak check is also performed.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000298
DAS	Campbell	CR3000	2117	000338
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA110	0000124	00209
Flow Rate	Apex	AXMC105LPMDPC	illegible	000809
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	03555
Modem	Raven	V4221-V	0844352818	06588
Ozone	ThermoElectron Inc	49i A1NAA	1105347315	000746
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124687	000364
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200012	000436
Sample Tower	Aluma Tower	B	none	000180
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	Climatronics	100325	illegible	00768
Siting Criteria	Siting Criteria	1	None	None
Temperature	Climatronics	100093	missing	06708
Zero air pump	Werther International	C 70/4	000836202	06933

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>HOX148-Eric Hebert-08/25/2014</i>						
1	8/25/2014	Computer	Dell	000289	D520	unknown
2	8/25/2014	DAS	Campbell	000426	CR3000	2533
3	8/25/2014	Elevation	Elevation	None	1	None
4	8/25/2014	Filter pack flow pump	Thomas	04927	107CAB18	110300021225
5	8/25/2014	Flow Rate	Apex	000526	AXMC105LPMPCV	48099
6	8/25/2014	Infrastructure	Infrastructure	none	none	none
7	8/25/2014	Met tower	Universal Tower	03560	unknown	none
8	8/25/2014	Modem	Raven	06480	H4222-C	0808311145
9	8/25/2014	Ozone	ThermoElectron Inc	000614	49i A1NAA	1009241794
10	8/25/2014	Ozone Standard	ThermoElectron Inc	000432	49i A3NAA	CM08200008
11	8/25/2014	Sample Tower	Aluma Tower	000131	B	none
12	8/25/2014	Shelter Temperature	Campbell	none	107-L	none
13	8/25/2014	Shield (10 meter)	RM Young	00794	Aspirated 43408	none
14	8/25/2014	Siting Criteria	Siting Criteria	None	1	None
15	8/25/2014	Temperature	RM Young	06544	41342	14805
16	8/25/2014	Zero air pump	Werther International	06938	C 70/4	000829164

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2533	HOX148	Eric Hebert	08/25/2014	DAS	Primary

Das Date:	<input type="text" value="8 /25/2014"/>	Audit Date:	<input type="text" value="8 /25/2014"/>
Das Time:	<input type="text" value="13:14:15"/>	Audit Time:	<input type="text" value="13:15:00"/>
Das Day:	<input type="text" value="237"/>	Audit Day:	<input type="text" value="237"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/22/2014"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0004	0.0004	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.3003	0.3004	V	V	0.0001
7	0.5000	0.5004	0.5005	V	V	0.0001
7	0.7000	0.7002	0.7003	V	V	0.0001
7	0.9000	0.9005	0.9004	V	V	-0.0001
7	1.0000	1.0000	1.0000	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	48099		HOX148	Eric Hebert	08/25/2014	Flow Rate	000526

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.05
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1.06
0.67%	0.67%	Rotometer Reading:	1.4

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	-0.08	0.000	-0.03	l/m	l/m	
primary	leak check	0.000	0.000	-0.02	0.000	0.04	l/m	l/m	
primary	test pt 1	1.499	1.500	1.43	0.000	1.49	l/m	l/m	-0.67%
primary	test pt 2	1.495	1.500	1.43	0.000	1.49	l/m	l/m	-0.67%
primary	test pt 3	1.500	1.500	1.43	0.000	1.49	l/m	l/m	-0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241794		HOX148	Eric Hebert	08/25/2014	Ozone	000614

Slope:	0.97404	Slope:	0.00000
Intercept	1.20525	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.4%	2.2%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	0419606966	Tfer Desc.	Ozone primary stan
Tfer ID	01112		
Slope	1.00928	Intercept	0.11780
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.56	-0.67	0.72	ppb	
primary	2	24.81	24.46	25.00	ppb	2.21%
primary	3	52.58	51.97	51.63	ppb	-0.65%
primary	4	81.19	80.32	79.30	ppb	-1.27%
primary	5	113.06	111.90	110.40	ppb	-1.34%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.50	Status	pass
Sensor Component	Span	Condition	1.022	Status	pass
Sensor Component	Cell B Freq.	Condition	95.7 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	711.8 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	89.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14805		HOX148	Eric Hebert	08/25/2014	Temperature	06544

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.11	0.18		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	-0.06	0.17	0.000	0.1	C	-0.05
primary	Temp Mid Range	22.61	22.73	0.000	22.6	C	-0.1
primary	Temp High Range	43.57	43.58	0.000	43.4	C	-0.18

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	HOX148	Eric Hebert	08/25/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.29	0.60		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	20.94	21.07	0.000	20.8	C	-0.25
primary	Temp Mid Range	26.36	26.46	0.000	26.4	C	-0.03
primary	Temp Mid Range	19.35	19.48	0.000	20.1	C	0.6

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	HOX148	Eric Hebert	08/25/2014	Moisture Present	Apex	3194	<input type="checkbox"/>	<input type="checkbox"/>
-----------	--------	-------------	------------	------------------	------	------	--------------------------	--------------------------

Although there currently is no moisture in the flow sample train, there is evidence of previous moisture events.

Shelter Temperature	HOX148	Eric Hebert	08/25/2014	System Memo	Campbell	3192	<input type="checkbox"/>	<input type="checkbox"/>
---------------------	--------	-------------	------------	-------------	----------	------	--------------------------	--------------------------

The shelter thermostat for cooling has been bypassed and the air conditioning system is no longer being controlled by the shelter thermostat.

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone analyzer sample train is leak-checked every two weeks.

2 **Parameter:** SitingCriteriaCom

There is a co-generating and smelting facility in Cadillac approximately 30 km to the northeast. The site is located in a hay field which is cut 2 or 3 times per year.

3 **Parameter:** ShelterCleanNotes

The shelter is clean, neat, well organized.

4 **Parameter:** MetSensorComme

Met tower and 10 meter temperature operating and audited.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Hoxeyville"/>
Operating Group	<input type="text" value="private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="26-165-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodlands - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(231) 862-3750"/>	Audit Latitude	<input type="text" value="44.18089"/>
Site Address 1	<input type="text" value="10637 South 9 Rd."/>	Audit Longitude	<input type="text" value="-85.73898"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="297"/>
County	<input type="text" value="Wexford"/>	Audit Declination	<input type="text" value="-5"/>
City, State	<input type="text" value="Cadillac, MI"/>		
Zip Code	<input type="text" value="49601"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is clean, neat, well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Cadillac proceed west on route 55 for approximately 12.5 miles. Turn left (south) on Hoxeyville Road (S13) and continue approximately 2 miles to the first stop sign. Turn right (west) on an unmarked road and continue approximately 2 miles to 9 road. Turn left (south) on 9 road which is not paved and continue approximately 1 mile, the site is on the left.

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	~ 30 km	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	10 m	<input type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

There is a co-generating and smelting facility in Cadillac approximately 30 km to the northeast. The site is located in a hay field which is cut 2 or 3 times per year.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 15 meters |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 15 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input checked="" type="checkbox"/> | Flow line only |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | Clean and dry |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|--|----------------------|--|----------|-------------------------------------|--|-------------------------------------|----------------------|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | <input type="text"/> | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | <input type="text"/> |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | <input type="text"/> |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2001	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	June 1987	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000289
DAS	Campbell	CR3000	2533	000426
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	110300021225	04927
Flow Rate	Apex	AXMC105LPMDPC	48099	000526
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	03560
Modem	Raven	H4222-C	0808311145	06480
Ozone	ThermoElectron Inc	49i A1NAA	1009241794	000614
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200008	000432
Sample Tower	Aluma Tower	B	none	000131
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	RM Young	Aspirated 43408	none	00794
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	14805	06544
Zero air pump	Werther International	C 70/4	000829164	06938

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>UVL124-Eric Hebert-08/26/2014</i>						
1	8/26/2014	Computer	Dell	000294	D520	unknown
2	8/26/2014	DAS	Campbell	000423	CR3000	2517
3	8/26/2014	Elevation	Elevation	None	1	None
4	8/26/2014	Filter pack flow pump	Thomas	02973	107CAB18	0493002467
5	8/26/2014	Flow Rate	Apex	000600	AXMC105LPMDPCV	illegible
6	8/26/2014	Infrastructure	Infrastructure	none	none	none
7	8/26/2014	Met tower	Universal Tower	02745	unknown	none
8	8/26/2014	Modem	Raven	06466	V4221-V	0808339409
9	8/26/2014	Ozone	ThermoElectron Inc	000745	49i A1NAA	1105347310
10	8/26/2014	Ozone Standard	ThermoElectron Inc	000365	49i A3NAA	0726124688
11	8/26/2014	Sample Tower	Aluma Tower	03557	A	none
12	8/26/2014	Shelter Temperature	Campbell	none	107-L	none
13	8/26/2014	Shield (10 meter)	RM Young	missing	Aspirated 43408	none
14	8/26/2014	Siting Criteria	Siting Criteria	None	1	None
15	8/26/2014	Temperature	RM Young	06504	41342	14624
16	8/26/2014	Zero air pump	Werther International	06936	C 70/4	000829169

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2517	UVL124	Eric Hebert	08/26/2014	DAS	Primary

Das Date:	<input type="text" value="8 /26/2014"/>	Audit Date:	<input type="text" value="8 /26/2014"/>
Das Time:	<input type="text" value="13:05:00"/>	Audit Time:	<input type="text" value="13:05:01"/>
Das Day:	<input type="text" value="238"/>	Audit Day:	<input type="text" value="238"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0002"/>	Max Diff:	<input type="text" value="0.0003"/>
		Avg Diff:	<input type="text" value="0.0002"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/22/2014"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0002	0.0000	V	V	0.0002
7	0.1000	0.0997	0.0996	V	V	-0.0001
7	0.3000	0.2996	0.2997	V	V	0.0001
7	0.5000	0.4994	0.4996	V	V	0.0002
7	0.7000	0.6998	0.6999	V	V	0.0001
7	0.9000	0.8999	0.8996	V	V	-0.0003
7	1.0000	1.0000	0.9998	V	V	-0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		UVL124	Eric Hebert	08/26/2014	Flow Rate	000600

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.67%	0.67%

Cal Factor Zero	-0.02
Cal Factor Full Scale	0.99
Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.00	l/m	l/m	
primary	test pt 1	1.488	1.490	1.50	0.000	1.50	l/m	l/m	0.67%
primary	test pt 2	1.485	1.490	1.50	0.000	1.50	l/m	l/m	0.67%
primary	test pt 3	1.494	1.490	1.51	0.000	1.50	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347310		UVL124	Eric Hebert	08/26/2014	Ozone	000745

Slope:	0.99192	Slope:	0.00000
Intercept	0.80640	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.9%	2.2%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	0419606966	Tfer Desc.	Ozone primary stan
Tfer ID	01112		
Slope	1.00928	Intercept	0.11780
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.41	-0.52	0.29	ppb	
primary	2	26.07	25.71	26.28	ppb	2.22%
primary	3	51.19	50.60	51.06	ppb	0.91%
primary	4	77.54	76.71	76.86	ppb	0.20%
primary	5	113.77	112.60	112.50	ppb	-0.09%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.10	Status	pass
Sensor Component	Span	Condition	1.049	Status	pass
Sensor Component	Cell B Freq.	Condition	90.4 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.46 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.4 C	Status	pass
Sensor Component	Cell A Pressure	Condition	726.5 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	87.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.64 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14624		UVL124	Eric Hebert	08/26/2014	Temperature	06504

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.08	0.11		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	-0.06	0.17	0.000	0.1	C	-0.06
primary	Temp Mid Range	25.21	25.31	0.000	25.2	C	-0.08
primary	Temp High Range	46.38	46.38	0.000	46.3	C	-0.11

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	UVL124	Eric Hebert	08/26/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.34	0.50		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	24.28	24.39	0.000	24.6	C	0.16
primary	Temp Mid Range	23.99	24.10	0.000	23.8	C	-0.35
primary	Temp Mid Range	26.15	26.25	0.000	25.8	C	-0.5

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	UVL124	Eric Hebert	08/26/2014	Moisture Present	Apex	3991	<input type="checkbox"/>	<input type="checkbox"/>
-----------	--------	-------------	------------	------------------	------	------	--------------------------	--------------------------

Although there currently is no moisture in the flow sample train, there is evidence of previous moisture events.

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

Ozone sample train leak-check performed every two weeks.

2 **Parameter:** DocumentationCo

The ozone diagnostic and observation sections of the SSRF were completed during the filter removal visit and not the installation visit as indicated on the form.

3 **Parameter:** SitingCriteriaCom

The site is located in an active agriculture field usually planted with beans or corn.

4 **Parameter:** ShelterCleanNotes

The shelter is clean and in good condition.

5 **Parameter:** MetOpMaintCom

Met tower and 10 meter temperature operating and audited.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Ellington"/>
Operating Group	<input type="text" value="private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="26-157-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="agriculture"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="flat"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(989) 673-5901"/>	Audit Latitude	<input type="text" value="43.613572"/>
Site Address 1	<input type="text" value="1821 E. Dickerson Rd."/>	Audit Longitude	<input type="text" value="-83.359869"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="202"/>
County	<input type="text" value="Tuscola"/>	Audit Declination	<input type="text" value="-7"/>
City, State	<input type="text" value="Unionville, MI"/>		
Zip Code	<input type="text" value="48767"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is clean and in good condition."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	30 m	<input type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 12 meters |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 12 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input checked="" type="checkbox"/> | Flow line only |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | Clean and dry |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|---|---------------------|----------|-------------------------------------|--------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | Towers not grounded | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2001	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	4/2/2014	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone diagnostic and observation sections of the SSRF were completed during the filter removal visit and not the installation visit as indicated on the form.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters? Unknown
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? SSRF, logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	With noted exceptions
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000294
DAS	Campbell	CR3000	2517	000423
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	0493002467	02973
Flow Rate	Apex	AXMC105LPMDPC	illegible	000600
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	02745
Modem	Raven	V4221-V	0808339409	06466
Ozone	ThermoElectron Inc	49i A1NAA	1105347310	000745
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124688	000365
Sample Tower	Aluma Tower	A	none	03557
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	RM Young	Aspirated 43408	none	missing
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	14624	06504
Zero air pump	Werther International	C 70/4	000829169	06936

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

EGB181-Eric Hebert-08/28/2014

1	8/28/2014	Computer	Dell	000263	D520	unknown
2	8/28/2014	DAS	Campbell	000408	CR3000	2538
3	8/28/2014	Elevation	Elevation	None	1	None
4	8/28/2014	Filter pack flow pump	Thomas	04285	107CAB18B	129800010108
5	8/28/2014	Flow Rate	Apex	000663	AXMC105LPMDPCV	illegible
6	8/28/2014	Infrastructure	Infrastructure	none	none	none
7	8/28/2014	Met tower	Universal Tower	04649	unknown	none
8	8/28/2014	Modem	Raven	06584	H4223-C	0844381230
9	8/28/2014	Sample Tower	Aluma Tower	01791	A	none
10	8/28/2014	Shelter Temperature	Campbell	none	107-L	none
11	8/28/2014	Shield (10 meter)	RM Young	02942	Aspirated 43408	none
12	8/28/2014	Siting Criteria	Siting Criteria	None	1	None
13	8/28/2014	Temperature	RM Young	06502	41342	14622

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2538	EGB181	Eric Hebert	08/28/2014	DAS	Primary

Das Date:	<input type="text" value="8 /28/2014"/>	Audit Date	<input type="text" value="8 /28/2014"/>
Das Time:	<input type="text" value="13:15:20"/>	Audit Time	<input type="text" value="13:14:00"/>
Das Day:	<input type="text" value="240"/>	Audit Day	<input type="text" value="240"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0002"/>	Max Diff:	<input type="text" value="0.0004"/>
		Avg Diff:	<input type="text" value="0.0002"/>
		Max Diff:	<input type="text" value="0.0004"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/22/2014"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0005	-0.0001	V	V	0.0004
7	0.1000	0.0997	0.0996	V	V	-0.0001
7	0.3000	0.2996	0.2993	V	V	-0.0003
7	0.5000	0.4994	0.4994	V	V	0.0000
7	0.7000	0.7000	0.6999	V	V	-0.0001
7	0.9000	0.9000	0.8997	V	V	-0.0003
7	1.0000	1.0000	0.9999	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		EGB181	Eric Hebert	08/28/2014	Flow Rate	000663

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
2.40%	2.63%

Cal Factor Zero	-0.015
Cal Factor Full Scale	0.994
Rotometer Reading:	1.6

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.46	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.26	0.000	-0.01	l/m	l/m	
primary	test pt 1	1.524	1.520	1.49	0.000	1.49	l/m	l/m	-1.97%
primary	test pt 2	1.523	1.520	1.49	0.000	1.48	l/m	l/m	-2.63%
primary	test pt 3	1.530	1.530	1.50	0.000	1.49	l/m	l/m	-2.61%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14622		EGB181	Eric Hebert	08/28/2014	Temperature	06502

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.06	0.08		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.30	0.53	0.000	0.5	C	-0.07
primary	Temp Mid Range	25.20	25.30	0.000	25.2	C	-0.08
primary	Temp High Range	48.64	48.63	0.000	48.6	C	-0.02

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	EGB181	Eric Hebert	08/28/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.27	0.36		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.81	22.93	0.000	23.3	C	0.36
primary	Temp Mid Range	23.28	23.39	0.000	23.6	C	0.17
primary	Temp Mid Range	23.65	23.76	0.000	23.5	C	-0.27

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="custom"/>	<input type="text" value="N/A"/>	<input type="text" value="7200 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

Filters are sent 4 at a time and stored in a refrigerator before and after sampling prior to shipment to the lab.

2 **Parameter:** DasComments

The sample tower is badly damaged at the hinge point and should be replaced.

3 **Parameter:** DocumentationCo

The site operator no longer uses the station logbook during routine site visits.

4 **Parameter:** ShelterCleanNotes

The shelter is provided by the Center for Atmospheric Research and is clean, organized, and spacious.

5 **Parameter:** PollAnalyzerCom

Ozone concentration is not measured at EGB181 as part of CASTNET.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map
 Operating Group Map Scale
 AQS # Map Date

Meteorological Type
 Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude
 Land Use QAPP Elevation Meters

Terrain QAPP Declination
 Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State Present

Zip Code Fire Extinguisher

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

N/A
3/8 teflon by 20 meters
N/A
N/A
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone concentration is not measured at EGB181 as part of CASTNET.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	March 2006 version QAPP on Disc	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Logbook not used
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator no longer uses the station logbook during routine site visits.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Daily	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Filters are sent 4 at a time and stored in a refrigerator before and after sampling prior to shipment to the lab.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000263
DAS	Campbell	CR3000	2538	000408
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18B	129800010108	04285
Flow Rate	Apex	AXMC105LPMDPC	illegible	000663
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	04649
Modem	Raven	H4223-C	0844381230	06584
Sample Tower	Aluma Tower	A	none	01791
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	RM Young	Aspirated 43408	none	02942
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	14622	06502

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

RED004-Alison Ray-09/04/2014

1	9/4/2014	DAS	Campbell	Unknown	CR850	unknown
2	9/4/2014	Filter pack flow pump	gast	none	16D-6150-101-1039	1039
3	9/4/2014	Flow Rate	Apex	000599	AXMC105LPM DPCV	illegible
4	9/4/2014	Sample Tower	Aluma Tower	000813	B	unknown
5	9/4/2014	Temperature	RM Young	06986	41342	024087

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		RED004	Alison Ray	09/04/2014	Flow Rate	000599

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.99%	0.99%

Cal Factor Zero	0.01
Cal Factor Full Scale	1.014
Rotometer Reading:	3

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	test pt 1	3.026	3.030	2.97	0.000	3.00	l/m	l/m	-0.99%
primary	test pt 2	3.028	3.030	2.97	0.000	3.00	l/m	l/m	-0.99%
primary	test pt 3	3.033	3.030	2.97	0.000	3.00	l/m	l/m	-0.99%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Field Systems Comments

1 Parameter: DocumentationCo

There is no site logbook and all manuals are kept electronically since the site is a small footprint site with no place to store hardcopies.

2 Parameter: ShelterCleanNotes

Small footprint site with enclosure for instruments only.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map

Operating Group Map Scale

AQS # Map Date

Meteorological Type

Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude

Land Use QAPP Elevation Meters

Terrain QAPP Declination

Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State Present

Zip Code Fire Extinguisher

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

N/A
3/8 teflon by 8 meters
N/A
N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | |
|----|--|-------------------------------------|-------------------------------------|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is the met tower stable and grounded? | <input type="checkbox"/> | <input type="checkbox"/> |
| 10 | Is the sample tower stable and grounded? | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| 11 | Tower comments? | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is no site logbook and all manuals are kept electronically since the site is a small footprint site with no place to store hardcopies.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR850	unknown	Unknown
Filter pack flow pump	gast	16D-6150-101-1039	1039	none
Flow Rate	Apex	AXMC105LPMDPC	illegible	000599
Sample Tower	Aluma Tower	B	unknown	000813
Temperature	RM Young	41342	024087	06986

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>CTH110-Eric Hebert-09/05/2014</i>						
1	9/5/2014	Computer	Dell	000479	D630	unknown
2	9/5/2014	DAS	Campbell	000420	CR3000	2520
3	9/5/2014	Elevation	Elevation	None	1	None
4	9/5/2014	Filter pack flow pump	Thomas	04987	107CA18	050400022550
5	9/5/2014	Flow Rate	Apex	000559	AXMC105LPMDPCV	illegible
6	9/5/2014	Infrastructure	Infrastructure	none	none	none
7	9/5/2014	Met tower	Universal Tower	03442	unknown	none
8	9/5/2014	Modem	Raven	06599	V4221-V	0844349892
9	9/5/2014	Ozone	ThermoElectron Inc	000742	49i A1NAA	1105347313
10	9/5/2014	Ozone Standard	ThermoElectron Inc	000447	49i A3NAA	CM08200023
11	9/5/2014	Sample Tower	Aluma Tower	666363	B	AT-5107-E-4-10
12	9/5/2014	Shelter Temperature	Campbell	none	107-L	none
13	9/5/2014	Shield (10 meter)	Climatronics	00917	100325	illegible
14	9/5/2014	Siting Criteria	Siting Criteria	None	1	None
15	9/5/2014	Temperature	Climatronics	06647	100093	none
16	9/5/2014	UPS	APC	06796	RS900	unknown
17	9/5/2014	Zero air pump	Werther International	06864	PC70/4	000815261

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2520	CTH110	Eric Hebert	09/05/2014	DAS	Primary

Das Date:	<input type="text" value="9/5/2014"/>	Audit Date:	<input type="text" value="9/5/2014"/>
Das Time:	<input type="text" value="13:00:03"/>	Audit Time:	<input type="text" value="13:00:00"/>
Das Day:	<input type="text" value="248"/>	Audit Day:	<input type="text" value="248"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0003"/>	Max Diff:	<input type="text" value="0.0007"/>
		Avg Diff:	<input type="text" value="0.0003"/>
		Max Diff:	<input type="text" value="0.0007"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/22/2014"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0008	-0.0001	V	V	0.0007
7	0.1000	0.0992	0.0993	V	V	0.0001
7	0.3000	0.2997	0.2996	V	V	-0.0001
7	0.5000	0.4997	0.4995	V	V	-0.0002
7	0.7000	0.6995	0.6993	V	V	-0.0002
7	0.9000	0.8998	0.8994	V	V	-0.0004
7	1.0000	1.0000	0.9995	V	V	-0.0005

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		CTH110	Eric Hebert	09/05/2014	Flow Rate	000559

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.22%	0.67%

Cal Factor Zero	0.007
Cal Factor Full Scale	0.979
Rotometer Reading:	1.55

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.10	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.03	0.000	0.03	l/m	l/m	
primary	test pt 1	1.500	1.500	1.53	0.000	1.50	l/m	l/m	0.00%
primary	test pt 2	1.499	1.500	1.53	0.000	1.50	l/m	l/m	0.00%
primary	test pt 3	1.490	1.490	1.53	0.000	1.50	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347313		CTH110	Eric Hebert	09/05/2014	Ozone	000742

Slope:	0.97108	Slope:	0.00000
Intercept	0.71838	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.5%	2.3%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	0419606966	Tfer Desc.	Ozone primary stan
Tfer ID	01112		
Slope	1.00928	Intercept	0.11780
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.10	-0.01	0.56	ppb	
primary	2	28.84	28.45	28.52	ppb	0.25%
primary	3	52.06	51.46	50.76	ppb	-1.36%
primary	4	80.25	79.39	77.75	ppb	-2.07%
primary	5	109.89	108.76	106.30	ppb	-2.26%

Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.50	Status	pass
Sensor Component	Span	Condition	1.001	Status	pass
Sensor Component	Cell B Freq.	Condition	100.3 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	29.2 C	Status	pass
Sensor Component	Cell A Pressure	Condition	694.9 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	100.6 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	none		CTH110	Eric Hebert	09/05/2014	Temperature	06647

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.11	0.22		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.08	0.31	0.000	0.3	C	-0.04
primary	Temp Mid Range	25.21	25.31	0.000	25.1	C	-0.22
primary	Temp High Range	49.30	49.29	0.000	49.2	C	-0.08

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	CTH110	Eric Hebert	09/05/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.00	1.07		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.99	23.11	0.000	24.0	C	0.93
primary	Temp Mid Range	22.74	22.86	0.000	23.9	C	1
primary	Temp Mid Range	22.28	22.40	0.000	23.5	C	1.07

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2116-6)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	CTH110	Eric Hebert	09/05/2014	Moisture Present	Apex	3262	<input type="checkbox"/>	<input type="checkbox"/>

Although there currently is no moisture in the flow sample train, there is evidence of previous moisture events.

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone inlet filter is changed and the sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

There is a point source north of Ithaca within 40 km of the site. The tree line is less than 50 m from the site. The siting is acceptable even with the noted exceptions.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Mecklenburg"/>
Operating Group	<input type="text" value="IES"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="36-109-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, ammonia"/>	QAPP Latitude	<input type="text" value="42.4010"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-76.6535"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="515"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text" value="12.3"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="12/28/2004"/>
Site Telephone	<input type="text" value="(607) 564-7622"/>	Audit Latitude	<input type="text" value="42.400875"/>
Site Address 1	<input type="text" value="CR 136 (Connecticut Hill Road)"/>	Audit Longitude	<input type="text" value="-76.653516"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="511"/>
County	<input type="text" value="Tompkins"/>	Audit Declination	<input type="text" value="-12.0"/>
City, State	<input type="text" value="Newfield, NY"/>		
Zip Code	<input type="text" value="14867"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2116-6)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input type="checkbox"/>	Notes <input type="text"/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Ithaca take route 13 south to hwy 327. Bear right onto hwy 327 and go past both the lower and upper entrances for Robert Treman St Park. Turn left at the second left past the upper entrance to the park onto Trumbell Corners Road. Continue on Trumbell Corners Rd for approximately one mile to the stop sign. Turn right at the stop onto Connecticut Hill Road and continue for approximately 1/4 mile where it veers to the right. The site is up the hill on the left just after the turn in the road.

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

There is a point source north of Ithaca within 40 km of the site. The tree line is less than 50 m from the site. The siting is acceptable even with the noted exceptions.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|----------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2001	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D630	unknown	000479
DAS	Campbell	CR3000	2520	000420
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	050400022550	04987
Flow Rate	Apex	AXMC105LPMDPC	illegible	000559
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	03442
Modem	Raven	V4221-V	0844349892	06599
Ozone	ThermoElectron Inc	49i A1NAA	1105347313	000742
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200023	000447
Sample Tower	Aluma Tower	B	AT-5107-E-4-10	666363
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	Climatronics	100325	illegible	00917
Siting Criteria	Siting Criteria	1	None	None
Temperature	Climatronics	100093	none	06647
UPS	APC	RS900	unknown	06796
Zero air pump	Werther International	PC70/4	000815261	06864

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>MKG113-Sandy Grenville-09/20/2014</i>						
1	9/20/2014	Computer	Dell	000276	D520	unknown
2	9/20/2014	DAS	Campbell	000404	CR3000	2521
3	9/20/2014	Elevation	Elevation	None	1	None
4	9/20/2014	Filter pack flow pump	Thomas	03639	107CAB18	049400004427
5	9/20/2014	Flow Rate	Apex	000637	AXMC105LPMDPCV	illegible
6	9/20/2014	Infrastructure	Infrastructure	none	none	none
7	9/20/2014	Met tower	Universal Tower	03445	unknown	none
8	9/20/2014	Modem	Raven	06593	V4221-V	0844350394
9	9/20/2014	Ozone	ThermoElectron Inc	000612	49i A1NAA	1009241779
10	9/20/2014	Ozone Standard	ThermoElectron Inc	000374	49i A3NAA	0726124694
11	9/20/2014	Sample Tower	Aluma Tower	666362	B	AT-5107-E-4-11
12	9/20/2014	Shelter Temperature	Campbell	none	107-L	none
13	9/20/2014	Shield (10 meter)	Climatronics	01383	100325	illegible
14	9/20/2014	Siting Criteria	Siting Criteria	None	1	None
15	9/20/2014	Temperature	Climatronics	06706	100093	missing
16	9/20/2014	Zero air pump	Werther International	06937	C 70/4	000821896

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2521	MKG113	Sandy Grenville	09/20/2014	DAS	Primary

Das Date:	<input type="text" value="9 /20/2014"/>	Audit Date	<input type="text" value="9 /20/2014"/>
Das Time:	<input type="text" value="12:49:03"/>	Audit Time	<input type="text" value="12:49:02"/>
Das Day:	<input type="text" value="263"/>	Audit Day	<input type="text" value="263"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.1000	0.0999	V	V	-0.0001
7	0.3000	0.2998	0.2997	V	V	-0.0001
7	0.5000	0.4996	0.4996	V	V	0.0000
7	0.7000	0.6995	0.6995	V	V	0.0000
7	0.9000	0.8994	0.8993	V	V	-0.0001
7	1.0000	0.9993	0.9992	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		MKG113	Sandy Grenville	09/20/2014	Flow Rate	000637

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.66%	0.66%
A Avg %Dif	A Max % Di

Cal Factor Zero	0
Cal Factor Full Scale	1
Rotometer Reading:	1.6

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.02	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	test pt 1	1.538	1.510	1.50	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 2	1.538	1.510	1.50	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 3	1.539	1.510	1.50	0.000	1.50	l/m	l/m	-0.66%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	15 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241779		MKG113	Sandy Grenville	09/20/2014	Ozone	000612

Slope:	1.00307	Slope:	0.00000
Intercept	-0.04993	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.3%	0.6%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.38	0.49	0.47	ppb	
primary	2	30.96	30.93	31.02	ppb	0.29%
primary	3	50.19	50.07	50.19	ppb	0.24%
primary	4	82.55	82.28	82.10	ppb	-0.22%
primary	5	100.20	99.85	100.40	ppb	0.55%

Sensor Component	Cell B Noise	Condition	1.2 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	1.005	Status	pass
Sensor Component	Cell B Freq.	Condition	99.9 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	705.3 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	87.5 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.0 lpm	Status	Fail
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	missing		MKG113	Sandy Grenville	09/20/2014	Temperature	06706

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.09	0.19		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.69	0.84	0.000	0.7	C	-0.19
primary	Temp Mid Range	24.82	24.90	0.000	24.9	C	-0.01
primary	Temp High Range	49.38	49.39	0.000	49.3	C	-0.06

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	MKG113	Sandy Grenville	09/20/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.21	0.47		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	26.90	26.97	0.000	26.5	C	-0.47
primary	Temp Mid Range	24.60	24.68	0.000	24.6	C	-0.06
primary	Temp Mid Range	21.80	21.89	0.000	21.8	C	-0.11

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2116-4)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	MKG113	Sandy Grenville	09/20/2014	Cell A Flow	ThermoElectron	3362	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-------	--------	-----------------	------------	-------------	----------------	------	--------------------------	-------------------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 **Parameter:** ShelterCleanNotes

The shelter is clean and organized. Leak and rot below the air conditioner and on the floor under the counter. Mold beginning on walls and floor.

2 **Parameter:** MetOpMaintCom

The temperature shield forced-air blower has a loose connection and the operation is intermittent.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Hadley"/>
Operating Group	<input type="text" value="PA/private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="42-085-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="41.4250"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-80.1447"/>
Land Use	<input type="text" value="woodland - mixed, agriculture"/>	QAPP Elevation Meters	<input type="text" value="384"/>
Terrain	<input type="text" value="gently rolling"/>	QAPP Declination	<input type="text" value="9.25"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(724) 253-3685"/>	Audit Latitude	<input type="text" value="41.426847"/>
Site Address 1	<input type="text" value="M. K. Goddard St. Park"/>	Audit Longitude	<input type="text" value="-80.145247"/>
Site Address 2	<input type="text" value="684 Lake Wilhelm Rd."/>	Audit Elevation	<input type="text" value="377"/>
County	<input type="text" value="Mercer"/>	Audit Declination	<input type="text" value="-9.3"/>
City, State	<input type="text" value="Sandy Lake, PA"/>		
Zip Code	<input type="text" value="16145"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2116-4)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes	<input type="text" value="The shelter is clean and organized. Leak and rot below the air conditioner and on the floor under the counter. Mold beginning on walls and floor."/>	
Site OK <input checked="" type="checkbox"/>	Notes	<input type="text"/>	
Driving Directions	<input type="text" value="From I-79 take exit 130 (route 358). Go west and bear right onto Sheakleyville Road. Continue less than a mile to the stop sign, and turn right onto Lake Wilhelm Road. Continue approximately 1.5 miles, just after crossing the lake the site will be visible on the right at the state park headquarters facility."/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	1.5 km	<input type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m	60 m	<input type="checkbox"/>
Tree line	50 m	10 - 30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 15 meters
3/8 teflon by 15 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|----------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times of day
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID Technician Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000276
DAS	Campbell	CR3000	2521	000404
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	049400004427	03639
Flow Rate	Apex	AXMC105LPMDPC	illegible	000637
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	03445
Modem	Raven	V4221-V	0844350394	06593
Ozone	ThermoElectron Inc	49i A1NAA	1009241779	000612
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124694	000374
Sample Tower	Aluma Tower	B	AT-5107-E-4-11	666362
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	Climatronics	100325	illegible	01383
Siting Criteria	Siting Criteria	1	None	None
Temperature	Climatronics	100093	missing	06706
Zero air pump	Werther International	C 70/4	000821896	06937

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PSU106-Sandy Grenville-09/23/2014</i>						
1	9/23/2014	Computer	Dell	000268	D520	unknown
2	9/23/2014	DAS	Campbell	000407	CR3000	2512
3	9/23/2014	Elevation	Elevation	None	1	None
4	9/23/2014	Filter pack flow pump	Thomas	06023	107CAB18	060400022676
5	9/23/2014	Flow Rate	Apex	000560	AXMC105LPMDPCV	50732
6	9/23/2014	Infrastructure	Infrastructure	none	none	none
7	9/23/2014	Modem	Raven	06483	V4221-V	0808310813
8	9/23/2014	Ozone	ThermoElectron Inc	000678	49i A1NAA	1030244791
9	9/23/2014	Ozone Standard	ThermoElectron Inc	000219	49i A3NAA	0622717857
10	9/23/2014	Sample Tower	Aluma Tower	02747	A	none
11	9/23/2014	Shelter Temperature	Campbell	none	107-L	none
12	9/23/2014	Siting Criteria	Siting Criteria	None	1	None
13	9/23/2014	Temperature	RM Young	04316	41342VO	4013
14	9/23/2014	Zero air pump	Werther International	06914	C 70/4	000829156

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2512	PSU106	Sandy Grenville	09/23/2014	DAS	Primary

Das Date:	<input type="text" value="9/23/2014"/>	Audit Date	<input type="text" value="9/23/2014"/>
Das Time:	<input type="text" value="17:36:17"/>	Audit Time	<input type="text" value="17:36:16"/>
Das Day:	<input type="text" value="266"/>	Audit Day	<input type="text" value="266"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.2998	0.2997	V	V	-0.0001
7	0.5000	0.4997	0.4996	V	V	-0.0001
7	0.7000	0.6996	0.6995	V	V	-0.0001
7	0.9000	0.8995	0.8993	V	V	-0.0002
7	1.0000	0.9994	0.9993	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	50732		PSU106	Sandy Grenville	09/23/2014	Flow Rate	000560

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.66%	0.66%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.02
Cal Factor Full Scale	0.96
Rotometer Reading:	1.45

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.02	l/m	l/m	
primary	test pt 1	1.539	1.510	1.55	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 2	1.540	1.510	1.55	0.000	1.50	l/m	l/m	-0.66%
primary	test pt 3	1.541	1.510	1.55	0.000	1.50	l/m	l/m	-0.66%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244791		PSU106	Sandy Grenville	09/23/2014	Ozone	000678

Slope:	0.99612	Slope:	0.00000
Intercept	-0.56230	Intercept	0.00000
CorrCoff	0.99986	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.6%	2.5%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.05	0.16	-0.46	ppb	
primary	2	30.65	30.62	29.85	ppb	-2.51%
primary	3	52.82	52.69	51.72	ppb	-1.84%
primary	4	81.14	80.88	81.10	ppb	0.27%
primary	5	101.05	100.70	99.00	ppb	-1.69%

Sensor Component	Cell B Noise	Condition	1.1 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.60	Status	pass
Sensor Component	Span	Condition	0.994	Status	pass
Sensor Component	Cell B Freq.	Condition	104.5 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.9 C	Status	pass
Sensor Component	Cell A Pressure	Condition	709.5 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	106 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4013		PSU106	Sandy Grenville	09/23/2014	Temperature	04316

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.17	0.35		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.05	0.20	0.000	-0.2	C	-0.35
primary	Temp Mid Range	25.50	25.58	0.000	25.5	C	-0.08
primary	Temp High Range	48.20	48.21	0.000	48.3	C	0.09

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	PSU106	Sandy Grenville	09/23/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.14	0.25		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.90	22.99	0.000	23.2	C	0.25
primary	Temp Mid Range	23.86	23.94	0.000	23.9	C	-0.03
primary	Temp Mid Range	23.80	23.88	0.000	24.0	C	0.14

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="PSU"/>	<input type="text" value="N/A"/>	<input type="text" value="3840 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: DasComments

The meteorological tower has been removed.

2 Parameter: SitingCriteriaCom

The site is within 10 km of State College which has a population of approximately 50,000. The site is located in a university agricultural research field.

3 Parameter: ShelterCleanNotes

The shelter is owned by the university and is clean and orderly. The site is part of the Surfrad network.

4 Parameter: MetOpMaintCom

The 10-meter temperature sensor is now mounted in a naturally aspirated shield on the sample tower.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>KEF112-Sandy Grenville-09/23/2014</i>						
1	9/23/2014	Computer	Dell	000256	D520	unknown
2	9/23/2014	DAS	Campbell	000414	CR3000	2537
3	9/23/2014	Elevation	Elevation	None	1	None
4	9/23/2014	Filter pack flow pump	Thomas	000965	107CA18	00000878
5	9/23/2014	Flow Rate	Apex	000671	AXMC105LPM DPCV	illegible
6	9/23/2014	Infrastructure	Infrastructure	none	none	none
7	9/23/2014	Met tower	Universal Tower	06487	unknown	none
8	9/23/2014	Modem	Raven	06455	V4221-V	0808337420
9	9/23/2014	Ozone	ThermoElectron Inc	000700	49i A1NAA	1030244793
10	9/23/2014	Ozone Standard	ThermoElectron Inc	000438	49i A3NAA	CM08200014
11	9/23/2014	Sample Tower	Aluma Tower	03443	A	none
12	9/23/2014	Shelter Temperature	Campbell	none	107-L	none
13	9/23/2014	Shield (10 meter)	RM Young	01399	Aspirated 43408	none
14	9/23/2014	Siting Criteria	Siting Criteria	None	1	None
15	9/23/2014	Temperature	RM Young	06388	41342	13992
16	9/23/2014	Zero air pump	Werther International	06922	C 70/4	000836217

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2537	KEF112	Sandy Grenville	09/23/2014	DAS	Primary

Das Date:	<input type="text" value="9/23/2014"/>	Audit Date	<input type="text" value="9/23/2014"/>
Das Time:	<input type="text" value="11:11:32"/>	Audit Time	<input type="text" value="11:11:32"/>
Das Day:	<input type="text" value="266"/>	Audit Day	<input type="text" value="266"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0004"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0004"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.2997	0.2998	V	V	0.0001
7	0.5000	0.4996	0.4997	V	V	0.0001
7	0.7000	0.6996	0.6997	V	V	0.0001
7	0.9000	0.8999	0.8995	V	V	-0.0004
7	1.0000	0.9993	0.9994	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		KEF112	Sandy Grenville	09/23/2014	Flow Rate	000671

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.54%	1.97%
A Avg %Dif	A Max % Di

Cal Factor Zero	0
Cal Factor Full Scale	0.98
Rotometer Reading:	1.55

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.10	0.000	0.10	l/m	l/m	
primary	test pt 1	1.546	1.520	1.53	0.000	1.50	l/m	l/m	-1.32%
primary	test pt 2	1.542	1.520	1.53	0.000	1.49	l/m	l/m	-1.97%
primary	test pt 3	1.542	1.520	1.53	0.000	1.50	l/m	l/m	-1.32%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	330 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244793		KEF112	Sandy Grenville	09/23/2014	Ozone	000700

Slope:	1.00924	Slope:	0.00000
Intercept	0.71974	Intercept	0.00000
CorrCoff	0.99968	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.5%	8.0%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.04	0.15	-0.29	ppb	
primary	2	31.06	31.03	33.52	ppb	8.02%
primary	3	50.00	49.88	51.51	ppb	3.27%
primary	4	80.54	80.28	81.30	ppb	1.27%
primary	5	99.84	99.49	100.80	ppb	1.32%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.30	Status	pass
Sensor Component	Span	Condition	1.023	Status	pass
Sensor Component	Cell B Freq.	Condition	89.7 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	30.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	696.3 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	94.5 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	13992		KEF112	Sandy Grenville	09/23/2014	Temperature	06388

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.18	0.37		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.38	0.53	0.000	0.2	C	-0.37
primary	Temp Mid Range	25.43	25.51	0.000	25.4	C	-0.13
primary	Temp High Range	47.74	47.75	0.000	47.7	C	-0.03

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	KEF112	Sandy Grenville	09/23/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.41	1.06		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	19.50	19.60	0.000	20.7	C	1.06
primary	Temp Mid Range	19.52	19.61	0.000	19.7	C	0.11
primary	Temp Mid Range	20.66	20.75	0.000	20.8	C	0.06

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-14)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is in a clearing within the Kane Experimental Forest, the tree line is within 10 meters of the site.

3 Parameter: ShelterCleanNotes

The shelter is clean and very well organized. The floor and bottom of walls are beginning to deteriorate.

4 Parameter: PollAnalyzerCom

The MFC was observed to fluctuate from 1.4 to 1.6 lpm. Trees to the east are within 20 meters of the ozone inlet.

5 Parameter: MetSensorComme

The meteorological tower is attached to the shelter and the temperature sensor is positioned directly over the metal roof of the shelter.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map
 Operating Group Map Scale
 AQS # Map Date

Meteorological Type
 Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude
 Land Use QAPP Elevation Meters

Terrain QAPP Declination
 Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude
 Site Address 1 Audit Longitude

Site Address 2 Audit Elevation
 County Audit Declination

City, State Present
 Zip Code Fire Extinguisher

Time Zone First Aid Kit
 Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat
 Primary Op. E-mail Climbing Belt

Backup Operator Security Fence
 Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step
 Shelter Working Room Make Model Shelter Size

Shelter Clean Notes
 Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	State College	<input type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	10 m	<input type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is within 10 km of State College which has a population of approximately 50,000. The site is located in a university agricultural research field.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID PSU106

Technician Sandy Grenville

Site Visit Date 09/23/2014

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 20 meters
3/8 teflon by 20 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID PSU106

Technician Sandy Grenville

Site Visit Date 09/23/2014

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|---|-------------------|-----------------|--------------------------|--------------------------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 10 | Is the sample tower stable and grounded? | | | | | | | | |
| 11 | Tower comments? | | Met tower removed | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower has been removed.

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	gloves are not used
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID PSU106

Technician Sandy Grenville

Site Visit Date 09/23/2014

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000268
DAS	Campbell	CR3000	2512	000407
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	060400022676	06023
Flow Rate	Apex	AXMC105LPMDPC	50732	000560
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0808310813	06483
Ozone	ThermoElectron Inc	49i A1NAA	1030244791	000678
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717857	000219
Sample Tower	Aluma Tower	A	none	02747
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	4013	04316
Zero air pump	Werther International	C 70/4	000829156	06914

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="James City"/>
Operating Group	<input type="text" value="PAFS/private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="42-047-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="41.5981"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-78.7683"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="622"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text" value="10.5"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="2/24/2006"/>
Site Telephone	<input type="text" value="(814) 837-8069"/>	Audit Latitude	<input type="text" value="41.598119"/>
Site Address 1	<input type="text" value="Kane Experimental Forest Hdqts"/>	Audit Longitude	<input type="text" value="-78.767866"/>
Site Address 2	<input type="text" value="Seven Mile Road"/>	Audit Elevation	<input type="text" value="618"/>
County	<input type="text" value="Elk"/>	Audit Declination	<input type="text" value="-10.3"/>
City, State	<input type="text" value="Kane, PA"/>		
Zip Code	<input type="text" value="16735"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	10 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|--|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input type="checkbox"/> | Temperature sensor mounted over shelter roof |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower is attached to the shelter and the temperature sensor is positioned directly over the metal roof of the shelter.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	N/A
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 15 meters
3/8 teflon by 12 meters
At inlet only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The MFC was observed to fluctuate from 1.4 to 1.6 lpm. Trees to the east are within 20 meters of the ozone inlet.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|--|-------------------------|-----------------|--------------------------|--------------------------|-------------------------------------|--------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| 10 | Is the sample tower stable and grounded? | | | | | | | | |
| 11 | Tower comments? | | Towers are not grounded | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Oct 2011	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings 90% of the time
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000256
DAS	Campbell	CR3000	2537	000414
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	00000878	000965
Flow Rate	Apex	AXMC105LPMDPC	illegible	000671
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	06487
Modem	Raven	V4221-V	0808337420	06455
Ozone	ThermoElectron Inc	49i A1NAA	1030244793	000700
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200014	000438
Sample Tower	Aluma Tower	A	none	03443
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	RM Young	Aspirated 43408	none	01399
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	13992	06388
Zero air pump	Werther International	C 70/4	000836217	06922

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>ARE128-Sandy Grenville-09/25/2014</i>						
1	9/25/2014	Computer	Dell	000244	D520	67FNHB1
2	9/25/2014	DAS	Campbell	000400	CR3000	2524
3	9/25/2014	Elevation	Elevation	None	1	None
4	9/25/2014	Filter pack flow pump	Thomas	02661	107CA110	000012187C
5	9/25/2014	Flow Rate	Apex	000462	AXMC105LPMDPCV	42228
6	9/25/2014	Infrastructure	Infrastructure	none	none	none
7	9/25/2014	Met tower	Universal Tower	03505	unknown	none
8	9/25/2014	Modem	Raven	06809	V4221-V	093644408
9	9/25/2014	Ozone	ThermoElectron Inc	000609	49i A1NAA	1009241782
10	9/25/2014	Ozone Standard	ThermoElectron Inc	000199	49i A3NAA	0607315737
11	9/25/2014	Sample Tower	Aluma Tower	666361	B	none
12	9/25/2014	Shelter Temperature	Campbell	none	107-L	none
13	9/25/2014	Shield (10 meter)	Climatronics	01167	100325	1272
14	9/25/2014	Siting Criteria	Siting Criteria	None	1	None
15	9/25/2014	Temperature	Climatronics	06678	100093	missing
16	9/25/2014	Zero air pump	Werther International	06866	PC70/4	000815262

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2524	ARE128	Sandy Grenville	09/25/2014	DAS	Primary

Das Date:	<input type="text" value="9/25/2014"/>	Audit Date	<input type="text" value="9/25/2014"/>
Das Time:	<input type="text" value="15:28:25"/>	Audit Time	<input type="text" value="15:28:26"/>
Das Day:	<input type="text" value="268"/>	Audit Day	<input type="text" value="268"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0000"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0000"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="12/28/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2997	0.2997	V	V	0.0000
7	0.5000	0.4996	0.4996	V	V	0.0000
7	0.7000	0.6995	0.6995	V	V	0.0000
7	0.9000	0.8994	0.8993	V	V	-0.0001
7	1.0000	0.9993	0.9992	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	42228		ARE128	Sandy Grenville	09/25/2014	Flow Rate	000462

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	1.00846	Intercept	0.01358
Cert Date	1/8/2014	CorrCoff	0.99997

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.22%	0.67%
A Avg %Dif	A Max % Di

Cal Factor Zero	0.04
Cal Factor Full Scale	1.02
Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.10	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.05	0.000	-0.02	l/m	l/m	
primary	test pt 1	1.525	1.500	1.49	0.000	1.51	l/m	l/m	0.67%
primary	test pt 2	1.522	1.500	1.49	0.000	1.50	l/m	l/m	0.00%
primary	test pt 3	1.528	1.500	1.49	0.000	1.50	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	2.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	250 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241782		ARE128	Sandy Grenville	09/25/2014	Ozone	000609

Slope:	0.99159	Slope:	0.00000
Intercept	0.17333	Intercept	0.00000
CorrCoff	0.99995	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.0%	1.8%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.05	0.16	-0.03	ppb	
primary	2	31.26	31.23	31.78	ppb	1.76%
primary	3	51.05	50.93	50.50	ppb	-0.84%
primary	4	80.17	79.91	79.44	ppb	-0.59%
primary	5	101.56	101.21	100.40	ppb	-0.80%

Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	0.999	Status	pass
Sensor Component	Cell B Freq.	Condition	106.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.75 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	31.9 C	Status	pass
Sensor Component	Cell A Pressure	Condition	716 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	97.0 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	missing		ARE128	Sandy Grenville	09/25/2014	Temperature	06678

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.19	0.24		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.50	0.65	0.000	0.5	C	-0.14
primary	Temp Mid Range	25.66	25.74	0.000	25.6	C	-0.18
primary	Temp High Range	49.67	49.68	0.000	49.4	C	-0.24

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ARE128	Sandy Grenville	09/25/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.51	0.65		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00288	Intercept	-0.15155
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.78	22.87	0.000	22.3	C	-0.54
primary	Temp Mid Range	22.94	23.03	0.000	22.7	C	-0.35
primary	Temp Mid Range	25.92	26.00	0.000	25.4	C	-0.65

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2116-7)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: DasComments

The meteorological tower is grounded but the lightning rod has been removed. The sample tower is not grounded.

2 Parameter: SitingCriteriaCom

The site is located in an active orchard where spraying occurs. Fruit trees are rotated with corn and other crops.

3 Parameter: MetOpMaintCom

The 10-meter temperature sensor is being operated and maintained on the meteorological tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Arendtsville"/>
Operating Group	<input type="text" value="PSU/private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="42-001-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMROVE"/>	QAPP Latitude	<input type="text" value="39.9231"/>
Deposition Measurement	<input type="text" value="dry, wet, Hg, PM"/>	QAPP Longitude	<input type="text" value="-77.3078"/>
Land Use	<input type="text" value="agriculture"/>	QAPP Elevation Meters	<input type="text" value="269"/>
Terrain	<input type="text" value="complex - rolling"/>	QAPP Declination	<input type="text" value="10.9"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(717) 677-9866"/>	Audit Latitude	<input type="text" value="39.923241"/>
Site Address 1	<input type="text" value="PSU Fruit Research Orchard"/>	Audit Longitude	<input type="text" value="-77.307863"/>
Site Address 2	<input type="text" value="Winding Road"/>	Audit Elevation	<input type="text" value="266"/>
County	<input type="text" value="Adams"/>	Audit Declination	<input type="text" value="-11"/>
City, State	<input type="text" value="Arendtsville, PA"/>		
Zip Code	<input type="text" value="17307"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2116-7)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Gettysburg take route 34 north to Biglerville. At the intersection of 34 and 234 turn left (west) to Arendtsville. Continue into the town of Arendtsville. At the stop sign next to the gas station, turn left and immediately turn right, onto Chambersburg Street. Continue approximately 0.4 miles and turn right onto Winding Road. There is a sign for Boyer Nursery & Orchard. The site will be visible at the top of the hill in the orchard on the right.

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text" value="20 m"/>	<input type="checkbox"/>
Limited agricultural operations	200 m	<input type="text" value="20 m"/>	<input type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Moisture in tubing only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input checked="" type="checkbox"/>					
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input checked="" type="checkbox"/>					
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input checked="" type="checkbox"/>	Met sensors only				
4	Are the signal connections protected from the weather and well maintained?	<input checked="" type="checkbox"/>					
5	Are the signal leads connected to the correct DAS channel?	<input checked="" type="checkbox"/>					
6	Are the DAS, sensor translators, and shelter properly grounded?	<input checked="" type="checkbox"/>					
7	Does the instrument shelter have a stable power source?	<input checked="" type="checkbox"/>					
8	Is the instrument shelter temperature controlled?	<input checked="" type="checkbox"/>					
9	Is the met tower stable and grounded?	<table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table>	Stable	Grounded	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Stable	Grounded						
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>						
10	Is the sample tower stable and grounded?	<table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table>	Stable	Grounded	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Stable	Grounded						
<input checked="" type="checkbox"/>	<input type="checkbox"/>						
11	Tower comments?		Met tower grounded but lightning rod removed, sample tower not grounded				

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2010	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Oct 2010	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	Gloves not consistently used
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	67FNHB1	000244
DAS	Campbell	CR3000	2524	000400
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA110	000012187C	02661
Flow Rate	Apex	AXMC105LPMDPC	42228	000462
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	03505
Modem	Raven	V4221-V	093644408	06809
Ozone	ThermoElectron Inc	49i A1NAA	1009241782	000609
Ozone Standard	ThermoElectron Inc	49i A3NAA	0607315737	000199
Sample Tower	Aluma Tower	B	none	666361
Shelter Temperature	Campbell	107-L	none	none
Shield (10 meter)	Climatronics	100325	1272	01167
Siting Criteria	Siting Criteria	1	None	None
Temperature	Climatronics	100093	missing	06678
Zero air pump	Werther International	PC70/4	000815262	06866

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CAT175-Eric Hebert-09/26/2014

1	9/26/2014	Computer	Dell	000275	D520	unknown
2	9/26/2014	DAS	Campbell	000412	CR3000	2532
3	9/26/2014	Elevation	Elevation	None	1	None
4	9/26/2014	Filter pack flow pump	Brailsford	none	TD-4X2N	none
5	9/26/2014	Flow Rate	Apex	000644	AXMC105LPMDPCV	illegible
6	9/26/2014	Infrastructure	Infrastructure	none	none	none
7	9/26/2014	Met tower	Universal Tower	02742	unknown	none
8	9/26/2014	Modem	Raven	06660	V4221-V	0918425101
9	9/26/2014	Sample Tower	Aluma Tower	666359	B	none
10	9/26/2014	Shield (10 meter)	RM Young	none	41003	none
11	9/26/2014	Siting Criteria	Siting Criteria	None	1	None
12	9/26/2014	Temperature	RM Young	06409	41342VO	14042
13	9/26/2014	UPS	ProSine	04576	1000w	unknown

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		CAT175	Eric Hebert	09/26/2014	Flow Rate	000644

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0
3.21%	3.21%	Rotometer Reading:	1.55

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	-0.03	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.000	0.02	l/m	l/m	
primary	test pt 1	1.556	1.560	1.50	0.000	1.51	l/m	l/m	-3.21%
primary	test pt 2	1.560	1.560	1.50	0.000	1.51	l/m	l/m	-3.21%
primary	test pt 3	1.564	1.560	1.50	0.000	1.51	l/m	l/m	-3.21%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	-0.5 cm	Status	Fail
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14042		CAT175	Eric Hebert	09/26/2014	Temperature	06409

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.06	0.11		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	-0.07	0.16	0.000	0.2	C	0.01
primary	Temp Mid Range	24.98	25.09	0.000	25.0	C	-0.11
primary	Temp High Range	47.52	47.51	0.000	47.5	C	-0.06

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 1977-1)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Flow Rate	CAT175	Eric Hebert	09/26/2014	Filter Position	Apex	4212	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-----------	--------	-------------	------------	-----------------	------	------	--------------------------	-------------------------------------

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator was not available to meet with the auditor during the audit visit due to a personal family matter. Audit information was obtained from review of the site documentation.

2 **Parameter:** DasComments

The shelter is not temperature controlled. The site is solar and DC battery powered.

3 **Parameter:** ShelterCleanNotes

The shelter is neat and clean. The vegetation has been allowed to grow. The shelter roof has been repaired.

4 **Parameter:** PollAnalyzerCom

Ozone monitoring is no longer being conducted at the site.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Claryville"/>
Operating Group	<input type="text" value="private"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="41.9423"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-74.5519"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="765"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="13.5"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(845) 798-0947"/>	Audit Latitude	<input type="text" value="41.942325"/>
Site Address 1	<input type="text" value="Wildcat Mt. Road"/>	Audit Longitude	<input type="text" value="-74.551999"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="754"/>
County	<input type="text" value="Ulster"/>	Audit Declination	<input type="text" value="-13.2"/>
City, State	<input type="text" value="Claryville, NY"/>		
Zip Code	<input type="text" value="12725"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	Natural aspiration
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

Ozone not measured
N/A
3/8 teflon by 18 meters
N/A
N/A
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|------------------------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input type="checkbox"/> | Solar power | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input type="checkbox"/> | Shelter not temperature controlled | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The shelter is not temperature controlled. The site is solar and DC battery powered.

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2001	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	N/A	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input type="checkbox"/>	
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, e-mail
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/> Not performed	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was not available to meet with the auditor during the audit visit due to a personal family matter. Audit information was obtained from review of the site documentation.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000275
DAS	Campbell	CR3000	2532	000412
Elevation	Elevation	1	None	None
Filter pack flow pump	Brailsford	TD-4X2N	none	none
Flow Rate	Apex	AXMC105LPMDPC	illegible	000644
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	02742
Modem	Raven	V4221-V	0918425101	06660
Sample Tower	Aluma Tower	B	none	666359
Shield (10 meter)	RM Young	41003	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	14042	06409
UPS	ProSine	1000w	unknown	04576

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>HWF187-Eric Hebert-09/30/2014</i>						
1	9/30/2014	Computer	Dell	000290	D520	unknown
2	9/30/2014	DAS	Campbell	000356	CR3000	2134
3	9/30/2014	Elevation	Elevation	None	1	None
4	9/30/2014	Filter pack flow pump	Thomas	02358	illegible	illegible
5	9/30/2014	Flow Rate	Apex	000592	AXMC105LPM DPCV	illegible
6	9/30/2014	Infrastructure	Infrastructure	none	none	none
7	9/30/2014	Met tower	Universal Tower	03579	unknown	none
8	9/30/2014	Modem	Raven	06807	H4223-C	0934393748
9	9/30/2014	Ozone	ThermoElectron Inc	000681	49i A1NAA	1030244790
10	9/30/2014	Ozone Standard	ThermoElectron Inc	000445	49i A3NAA	CM08200021
11	9/30/2014	Sample Tower	Aluma Tower	illegible	B	AT-5107-E-4-12
12	9/30/2014	Shelter Temperature	Campbell	none	107-L	unknown
13	9/30/2014	Shield (10 meter)	RM Young	04676	Aspirated 43408	none
14	9/30/2014	Siting Criteria	Siting Criteria	None	1	None
15	9/30/2014	Temperature	RM Young	06401	41342VO	14034
16	9/30/2014	Zero air pump	Teledyne	000775	701H	611

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2134	HWF187	Eric Hebert	09/30/2014	DAS	Primary

Das Date:	<input type="text" value="10/1 /2014"/>	Audit Date	<input type="text" value="10/1 /2014"/>
Das Time:	<input type="text" value="9:00:15"/>	Audit Time	<input type="text" value="9:00:00"/>
Das Day:	<input type="text" value="274"/>	Audit Day	<input type="text" value="274"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0002"/>	Max Diff:	<input type="text" value="0.0004"/>
		Avg Diff:	<input type="text" value="0.0002"/>
		Max Diff:	<input type="text" value="0.0004"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="86590148"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01310"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/22/2014"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0004	0.0000	V	V	0.0004
7	0.1000	0.0997	0.0997	V	V	0.0000
7	0.2000	0.1996	0.1995	V	V	-0.0001
7	0.5000	0.4994	0.4995	V	V	0.0001
7	0.7000	0.6999	0.6997	V	V	-0.0002
7	0.9000	0.8995	0.8994	V	V	-0.0001
7	1.0000	1.0003	1.0005	V	V	0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		HWF187	Eric Hebert	09/30/2014	Flow Rate	000592

Mfg	BIOS	Parameter	Flow Rate
Serial Number	131818	Tfer Desc.	BIOS 220-H
Tfer ID	01417		
Slope	1.00000	Intercept	0.00000
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.12%	1.35%

Cal Factor Zero	0.01
Cal Factor Full Scale	0.99
Rotometer Reading:	1.55

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	test pt 1	1.483	1.480	1.52	0.000	1.50	l/m	l/m	1.35%
primary	test pt 2	1.485	1.480	1.51	0.000	1.50	l/m	l/m	1.35%
primary	test pt 3	1.492	1.490	1.52	0.000	1.50	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	6.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Tag Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244790	HWF187	Eric Hebert	09/30/2014	Ozone	000681

Slope:	0.97152	Slope:	0.00000
Intercept	-0.17924	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	0419606966	Tfer Desc.	Ozone primary stan
Tfer ID	01112		
Slope	1.00928	Intercept	0.11780
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.2%	3.4%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.20	-0.31	-0.50	ppb	
primary	2	26.78	26.41	25.55	ppb	-3.26%
primary	3	47.59	47.03	45.44	ppb	-3.38%
primary	4	77.75	76.91	74.56	ppb	-3.06%
primary	5	107.83	106.72	103.50	ppb	-3.02%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.006	Status	pass
Sensor Component	Cell B Freq.	Condition	90.4 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.9 C	Status	pass
Sensor Component	Cell A Pressure	Condition	692.5 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	89.7 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.32 lpm	Status	Fail
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14034		HWF187	Eric Hebert	09/30/2014	Temperature	06401

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.14	0.29		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	-0.02	0.21	0.000	0.3	C	0.06
primary	Temp Mid Range	24.57	24.68	0.000	24.6	C	-0.06
primary	Temp High Range	47.90	47.89	0.000	48.2	C	0.29

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	unknown	HWF187	Eric Hebert	09/30/2014	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.28	0.36		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00496	Intercept	-0.23009
Cert Date	1/8/2014	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.40	22.52	0.000	22.9	C	0.36
primary	Temp Mid Range	22.02	22.14	0.000	22.4	C	0.21

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="ESF"/>	<input type="text" value="none"/>	<input type="text" value="1630 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	HWF187	Eric Hebert	09/30/2014	Moisture Present	Apex	4026	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								
Ozone	HWF187	Eric Hebert	09/30/2014	Cell A Flow	ThermoElectron	3368	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone inlet filter is replaced and the sample train is leak tested every other week.

2 **Parameter:** ShelterCleanNotes

The shelter is in good condition.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Newcomb"/>
Operating Group	<input type="text" value="SUNY/ESF"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="36-031-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, Hg"/>	QAPP Latitude	<input type="text" value="43.9732"/>
Deposition Measurement	<input type="text" value="dry, wet, Hg"/>	QAPP Longitude	<input type="text" value="-74.2232"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="502"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="14.5"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="6/17/2004"/>
Site Telephone	<input type="text" value="(518) 582-4800"/>	Audit Latitude	<input type="text" value="43.973044"/>
Site Address 1	<input type="text" value="Adirondack Ecological Center"/>	Audit Longitude	<input type="text" value="-74.223317"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="497"/>
County	<input type="text" value="Essex"/>	Audit Declination	<input type="text" value="-14"/>
City, State	<input type="text" value="Newcomb, NY"/>		
Zip Code	<input type="text" value="12852"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Oct 2014"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="ESF"/>	Model <input type="text" value="none"/>	Shelter Size <input type="text" value="1630 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in good condition."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	20 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Moisture in tubing only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Nov 2009	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	000290
DAS	Campbell	CR3000	2134	000356
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	illegible	illegible	02358
Flow Rate	Apex	AXMC105LPMDPC	illegible	000592
Infrastructure	Infrastructure	none	none	none
Met tower	Universal Tower	unknown	none	03579
Modem	Raven	H4223-C	0934393748	06807
Ozone	ThermoElectron Inc	49i A1NAA	1030244790	000681
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200021	000445
Sample Tower	Aluma Tower	B	AT-5107-E-4-12	illegible
Shelter Temperature	Campbell	107-L	unknown	none
Shield (10 meter)	RM Young	Aspirated 43408	none	04676
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	14034	06401
Zero air pump	Teledyne	701H	611	000775

APPENDIX B

CASTNET Site Spot Report Forms

EEMS Spot Report

Data Compiled: 1/23/2015 12:39:32 PM

SiteVisitDate	Site	Technician
07/22/2014	ALH157	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99162	unitless	P
2	Ozone Intercept	P	0	5	4	0.55984	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
4	Ozone % difference avg	P	7	10	4	1.0	%	P
5	Ozone % difference max	P	7	10	4	3.0	%	P

EEMS Spot Report

Data Compiled: 5/10/2016 9:43:24 AM

Site Visit Date Site Technician

08/19/2014 ANA115 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.20	c	P
2	Temperature max error	P	4	0.5	9	0.28	c	P
3	Ozone Slope	P	0	1.1	4	0.80101	unitless	Fail
4	Ozone Intercept	P	0	5	4	2.22814	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	16.0	%	Fail
7	Ozone % difference max	P	7	10	4	17.9	%	Fail
8	Flow Rate average % difference	P	10	5	2	2.04	%	P
9	Flow Rate max % difference	P	10	5	2	2.04	%	P
10	DAS Time maximum error	P	0	5	1	0.05	min	P
11	DAS Voltage average error	P	7	0.003	7	0.0000	V	P

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** System Memo **CommentCode** 81

There is no plastic bag for the installed filter. The operator uses the received bag for the installed filter to ship the removed filter to the lab.

- 2 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 72

The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm

Gloves were not used to change the filter. It was observed that the dry deposition filter was replaced while the sample pump was running with the sample tower lowered. The filter was changed during a rain storm and water entered the filter and sample lines (flow and ozone). The filter can be exposed and sampling from ground level for up to 30 minutes if the ozone leak check is also performed.

- 2 **Parameter:** DasComments

The air conditioner thermostat control is by-passed and the air conditioner is running continuously.

- 3 **Parameter:** SitingCriteriaCom

Site is confined within a fenced area that is somewhat small. There is available space adjacent to the fenced area that could be utilized to improve the instrument siting.

- 4 **Parameter:** ShelterCleanNotes

The shelter is well organized and in fair condition.

- 5 **Parameter:** PollAnalyzerCom

Moisture is present in the flow tubing outside of the shelter.

EEMS Spot Report

Data Compiled: 1/23/2015 1:10:27 PM

Site Visit Date Site Technician

09/24/2014 ANA115 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97366	unitless	P
2	Ozone Intercept	P	0	5	4	0.48989	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.6	%	P
5	Ozone % difference max	P	7	10	4	2.4	%	P

EEMS Spot Report

Data Compiled: 5/10/2016 5:35:03 PM

Site Visit Date	Site	Technician
09/25/2014	ARE128	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.19	c	P
2	Temperature max error	P	4	0.5	9	0.24	c	P
3	Ozone Slope	P	0	1.1	4	0.99159	unitless	P
4	Ozone Intercept	P	0	5	4	0.17333	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
6	Ozone % difference avg	P	7	10	4	1.0	%	P
7	Ozone % difference max	P	7	10	4	1.8	%	P
8	Flow Rate average % difference	P	10	5	4	0.22	%	P
9	Flow Rate max % difference	P	10	5	4	0.67	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0000	V	P

Field Systems Comments

1 Parameter: DasComments

The meteorological tower is grounded but the lightning rod has been removed. The sample tower is not grounded.

2 Parameter: SitingCriteriaCom

The site is located in an active orchard where spraying occurs. Fruit trees are rotated with corn and other crops.

3 Parameter: MetOpMaintCom

The 10-meter temperature sensor is being operated and maintained on the meteorological tower.

EEMS Spot Report

Data Compiled: 1/23/2015 12:34:36 PM

SiteVisitDate	Site	Technician
07/17/2014	BAS601	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96978	unitless	P
2	Ozone Intercept	P	0	5	4	0.45325	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	2.0	%	P
5	Ozone % difference max	P	7	10	4	2.9	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 1/23/2015 1:08:34 PM

Site Visit Date Site Technician

09/20/2014 BVL130 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96651	unitless	P
2	Ozone Intercept	P	0	5	4	0.76544	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	2.0	%	P
5	Ozone % difference max	P	7	10	4	2.7	%	P

EEMS Spot Report

Data Compiled: 5/11/2016 6:12:47 PM

SiteVisitDate	Site	Technician
09/26/2014	CAT175	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.06	c	P
2	Temperature max error	P	4	0.5	12	0.11	c	P
3	Flow Rate average % difference	P	10	5	2	3.21	%	P
4	Flow Rate max % difference	P	10	5	2	3.21	%	P

Field Performance Comments

1 **Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode** 71

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator was not available to meet with the auditor during the audit visit due to a personal family matter. Audit information was obtained from review of the site documentation.

2 **Parameter:** DasComments

The shelter is not temperature controlled. The site is solar and DC battery powered.

3 **Parameter:** ShelterCleanNotes

The shelter is neat and clean. The vegetation has been allowed to grow. The shelter roof has been repaired.

4 **Parameter:** PollAnalyzerCom

Ozone monitoring is no longer being conducted at the site.

EEMS Spot Report

Data Compiled: 2/9/2015 12:25:52 PM

Site Visit Date Site Technician

08/23/2014 CNT169 Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99705	unitless	P
2	Ozone Intercept	P	0	5	4	-1.82502	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	3.8	%	P
5	Ozone % difference max	P	7	10	4	6.3	%	P

EEMS Spot Report

Data Compiled: 5/10/2016 5:06:26 PM

Site Visit Date Site Technician

09/05/2014 CTH110 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.11	c	P
2	Temperature max error	P	4	0.5	9	0.22	c	P
3	Ozone Slope	P	0	1.1	4	0.97108	unitless	P
4	Ozone Intercept	P	0	5	4	0.71838	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.5	%	P
7	Ozone % difference max	P	7	10	4	2.3	%	P
8	Flow Rate average % difference	P	10	5	4	0.22	%	P
9	Flow Rate max % difference	P	10	5	4	0.67	%	P
10	DAS Time maximum error	P	0	5	1	0.05	min	P
11	DAS Voltage average error	P	7	0.003	35	0.0003	V	P

Field Performance Comments

1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 70

Although there currently is no moisture in the flow sample train, there is evidence of previous moisture events.

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone inlet filter is changed and the sample train is leak tested every two weeks.

2 **Parameter:** SitingCriteriaCom

There is a point source north of Ithaca within 40 km of the site. The tree line is less than 50 m from the site. The siting is acceptable even with the noted exceptions.

EEMS Spot Report

Data Compiled: 7/31/2015 8:15:06 PM

Site Visit Date Site

Technician

07/15/2014 DIN431

Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.44	c	P
2	Temperature max error	P	4	0.5	3	0.54	c	Fail
3	Ozone Slope	P	0	1.1	4	0.99366	unitless	P
4	Ozone Intercept	P	0	5	4	0.33934	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99996	unitless	P
6	Ozone % difference avg	P	7	10	4	0.9	%	P
7	Ozone % difference max	P	7	10	4	2.4	%	P
8	Flow Rate average % difference	P	9	5	8	0.24	%	P
9	Flow Rate max % difference	P	9	5	8	0.28	%	P
10	DAS Time maximum error	P	0	5	1	1.25	min	P
11	DAS Voltage average error	P	9	0.003	42	0.0002	V	P
12	DAS Voltage average error	P	2	0.003	42	0.0002	V	P
13	Shelter Temperature average error	P	5	1	3	0.23	c	P
14	Shelter Temperature max error	P	5	1	3	0.49	c	P

Field Performance Comments

- 1 **Parameter:** Temperature **SensorComponent:** System Memo **CommentCode** 141
The temperature sensor is mounted directly above the shelter roof.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm
The site operator was observed to lower the sample tower and replace the filter pack with the sample pump running and the channel marked as valid. Although gloves were used to handle the filter, they were kept in a pants pocket until needed and many items were touched between handling the filters. The operator was not completely familiar with the CASTNET procedures.
- 2 **Parameter:** DasComments
All sensors, filter pack, and ozone sample inlet are on a single, crank-down tower.
- 3 **Parameter:** SiteOpsProcedures
The site operator is not responsible for manual zero/span/precision checks of the ozone analyzer.
- 4 **Parameter:** DocumentationCo
There is very little documentation of onsite activities. No manual entries in Dataview. The COC section of the SSRF is not being used.
- 5 **Parameter:** SitingCriteriaCom
A small parking lot for park service employees is located approximately 40 meters north of the site.
- 6 **Parameter:** ShelterCleanNotes
The shelter is in good condition, clean, and well organized.
- 7 **Parameter:** MetSensorComme
The ambient temperature sensor is mounted approximately 8 meters from the ground and above the shelter roof.

EEMS Spot Report

Data Compiled: 5/10/2016 4:26:35 PM

Site Visit Date Site Technician

08/28/2014 EGB181 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.06	c	P
2	Temperature max error	P	4	0.5	9	0.08	c	P
3	Flow Rate average % difference	P	10	5	3	2.41	%	P
4	Flow Rate max % difference	P	10	5	3	2.63	%	P
5	DAS Time maximum error	P	0	5	1	1.33	min	P
6	DAS Voltage average error	P	7	0.003	21	0.0002	V	P

Field Systems Comments

1 Parameter: SiteOpsProcComm

Filters are sent 4 at a time and stored in a refrigerator before and after sampling prior to shipment to the lab.

2 Parameter: DasComments

The sample tower is badly damaged at the hinge point and should be replaced.

3 Parameter: DocumentationCo

The site operator no longer uses the station logbook during routine site visits.

4 Parameter: ShelterCleanNotes

The shelter is provided by the Center for Atmospheric Research and is clean, organized, and spacious.

5 Parameter: PollAnalyzerCom

Ozone concentration is not measured at EGB181 as part of CASTNET.

EEMS Spot Report

Data Compiled: 5/10/2016 3:29:09 PM

Site Visit Date Site Technician

07/21/2014 FOR605 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.07	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.17	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	4	0.6	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	4	1.3	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.00	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.0	g-cm	P
7	Wind Direction Input Deg True average error (de	P	2	5	8	3.5	degrees	P
8	Wind Direction Input Deg True max error (deg)	P	2	5	8	5	degrees	P
9	Temperature average error	P	4	0.5	3	0.67	c	Fail
10	Temperature max error	P	4	0.5	3	1.45	c	Fail
11	Relative Humidity average above 85%	P	6	10	1	6.5	%	P
12	Relative Humidity max above 85%	P	6	10	1	6.5	%	P
13	Relative Humidity average below 85%	P	6	10	2	3.5	%	P
14	Relative Humidity max below 85%	P	6	10	2	4.7	%	P
15	Solar Radiation % diff of avg	P	9	10	2	2.29	%	P
16	Solar Radiation % diff of max STD value	P	9	10	2	1.7	%	P
17	Precipitation average % difference	P	1	10	2	9.7	%	P
18	Precipitation max % difference	P	1	10	2	10.3	%	Fail
19	Flow Rate average % difference	P	10	5	2	6.56	%	Fail
20	Flow Rate max % difference	P	10	5	2	6.82	%	Fail

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** System Memo **CommentCode** 174
Additional details can be found in the hardcopy of the site audit report.
- Parameter:** Temperature **SensorComponent:** System Memo **CommentCode** 174
Additional details can be found in the hardcopy of the site audit report.

Field Systems Comments

- Parameter:** SiteOpsProcComm
The dry deposition sample height is approximately 6 meters and not 10 meters.
- Parameter:** DocumentationCo
There is no documentation available at the site since there is no place to store documents. The site does not have a computer or shelter other than the small enclosure. The site operator completes a site checklist which remains in his vehicle. Information from the checklist is later filed at his office.
- Parameter:** SitingCriteriaCom
The site is located in a wellfield with oil and gas operations nearby.
- Parameter:** ShelterCleanNotes
This is a small footprint site with instruments mounted in enclosure on tripod tower.
- Parameter:** MetOpMaintCom
The temperature and relative humidity sensor is a combination sensor which cannot be submersed making it difficult to audit throughout a range of temperatures.

EEMS Spot Report

Data Compiled: 2/9/2015 11:17:01 AM

Site Visit Date	Site	Technician
08/23/2014	GLR468	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98527	unitless	P
2	Ozone Intercept	P	0	5	4	0.12602	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	1.4	%	P
5	Ozone % difference max	P	7	10	4	1.7	%	P

EEMS Spot Report

Data Compiled: 2/9/2015 12:10:28 PM

Site Visit Date	Site	Technician
08/21/2014	GTH161	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.95395	unitless	P
2	Ozone Intercept	P	0	5	4	-0.665	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99984	unitless	P
4	Ozone % difference avg	P	7	10	4	5.3	%	P
5	Ozone % difference max	P	7	10	4	6.3	%	P

EEMS Spot Report

Data Compiled: 5/10/2016 9:46:36 AM

Site Visit Date Site Technician

08/25/2014 HOX148 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.11	c	P
2	Temperature max error	P	4	0.5	6	0.18	c	P
3	Ozone Slope	P	0	1.1	4	0.97404	unitless	P
4	Ozone Intercept	P	0	5	4	1.20525	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	1.4	%	P
7	Ozone % difference max	P	7	10	4	2.2	%	P
8	Flow Rate average % difference	P	10	5	4	0.67	%	P
9	Flow Rate max % difference	P	10	5	4	0.67	%	P
10	DAS Time maximum error	P	0	5	1	0.75	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0001	V	P

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 70
Although there currently is no moisture in the flow sample train, there is evidence of previous moisture events.
- Parameter:** Shelter Temperatur **SensorComponent:** System Memo **CommentCode** 215
The shelter thermostat for cooling has been bypassed and the air conditioning system is no longer being controlled by the shelter thermostat.

Field Systems Comments

- Parameter:** SiteOpsProcedures
The ozone analyzer sample train is leak-checked every two weeks.
- Parameter:** SitingCriteriaCom
There is a co-generating and smelting facility in Cadillac approximately 30 km to the northeast. The site is located in a hay field which is cut 2 or 3 times per year.
- Parameter:** ShelterCleanNotes
The shelter is clean, neat, well organized.
- Parameter:** MetSensorComme
Met tower and 10 meter temperature operating and audited.

EEMS Spot Report

Data Compiled: 5/11/2016 5:25:56 PM

Site Visit Date Site Technician

09/30/2014 HWF187 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.14	c	P
2	Temperature max error	P	4	0.5	12	0.29	c	P
3	Ozone Slope	P	0	1.1	4	0.97152	unitless	P
4	Ozone Intercept	P	0	5	4	-0.17924	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	3.2	%	P
7	Ozone % difference max	P	7	10	4	3.4	%	P
8	Flow Rate average % difference	P	10	5	2	1.12	%	P
9	Flow Rate max % difference	P	10	5	2	1.35	%	P
10	DAS Time maximum error	P	0	5	1	0.25	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0002	V	P

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 72
The filter sample tubing has drops of moisture in low sections outside the shelter.
- Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

- Parameter:** SiteOpsProcedures
The ozone inlet filter is replaced and the sample train is leak tested every other week.
- Parameter:** ShelterCleanNotes
The shelter is in good condition.

EEMS Spot Report

Data Compiled: 5/10/2016 6:09:55 PM

Site	Visit Date	Technician
KEF112	09/23/2014	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.18	c	P
2	Temperature max error	P	4	0.5	9	0.37	c	P
3	Ozone Slope	P	0	1.1	4	1.00924	unitless	P
4	Ozone Intercept	P	0	5	4	0.71974	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99968	unitless	P
6	Ozone % difference avg	P	7	10	4	3.5	%	P
7	Ozone % difference max	P	7	10	4	8.0	%	P
8	Flow Rate average % difference	P	10	5	3	1.54	%	P
9	Flow Rate max % difference	P	10	5	3	1.97	%	P
10	DAS Time maximum error	P	0	5	1	0.00	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0001	V	P

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is in a clearing within the Kane Experimental Forest, the tree line is within 10 meters of the site.

3 Parameter: ShelterCleanNotes

The shelter is clean and very well organized. The floor and bottom of walls are beginning to deteriorate.

4 Parameter: PollAnalyzerCom

The MFC was observed to fluctuate from 1.4 to 1.6 lpm. Trees to the east are within 20 meters of the ozone inlet.

5 Parameter: MetSensorComme

The meteorological tower is attached to the shelter and the temperature sensor is positioned directly over the metal roof of the shelter.

EEMS Spot Report

Data Compiled: 1/27/2015 6:24:16 PM

Site Visit Date	Site	Technician
09/19/2014	LRL117	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99928	unitless	P
2	Ozone Intercept	P	0	5	4	0.45197	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	0.9	%	P
5	Ozone % difference max	P	7	10	4	2.0	%	P

EEMS Spot Report

Data Compiled: 5/11/2016 1:01:23 PM

Site	VisitDate	Technician
MKG113	09/20/2014	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.09	c	P
2	Temperature max error	P	4	0.5	9	0.19	c	P
3	Ozone Slope	P	0	1.1	4	1.00307	unitless	P
4	Ozone Intercept	P	0	5	4	-0.04993	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	0.3	%	P
7	Ozone % difference max	P	7	10	4	0.6	%	P
8	Flow Rate average % difference	P	10	5	2	0.66	%	P
9	Flow Rate max % difference	P	10	5	2	0.66	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0001	V	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 **Parameter:** ShelterCleanNotes

The shelter is clean and organized. Leak and rot below the air conditioner and on the floor under the counter. Mold beginning on walls and floor.

2 **Parameter:** MetOpMaintCom

The temperature shield forced-air blower has a loose connection and the operation is intermittent.

EEMS Spot Report

Data Compiled: 1/23/2015 12:53:57 PM

Site Visit Date Site Technician

07/22/2014 NEC602 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96496	unitless	P
2	Ozone Intercept	P	0	5	4	0.39273	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	2.5	%	P
5	Ozone % difference max	P	7	10	4	3.5	%	P

EEMS Spot Report

Data Compiled: 1/23/2015 12:32:41 PM

SiteVisitDate	Site	Technician
07/16/2014	PND165	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97661	unitless	P
2	Ozone Intercept	P	0	5	4	0.15722	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	2.1	%	P
5	Ozone % difference max	P	7	10	4	2.6	%	P

EEMS Spot Report

Data Compiled: 1/23/2015 1:07:01 PM

Site Visit Date	Site	Technician
09/10/2014	PRK134	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97063	unitless	P
2	Ozone Intercept	P	0	5	4	-0.08659	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	3.1	%	P
5	Ozone % difference max	P	7	10	4	3.3	%	P

EEMS Spot Report

Data Compiled: 5/11/2016 1:26:54 PM

SiteVisitDate	Site	Technician
09/23/2014	PSU106	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.17	c	P
2	Temperature max error	P	4	0.5	12	0.35	c	P
3	Ozone Slope	P	0	1.1	4	0.99612	unitless	P
4	Ozone Intercept	P	0	5	4	-0.5623	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99986	unitless	P
6	Ozone % difference avg	P	7	10	4	1.6	%	P
7	Ozone % difference max	P	7	10	4	2.5	%	P
8	Flow Rate average % difference	P	10	5	3	0.66	%	P
9	Flow Rate max % difference	P	10	5	3	0.66	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0001	V	P

Field Systems Comments

1 Parameter: DasComments

The meteorological tower has been removed.

2 Parameter: SitingCriteriaCom

The site is within 10 km of State College which has a population of approximately 50,000. The site is located in a university agricultural research field.

3 Parameter: ShelterCleanNotes

The shelter is owned by the university and is clean and orderly. The site is part of the Surfrad network.

4 Parameter: MetOpMaintCom

The 10-meter temperature sensor is now mounted in a naturally aspirated shield on the sample tower.

EEMS Spot Report

Data Compiled: 5/11/2016 2:19:04 PM

Site Visit Date	Site	Technician
09/04/2014	RED004	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Flow Rate average % difference	P	10	5	2	0.99	%	P
2	Flow Rate max % difference	P	10	5	2	0.99	%	P

Field Systems Comments

1 Parameter: DocumentationCo

There is no site logbook and all manuals are kept electronically since the site is a small footprint site with no place to store hardcopies.

2 Parameter: ShelterCleanNotes

Small footprint site with enclosure for instruments only.

EEMS Spot Report

Data Compiled: 1/23/2015 12:59:15 PM

SiteVisitDate	Site	Technician
08/16/2014	ROM206	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99749	unitless	P
2	Ozone Intercept	P	0	5	4	1.26437	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	2.4	%	P
5	Ozone % difference max	P	7	10	4	4.9	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell B Flow **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 1/23/2015 1:01:10 PM

SiteVisitDate	Site	Technician
08/16/2014	ROM406	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97262	unitless	P
2	Ozone Intercept	P	0	5	4	1.35157	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.5	%	P
5	Ozone % difference max	P	7	10	4	3.0	%	P

EEMS Spot Report

Data Compiled: 5/10/2016 10:14:19 AM

Site Visit Date	Site	Technician
07/19/2014	SAL133	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.10	c	P
2	Temperature max error	P	4	0.5	3	0.18	c	P
3	Ozone Slope	P	0	1.1	4	1.01925	unitless	P
4	Ozone Intercept	P	0	5	4	-0.3512	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	1.4	%	P
7	Ozone % difference max	P	7	10	4	1.6	%	P
8	Flow Rate average % difference	P	10	5	4	1.12	%	P
9	Flow Rate max % difference	P	10	5	4	1.35	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0001	V	P

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is located next to a field usually planted with corn or soy beans.

3 Parameter: ShelterCleanNotes

There is evidence of a leak in the shelter roof, and the condition has deteriorated since the previous audit visit. Only one light is working. There are signs of ants in the shelter.

EEMS Spot Report

Data Compiled: 1/23/2015 12:37:02 PM

SiteVisitDate	Site	Technician
07/21/2014	STK138	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00334	unitless	P
2	Ozone Intercept	P	0	5	4	0.41983	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	1.2	%	P
5	Ozone % difference max	P	7	10	4	2.1	%	P

EEMS Spot Report

Data Compiled: 2/9/2015 12:11:08 PM

Site Visit Date	Site	Technician
08/25/2014	THR422	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01485	unitless	P
2	Ozone Intercept	P	0	5	4	0.46186	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	2.2	%	P
5	Ozone % difference max	P	7	10	4	2.9	%	P

EEMS Spot Report

Data Compiled: 5/5/2016 3:41:21 PM

Site Visit Date Site Technician

08/26/2014 UVL124 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.08	c	P
2	Temperature max error	P	4	0.5	9	0.11	c	P
3	Ozone Slope	P	0	1.1	4	0.99192	unitless	P
4	Ozone Intercept	P	0	5	4	0.80640	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	0.9	%	P
7	Ozone % difference max	P	7	10	4	2.2	%	P
8	Flow Rate average % difference	P	10	5	2	0.67	%	P
9	Flow Rate max % difference	P	10	5	2	0.67	%	P
10	DAS Time maximum error	P	0	5	1	0.02	min	P
11	DAS Voltage average error	P	7	0.003	42	0.0002	V	P

Field Performance Comments

1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 70

Although there currently is no moisture in the flow sample train, there is evidence of previous moisture events.

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

Ozone sample train leak-check performed every two weeks.

2 **Parameter:** DocumentationCo

The ozone diagnostic and observation sections of the SSRF were completed during the filter removal visit and not the installation visit as indicated on the form.

3 **Parameter:** SitingCriteriaCom

The site is located in an active agriculture field usually planted with beans or corn.

4 **Parameter:** ShelterCleanNotes

The shelter is clean and in good condition.

5 **Parameter:** MetOpMaintCom

Met tower and 10 meter temperature operating and audited.

EEMS Spot Report

Data Compiled: 1/23/2015 12:55:38 PM

SiteVisitDate	Site	Technician
07/23/2014	VIN140	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99454	unitless	P
2	Ozone Intercept	P	0	5	4	0.34110	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	0.7	%	P
5	Ozone % difference max	P	7	10	4	1.6	%	P

EEMS Spot Report

Data Compiled: 1/23/2015 1:04:39 PM

Site Visit Date	Site	Technician
09/08/2014	VOY413	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98467	unitless	P
2	Ozone Intercept	P	0	5	4	0.48500	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	0.8	%	P
5	Ozone % difference max	P	7	10	4	1.1	%	P

EEMS Spot Report

Data Compiled: 1/23/2015 12:57:09 PM

Site Visit Date Site Technician

07/23/2014 WNC429 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.95292	unitless	P
2	Ozone Intercept	P	0	5	4	0.08442	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
4	Ozone % difference avg	P	7	10	4	4.3	%	P
5	Ozone % difference max	P	7	10	4	4.8	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 2/9/2015 11:03:04 AM

SiteVisitDate	Site	Technician
08/24/2014	YEL408	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99470	unitless	P
2	Ozone Intercept	P	0	5	4	0.81971	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.9	%	P
5	Ozone % difference max	P	7	10	4	1.6	%	P

APPENDIX C

CASTNET Ozone Performance Evaluation Forms

EEMS Spot Report

Data Compiled: 1/23/2015 12:32:41 PM

Site Visit Date Site Technician

07/16/2014 PND165 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97661	unitless	P
2	Ozone Intercept	P	0	5	4	0.15722	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	2.1	%	P
5	Ozone % difference max	P	7	10	4	2.6	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241791		PND165	Eric Hebert	07/16/2014	Ozone	000619

Slope:	0.97661	Slope:	0.00000
Intercept	0.15722	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.1%	2.6%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.28	0.48	0.68	ppb	
primary	2	31.20	31.18	30.38	ppb	-2.57%
primary	3	49.31	49.17	48.51	ppb	-1.34%
primary	4	77.28	76.94	75.03	ppb	-2.48%
primary	5	104.29	103.76	101.60	ppb	-2.08%

Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.60	Status	pass
Sensor Component	Span	Condition	1.033	Status	pass
Sensor Component	Cell B Freq.	Condition	94.5 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.62 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.9 C	Status	pass
Sensor Component	Cell A Pressure	Condition	562 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	100.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.62 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

PND165-Eric Hebert-07/16/2014

1	7/16/2014	DAS	Campbell	000403	CR3000	2516
2	7/16/2014	Modem	Raven	06474	H4222-C	0808311240
3	7/16/2014	Ozone	ThermoElectron Inc	000619	49i A1NAA	1009241791
4	7/16/2014	Ozone Standard	ThermoElectron Inc	000329	49i A3NAA	0622717853
5	7/16/2014	Sample Tower	Aluma Tower	000055	B	AT-81213-J12
6	7/16/2014	Zero air pump	Werther International	06926	PC70/4	000836218

EEMS Spot Report

Data Compiled: 1/23/2015 12:34:36 PM

SiteVisitDate	Site	Technician
07/17/2014	BAS601	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96978	unitless	P
2	Ozone Intercept	P	0	5	4	0.45325	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	2.0	%	P
5	Ozone % difference max	P	7	10	4	2.9	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1214552973		BAS601	Eric Hebert	07/17/2014	Ozone	L0534684

Slope:	0.96978	Slope:	0.00000
Intercept	0.45325	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Avg %Dif
A Max % Di	A Max % Di
2.0%	2.9%

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.04	0.24	0.46	ppb	
primary	2	25.63	25.65	25.19	ppb	-1.79%
primary	3	48.59	48.45	47.83	ppb	-1.28%
primary	4	79.40	79.05	77.45	ppb	-2.02%
primary	5	116.11	115.50	112.10	ppb	-2.94%

Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.2	Status	pass
Sensor Component	Span	Condition	1.030	Status	pass
Sensor Component	Cell B Freq.	Condition	56.7 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	46.4 C	Status	fail
Sensor Component	Cell A Pressure	Condition	643 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	52.7 kHz	Status	fail
Sensor Component	Cell A Flow	Condition	0.65 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	BAS601	Eric Hebert	07/17/2014	Cell B Freq.	ThermoElectron	3802	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	BAS601	Eric Hebert	07/17/2014	Cell A Freq.	ThermoElectron	3802	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	BAS601	Eric Hebert	07/17/2014	Cell A Tmp.	ThermoElectron	3802	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

BAS601-Eric Hebert-07/17/2014

1	7/17/2014	DAS	Campbell	none	CR1000	unknown1
2	7/17/2014	Ozone	ThermoElectron Inc	L0534684	49i A1NAA	1214552973
3	7/17/2014	Ozone Standard	ThermoElectron Inc	none	49i E3CAA	1214552971
4	7/17/2014	Zero air pump	Thomas	none	107CAB18	100800031636

EEMS Spot Report

Data Compiled: 1/23/2015 12:37:02 PM

Site Visit Date	Site	Technician
07/21/2014	STK138	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.00334	unitless	P
2	Ozone Intercept	P	0	5	4	0.41983	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	1.2	%	P
5	Ozone % difference max	P	7	10	4	2.1	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347321		STK138	Sandy Grenville	07/21/2014	Ozone	000743

Slope:	1.00334	Slope:	0.00000
Intercept	0.41983	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.2%	2.1%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.55	0.66	1.05	ppb	
primary	2	30.41	30.38	31.02	ppb	2.11%
primary	3	50.13	50.01	50.54	ppb	1.06%
primary	4	80.79	80.53	81.10	ppb	0.71%
primary	5	99.60	99.26	100.10	ppb	0.85%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.50	Status	pass
Sensor Component	Span	Condition	0.997	Status	pass
Sensor Component	Cell B Freq.	Condition	92.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	709 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	91.5 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

STK138-Sandy Grenville-07/21/2014

1	7/21/2014	DAS	Campbell	000349	CR3000	2128
2	7/21/2014	Modem	Raven	06603	H4223-C	0844356279
3	7/21/2014	Ozone	ThermoElectron Inc	000743	49i A1NAA	1105347321
4	7/21/2014	Ozone Standard	ThermoElectron Inc	000450	49i A3NAA	CM08200026
5	7/21/2014	Sample Tower	Aluma Tower	03554	A	none
6	7/21/2014	Zero air pump	Werther International	06915	C 70/4	000829162

EEMS Spot Report

Data Compiled: 1/23/2015 12:39:32 PM

SiteVisitDate	Site	Technician
07/22/2014	ALH157	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99162	unitless	P
2	Ozone Intercept	P	0	5	4	0.55984	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
4	Ozone % difference avg	P	7	10	4	1.0	%	P
5	Ozone % difference max	P	7	10	4	3.0	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244798		ALH157	Sandy Grenville	07/22/2014	Ozone	000683

Slope:	0.99162	Slope:	0.00000
Intercept	0.55984	Intercept	0.00000
CorrCoff	0.99994	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.0%	3.0%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.24	0.35	0.67	ppb	
primary	2	30.05	30.02	30.91	ppb	2.96%
primary	3	50.03	49.91	49.93	ppb	0.04%
primary	4	81.22	80.96	80.30	ppb	-0.82%
primary	5	102.64	102.28	102.30	ppb	0.02%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.10	Status	pass
Sensor Component	Span	Condition	0.989	Status	pass
Sensor Component	Cell B Freq.	Condition	94.7 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.73 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	722 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	95.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.74 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ALH157-Sandy Grenville-07/22/2014

1	7/22/2014	DAS	Campbell	000405	CR3000	2522
2	7/22/2014	Modem	Raven	06605	H4222-C	0844355805
3	7/22/2014	Ozone	ThermoElectron Inc	000683	49i A1NAA	1030244798
4	7/22/2014	Ozone Standard	ThermoElectron Inc	000440	49i A3NAA	CM08200016
5	7/22/2014	Sample Tower	Aluma Tower	illegible	B	none
6	7/22/2014	Zero air pump	Werther International	06910	C 70/4	000829160

EEMS Spot Report

Data Compiled: 1/23/2015 12:53:57 PM

Site Visit Date Site Technician

07/22/2014 NEC602 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96496	unitless	P
2	Ozone Intercept	P	0	5	4	0.39273	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	2.5	%	P
5	Ozone % difference max	P	7	10	4	3.5	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1214552974		NEC602	Eric Hebert	07/22/2014	Ozone	none

Slope:	0.96496	Slope:	0.00000
Intercept	0.39273	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.5%	3.5%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.12	0.32	0.44	ppb	
primary	2	24.68	24.71	24.30	ppb	-1.66%
primary	3	47.87	47.74	46.57	ppb	-2.45%
primary	4	77.61	77.27	75.43	ppb	-2.38%
primary	5	112.92	112.33	108.40	ppb	-3.50%

Sensor Component	Cell B Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.6	Status	pass
Sensor Component	Span	Condition	1.013	Status	pass
Sensor Component	Cell B Freq.	Condition	66.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	37.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	633 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	83.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.61 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

NEC602-Eric Hebert-07/22/2014

1	7/22/2014	DAS	Campbell	none	CR1000	41007
2	7/22/2014	Ozone	ThermoElectron Inc	none	49i A1NAA	1214552974
3	7/22/2014	Ozone Standard	ThermoElectron Inc	L0534683	49i E3CAA	1214552972
4	7/22/2014	Zero air pump	ThermoElectron Inc	none	107CAB18	106580-00

EEMS Spot Report

Data Compiled: 1/23/2015 12:55:38 PM

Site Visit Date	Site	Technician
07/23/2014	VIN140	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99454	unitless	P
2	Ozone Intercept	P	0	5	4	0.34110	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	0.7	%	P
5	Ozone % difference max	P	7	10	4	1.6	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241798		VIN140	Sandy Grenville	07/23/2014	Ozone	000630

Slope:	0.99454	Slope:	0.00000
Intercept	0.34110	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.7%	1.6%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.04	0.15	0.18	ppb	
primary	2	31.02	30.99	31.49	ppb	1.61%
primary	3	50.05	49.93	50.20	ppb	0.54%
primary	4	81.56	81.30	81.10	ppb	-0.25%
primary	5	100.78	100.43	100.10	ppb	-0.33%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.30	Status	pass
Sensor Component	Span	Condition	1.015	Status	pass
Sensor Component	Cell B Freq.	Condition	100 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	725 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	93.4 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.65 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

VIN140-Sandy Grenville-07/23/2014

1	7/23/2014	DAS	Campbell	000358	CR3000	2136
2	7/23/2014	Modem	Raven	06461	V4221-V	0808338875
3	7/23/2014	Ozone	ThermoElectron Inc	000630	49i A1NAA	1009241798
4	7/23/2014	Ozone Standard	ThermoElectron Inc	000513	49i A3NAA	0922236889
5	7/23/2014	Sample Tower	Aluma Tower	000137	B	none
6	7/23/2014	Zero air pump	Werther International	06906	C 70/4	000821908

EEMS Spot Report

Data Compiled: 1/23/2015 12:57:09 PM

SiteVisitDate	Site	Technician
07/23/2014	WNC429	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.95292	unitless	P
2	Ozone Intercept	P	0	5	4	0.08442	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
4	Ozone % difference avg	P	7	10	4	4.3	%	P
5	Ozone % difference max	P	7	10	4	4.8	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	0615817056		WNC429	Eric Hebert	07/23/2014	Ozone	none

Slope:	0.95292	Slope:	0.00000
Intercept	0.08442	Intercept	0.00000
CorrCoff	0.99995	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
4.3%	4.8%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.13	0.33	0.05	ppb	
primary	2	25.66	25.68	24.52	ppb	-4.52%
primary	3	49.19	49.05	47.54	ppb	-3.08%
primary	4	80.84	80.48	76.65	ppb	-4.76%
primary	5	117.44	116.82	111.20	ppb	-4.81%

Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	9.9982	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.353	Status	pass
Sensor Component	Cell B Freq.	Condition	56.4 kHz	Status	fail
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	1.33 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	32.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	647 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	49.4 kHz	Status	fail
Sensor Component	Cell A Flow	Condition	0.64 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	0.0075	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
-----------	------	------------	-----------	-----------	-----	------------	--------	---------

Ozone	WNC429	Eric Hebert	07/23/2014	Cell B Freq.	ThermoElectron	3398	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Ozone	WNC429	Eric Hebert	07/23/2014	Cell A Freq.	ThermoElectron	3398	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

WNC429-Eric Hebert-07/23/2014

1	7/23/2014	DAS	Environmental Sys Corp	missing	8816	4159
2	7/23/2014	Modem	US Robotics	none	56k fax modem	unknown
3	7/23/2014	Ozone	ThermoElectron Inc	none	49i A3NAA	0615817056
4	7/23/2014	Ozone Standard	ThermoElectron Inc	none	49i PSA2AB	0807328333
5	7/23/2014	Zero air pump	ThermoElectron Inc	none	111	111-78387-388

EEMS Spot Report

Data Compiled: 1/23/2015 12:59:15 PM

SiteVisitDate	Site	Technician
08/16/2014	ROM206	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99749	unitless	P
2	Ozone Intercept	P	0	5	4	1.26437	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	2.4	%	P
5	Ozone % difference max	P	7	10	4	4.9	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell B Flow **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241798		ROM206	Eric Hebert	08/16/2014	Ozone	000621

Slope:	0.99749	Slope:	0.00000
Intercept	1.26437	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.4%	4.9%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.40	0.60	1.75	ppb	
primary	2	26.54	26.56	27.87	ppb	4.93%
primary	3	49.36	49.22	50.39	ppb	2.38%
primary	4	76.55	76.22	77.32	ppb	1.44%
primary	5	115.18	114.58	115.50	ppb	0.80%

Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-1.8	Status	pass
Sensor Component	Span	Condition	1.023	Status	pass
Sensor Component	Cell B Freq.	Condition	98.8 kHz	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	1.4 lpm	Status	fail
Sensor Component	Cell A Tmp.	Condition	33.3 C	Status	pass
Sensor Component	Cell A Pressure	Condition	525 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	104.5 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.59 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	ROM206	Eric Hebert	08/16/2014	Cell B Flow	ThermoElectron	3460	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ROM206-Eric Hebert-08/16/2014

1	8/16/2014	DAS	Campbell	000428	CR3000	2534
2	8/16/2014	Modem	Raven	06473	V4221-V	0808311135
3	8/16/2014	Ozone	ThermoElectron Inc	000621	49i A1NAA	1009241798
4	8/16/2014	Ozone Standard	ThermoElectron Inc	000514	49i A3NAA	0922236892
5	8/16/2014	Sample Tower	Aluma Tower	666369	B	illegible
6	8/16/2014	Zero air pump	Teledyne	000777	701H	607

EEMS Spot Report

Data Compiled: 1/23/2015 1:01:10 PM

Site Visit Date	Site	Technician
08/16/2014	ROM406	Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97262	unitless	P
2	Ozone Intercept	P	0	5	4	1.35157	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.5	%	P
5	Ozone % difference max	P	7	10	4	3.0	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Teledyne	2551		ROM406	Eric Hebert	08/16/2014	Ozone	WYDEQ

Slope:	0.97262	Slope:	0.00000
Intercept	1.35157	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.5%	3.0%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.14	0.34	1.63	ppb	
primary	2	26.77	26.79	27.59	ppb	2.99%
primary	3	49.72	49.57	49.34	ppb	-0.46%
primary	4	77.52	77.18	76.54	ppb	-0.83%
primary	5	116.56	115.95	114.10	ppb	-1.60%

Sensor Component	Cell B Noise	Condition	N/A	Status	pass
Sensor Component	Cell B Tmp.	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.4	Status	pass
Sensor Component	Span	Condition	0.987	Status	pass
Sensor Component	Cell B Freq.	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition	N/A	Status	pass
Sensor Component	Cell B Flow	Condition	N/A	Status	pass
Sensor Component	Cell A Tmp.	Condition	38.7 C	Status	pass
Sensor Component	Cell A Pressure	Condition	N/A	Status	pass
Sensor Component	Cell A Noise	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	N/A	Status	pass
Sensor Component	Cell A Flow	Condition	0.57 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ROM406-Eric Hebert-08/16/2014

1	8/16/2014	DAS	Environmental Sys Corp	90535	8816	2025
2	8/16/2014	Modem	US Robotics	none	33.6 fax modem	unknown
3	8/16/2014	Ozone	Teledyne	WYDEQ	400E	2551
4	8/16/2014	Ozone Standard	ThermoElectron Inc	none	49i A3NAA	1030745086
5	8/16/2014	Sample Tower	Aluma Tower	illegible	B	none
6	8/16/2014	Zero air pump	Werther International	none	PC70/4	531392

EEMS Spot Report

Data Compiled: 2/9/2015 12:10:28 PM

Site Visit Date	Site	Technician
08/21/2014	GTH161	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.95395	unitless	P
2	Ozone Intercept	P	0	5	4	-0.665	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99984	unitless	P
4	Ozone % difference avg	P	7	10	4	5.3	%	P
5	Ozone % difference max	P	7	10	4	6.3	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1008241788		GTH161	Alison Ray	08/21/2014	Ozone	unknown

Slope:	0.95395	Slope:	0.00000
Intercept	-0.66500	Intercept	0.00000
CorrCoff	0.99984	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
5.3%	6.3%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.10	0.10	-1.20	ppb	
primary	2	29.90	29.89	28.00	ppb	-6.32%
primary	3	50.50	50.35	48.56	ppb	-3.56%
primary	4	81.00	80.64	75.79	ppb	-6.01%
primary	5	109.60	109.03	103.10	ppb	-5.44%

Sensor Component	Cell B Noise	Condition	Not tested	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	Not tested	Status	pass
Sensor Component	Span	Condition	Not tested	Status	pass
Sensor Component	Cell B Freq.	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.57 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	Not tested	Status	pass
Sensor Component	Cell A Pressure	Condition	Not tested	Status	pass
Sensor Component	Cell A Noise	Condition	Not tested	Status	pass
Sensor Component	Cell A Freq.	Condition	Not tested	Status	pass
Sensor Component	Cell A Flow	Condition	0.56 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

GTH161-Alison Ray-08/21/2014

1	8/21/2014	DAS	Campbell	000416	CR3000	2513
2	8/21/2014	Modem	Raven	06589	H4223-C	0844321356
3	8/21/2014	Ozone	ThermoElectron Inc	unknown	49i A1NAA	1008241788
4	8/21/2014	Ozone Standard	ThermoElectron Inc	000439	49i A3NAA	CM08200015
5	8/21/2014	Zero air pump	Werther International	06927	P 70/4	000836211

EEMS Spot Report

Data Compiled: 2/9/2015 12:25:52 PM

Site Visit Date	Site	Technician
08/23/2014	CNT169	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99705	unitless	P
2	Ozone Intercept	P	0	5	4	-1.82502	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	3.8	%	P
5	Ozone % difference max	P	7	10	4	6.3	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244804		CNT169	Alison Ray	08/23/2014	Ozone	000699

Slope:	0.99274	Slope:	0.00000
Intercept	-1.70626	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.9%	6.3%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.10	0.30	-1.46	ppb	
primary	2	29.43	29.43	27.57	ppb	-6.32%
primary	3	49.43	49.29	47.32	ppb	-4.00%
primary	4	79.37	79.02	76.58	ppb	-3.09%
primary	5	109.50	108.94	106.50	ppb	-2.24%

Sensor Component	Cell B Noise	Condition	Not tested	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	Not tested	Status	pass
Sensor Component	Span	Condition	Not tested	Status	pass
Sensor Component	Cell B Freq.	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.54 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	Not tested	Status	pass
Sensor Component	Cell A Pressure	Condition	Not tested	Status	pass
Sensor Component	Cell A Noise	Condition	Not tested	Status	pass
Sensor Component	Cell A Freq.	Condition	Not tested	Status	pass
Sensor Component	Cell A Flow	Condition	0.54 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

CNT169-Alison Ray-08/23/2014

1	8/23/2014	DAS	Campbell	000417	CR3000	2515
2	8/23/2014	Modem	Raven	06600	V4221-V	0844349098
3	8/23/2014	Ozone	ThermoElectron Inc	000699	49i A1NAA	1030244804
4	8/23/2014	Ozone Standard	ThermoElectron Inc	000434	49i A3NAA	CM08200010
5	8/23/2014	Zero air pump	Werther International	06925	P 70/4	000836220

EEMS Spot Report

Data Compiled: 2/9/2015 11:17:01 AM

SiteVisitDate	Site	Technician
08/23/2014	GLR468	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98527	unitless	P
2	Ozone Intercept	P	0	5	4	0.12602	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
4	Ozone % difference avg	P	7	10	4	1.4	%	P
5	Ozone % difference max	P	7	10	4	1.7	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1023943901		GLR468	Sandy Grenville	08/23/2014	Ozone	none

Slope:	0.98527	Slope:	0.00000
Intercept	0.12602	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.4%	1.7%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.39	0.50	0.82	ppb	
primary	2	30.79	30.76	30.39	ppb	-1.20%
primary	3	50.42	50.30	49.45	ppb	-1.69%
primary	4	82.21	81.94	80.57	ppb	-1.67%
primary	5	100.86	100.51	99.52	ppb	-0.98%

Sensor Component	Cell B Noise	Condition	0.4 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	Not tested	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.2	Status	pass
Sensor Component	Span	Condition	1.023	Status	pass
Sensor Component	Cell B Freq.	Condition	84.4 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.1 C	Status	pass
Sensor Component	Cell A Pressure	Condition	672 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	82.6 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	Not tested	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

GLR468-Sandy Grenville-08/23/2014

1	8/23/2014	DAS	Environmental Sys Corp	90653	8816	2566
2	8/23/2014	Modem	US Robotics	none	56k	unknown
3	8/23/2014	Ozone	ThermoElectron Inc	none	49i A3NAA	1023943901
4	8/23/2014	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460050
5	8/23/2014	Printer	Hewlett Packard	none	842C	unknown
6	8/23/2014	Sample Tower	Aluma Tower	none	B	none
7	8/23/2014	Zero air pump	Werther International	none	PC70/4	000756725

EEMS Spot Report

Data Compiled: 2/9/2015 11:03:04 AM

SiteVisitDate	Site	Technician
08/24/2014	YEL408	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99470	unitless	P
2	Ozone Intercept	P	0	5	4	0.81971	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	0.9	%	P
5	Ozone % difference max	P	7	10	4	1.6	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-66828-354		YEL408	Sandy Grenville	08/24/2014	Ozone	90714

Slope:	0.99470	Slope:	0.00000
Intercept	0.81971	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.9%	1.6%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.10	0.21	1.16	ppb	
primary	2	30.69	30.66	31.15	ppb	1.60%
primary	3	50.17	50.05	50.60	ppb	1.10%
primary	4	80.80	80.54	80.87	ppb	0.41%
primary	5	100.96	100.61	101.00	ppb	0.39%

Sensor Component	Cell B Noise	Condition	1.7 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.4	Status	pass
Sensor Component	Span	Condition	1.004	Status	pass
Sensor Component	Cell B Freq.	Condition	76.6 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	561 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	95.2 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.64 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

YELA08-Sandy Grenville-08/24/2014

1	8/24/2014	Computer	Gateway	none	Solo	2500251339
2	8/24/2014	DAS	Environmental Sys Corp	90647	8816	2560
3	8/24/2014	Modem	US Robotics	none	56k fax modem	unknown
4	8/24/2014	Ozone	ThermoElectron Inc	90714	49C	49C-66828-354
5	8/24/2014	Ozone Standard	ThermoElectron Inc	90605	49C	49C-62025-333
6	8/24/2014	Sample Tower	Aluma Tower	illegible	B	none
7	8/24/2014	Zero air pump	Werther International	none	PC70/4	531393

EEMS Spot Report

Data Compiled: 2/9/2015 12:11:08 PM

SiteVisitDate	Site	Technician
08/25/2014	THR422	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	1.01485	unitless	P
2	Ozone Intercept	P	0	5	4	0.46186	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	2.2	%	P
5	Ozone % difference max	P	7	10	4	2.9	%	P

Ozone Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	0632119500	THR422	Sandy Grenville	08/25/2014	Ozone	none

Slope:	1.01485	Slope:	0.00000
Intercept	0.46186	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.2%	2.9%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.15	0.26	0.87	ppb	
primary	2	30.37	30.34	31.22	ppb	2.90%
primary	3	51.54	51.41	52.27	ppb	1.67%
primary	4	81.23	80.97	82.93	ppb	2.42%
primary	5	100.05	99.70	101.60	ppb	1.91%

Sensor Component	Cell B Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	Not tested	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Dirty	Status	Fail
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.5	Status	pass
Sensor Component	Span	Condition	1.016	Status	pass
Sensor Component	Cell B Freq.	Condition	67.9 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	30.6 C	Status	pass
Sensor Component	Cell A Pressure	Condition	680 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.4 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	103.6 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.65 lpm	Status	pass
Sensor Component	Battery Backup	Condition	Functioning	Status	pass
Sensor Component	Zero Voltage	Condition	Not tested	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

THR422-Sandy Grenville-08/25/2014

1	8/25/2014	Computer	Hewlett Packard	none	65606	5CB1520H68
2	8/25/2014	DAS	Environmental Sys Corp	90656	8816	2600
3	8/25/2014	Modem	US Robotics	none	14.4 fax modem	9244894
4	8/25/2014	Ozone	ThermoElectron Inc	none	49i A3NAA	0632119500
5	8/25/2014	Sample Tower	Aluma Tower	none	B	AT-81077-J5
6	8/25/2014	UPS	APC	none	RS500	unknown
7	8/25/2014	Zero air pump	Thomas	none	607CA22C	039500000348

EEMS Spot Report

Data Compiled: 1/23/2015 1:04:39 PM

Site Visit Date	Site	Technician
09/08/2014	VOY413	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98467	unitless	P
2	Ozone Intercept	P	0	5	4	0.48500	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	0.8	%	P
5	Ozone % difference max	P	7	10	4	1.1	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-70522-366		VOY413	Alison Ray	09/08/2014	Ozone	90730

Slope:	0.98467	Slope:	0.00000
Intercept	0.48500	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.8%	1.1%		

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.00	0.20	0.91	ppb	
primary	2	29.63	29.63	29.63	ppb	0.00%
primary	3	49.45	49.31	48.75	ppb	-1.14%
primary	4	79.48	79.13	78.23	ppb	-1.14%
primary	5	109.44	108.88	107.96	ppb	-0.84%

Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.8	Status	pass
Sensor Component	Span	Condition	0.988	Status	pass
Sensor Component	Cell B Freq.	Condition	88.1 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.76 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.3 C	Status	pass
Sensor Component	Cell A Pressure	Condition	705 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	95.6 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

VOY413-Alison Ray-09/08/2014

1	9/8/2014	DAS	Environmental Sys Corp	none	8816	4059
2	9/8/2014	Ozone	ThermoElectron Inc	90730	49C	49C-70522-366
3	9/8/2014	Ozone Standard	ThermoElectron Inc	90717	49C	49C-66823-354
4	9/8/2014	Sample Tower	Aluma Tower	none	B	AT-51159-11-G
5	9/8/2014	Zero air pump	Twin Tower Engineering	90719	TT70/E4	526294

EEMS Spot Report

Data Compiled: 1/23/2015 1:07:01 PM

Site Visit Date	Site	Technician
09/10/2014	PRK134	Alison Ray

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97063	unitless	P
2	Ozone Intercept	P	0	5	4	-0.08659	ppb	P
3	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
4	Ozone % difference avg	P	7	10	4	3.1	%	P
5	Ozone % difference max	P	7	10	4	3.3	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244800		PRK134	Alison Ray	09/10/2014	Ozone	000690

Slope:	0.97063	Slope:	0.00000
Intercept	-0.08659	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.1%	3.3%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00707	Intercept	-0.21032
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.24	0.44	0.30	ppb	
primary	2	27.45	27.46	26.56	ppb	-3.28%
primary	3	47.19	47.06	45.67	ppb	-2.95%
primary	4	80.01	79.65	77.22	ppb	-3.05%
primary	5	116.22	115.61	112.10	ppb	-3.04%

Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.4	Status	pass
Sensor Component	Span	Condition	1.020	Status	pass
Sensor Component	Cell B Freq.	Condition	86.9 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	32.8 C	Status	pass
Sensor Component	Cell A Pressure	Condition	698 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	96.3 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

PRK134-Alison Ray-09/10/2014

1	9/10/2014	DAS	Campbell	000411	CR3000	2509
2	9/10/2014	Ozone	ThermoElectron Inc	000690	49i A1NAA	1030244800
3	9/10/2014	Ozone Standard	ThermoElectron Inc	000362	49i A3NAA	0726124686
4	9/10/2014	Sample Tower	Aluma Tower	03518	A	none
5	9/10/2014	Zero air pump	Werther International	06905	C 70/4	000821907

EEMS Spot Report

Data Compiled: 1/27/2015 6:24:16 PM

Site Visit Date	Site	Technician
09/19/2014	LRL117	Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99928	unitless	P
2	Ozone Intercept	P	0	5	4	0.45197	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	0.9	%	P
5	Ozone % difference max	P	7	10	4	2.0	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244808		LRL117	Sandy Grenville	09/19/2014	Ozone	000701

Slope:	0.99928	Slope:	0.00000
Intercept	0.45197	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.9%	2.0%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49C-73104-373	Tfer Desc.	Ozone transfer
Tfer ID	01100		
Slope	1.00458	Intercept	-0.11484
Cert Date	12/10/2013	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	0.05	0.16	0.53	ppb	
primary	2	30.63	30.60	31.20	ppb	1.96%
primary	3	50.88	50.76	51.02	ppb	0.51%
primary	4	80.37	80.11	80.70	ppb	0.74%
primary	5	101.20	100.85	101.10	ppb	0.25%

Sensor Component	Cell B Noise	Condition	1.0 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.1	Status	pass
Sensor Component	Span	Condition	1.011	Status	pass
Sensor Component	Cell B Freq.	Condition	92.9 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.3 C	Status	pass
Sensor Component	Cell A Pressure	Condition	699.1 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	105.6 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

LRL117-Sandy Grenville-09/19/2014

1	9/19/2014	DAS	Campbell	000344	CR300	2123
2	9/19/2014	Modem	Raven	06612	H4223-C	0844355815
3	9/19/2014	Ozone	ThermoElectron Inc	000701	49i A1NAA	1030244808
4	9/19/2014	Ozone Standard	ThermoElectron Inc	000444	49i A3NAA	CM08200020
5	9/19/2014	Sample Tower	Aluma Tower	03446	A	none
6	9/19/2014	Zero air pump	Werther International	06904	C 70/4	000821901

EEMS Spot Report

Data Compiled: 1/23/2015 1:08:34 PM

Site Visit Date Site Technician

09/20/2014 BVL130 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.96651	unitless	P
2	Ozone Intercept	P	0	5	4	0.76544	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	2.0	%	P
5	Ozone % difference max	P	7	10	4	2.7	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241797		BVL130	Eric Hebert	09/20/2014	Ozone	000625

Slope:	0.96651	Slope:	0.00000
Intercept	0.76544	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.0%	2.7%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	0419606966	Tfer Desc.	Ozone primary stan
Tfer ID	01112		
Slope	1.00928	Intercept	0.11780
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.55	-0.66	0.24	ppb	
primary	2	29.76	29.36	28.94	ppb	-1.43%
primary	3	49.56	48.98	48.09	ppb	-1.82%
primary	4	80.76	79.90	78.14	ppb	-2.20%
primary	5	116.43	115.24	112.10	ppb	-2.72%

Sensor Component	Cell B Noise	Condition	Not tested	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	-0.40	Status	pass
Sensor Component	Span	Condition	1.012	Status	pass
Sensor Component	Cell B Freq.	Condition	100.8 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.76 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.3 C	Status	pass
Sensor Component	Cell A Pressure	Condition	714 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	Not tested	Status	pass
Sensor Component	Cell A Freq.	Condition	100.1 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.80 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

BVL130-Eric Hebert-09/20/2014

1	9/20/2014	DAS	Campbell	000424	CR3000	2539
2	9/20/2014	Modem	Raven	06610	H4223-C	0844355827
3	9/20/2014	Ozone	ThermoElectron Inc	000625	49i A1NAA	1009241797
4	9/20/2014	Ozone Standard	ThermoElectron Inc	000512	49i A3NAA	0922236890
5	9/20/2014	Sample Tower	Aluma Tower	000182	B	unknown
6	9/20/2014	Zero air pump	Teledyne	000759	701H	576

EEMS Spot Report

Data Compiled: 1/23/2015 1:10:27 PM

Site Visit Date Site Technician

09/24/2014 ANA115 Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.97366	unitless	P
2	Ozone Intercept	P	0	5	4	0.48989	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.6	%	P
5	Ozone % difference max	P	7	10	4	2.4	%	P

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241778		ANA115	Eric Hebert	09/24/2014	Ozone	000610

Slope:	0.97366	Slope:	0.00000
Intercept	0.48989	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.6%	2.4%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	0419606966	Tfer Desc.	Ozone primary stan
Tfer ID	01112		
Slope	1.00928	Intercept	0.11780
Cert Date	1/8/2014	CorrCoff	1.00000

UseDescription:	ConcGroup:	Tfer Raw:	Tfer Corr:	Site:	Site Unit:	PctDifference:
primary	1	-0.43	-0.54	-0.25	ppb	
primary	2	28.80	28.41	28.22	ppb	-0.67%
primary	3	53.24	52.63	51.94	ppb	-1.31%
primary	4	82.56	81.68	80.20	ppb	-1.81%
primary	5	115.76	114.57	111.80	ppb	-2.42%

Sensor Component	Cell B Noise	Condition	1.4 ppb	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.004	Status	pass
Sensor Component	Cell B Freq.	Condition	97.3 kHz	Status	pass
Sensor Component	System Memo	Condition		Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	Cell B Pressure	Condition		Status	pass
Sensor Component	Cell B Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.0 C	Status	pass
Sensor Component	Cell A Pressure	Condition	720 mmHg	Status	pass
Sensor Component	Cell A Noise	Condition	1.9 ppb	Status	pass
Sensor Component	Cell A Freq.	Condition	97.7 kHz	Status	pass
Sensor Component	Cell A Flow	Condition	0.65 lpm	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ANA115-Eric Hebert-09/24/2014

1	9/24/2014	DAS	Campbell	000338	CR3000	2117
2	9/24/2014	Ozone	ThermoElectron Inc	000610	49i A1NAA	1009241778
3	9/24/2014	Ozone Standard	ThermoElectron Inc	000364	49i A3NAA	0726124687
4	9/24/2014	Zero air pump	Werther International	06933	C 70/4	000836202