

Chapter 129 -- Standards for Sources

SOURCES OF VOCs

§ 129.61. Small gasoline storage tank control (Stage 1 control).

(a) This section applies Statewide.

(b) The following tanks and facilities are exempted:

(1) Stationary storage tanks with a capacity of less than 2,000 gallons (7,600 liters) that were installed before January 1, 1979.

(2) Stationary storage tanks with a capacity of less than 250 gallons (950 liters) that were installed after January 1, 1979.

(3) Stationary storage tanks used for agricultural purposes with a capacity of less than 550 gallons (2100 liters). These tanks shall be equipped with a submerged fill pipe.

(c) A person may not transfer gasoline from a delivery vessel into a stationary storage tank unless the displaced vapors from the storage tank are transferred to the dispensing delivery tank through a vapor tight return line and unless the receiving tank is equipped with a submerged fill pipe which extends from the filling orifice to within 6 inches of the bottom of the tank. The vapors collected in the dispensing tank shall be disposed of in accordance with §129.59 or §129.60(c) (relating to bulk gasoline terminals; and bulk gasoline plants).

(d) The dispensing delivery tank shall remain vapor tight at all times. The delivery tank may be opened after the vapors are disposed of in accordance with §129.59 or §129.60(c).