

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES
SOUTHCENTRAL REGION - FIELD OPERATIONS
AIR QUALITY CONTROL PROGRAM

ORC

EPA

PLAN APPROVAL

Approval No: <u>67-2012</u>	Source & Air Cleaning Device: <u>Two Engines Cooper-Bessemer 12V-250</u>
Owner: <u>Transcontinental Gas Pipe Line Corporation</u>	<u>with LEC Retrofit & Engine Parametric</u>
Address: <u>P.O. Box 369</u>	<u>Controls, and Three Engines Nordberg</u>
<u>Delta, PA 17314</u>	<u>FSE-16 with Engine Parametric Controls</u>
Attention: <u>Mr. J. R. Gattis</u>	Location: <u>Route 851, Bryansville Road</u>
<u>Senior V. P., Technical Services</u>	<u>Peach Bottom Township</u>
	<u>York County</u>

In accordance with provisions of the Air Pollution Control Act, the Act of January 8, 1960, P.L. 2119, as amended, and with Chapter 127 of the Rules and Regulations of the Department of Environmental Resources, the Department on ~~MAY 5 1995~~ approved plans for installation of air cleaning devices at the above indicated air contamination sources.

REG. DIV. 2
Ozone & Mobile Sources
Section (3AT13)

This PLAN APPROVAL expires ~~November 27, 1996~~.

JUN 9 1995

The plan approved is subject to the following conditions:

1. The installation of above air cleaning devices is to be completed in accordance with the plans submitted with the application (as herein approved).
2. See attached.

EPA REGION III

Notify the person noted below when the installation is completed so that the source can be inspected for issuance of an OPERATING PERMIT.

NOTE: Mr. Ranjan Roy
Air Pollution Control Engineer
One Ararat Boulevard
Harrisburg, PA 17110
(717) 657-4587

[Signature]
Program Manager

Southcentral Region 67-2012
York District
Permits



APPROVAL NO. 67-2012

TRANSCONTINENTAL GAS PIPE LINE CORPORATION

STATION 195, DELTA PA

Conditions, Continued

12. Two (2) copies of the stack test results shall be submitted to the Program Manager for review within sixty (60) days of completion of testing. The emissions shall be reported in the following units:
 - a. Concentration as measured - parts per million (ppm)-
 - b. Specific output - g/hp-hr.
 - c. Total output, mass rate - lb/hr.
 - d. Total output, heat rate - lb/mmbtu.
13. Upon issuance of the operating permit, verification of the NO_x emission standard listed in the Condition 5 shall be conducted annually utilizing methodology outlined in 25 Pa. Code, Section 139 and the Department's Source Testing Manual or by other means approved by the Department.
14. The Department reserves the right to revise the emission standard listed in Condition 5, based on information obtained during the testing program outlined in Condition 8 through 12.
15. Transcontinental Gas Pipe Line Corporation will report to the Program Manager any modification to the sources listed in the application, which is expected to increase NO_x and VOC emissions from source/facility.
16. Source listed in Condition 2 (f) is subject to PRESUMPTIVE RACT as per the 25 Pa. Code, Section 129.93(c)(1).
17. The facility shall maintain monthly record of fuel usage in the engines listed in the Condition 2 (a) through (e).
18. The facility shall keep a record of all maintenance and repairs activities of the sources listed in the Condition 2.
19. The records listed in the Conditions 17 and 18 shall be available to the Department upon request.