
2017 – 3rd Quarter Report
Support for Conducting Systems &
Performance Audits of CASTNET Sites and
NADP Monitoring Stations

EPA Contract No. GS-10F-075AA

Prepared for:

U. S. Environmental Protection Agency

Prepared by:



1128 NW 39th Drive
Gainesville, FL 32605

October 2017

Table of Contents

1.0 CASTNET Quarterly Report.....	1-1
1.1 Introduction.....	1-1
1.2 Project Objectives	1-1
1.3 CASTNET Sites Visited Third Quarter 2017	1-4
1.4 Audit Results.....	1-6
2.0 NADP Quarterly Report	2-1
2.1 Introduction.....	2-1
2.2 Project Objectives	2-1
2.3 NADP Sites Visited Third Quarter 2017.....	2-2
2.4 Survey Results.....	2-3

List of Appendices

Appendix A	CASNET Audit Report Forms
Appendix B	CASTNET Site Spot Report Forms
Appendix C	CASTNET Ozone Performance Evaluation Forms

List of Tables

Table 1.	Performance Audit Challenge and Acceptance Criteria	1-2
Table 2.	Site Audit Visits	1-4
Table 3.	TTP Pollutant PE Visits	1-5
Table 4.	Sites Surveyed – Third Quarter 2017	2-2

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialist, Inc.
ASTM	American Society for Testing and Materials
CASTNET	Clean Air Status and Trends Network
DAS	data acquisition system
DC	direct current
deg	degree
DVM	digital voltmeter
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSAD	Field Site Audit Database
GPS	geographical positioning system
lpm	liters per minute
MLM	Multilayer Model
m/s	meters per second
mv	milivolt
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
QAPP	Quality Assurance Project Plan
SOP	standard operating procedure
TEI	Thermo Environmental Instruments
USNO	United States Naval Observatory
V	volts
WRR	World Radiation Reference

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program developed under mandate of the 1990 Clean Air Act Amendments. Each site in the network measures acidic gases and particles using a continuous collection filter aggregated over a one week period, and/or other forms of atmospheric pollution. Hourly averages of surface ozone concentrations and selected meteorological variables are also measured.

Site measurements are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and effects research.

CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and model-estimated deposition velocities. Currently, the Community Multi-scale Air Quality (CMAQ) Model is used to derive deposition velocity estimates.

As of October 2017, the network is comprised of 95 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Environment Canada, Bureau of Land Management (BLM) and several independent partners. Wood Group (Wood) is responsible for operating the EPA and Environment Canada sponsored sites, and Air Resource Specialist, Inc. (ARS) is responsible for operating the NPS and BLM sponsored sites.

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network.

Performance audits verify that all evaluated variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1. Only four EPA sponsored sites that are operated by Wood continue to operate meteorological sensors. Those sites are BEL116, BVL30, CHE185, and PAL190. Six sites in WY sponsored by EPA and operated by the BLM/ARS also operate

meteorological sensors and are PND165, BAS601, NEC602, BUF603, FOR604, and SHE604. The NPS added a new site at Chaco Culture National Historical Park (CHC432) which also monitors meteorological variables. The meteorological sensors at sites PND165, BAS601, SHE604, BUF603, and NEC602 were audited during the station audits performed in third quarter 2017.

Some or all of the additional monitored variables, NO_y, CO, and SO₂ have been added to the EPA sponsored sites BVL130, HWF187, PND165, PNF126, GRS420, MAC426, ROM206, and BEL116. Those variables were audited at sites ROM206 and PND165 during third quarter 2017. All of the trace gas results for those audits were found to be within acceptance criteria. The preliminary reports of those results were delivered following the audits and are not included in this report.

Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	≤ ±10.0% of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	≤ ±10.0% RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	≤ ±10.0% of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	≤ ± 0.5° C
Temperature Difference	Accuracy	Comparison to station temperature sensor	≤ ± 0.50° C
Shelter Temperature	Accuracy	Comparison to station temperature sensor	≤ ± 2.0° C
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	≤ ±5° from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	≤ ±5° mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5$ mps below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-point test gas concentration as measured with a certified transfer standard	$0.9000 \leq m \leq 1.1000$
Ozone	Intercept		$-5.0 \text{ ppb} \leq b \leq 5.0 \text{ ppb}$
Ozone	Correlation Coefficient		$0.9950 \leq r$
Ozone	Percent Difference	Comparison with Level 2 standard concentration	$\leq \pm 10.0\%$ of test gas concentration
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003$ VDC

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, and certified as current.

Site systems audits are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.

- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 CASTNET Sites Visited Third Quarter 2017

This report consists of the systems and performance and other audit results from the CASTNET sites visited during the third quarter (July through September) of 2017. The locations and dates of the site visits for complete audits are presented in Table 2.

Table 2. Site Audit Visits

<u>Side ID</u>	<u>Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
PND165	With Met	BLM/EPA	7/14/2017	Pinedale
BAS601	With Met	BLM	7/17/2017	Basin
SHE604	Flow & Met	BLM	7/18/2017	Sheridan
VPI120	Without Met	EPA	7/18/2017	Horton Station
BUF603	Flow & Met	BLM	7/19/2017	Buffalo
CDR119	Without Met	EPA	7/20/2017	Cedar Creek St. Park
NEC602	With Met	BLM	7/21/2017	Newcastle
PAR107	Without Met	EPA	7/21/2017	Parsons
CNT169	Without Met	EPA	7/22/2017	Centennial
PED108	Without Met	EPA	7/25/2017	Prince Edward
ROM206	Without Met	EPA	8/2/2017	Rocky Mountain NP
ROM406	Without Met	NPS	8/8/2017	Rocky Mountain NP (NPS)

<u>Side ID</u>	<u>Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
YEL408	Without Met	NPS	8/16/2017	Yellowstone NP
GLR468	Without Met	NPS	8/17/2017	Glacier NP
LRL117	Without Met	EPA	8/17/2017	Laurel Hill St. Park
THR422	Without Met	NPS	8/29/2017	Theodore Roosevelt NP
VOY413	Without Met	NPS	9/1/2017	Voyageurs NP
SAN189	Flow Only	EPA	9/7/2017	Santee Sioux
NIC001	Flow Only	EPA	9/26/2017	Nick's Lake
WFM105	Flow Only	EPA	9/27/2017	Whiteface Mountain
UND002	Flow Only	EPA	9/28/2017	Underhill

In addition to the sites listed in Table 2 that were visited for complete audits, the sites listed in Table 3 were visited to conduct Through-The-Probe (TTP) pollutant Performance Evaluations (PE).

Table 3. TTP Pollutant PE Visits

<u>Side ID</u>	<u>PE Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
ROM206	NOy	EPA	7/13/2017	Rocky Mountain NP
PND165	NOy	BLM/EPA	7/15/2017	Pinedale
KEF112	Ozone	EPA	8/16/2017	Kane Experimental Forest
MKG113	Ozone	EPA	8/17/2017	M. K. Goddard St. Park
ABT147	Ozone	EPA	8/21/2017	Abington
NPT006	Ozone	EPA	8/22/2017	Nez Perce Tribe

<u>Side ID</u>	<u>PE Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	<u>Station Name</u>
CRMO	Ozone	NPS	8/23/2017	Craters of the Moon NP
WST109	Ozone	EPA	8/24/2017	Woodstock

1.4 Audit Results

The observations and results of the systems and performance audits are included in Appendix A, *CASTNET Audit Report Forms* by site, arranged by audit date.

Photographs of site conditions are included within each systems report where necessary.

Copies of the spot reports that were sent immediately following the audit of each site are included as Appendix B, *CASTNET Site Spot Report Forms*.

The Ozone PE results and observations are included in Appendix C, *CASTNET Ozone Performance Evaluation Forms*.

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates three precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The Atmospheric Integrated Research Monitoring Network (AIRMoN) began operation in 1992 and currently measures event based precipitation events at 6 sites. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from more than 120 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry.

The NADP Program Office operates and administers the three precipitation chemistry networks (NTN, MDN and AIRMoN), two atmospheric concentration networks (AMNet and AMoN), two analytical laboratories (the Central Analytical Laboratory (CAL) located at the University of Illinois/Illinois State Water Survey and the Mercury Analytical Laboratory (HAL) located at Eurofins Frontier Global Sciences), and the network equipment depot (NED).

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites along with its operations. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 NADP Sites Visited Third Quarter 2017

This report covers the results from the NADP sites surveyed during the third quarter (July through September) of 2017. The station names and dates of the audits are presented in Table 4.

Table 4. Sites Surveyed – Third Quarter 2017

<u>Side ID</u>	<u>Network</u>	<u>Visit Date</u>	<u>Station Name</u>
CO15	NTN	7/26/2017	Sand Spring
NC45	NTN	7/17/2017	Mt. Mitchell
VA00	NTN	7/24/2017	Charlottesville
VA13	NTN	7/18/2017	Horton's Station
VA24	NTN/AMoN	7/25/2017	Prince Edward
VA99	NTN	7/19/2017	Natural Bridge Station
WV04	NTN	7/19/2017	Babcock State Park
CO19	NTN	8/1/2017	Rocky Mountain National Park - Beaver Meadow
CT15	NTN/AMoN	8/21/2017	Abington
MT97	NTN	8/15/2017	Lost Trail Pass
ND08	NTN	8/31/2017	Icelandic State Park
ND11	NTN	8/30/2017	Woodworth
NH02	NTN/AMoN	8/22/2017	Hubbard Brook
NY01	NTN	8/15/2017	Alfred
NY52	NTN	8/15/2017	Bennett Bridge
NY68	MDN/NTN	8/13/2017	Biscuit Brook
NY99	NTN	8/14/2017	West Point
PA18	NTN	8/26/2017	Young Woman's Creek
PA29	AMoN	8/16/2017	Kane Experimental Forest
PA90	NTN	8/19/2017	Hills Creek State Park

<u>Side ID</u>	<u>Network</u>	<u>Visit Date</u>	<u>Station Name</u>
VT01	NTN	8/22/2017	Bennington
VT99	MDN/NTN/AMoN	8/23/2017	Underhill
WA98	NTN	8/18/2017	Columbia River Gorge
WV18	AMoN	8/27/2017	Parsons
WV99	AIRMoN	8/27/2017	Canaan Valley Institute
MN16	MDN/NTN	9/6/2017	Marcell Experimental Forest
MN18	MDN/NTN/AMoN	9/5/2017	Fernberg
NE98	AMoN	9/7/2017	Santee
PA15	AIRMoN	8/18/2017	Penn State
NY98	NTN/AMoN	9/27/2017	Whiteface

2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to EEMS' server where the NADP PO and the U.S. EPA POs can access them and download them as needed by login into the server site.

Given the volume of data generated, and the fact that data is distributed and/or is available through EEMS' server, no survey results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

PND165-Martin Valvur-07/15/2017

1	7/15/2017	Computer	Dell	07048	Inspiron 15	B72MC12
2	7/15/2017	DAS	Campbell	000403	CR3000	2516
3	7/15/2017	Elevation	Elevation	None	1	None
4	7/15/2017	Filter pack flow pump	Thomas	00534	107CA18	0000162757
5	7/15/2017	Flow Rate	Apex	000549	AXMC105LPMDPCV	illegible
6	7/15/2017	Infrastructure	Infrastructure	none	none	none
7	7/15/2017	Modem	Raven	06608	V4221-V	0844349088
8	7/15/2017	Noy	Teledyne	000795	T200U	101
9	7/15/2017	Ozone	ThermoElectron Inc	000619	49i A1NAA	1009241791
10	7/15/2017	Ozone Standard	ThermoElectron Inc	000329	49i A3NAA	0622717853
11	7/15/2017	Precipitation	Texas Electronics	none	TR-525i-HT	59576-414
12	7/15/2017	Relative Humidity	Vaisala	05026	HMP50	Z4320017
13	7/15/2017	Sample Tower	Aluma Tower	000055	B	AT-81213-J12
14	7/15/2017	Shelter Temperature	Campbell	none	107-L	none
15	7/15/2017	Siting Criteria	Siting Criteria	None	1	None
16	7/15/2017	Solar Radiation	Licor	missing	Pyranometer	PY77051
17	7/15/2017	Surface Wetness	RM Young	illegible	58101	none
18	7/15/2017	Temperature	RM Young	06539	41342	14800
19	7/15/2017	Temperature2meter	RM Young	06305	41342VC	12544
20	7/15/2017	Wind Direction	RM Young	00853	05305	39243wdr
21	7/15/2017	Wind Speed	RM Young	00853	05305	39243wsp
22	7/15/2017	Zero air pump	Werther International	06881	C 70/4	000815264

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		PND165	Martin Valvur	07/15/2017	Flow Rate	000549

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.31%	1.31%

Cal Factor Zero	-0.04
Cal Factor Full Scale	0.94
Rotometer Reading:	3.45

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	-0.03	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	-0.03	l/m	l/m	
primary	test pt 1	3.057	3.050	3.03	0.000	3.01	l/m	l/m	-1.31%
primary	test pt 2	3.060	3.050	3.03	0.000	3.01	l/m	l/m	-1.31%
primary	test pt 3	3.062	3.050	3.04	0.000	3.01	l/m	l/m	-1.31%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	225 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241791		PND165	Martin Valvur	07/15/2017	Ozone	000619

Slope:	0.97341	Slope:	0.00000
Intercept	-0.24393	Intercept	0.00000
CorrCoff	0.99995	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
4.2%	6.4%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.23	0.21	0.55	ppb	
primary	2	15.63	15.54	14.55	ppb	-6.37%
primary	3	34.69	34.51	33.08	ppb	-4.14%
primary	4	63.81	63.50	61.29	ppb	-3.48%
primary	5	110.92	110.39	107.50	ppb	-2.62%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	-0.60	Status	pass
Sensor Component	Span	Condition	1.033	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	100.7 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.0 lpm	Status	Fail
Sensor Component	Cell A Pressure	Condition	568.0 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.7 C	Status	pass
Sensor Component	Cell B Freq.	Condition	92.5 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.4 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.0 lpm	Status	Fail
Sensor Component	Cell B Pressure	Condition	567.4 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	39243wsp		PND165	Martin Valvur	07/15/2017	Wind Speed	00853

Mfg	RM Young	Parameter	wind speed
Serial Number	CA4353	Tfer Desc.	wind speed motor (h
Tfer ID	01457		
Slope	1.00000	Intercept	0.00000
Cert Date	4/13/2017	CorrCoff	1.00000

Prop or Cups SN
Prop or Cups Torque to
Prop Correction Fact

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.05"/>	<input type="text" value="0.00%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.20"/>	<input type="text" value="0.00%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	Input Device	Input RPM	Input m/s	Out V	DAS m/s	Diff/ %Diff	Diff	WsM
primary	none	0	0.20	0.0	0.0		-0.20	
primary	01457	200	1.02	0.0	1.0		0.00	
primary	01457	400	2.05	0.0	2.1		0.00	
primary	01457	800	4.10	0.0	4.1		0.00	
primary	01457	1200	6.14	0.0	6.1	0.00%		
primary	01457	2400	12.29	0.0	12.3	0.00%		
primary	01457	4000	20.48	0.0	20.5	0.00%		
primary	01457	9400	48.13	0.0	48.1	0.00%		

Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Prop or Cups Condition	Condition	Good	Status	pass
Sensor Component	Sensor Heater	Condition	N/A	Status	pass
Sensor Component	Torque	Condition		Status	pass
Sensor Component	Sensor Plumb	Condition	Plumb	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	39243wdr		PND165	Martin Valvur	07/15/2017	Wind Direction	00853

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/1/2006"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/8/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Orientation	Linearity:	Orientation	Linearity:
Abs Avg Err	<input type="text" value="2.8"/>	<input type="text" value="0.7"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="4"/>	<input type="text" value="2"/>	<input type="text"/>	<input type="text"/>

UseDescription	TferID	Input Raw	Linearity	Output V	Output Deg.	Difference	Change	Error
primary	01266	0	<input checked="" type="checkbox"/>	0.000	2	2	46.3	1.3
primary	01266	45	<input checked="" type="checkbox"/>	0.000	47	2	44.6#####	
primary	01266	90	<input checked="" type="checkbox"/>	0.000	93	2	45.6#####	
primary	01266	135	<input checked="" type="checkbox"/>	0.000	137	2	44.4#####	
primary	01266	180	<input checked="" type="checkbox"/>	0.000	180	0	43.4#####	
primary	01266	225	<input checked="" type="checkbox"/>	0.000	226	1	45.5	0.5
primary	01266	270	<input checked="" type="checkbox"/>	0.000	271	0	44.7#####	
primary	01266	315	<input checked="" type="checkbox"/>	0.000	316	1	45.5	0.5
primary	01265	1	<input type="checkbox"/>	0.000	4	3		3
primary	01265	91	<input type="checkbox"/>	0.000	95	4		4
primary	01265	181	<input type="checkbox"/>	0.000	180	1		1
primary	01265	271	<input type="checkbox"/>	0.000	274	3		3

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14800		PND165	Martin Valvur	07/15/2017	Temperature	06539

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.20	0.30		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.07	0.04	0.000	0.34	C	0.3
primary	Temp Mid Range	24.29	24.26	0.000	24.27	C	0.01
primary	Temp High Range	47.52	47.49	0.000	47.77	C	0.28

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12544		PND165	Martin Valvur	07/15/2017	Temperature2meter	06305

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.21	0.48		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.07	0.04	0.000	0.52	C	0.48
primary	Temp Mid Rang	24.29	24.26	0.000	24.18	C	-0.08
primary	Temp High Rang	47.52	47.49	0.000	47.57	C	0.08

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	Z4320017		PND165	Martin Valvur	07/15/2017	Relative Humidity	05026

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	75296	Tfer Desc.	GTL
Tfer ID	01220		
Slope	0.99780	Intercept	0.06850
Cert Date	1/23/2017	CorrCoff	0.99994

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	3.6	0.7		
Abs Max Er	4.6	0.7		

UseDesc.	Test type	Device	Input RH	GTL Raw	RH Corr.	DAS Volts	DAS %RH	Difference
primary	RH Low Range	GTL	32.8	31.7	32.8	0.000	30.2	-2.6
primary	RH Low Range	GTL	52.9	50.3	52.9	0.000	48.3	-4.6
primary	RH High Range	GTL	93.6	88.9	93.6	0.000	92.9	-0.7

Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Solar Radiation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Licor	PY77051		PND165	Martin Valvur	07/15/2017	Solar Radiation	missing

Mfg	Eppley	Parameter	solar radiation
Serial Number	23824	Tfer Desc.	SR transfer sensor
Tfer ID	01247		
Slope	1.00000	Intercept	0.00000
Cert Date	2/16/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
% Diff of Avg	%Diff of Max	%Diff of Avg	%Diff of Max
2.6%	3.0%	0.0%	0.0%

UseDescription	Measure Date	MeasureTime	Tfer Raw	Tfer Corr	DAS w/m2	PctDifference
primary	7/15/2017	12:00	880	880	906	3.0%
primary	7/15/2017	13:00	558	558	550	-1.5%
primary	7/15/2017	14:00	123	122	96	-21.1%
primary	7/15/2017	15:00	266	266	226	-14.9%

Sensor Component	Sensor Clean	Condition	Clean	Status	pass
Sensor Component	Sensor Level	Condition	Level	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Texas Electronics	59576-414		PND165	Martin Valvur	07/15/2017	Precipitation	none

DAS 1:		DAS 2:	
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
4.6%	5.6%		

Mfg	PMP	Parameter	Precipitation
Serial Number	None	Tfer Desc.	250ml graduate
Tfer ID	01249		
Slope	1.00000	Intercept	0.00000
Cert Date	4/26/2013	CorrCoff	1.00000

UseDesc.	Test type	TferVolume	Iteration	TimePerTip	Eq.Ht	DAS eng	Eq.HtUnit	OSE Unit	TferUnits	PctDifference
primary	test 1	250	1	8 - 10 sec	0.54	0.51	in	in	ml	-5.6%
primary	test 2	250	2	8 - 10 sec	0.54	0.52	in	in	ml	-3.7%

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Installed	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Sensor Heater	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Surface Wetness Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	none		PND165	Martin Valvur	07/15/2017	Surface Wetness	illegible

Mfg	Ohmite	Parameter	surface wetness
Serial Number	296-1200	Tfer Desc.	decade box
Tfer ID	01210		
Slope	1.00000	Intercept	0.00000
Cert Date	1/4/2011	CorrCoff	1.00000

Manual Test Pass

UseDescription	Test Type	Tfer kOhms	OutputSignal	DAS eng	OutputSignalEngUni	TferUnits	OutputSignalUnit
primary	dry	N/A	0.000	1.01	V	N/A	V
primary	wet	N/A	0.000	1.01	V	N/A	V

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Grid Clean	Condition	Clean	Status	pass
Sensor Component	Grid Angle	Condition	About 30 deg	Status	pass
Sensor Component	Grid Orientation	Condition	North	Status	pass
Sensor Component	Grid Condition	Condition	Fair	Status	pass
Sensor Component	Grid Type	Condition	Grid without holes	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	Fail

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	PND165	Martin Valvur	07/15/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.60	1.12		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.64	25.61	0.000	26.7	C	1.12
primary	Temp Mid Range	26.90	26.87	0.000	27.1	C	0.2
primary	Temp Mid Range	27.12	27.09	0.000	27.6	C	0.47

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-22)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	PND165	Martin Valvur	07/15/2017	Cell B Flow	ThermoElectron	3360	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Ozone	PND165	Martin Valvur	07/15/2017	Cell A Flow	ThermoElectron	3360	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								
Surface Wetness	PND165	Martin Valvur	07/15/2017	System Memo	RM Young	2855	<input type="checkbox"/>	<input checked="" type="checkbox"/>
This measurement system is damaged and not functioning.								

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator was unable to meet the audit team during the site audit. Audit data was obtained by reviewing the on-site documentation and from previous audits.

2 **Parameter:** SitingCriteriaCom

Construction at the bottom of the hill and entrance to the site access road has been completed.

3 **Parameter:** ShelterCleanNotes

The shelter is well maintained.

4 **Parameter:** MetSensorComme

The RH sensor is now mounted in a shield. Both the RH and temperature sensors are mounted above the shelter. The surface wetness sensor is no longer functioning and always indicates a wet response.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Fremont Lake South"/>
Operating Group	<input type="text" value="Private / BLM"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="56-035-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="42.9214"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-109.7900"/>
Land Use	<input type="text" value="range"/>	QAPP Elevation Meters	<input type="text" value="2388"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="12.75"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="2/22/2006"/>
Site Telephone	<input type="text" value="(307) 367-6584"/>	Audit Latitude	<input type="text" value="42.929031"/>
Site Address 1	<input type="text" value="Skyline Drive"/>	Audit Longitude	<input type="text" value="-109.787796"/>
Site Address 2	<input type="text" value="Fremont Lake Rd."/>	Audit Elevation	<input type="text" value="2386"/>
County	<input type="text" value="Sublette"/>	Audit Declination	<input type="text" value="10.9"/>
City, State	<input type="text" value="Pinedale, WY"/>		
Zip Code	<input type="text" value="82941"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2015"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2149-22)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is well maintained."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|--------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | Over shelter |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | Over shelter |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The RH sensor is now mounted in a shield. Both the RH and temperature sensors are mounted above the shelter. The surface wetness sensor is no longer functioning and always indicates a wet response.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

- 1 Do all the meteorological sensors appear to be intact, in good condition, and well maintained?
- 2 Are all the meteorological sensors operational online, and reporting data?
- 3 Are the shields for the temperature and RH sensors clean?
- 4 Are the aspirated motors working?
- 5 Is the solar radiation sensor's lens clean and free of scratches?
- 6 Is the surface wetness sensor grid clean and undamaged?
- 7 Are the sensor signal and power cables intact, in good condition, and well maintained?
- 8 Are the sensor signal and power cable connections protected from the elements and well maintained?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|----------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons approximately 80%
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator was unable to meet the audit team during the site audit. Audit data was obtained by reviewing the on-site documentation and from previous audits.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID Technician Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	B72MC12	07048
DAS	Campbell	CR3000	2516	000403
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	0000162757	00534
Flow Rate	Apex	AXMC105LPMDPC	illegible	000549
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0844349088	06608
Noy	Teledyne	T200U	101	000795
Ozone	ThermoElectron Inc	49i A1NAA	1009241791	000619
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717853	000329
Precipitation	Texas Electronics	TR-525i-HT	59576-414	none
Relative Humidity	Vaisala	HMP50	Z4320017	05026
Sample Tower	Aluma Tower	B	AT-81213-J12	000055
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Solar Radiation	Licor	Pyranometer	PY77051	missing
Surface Wetness	RM Young	58101	none	illegible
Temperature	RM Young	41342	14800	06539
Temperature2meter	RM Young	41342VC	12544	06305
Wind Direction	RM Young	05305	39243wdr	00853
Wind Speed	RM Young	05305	39243wsp	00853
Zero air pump	Werther International	C 70/4	000815264	06881

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

BAS601-Martin Valvur-07/17/2017

1	7/17/2017	DAS	Campbell	none	CR1000	unknown1
2	7/17/2017	elevation	Elevation	none	none	none
3	7/17/2017	Filter pack flow pump	Thomas	none	107CAB18	099800009743
4	7/17/2017	Flow Rate	Omega	none	FMA6518ST-RS232	318559-1
5	7/17/2017	Infrastructure	Infrastructure	none	none	none
6	7/17/2017	Met tower	unknown	none	unknown	none
7	7/17/2017	Ozone	ThermoElectron Inc	L0534684	49i A1NAA	1214552973
8	7/17/2017	Ozone Standard	ThermoElectron Inc	none	49i E3CAA	1214552971
9	7/17/2017	Precipitation	Met One	T15382	385	T15382
10	7/17/2017	Relative Humidity	Vaisala	none	HMP45AC	C2410012
11	7/17/2017	Shelter Temperature	unknown	none	unknown	none
12	7/17/2017	siting criteria	Siting Criteria	none	none	None
13	7/17/2017	Solar Radiation	Licor	none	LI-200	PY47987
14	7/17/2017	Temperature2meter	Vaisala	none	HMP45AC	C2410012
15	7/17/2017	Wind Direction	Met One	none	024	M5198
16	7/17/2017	Wind Speed	Met One	W4806	014	W4806
17	7/17/2017	Zero air pump	Thomas	none	107CAB18	100800033636

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	unknown1	BAS601	Martin Valvur	07/17/2017	DAS	Primary

Das Date:	<input type="text" value="7 /17/2017"/>	Audit Date	<input type="text" value="7 /17/2017"/>
Das Time:	<input type="text" value="7:00:00"/>	Audit Time	<input type="text" value="7:00:00"/>
Das Day:	<input type="text" value="198"/>	Audit Day	<input type="text" value="198"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Omega	318559-1		BAS601	Martin Valvur	07/17/2017	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
3.98%	4.90%

Cal Factor Zero	0.298
Cal Factor Full Scale	0.993
Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.30	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.30	l/m	l/m	
primary	test pt 1	3.129	3.120	0.00	0.000	3.27	l/m	l/m	4.90%
primary	test pt 2	3.172	3.160	0.00	0.000	3.28	l/m	l/m	3.70%
primary	test pt 3	3.179	3.170	0.00	0.000	3.28	l/m	l/m	3.34%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	6.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	-3.0 cm	Status	Fail
Sensor Component	Filter Azimuth	Condition	30 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1214552973		BAS601	Martin Valvur	07/17/2017	Ozone	L0534684

Slope:	0.99633	Slope:	0.00000
Intercept	0.22520	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.5%	1.5%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.25	0.23	0.55	ppb	
primary	2	15.26	15.17	15.39	ppb	1.45%
primary	3	37.23	37.04	36.98	ppb	-0.16%
primary	4	63.29	62.98	62.88	ppb	-0.16%
primary	5	110.21	109.68	109.60	ppb	-0.07%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	-0.4	Status	pass
Sensor Component	Span	Condition	1.024	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	106.1 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	646.2 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	45.3 C	Status	Fail
Sensor Component	Cell B Freq.	Condition	75.7 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	645.7 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	W4806		BAS601	Martin Valvur	07/17/2017	Wind Speed	W4806

Prop or Cups SN
Prop or Cups Torque to
Prop Correction Fact

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (l"/>
Tfer ID	<input type="text" value="01261"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2017"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text" value="CA4353"/>	Tfer Desc.	<input type="text" value="wind speed motor (h"/>
Tfer ID	<input type="text" value="01457"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="4/13/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.18"/>	<input type="text" value="1.03%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.30"/>	<input type="text" value="2.61%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	Input Device	Input RPM	Input m/s	Out V	DAS m/s	Diff/ %Diff	Diff	WsM
primary	none	0	0.20	0.0	0.0		-0.20	
primary	01261	40	1.67	0.0	1.7		-0.02	
primary	01261	80	2.75	0.0	2.5		-0.30	
primary	01261	140	4.26	0.0	4.5		0.19	
primary	01261	210	6.07	0.0	6.1	-0.33%		
primary	01457	400	11.11	0.0	11.2	1.17%		
primary	01457	800	22.22	0.0	21.6	-2.61%		
primary	01457	1800	48.44	0.0	48.4	0.00%		

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Prop or Cups Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	M5198		BAS601	Martin Valvur	07/17/2017	Wind Direction	none

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/1/2006"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/8/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

DAS 1:	DAS 2:
Orientation	Orientation
Linearity:	Linearity:
Abs Avg Err <input type="text" value="1.8"/>	<input type="text"/>
Abs Max Er <input type="text" value="3"/>	<input type="text"/>

UseDescription	TferID	Input Raw	Linearity	Output V	Output Deg.	Difference	Change	Error
primary	01265	2	<input type="checkbox"/>	0.000	2	0		0
primary	01265	92	<input type="checkbox"/>	0.000	91	1		1
primary	01265	182	<input type="checkbox"/>	0.000	179	3		3
primary	01265	272	<input type="checkbox"/>	0.000	269	3		3

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text" value="See comments"/>	Status	<input type="text" value="pass"/>

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2410012		BAS601	Martin Valvur	07/17/2017	Temperature2meter	none

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
2.31	3.17		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	4.50	4.47	0.000	7.20	C	2.73
primary	Temp Mid Rang	24.50	24.47	0.000	25.50	C	1.03
primary	Temp High Rang	42.70	42.67	0.000	39.50	C	-3.17

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2410012		BAS601	Martin Valvur	07/17/2017	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	75296	Tfer Desc.	GTL
Tfer ID	01220		
Slope	0.99780	Intercept	0.06850
Cert Date	1/23/2017	CorrCoff	0.99994

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	1.3	7.4		
Abs Max Er	1.4	7.4		

UseDesc.	Test type	Device	Input RH	GTL Raw	RH Corr.	DAS Volts	DAS %RH	Difference
primary	RH Low Range	GTL	32.8	32.6	32.8	0.000	31.4	-1.4
primary	RH Low Range	GTL	52.9	52.4	52.9	0.000	51.8	-1.1
primary	RH High Range	GTL	93.6	89.5	93.6	0.000	86.2	-7.4

Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	T15382	BAS601	Martin Valvur	07/17/2017	Precipitation	T15382

DAS 1:		DAS 2:	
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
9.7%	14.5%		

Mfg	PMP	Parameter	Precipitation
Serial Number	None	Tfer Desc.	250ml graduate
Tfer ID	01249		
Slope	1.00000	Intercept	0.00000
Cert Date	4/26/2013	CorrCoff	1.00000

UseDesc.	Test type	TferVolume	Iteration	TimePerTip	Eq.Ht	DAS eng	Eq.HtUnit	OSE Unit	TferUnits	PctDifference
primary	test 1	250	1	8 - 10 sec	7.67	6.56	mm	mm	ml	-14.5%
primary	test 2	250	2	13 - 15 sec	7.67	7.11	mm	mm	ml	-7.3%
primary	test 3	250	3	13 - 15 sec	7.67	7.11	mm	mm	ml	-7.3%

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Installed	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Sensor Heater	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Solar Radiation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Licor	PY47987		BAS601	Martin Valvur	07/17/2017	Solar Radiation	none

Mfg	Eppley	Parameter	solar radiation
Serial Number	23824	Tfer Desc.	SR transfer sensor
Tfer ID	01247		
Slope	1.00000	Intercept	0.00000
Cert Date	2/16/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
% Diff of Avg	%Diff of Max	%Diff of Avg	%Diff of Max
2.5%	4.4%	0.0%	0.0%

UseDescription	Measure Date	MeasureTime	Tfer Raw	Tfer Corr	DAS w/m2	PctDifference
primary	7/17/2017	7:00	443	443	453	2.2%
primary	7/17/2017	8:00	621	621	624	0.5%
primary	7/17/2017	9:00	793	793	783	-1.2%
primary	7/17/2017	10:00	893	893	862	-3.5%
primary	7/17/2017	11:00	959	958	920	-4.0%
primary	7/17/2017	12:00	985	985	942	-4.4%
primary	7/17/2017	13:00	809	809	783	-3.2%

Sensor Component	Sensor Clean	Condition	Clean	Status	pass
Sensor Component	Sensor Level	Condition	Level	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
unknown	none	BAS601	Martin Valvur	07/17/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
2.16	2.72		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	27.41	27.38	0.000	30.1	C	2.72
primary	Temp Mid Range	28.89	28.86	0.000	30.4	C	1.54
primary	Temp Mid Range	28.52	28.49	0.000	30.7	C	2.21

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Shelter One"/>	<input type="text" value="AR 263648"/>	<input type="text" value="24 cuft"/>
Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Other"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
-----------	------	------------	-----------	-----------	-----	------------	--------	---------

Flow Rate	BAS601	Martin Valvur	07/17/2017	Filter Depth	Omega	3806	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-----------	--------	---------------	------------	--------------	-------	------	--------------------------	-------------------------------------

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

Ozone	BAS601	Martin Valvur	07/17/2017	Cell A Tmp.	ThermoElectron	3802	<input type="checkbox"/>	<input type="checkbox"/>
-------	--------	---------------	------------	-------------	----------------	------	--------------------------	--------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 Parameter: SiteOpsProcComm

There are no clean spare filter caps or Ziploc filter bags on site as was the case during the previous site audit visit. The bag and caps for the received filter are being used to send the removed filter back to the lab. The importance of keeping the shipping material with each filter was discussed with the operator. Some additional information regarding completion of the SSRF was provided to the site operator.

2 Parameter: SiteOpsProcedures

The ozone inlet filter is replaced each month.

3 Parameter: DocumentationCo

The filter pack chain-of-custody labels are not being used.

4 Parameter: ShelterCleanNotes

The enclosure houses the ozone, DAS, and MFC only.

5 Parameter: MetSensorComme

Some objects violate the 45 degree rule for the tipping bucket rain gage. The Temperature shield is mounted on the south side of the tower tripod at 2 meters.

6 Parameter: MetOpMaintCom

The site utilizes a combination sensor for humidity and temperature. It was audited without submersion in a water bath. The temperature sensor is mounted at approximately 2 meters from the ground. The accuracy of the DAS was not tested due to no available channels for the test equipment. The wind direction sensor was not functioning upon arrival for the site audit. The site operator provided a replacement sensor which had been shipped from ARS. EEMS assisted the operator with the installation of the replacement sensor. The wind direction audit results are provided for the replacement sensor.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text"/>
Operating Group	<input type="text" value="BLM"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="56-003-0002"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text"/>		
Air Pollutant Analyzer	<input type="text"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="44.279947"/>
Site Address 1	<input type="text"/>	Audit Longitude	<input type="text" value="-108.04082"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="1241"/>
County	<input type="text" value="Big Horn"/>	Audit Declination	<input type="text" value="10.3"/>
City, State	<input type="text" value="Basin, WY"/>		
Zip Code	<input type="text" value="82410"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text"/>
Time Zone	<input type="text" value="Mountain"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input type="checkbox"/>	Make <input type="text" value="Shelter One"/>	Model <input type="text" value="AR 263648"/>	Shelter Size <input type="text" value="24 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The enclosure houses the ozone, DAS, and MFC only."/>		
Site OK <input type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text"/>		

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text"/>
Operating Group	<input type="text" value="BLM"/>	Map Scale	<input type="text"/>

AQS #	56-003-0002	Map Date	
Meteorological Type			
Air Pollutant Analyzer		QAPP Latitude	
Deposition Measurement		QAPP Longitude	
Land Use		QAPP Elevation Meters	
Terrain		QAPP Declination	
Conforms to MLM		QAPP Declination Date	
Site Telephone		Audit Latitude	44.279947
Site Address 1		Audit Longitude	-108.04082
Site Address 2		Audit Elevation	1241
County	Big Horn	Audit Declination	10.3
City, State	Basin, WY		
Zip Code	82410	Fire Extinguisher <input type="checkbox"/>	
Time Zone	Mountain	First Aid Kit <input type="checkbox"/>	
Primary Operator		Safety Glasses <input type="checkbox"/>	
Primary Op. Phone #		Safety Hard Hat <input type="checkbox"/>	
Primary Op. E-mail		Climbing Belt <input type="checkbox"/>	
Backup Operator		Security Fence <input type="checkbox"/>	
Backup Op. Phone #		Secure Shelter <input type="checkbox"/>	
Backup Op. E-mail		Stable Entry Step <input type="checkbox"/>	
Shelter Working Room <input type="checkbox"/>	Make		Shelter Size
		Model	
Shelter Clean <input type="checkbox"/>	Notes		
Site OK <input type="checkbox"/>	Notes		
Driving Directions			

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	100 m	<input type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input type="checkbox"/>
Major industrial complex	10 to 20 km		<input type="checkbox"/>
City > 50,000 population	40 km		<input type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input type="checkbox"/>
Major highway, airport or rail yard	2 km		<input type="checkbox"/>
Secondary road, heavily traveled	500 m		<input type="checkbox"/>
Secondary road, lightly traveled	200 m		<input type="checkbox"/>
Feedlot operations	500 m		<input type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input type="checkbox"/>
Limited agricultural operations	200 m		<input type="checkbox"/>
Large parking lot	200 m		<input type="checkbox"/>
Small parking lot	100 m		<input type="checkbox"/>
Tree line	50 m		<input type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID Technician Site Visit Date

- 1 Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?
- 2 Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)
- 3 Are the tower and sensors plumb?
- 4 Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? Pointing south
- 5 Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)
- 6 Is the solar radiation sensor plumb?
- 7 Is it sited to avoid shading, or any artificial or reflected light?
- 8 Is the rain gauge plumb?
- 9 Is it sited to avoid sheltering effects from buildings, trees, towers, etc? 45 degree rule violation
- 10 Is the surface wetness sensor sited with the grid surface facing north? N/A
- 11 Is it inclined approximately 30 degrees? N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Some objects violate the 45 degree rule for the tipping bucket rain gage. The Temperature shield is mounted on the south side of the tower tripod at 2 meters.

Site ID Technician Site Visit Date

- 1 Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?
- 2 Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)

- | | | |
|--|--------------------------|--|
| 3 Are the tower and sensors plumb? | <input type="checkbox"/> | |
| 4 Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input type="checkbox"/> | |
| 5 Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input type="checkbox"/> | |
| 6 Is the solar radiation sensor plumb? | <input type="checkbox"/> | |
| 7 Is it sited to avoid shading, or any artificial or reflected light? | <input type="checkbox"/> | |
| 8 Is the rain gauge plumb? | <input type="checkbox"/> | |
| 9 Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | |
| 10 Is the surface wetness sensor sited with the grid surface facing north? | <input type="checkbox"/> | |
| 11 Is it inclined approximately 30 degrees? | <input type="checkbox"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID Technician Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site utilizes a combination sensor for humidity and temperature. It was audited without submersion in a water bath. The temperature sensor is mounted at approximately 2 meters from the ground. The accuracy of the DAS was not tested due to no available channels for the test equipment. The wind direction sensor was not functioning upon arrival for the site audit. The site operator provided a replacement sensor which had been shipped from ARS. EEMS assisted the operator with the installation of the replacement sensor. The wind direction audit results are provided for the replacement sensor.

Site ID Technician Site Visit Date

- | | | | |
|----------|---|--------------------------|--|
| 1 | Do all the meteorological sensors appear to be intact, in good condition, and well maintained? | <input type="checkbox"/> | |
| 2 | Are all the meteorological sensors operational online, and reporting data? | <input type="checkbox"/> | |
| 3 | Are the shields for the temperature and RH sensors clean? | <input type="checkbox"/> | |
| 4 | Are the aspirated motors working? | <input type="checkbox"/> | |
| 5 | Is the solar radiation sensor's lens clean and free of scratches? | <input type="checkbox"/> | |
| 6 | Is the surface wetness sensor grid clean and undamaged? | <input type="checkbox"/> | |
| 7 | Are the sensor signal and power cables intact, in good condition, and well maintained? | <input type="checkbox"/> | |
| 8 | Are the sensor signal and power cable connections protected from the elements and well maintained? | <input type="checkbox"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 15 meters
3/8 nylon by 15 meters
At inlet only
Not present
Not present

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|----------|---|--------------------------|--|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | |
| 4 | Describe dry dep sample tube. | | |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input type="checkbox"/> | |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input type="checkbox"/> | |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input type="checkbox"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
- 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
- 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Not present
- 4 Are the signal connections protected from the weather and well maintained?
- 5 Are the signal leads connected to the correct DAS channel?
- 6 Are the DAS, sensor translators, and shelter properly grounded?
- 7 Does the instrument shelter have a stable power source?
- 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 10 Is the sample tower stable and grounded?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 11 Tower comments?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

1	Do the DAS instruments appear to be in good condition and well maintained?	<input type="checkbox"/>								
2	Are all the components of the DAS operational? (printers, modem, backup, etc)	<input type="checkbox"/>								
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?	<input type="checkbox"/>								
4	Are the signal connections protected from the weather and well maintained?	<input type="checkbox"/>								
5	Are the signal leads connected to the correct DAS channel?	<input type="checkbox"/>								
6	Are the DAS, sensor translators, and shelter properly grounded?	<input type="checkbox"/>								
7	Does the instrument shelter have a stable power source?	<input type="checkbox"/>								
8	Is the instrument shelter temperature controlled?	<input type="checkbox"/>								
9	Is the met tower stable and grounded?	<table border="1"> <tr> <td>Stable</td> <td></td> <td>Grounded</td> <td></td> </tr> <tr> <td><input type="checkbox"/></td> <td></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>	Stable		Grounded		<input type="checkbox"/>		<input type="checkbox"/>	
Stable		Grounded								
<input type="checkbox"/>		<input type="checkbox"/>								
10	Is the sample tower stable and grounded?	<table border="1"> <tr> <td><input type="checkbox"/></td> <td></td> <td><input type="checkbox"/></td> <td></td> </tr> </table>	<input type="checkbox"/>		<input type="checkbox"/>					
<input type="checkbox"/>		<input type="checkbox"/>								
11	Tower comments?									

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID Technician Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	Not present	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	in BLM office	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	in BLM office	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	in BLM office	<input checked="" type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>		<input type="checkbox"/>

- Is the station log properly completed during every site visit? Not present
- Are the Site Status Report Forms being completed and current?
- Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The filter pack chain-of-custody labels are not being used.

Site ID Technician Site Visit Date

Documentation

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters? Unknown
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? Unknown

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone inlet filter is replaced each month.

Site ID Technician Site Visit Date

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings 90% of the time
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> Not present	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There are no clean spare filter caps or Ziploc filter bags on site as was the case during the previous site audit visit. The bag and caps for the received filter are being used to send the removed filter back to the lab. The importance of keeping the shipping material with each filter was discussed with the operator. Some additional information regarding completion of the SSRF was provided to the site operator.

Site ID Technician Site Visit Date

Site operation procedures

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID Technician Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	unknown1	none
elevation	Elevation	none	none	none
Filter pack flow pump	Thomas	107CAB18	099800009743	none
Flow Rate	Omega	FMA6518ST-RS232	318559-1	none
Infrastructure	Infrastructure	none	none	none
Met tower	unknown	unknown	none	none
Ozone	ThermoElectron Inc	49i A1NAA	1214552973	L0534684
Ozone Standard	ThermoElectron Inc	49i E3CAA	1214552971	none
Precipitation	Met One	385	T15382	T15382
Relative Humidity	Vaisala	HMP45AC	C2410012	none
Shelter Temperature	unknown	unknown	none	none
siting criteria	Siting Criteria	none	None	none
Solar Radiation	Licor	LI-200	PY47987	none
Temperature2meter	Vaisala	HMP45AC	C2410012	none
Wind Direction	Met One	024	M5198	none
Wind Speed	Met One	014	W4806	W4806
Zero air pump	Thomas	107CAB18	100800033636	none

Site ID Technician Site Visit Date

Site Visit Sensors

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

VPI120-Sandy Grenville-07/18/2017

1	7/18/2017	Computer	Dell	07032	Inspiron 15	Unknown
2	7/18/2017	DAS	Campbell	000402	CR3000	2514
3	7/18/2017	Elevation	Elevation	None	1	None
4	7/18/2017	Filter pack flow pump	Thomas	02751	107CAB18	1192001884
5	7/18/2017	Flow Rate	Apex	000591	AXMC105LPMDPCV	illegible
6	7/18/2017	Infrastructure	Infrastructure	none	none	none
7	7/18/2017	Modem	Raven	06586	V4221-V	0844350237
8	7/18/2017	Ozone	ThermoElectron Inc	000628	49i A1NAA	1009241786
9	7/18/2017	Ozone Standard	ThermoElectron Inc	000443	49i A3NAA	CM08200019
10	7/18/2017	Sample Tower	Aluma Tower	none	B	unknown
11	7/18/2017	Shelter Temperature	Campbell	none	107-L	none
12	7/18/2017	Siting Criteria	Siting Criteria	None	1	None
13	7/18/2017	Temperature	RM Young	04318	41342	4037
14	7/18/2017	Zero air pump	Werther International	06907	C 70/4	000829179

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2514	VPI120	Sandy Grenville	07/18/2017	DAS	Primary

Das Date:	<input type="text" value="7/18/2017"/>	Audit Date:	<input type="text" value="7/18/2017"/>
Das Time:	<input type="text" value="15:11:02"/>	Audit Time:	<input type="text" value="15:11:02"/>
Das Day:	<input type="text" value="199"/>	Audit Day:	<input type="text" value="199"/>

Low Channel:	High Channel:		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2997	0.2998	V	V	0.0001
7	0.5000	0.4996	0.4996	V	V	0.0000
7	0.7000	0.6996	0.6996	V	V	0.0000
7	0.9000	0.8994	0.8994	V	V	0.0000
7	1.0000	0.9992	0.9993	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		VPI120	Sandy Grenville	07/18/2017	Flow Rate	000591

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.67%	0.67%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.01
Cal Factor Full Scale	0.99
Rotometer Reading:	1.45

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.02	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.00	l/m	l/m	
primary	test pt 1	1.489	1.490	1.51	0.000	1.50	l/m	l/m	0.67%
primary	test pt 2	1.489	1.490	1.51	0.000	1.50	l/m	l/m	0.67%
primary	test pt 3	1.493	1.490	1.51	0.000	1.50	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241786		VPI120	Sandy Grenville	07/18/2017	Ozone	000628

Slope:	0.99078	Slope:	0.00000
Intercept	0.53153	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
0.6%	1.2%		

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.02	-0.43	0.41	ppb	
primary	2	15.00	14.50	14.68	ppb	1.24%
primary	3	35.11	34.56	34.72	ppb	0.46%
primary	4	68.00	67.37	67.07	ppb	-0.45%
primary	5	110.04	109.30	109.00	ppb	-0.27%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.60	Status	pass
Sensor Component	Span	Condition	1.007	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	79.1 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.68 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	664.8 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	37.4 C	Status	pass
Sensor Component	Cell B Freq.	Condition	85.4 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.68 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	665.1 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4037		VPI120	Sandy Grenville	07/18/2017	Temperature	04318

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.21	0.43		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.16	0.01	0.000	-0.1	C	-0.08
primary	Temp Mid Range	25.81	25.47	0.000	25.3	C	-0.13
primary	Temp High Range	49.47	48.95	0.000	48.5	C	-0.43

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	VPI120	Sandy Grenville	07/18/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.99	1.64		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.53	23.21	0.000	24.9	C	1.64
primary	Temp Mid Range	24.71	24.38	0.000	25.6	C	1.25
primary	Temp Mid Range	27.68	27.32	0.000	27.4	C	0.09

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2107-3)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** SitingCriteriaCom

The site is on a wooded hillside. The temperature sensor and sample inlet are at the tree tops of the downhill trees. The uphill tree line is 30 meters away.

2 **Parameter:** ShelterCleanNotes

The shelter is clean, neat, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Eggleston"/>
Operating Group	<input type="text" value="VA Tech"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="51-071-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="37.3300"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-80.5573"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="920"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="7.9"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="1/31/2007"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="37.329832"/>
Site Address 1	<input type="text" value="Mountain Lake Rd."/>	Audit Longitude	<input type="text" value="-80.55751"/>
Site Address 2	<input type="text" value="Jefferson National Forest"/>	Audit Elevation	<input type="text" value="920"/>
County	<input type="text" value="Giles"/>	Audit Declination	<input type="text" value="-7.8"/>
City, State	<input type="text" value="Newport, VA"/>		
Zip Code	<input type="text" value="24128"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2015"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2107-3)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is clean, neat, and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is on a wooded hillside. The temperature sensor and sample inlet are at the tree tops of the downhill trees. The uphill tree line is 30 meters away.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 18 meters
3/8 teflon by 18 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|---|-------------------|-----------------|--------------------------|--------------------------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 11 | Tower comments? | | Met tower removed | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07032
DAS	Campbell	CR3000	2514	000402
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	1192001884	02751
Flow Rate	Apex	AXMC105LPMDPC	illegible	000591
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0844350237	06586
Ozone	ThermoElectron Inc	49i A1NAA	1009241786	000628
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200019	000443
Sample Tower	Aluma Tower	B	unknown	none
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	4037	04318
Zero air pump	Werther International	C 70/4	000829179	06907

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

SHE604-Martin Valvur-07/18/2017

1	7/18/2017	DAS	Campbell	49923	CR1000	unknown2
2	7/18/2017	elevation	Elevation	none	none	none
3	7/18/2017	Flow Rate	Omega	none	FMA6518ST-RS232	32433-2
4	7/18/2017	Infrastructure	Infrastructure	none	none	none
5	7/18/2017	Precipitation	Met One	none	370C	N8139
6	7/18/2017	Relative Humidity	Vaisala	none	HMP45AC	C2730121
7	7/18/2017	Sample Tower	Unknown	none	Unknown	None
8	7/18/2017	siting criteria	Siting Criteria	none	none	None
9	7/18/2017	Solar Radiation	Licor	none	LI-200	illegible
10	7/18/2017	Temperature2meter	Vaisala	none	HMP45AC	C2730121
11	7/18/2017	Wind Direction	Met One	none	024	D3050
12	7/18/2017	Wind Speed	Met One	none	014	K2273

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	unknown2	SHE604	Martin Valvur	07/18/2017	DAS	Primary

Das Date:	<input type="text" value="7 /18/2017"/>	Audit Date	<input type="text" value="7 /18/2017"/>
Das Time:	<input type="text" value="8:00:00"/>	Audit Time	<input type="text" value="8:00:00"/>
Das Day:	<input type="text" value="199"/>	Audit Day	<input type="text" value="199"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0000"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Omega	32433-2		SHE604	Martin Valvur	07/18/2017	Flow Rate	none

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:	Cal Factor Zero	0.199
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	1.003
1.36%	2.37%	Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.20	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.20	l/m	l/m	
primary	test pt 1	3.296	3.290	0.00	0.000	3.21	l/m	l/m	-2.37%
primary	test pt 2	3.245	3.240	0.00	0.000	3.21	l/m	l/m	-0.99%
primary	test pt 3	3.236	3.230	0.00	0.000	3.21	l/m	l/m	-0.71%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	K2273		SHE604	Martin Valvur	07/18/2017	Wind Speed	none

Prop or Cups SN
Prop or Cups Torque to
Prop Correction Fact

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (l"/>
Tfer ID	<input type="text" value="01261"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2017"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text" value="CA4353"/>	Tfer Desc.	<input type="text" value="wind speed motor (h"/>
Tfer ID	<input type="text" value="01457"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="4/13/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.22"/>	<input type="text" value="0.83%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.40"/>	<input type="text" value="1.17%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	Input Device	Input RPM	Input m/s	Out V	DAS m/s	Diff/ %Diff	Diff	WsM
primary	none	0	0.20	0.0	0.6		0.40	
primary	01261	40	1.67	0.0	1.6		-0.03	
primary	01261	80	2.75	0.0	2.5		-0.27	
primary	01261	140	4.26	0.0	4.4		0.18	
primary	01261	210	6.07	0.0	6.1	-0.33%		
primary	01457	400	11.11	0.0	11.2	1.17%		
primary	01457	800	22.22	0.0	22.0	-0.81%		
primary	01457	1800	48.94	0.0	48.5	-1.00%		

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Prop or Cups Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	D3050		SHE604	Martin Valvur	07/18/2017	Wind Direction	none

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/1/2006"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/8/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

DAS 1:	DAS 2:
Orientation	Orientation
Linearity:	Linearity:
Abs Avg Err <input type="text" value="2.0"/>	<input type="text"/>
Abs Max Er <input type="text" value="5"/>	<input type="text"/>

UseDescription	TferID	Input Raw	Linearity	Output V	Output Deg.	Difference	Change	Error
primary	01265	1	<input type="checkbox"/>	0.000	1	0		0
primary	01265	91	<input type="checkbox"/>	0.000	88	3		3
primary	01265	181	<input type="checkbox"/>	0.000	181	0		0
primary	01265	271	<input type="checkbox"/>	0.000	266	5		5

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2730121		SHE604	Martin Valvur	07/18/2017	Temperature2meter	none

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.56	0.83		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	2.90	2.87	0.000	3.70	C	0.83
primary	Temp Mid Rang	23.50	23.47	0.000	23.60	C	0.13
primary	Temp High Rang	48.77	48.74	0.000	48.01	C	-0.73

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2730121		SHE604	Martin Valvur	07/18/2017	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	75296	Tfer Desc.	GTL
Tfer ID	01220		
Slope	0.99780	Intercept	0.06850
Cert Date	1/23/2017	CorrCoff	0.99994

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	0.6	6.0		
Abs Max Er	0.7	6.0		

UseDesc.	Test type	Device	Input RH	GTL Raw	RH Corr.	DAS Volts	DAS %RH	Difference
primary	RH Low Range	GTL	32.8	32.0	32.8	0.000	33.3	0.5
primary	RH Low Range	GTL	52.9	53.6	52.9	0.000	52.2	-0.7
primary	RH High Range	GTL	93.6	95.8	93.6	0.000	87.6	-6.0

Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Solar Radiation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Licor	illegible		SHE604	Martin Valvur	07/18/2017	Solar Radiation	none

Mfg	Eppley	Parameter	solar radiation
Serial Number	23824	Tfer Desc.	SR transfer sensor
Tfer ID	01247		
Slope	1.00000	Intercept	0.00000
Cert Date	2/16/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
% Diff of Avg	%Diff of Max	%Diff of Avg	%Diff of Max
0.8%	1.7%	0.0%	0.0%

UseDescription	Measure Date	MeasureTime	Tfer Raw	Tfer Corr	DAS w/m2	PctDifference
primary	7/18/2017	8:00	443	443	437	-1.3%
primary	7/18/2017	9:00	611	610	613	0.5%
primary	7/18/2017	10:00	757	756	765	1.2%
primary	7/18/2017	11:00	862	862	877	1.7%

Sensor Component	Sensor Clean	Condition	Clean	Status	pass
Sensor Component	Sensor Level	Condition	Level	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	N8139	SHE604	Martin Valvur	07/18/2017	Precipitation	none

DAS 1:

A Avg % Diff:	A Max % Di
5.4%	7.2%

DAS 2:

A Avg % Dif	A Max % Di

Mfg	PMP	Parameter	Precipitation
Serial Number	None	Tfer Desc.	250ml graduate
Tfer ID	01249		
Slope	1.00000	Intercept	0.00000
Cert Date	4/26/2013	CorrCoff	1.00000

UseDesc.	Test type	TferVolume	Iteration	TimePerTip	Eq.Ht	DAS eng	Eq.HtUnit	OSE Unit	TferUnits	PctDifference
primary	test 1	231.5	1	8 - 10 sec	7.11	7.37	mm	mm	ml	3.7%
primary	test 2	231.5	2	8 - 10 sec	7.11	7.62	mm	mm	ml	7.2%

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Installed	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Sensor Heater	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Other"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Wind Speed One set screw is stripped.	SHE604	Martin Valvur	07/18/2017	Prop or Cups Con	Met One	4357	<input type="checkbox"/>	<input type="checkbox"/>

Field Systems Comments

1 Parameter: DasComments

The site power source is solar and wind with battery storage. The NEMA enclosure has a cooling fan.

2 Parameter: SiteOpsProcedures

observations of current meteorological measurements are recorded on a hardcopy checklist for ARS and not on the SSRF.

3 Parameter: DocumentationCo

The site operator received a disc with the 2013 QAPP, operating procedures, and HASP which is kept at his office. A hard copy BLM check list developed by ARS is completed and sent to ARS each week.

4 Parameter: SitingCriteriaCom

The site is located in range land. There is an active rail line with coal trains within one kilometer of the site.

5 Parameter: ShelterCleanNotes

NEMA enclosure, solar power

6 Parameter: PollAnalyzerCom

The dry deposition filter pack enclosure is not the standard "pot" size as at the other CASTNET sites. The diameter is much smaller. It is not clear if this will impact particle collection efficiency.

7 Parameter: MetSensorComme

The site is a small footprint solar powered site that has been operating as part of the WARMS network for 10 years. Objects violate the 45 degree rule for the tipping bucket rain gage. Temperature and RH are measured with a combined sensor that cannot be immersed making a temperature audit difficult. The temperature and RH are being measured at 2.5 meters above the ground.

8 Parameter: MetOpMaintCom

The accuracy of the DAS was not tested with a voltage source since there were no available test channels.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text"/>
Operating Group	<input type="text" value="BLM"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Met One"/>		
Air Pollutant Analyzer	<input type="text"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="44.933601"/>
Site Address 1	<input type="text"/>	Audit Longitude	<input type="text" value="-106.847161"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="1141"/>
County	<input type="text" value="Sheridan"/>	Audit Declination	<input type="text" value="9.8"/>
City, State	<input type="text" value="Sheridan, WY"/>		
Zip Code	<input type="text" value="82801"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text"/>
Time Zone	<input type="text" value="Mountain"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input type="checkbox"/>	Make <input type="text"/>	Model <input type="text"/>	Shelter Size <input type="text"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes	<input type="text" value="NEMA enclosure, solar power"/>	
Site OK <input type="checkbox"/>	Notes	<input type="text"/>	
Driving Directions	<input type="text"/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID Technician Site Visit Date

- | | | | |
|----|--|-------------------------------------|--------------------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | 45 degree rule violation |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site is a small footprint solar powered site that has been operating as part of the WARMS network for 10 years. Objects violate the 45 degree rule for the tipping bucket rain gage. Temperature and RH are measured with a combined sensor that cannot be immersed making a temperature audit difficult. The temperature and RH are being measured at 2.5 meters above the ground.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

N/A
N/A
N/A
3/8 teflon by 10 meters
N/A
N/A
Not present
Not present

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The dry deposition filter pack enclosure is not the standard "pot" size as at the other CASTNET sites. The diameter is much smaller. It is not clear if this will impact particle collection efficiency.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
- 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
- 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry? Not present
- 4 Are the signal connections protected from the weather and well maintained?
- 5 Are the signal leads connected to the correct DAS channel?
- 6 Are the DAS, sensor translators, and shelter properly grounded?
- 7 Does the instrument shelter have a stable power source?
- 8 Is the instrument shelter temperature controlled? Marginally
- 9 Is the met tower stable and grounded?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 10 Is the sample tower stable and grounded?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 11 Tower comments?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator received a disc with the 2013 QAPP, operating procedures, and HASP which is kept at his office. A hard copy BLM check list developed by ARS is completed and sent to ARS each week.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> Not present	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	unknown2	49923
elevation	Elevation	none	none	none
Flow Rate	Omega	FMA6518ST-RS232	32433-2	none
Infrastructure	Infrastructure	none	none	none
Precipitation	Met One	370C	N8139	none
Relative Humidity	Vaisala	HMP45AC	C2730121	none
Sample Tower	Unknown	Unknown	None	none
siting criteria	Siting Criteria	none	None	none
Solar Radiation	Licor	LI-200	illegible	none
Temperature2meter	Vaisala	HMP45AC	C2730121	none
Wind Direction	Met One	024	D3050	none
Wind Speed	Met One	014	K2273	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>BUF603-Martin Valvur-07/19/2017</i>						
1	7/19/2017	DAS	Campbell	49917	CR1000	43073
2	7/19/2017	elevation	Elevation	none	none	none
3	7/19/2017	Filter pack flow pump	Thomas	none	107CAB18A	100800033648
4	7/19/2017	Flow Rate	Omega	none	FMA6518ST-RS232	315688-1
5	7/19/2017	Infrastructure	Infrastructure	none	none	none
6	7/19/2017	MFC power supply	Sceptre	none	FMA65PWC	295106-12
7	7/19/2017	Precipitation	Met One	none	385	J7547
8	7/19/2017	Relative Humidity	Vaisala	none	HMP45AC	E3720077
9	7/19/2017	Sample Tower	Unknown	none	Unknown	None
10	7/19/2017	siting criteria	Siting Criteria	none	none	None
11	7/19/2017	Solar Radiation	Licor	none	LI-200	illegible
12	7/19/2017	Temperature2meter	Vaisala	none	HMP45AC	E3720077
13	7/19/2017	Wind Direction	Met One	none	024	J5555
14	7/19/2017	Wind Speed	Met One	none	014	1506

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	43073	BUF603	Martin Valvur	07/19/2017	DAS	Primary

Das Date:	<input type="text" value="7 /19/2017"/>	Audit Date:	<input type="text" value="7 /19/2017"/>
Das Time:	<input type="text" value="14:08:00"/>	Audit Time:	<input type="text" value="14:03:00"/>
Das Day:	<input type="text" value="200"/>	Audit Day:	<input type="text" value="200"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0000"/>	Max Diff:	<input type="text" value="0.0000"/>
		Avg Diff:	<input type="text" value="0.0000"/>
		Max Diff:	<input type="text" value="0.0000"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
4	0.0000	0.0000	0.0000	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Omega	315688-1		BUF603	Martin Valvur	07/19/2017	Flow Rate	none

Mfg	Sceptre
SN/Owner ID	295106-12 none
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
2.11%	3.38%

Cal Factor Zero	0.36
Cal Factor Full Scale	0.99
Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.36	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.36	l/m	l/m	
primary	test pt 1	3.414	3.410	0.00	0.000	3.34	l/m	l/m	-2.08%
primary	test pt 2	3.473	3.460	0.00	0.000	3.34	l/m	l/m	-3.38%
primary	test pt 3	3.396	3.390	0.00	0.000	3.36	l/m	l/m	-0.86%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	7.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	1506		BUF603	Martin Valvur	07/19/2017	Wind Speed	none

Prop or Cups SN
Prop or Cups Torque to
Prop Correction Fact

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (l"/>
Tfer ID	<input type="text" value="01261"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2017"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text" value="CA4353"/>	Tfer Desc.	<input type="text" value="wind speed motor (h"/>
Tfer ID	<input type="text" value="01457"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="4/13/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.19"/>	<input type="text" value="0.60%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.30"/>	<input type="text" value="1.26%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	Input Device	Input RPM	Input m/s	Out V	DAS m/s	Diff/ %Diff	Diff	WsM
primary	none	0	0.20	0.0	0.5		0.25	
primary	01261	40	1.67	0.0	1.7		-0.02	
primary	01261	80	2.75	0.0	2.5		-0.30	
primary	01261	140	4.26	0.0	4.5		0.19	
primary	01261	210	6.07	0.0	6.1	-0.33%		
primary	01457	400	11.11	0.0	11.3	1.26%		
primary	01457	800	22.22	0.0	22.1	-0.77%		
primary	01457	1800	48.44	0.0	48.5	0.02%		

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Prop or Cups Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	J5555		BUF603	Martin Valvur	07/19/2017	Wind Direction	none

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/1/2006"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/8/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

DAS 1:	DAS 2:
Orientation	Orientation
Linearity:	Linearity:
Abs Avg Err <input type="text" value="1.5"/>	<input type="text"/>
Abs Max Er <input type="text" value="3"/>	<input type="text"/>

UseDescription	TferID	Input Raw	Linearity	Output V	Output Deg.	Difference	Change	Error
primary	01265	89	<input type="checkbox"/>	0.000	92	3		3
primary	01265	179	<input type="checkbox"/>	0.000	178	1		1
primary	01265	269	<input type="checkbox"/>	0.000	269	0		0
primary	01265	359	<input type="checkbox"/>	0.000	2	2		2

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	E3720077		BUF603	Martin Valvur	07/19/2017	Temperature2meter	none

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.62	4.38		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.06	0.03	0.000	0.43	C	0.4
primary	Temp Mid Rang	28.40	28.37	0.000	28.30	C	-0.07
primary	Temp High Rang	48.35	48.32	0.000	52.70	C	4.38

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	E3720077		BUF603	Martin Valvur	07/19/2017	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	75296	Tfer Desc.	GTL
Tfer ID	01220		
Slope	0.99780	Intercept	0.06850
Cert Date	1/23/2017	CorrCoff	0.99994

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	2.4	5.9		
Abs Max Er	3.0	5.9		

UseDesc.	Test type	Device	Input RH	GTL Raw	RH Corr.	DAS Volts	DAS %RH	Difference
primary	RH Low Range	GTL	32.8	31.5	32.8	0.000	31.1	-1.7
primary	RH Low Range	GTL	52.9	51.3	52.9	0.000	49.9	-3.0
primary	RH High Range	GTL	93.6	89.6	93.6	0.000	87.7	-5.9

Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Solar Radiation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Licor	illegible		BUF603	Martin Valvur	07/19/2017	Solar Radiation	none

Mfg	Eppley	Parameter	solar radiation
Serial Number	23824	Tfer Desc.	SR transfer sensor
Tfer ID	01247		
Slope	1.00000	Intercept	0.00000
Cert Date	2/16/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
% Diff of Avg	%Diff of Max	%Diff of Avg	%Diff of Max
1.2%	0.8%	0.0%	0.0%

UseDescription	Measure Date	MeasureTime	Tfer Raw	Tfer Corr	DAS w/m2	PctDifference
primary	7/19/2017	11:00	942	942	950	0.8%
primary	7/19/2017	12:00	931	931	951	2.1%
primary	7/19/2017	13:00	878	878	884	0.7%

Sensor Component	Sensor Clean	Condition	Clean	Status	pass
Sensor Component	Sensor Level	Condition	Level	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	J7547	BUF603	Martin Valvur	07/19/2017	Precipitation	none

DAS 1:		DAS 2:	
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.5%	1.5%		

Mfg	PMP	Parameter	Precipitation
Serial Number	None	Tfer Desc.	250ml graduate
Tfer ID	01249		
Slope	1.00000	Intercept	0.00000
Cert Date	4/26/2013	CorrCoff	1.00000

UseDesc.	Test type	TferVolume	Iteration	TimePerTip	Eq.Ht	DAS eng	Eq.HtUnit	OSE Unit	TferUnits	PctDifference
primary	test 1	231.5	1	20 sec	3.35	3.30	mm	mm	ml	-1.5%
primary	test 2	231.5	2	20 sec	3.35	3.30	mm	mm	ml	-1.5%

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Gauge Drain Screen	Condition	Installed	Status	pass
Sensor Component	Funnel Clean	Condition	Clean	Status	pass
Sensor Component	Condition	Condition	Good	Status	pass
Sensor Component	Gauge Screen	Condition	Installed	Status	pass
Sensor Component	Gauge Clean	Condition	Clean	Status	pass
Sensor Component	Level	Condition	Level	Status	pass
Sensor Component	Sensor Heater	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Other"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Wind Speed One set screw is stripped.	BUF603	Martin Valvur	07/19/2017	Condition	Met One	4361	<input type="checkbox"/>	<input type="checkbox"/>

Field Systems Comments

1 Parameter: DasComments

The NEMA enclosure has a cooling fan.

2 Parameter: DocumentationCo

A disc with the current QAPP has been received and is kept at the site operator's office. The site operator completes and files a hardcopy checklist developed by ARS for BLM each week.

3 Parameter: ShelterCleanNotes

NEMA enclosure, 120 VAC power

4 Parameter: PollAnalyzerCom

The dry deposition filter pack enclosure is not the standard "pot" size that is used at the other CASTNET sites. The diameter of the enclosure is much smaller and the filter is mounted much deeper inside the opening. The geometry of the filter pack and enclosure is likely to impact particle collection efficiency.

5 Parameter: MetSensorComme

The temperature and RH are measured using a combined sensor which cannot be immersed making a temperature audit difficult. The temperature and RH are measured at 2.5 meters above the ground.

6 Parameter: MetOpMaintCom

Some of the signal cables are beginning to show signs of wear.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text"/>
Operating Group	<input type="text" value="BLM"/>	Map Scale	<input type="text"/>
AQS #	<input type="text"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text"/>		
Air Pollutant Analyzer	<input type="text"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="44.144135"/>
Site Address 1	<input type="text"/>	Audit Longitude	<input type="text" value="-106.108771"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="1320"/>
County	<input type="text" value="Johnson"/>	Audit Declination	<input type="text" value="9.3"/>
City, State	<input type="text" value="Buffalo, WY"/>		
Zip Code	<input type="text" value="82834"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text"/>
Time Zone	<input type="text" value="Mountain"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input type="checkbox"/>	Make <input type="text"/>	Model <input type="text"/>	Shelter Size <input type="text"/>
Shelter Clean <input type="checkbox"/>	Notes	<input type="text" value="NEMA enclosure, 120 VAC power"/>	
Site OK <input type="checkbox"/>	Notes	<input type="text"/>	
Driving Directions	<input type="text"/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID Technician Site Visit Date

- | | | | |
|----|--|-------------------------------------|--------------------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | 45 degree rule violation |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature and RH are measured using a combined sensor which cannot be immersed making a temperature audit difficult. The temperature and RH are measured at 2.5 meters above the ground.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | N/A |
| 3 | Describe ozone sample tube. | | N/A |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 10 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | N/A |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | N/A |
| 8 | Are there moisture traps in the sample lines? | <input type="checkbox"/> | Not present |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input type="checkbox"/> | Not present |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The dry deposition filter pack enclosure is not the standard "pot" size that is used at the other CASTNET sites. The diameter of the enclosure is much smaller and the filter is mounted much deeper inside the opening. The geometry of the filter pack and enclosure is likely to impact particle collection efficiency.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | |
|----|--|-------------------------------------|-------------------------------------|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input type="checkbox"/> | Not present |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | Marginally |
| 9 | Is the met tower stable and grounded? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 10 | Is the sample tower stable and grounded? | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 11 | Tower comments? | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The NEMA enclosure has a cooling fan.

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

A disc with the current QAPP has been received and is kept at the site operator's office. The site operator completes and files a hardcopy checklist developed by ARS for BLM each week.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> Not present	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	43073	49917
elevation	Elevation	none	none	none
Filter pack flow pump	Thomas	107CAB18A	100800033648	none
Flow Rate	Omega	FMA6518ST-RS232	315688-1	none
Infrastructure	Infrastructure	none	none	none
MFC power supply	Sceptre	FMA65PWC	295106-12	none
Precipitation	Met One	385	J7547	none
Relative Humidity	Vaisala	HMP45AC	E3720077	none
Sample Tower	Unknown	Unknown	None	none
siting criteria	Siting Criteria	none	None	none
Solar Radiation	Licor	LI-200	illegible	none
Temperature2meter	Vaisala	HMP45AC	E3720077	none
Wind Direction	Met One	024	J5555	none
Wind Speed	Met One	014	1506	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>CDR119-Sandy Grenville-07/20/2017</i>						
1	7/20/2017	Computer	Dell	07071	Inspiron 15	Unknown
2	7/20/2017	DAS	Campbell	None	CR3000	4935
3	7/20/2017	Elevation	Elevation	None	1	None
4	7/20/2017	Filter pack flow pump	Thomas	06027	107CAB18	060400022672
5	7/20/2017	Flow Rate	Apex	000660	AXMC105LPMDPCV	54747
6	7/20/2017	Infrastructure	Infrastructure	none	none	none
7	7/20/2017	Modem	Raven	06592	V4221-V	0844350437
8	7/20/2017	Ozone	ThermoElectron Inc	000623	49i A1NAA	1009241790
9	7/20/2017	Ozone Standard	ThermoElectron Inc	000365	49i A3NAA	0726124688
10	7/20/2017	Sample Tower	Aluma Tower	928376	B	AT-51060-56
11	7/20/2017	Shelter Temperature	Campbell	none	107-L	none
12	7/20/2017	Siting Criteria	Siting Criteria	None	1	None
13	7/20/2017	Temperature	RM Young	04448	41342	4546
14	7/20/2017	Zero air pump	Werther International	06903	C 70/4	000899159

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	4935	CDR119	Sandy Grenville	07/20/2017	DAS	Primary

Das Date:	<input type="text" value="7 /20/2017"/>	Audit Date	<input type="text" value="7 /20/2017"/>
Das Time:	<input type="text" value="15:57:00"/>	Audit Time	<input type="text" value="15:57:00"/>
Das Day:	<input type="text" value="201"/>	Audit Day	<input type="text" value="201"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0001	V	V	0.0001
7	0.1000	0.0999	0.1000	V	V	0.0001
7	0.3000	0.2997	0.2998	V	V	0.0001
7	0.5000	0.4996	0.4997	V	V	0.0001
7	0.7000	0.6995	0.6996	V	V	0.0001
7	0.9000	0.8994	0.8995	V	V	0.0001
7	1.0000	0.9993	0.9994	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	54747		CDR119	Sandy Grenville	07/20/2017	Flow Rate	000660

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.09%	1.31%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.006
Cal Factor Full Scale	1.005
Rotometer Reading:	1.55

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	test pt 1	1.530	1.530	1.50	0.000	1.51	l/m	l/m	-1.31%
primary	test pt 2	1.533	1.530	1.50	0.000	1.51	l/m	l/m	-1.31%
primary	test pt 3	1.527	1.520	1.50	0.000	1.51	l/m	l/m	-0.66%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	3
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	120 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241790		CDR119	Sandy Grenville	07/20/2017	Ozone	000623

Slope:	0.97705	Slope:	0.00000
Intercept	0.99177	Intercept	0.00000
CorrCoff	0.99996	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.6%	3.7%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.03	-0.42	1.01	ppb	
primary	2	14.90	14.40	14.93	ppb	3.68%
primary	3	34.77	34.22	34.21	ppb	-0.03%
primary	4	67.95	67.32	66.33	ppb	-1.47%
primary	5	110.00	109.26	108.10	ppb	-1.06%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition	See comments	Status	Fail
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.3	Status	pass
Sensor Component	Span	Condition	0.993	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	87.0 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	713.0 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	37.5 C	Status	pass
Sensor Component	Cell B Freq.	Condition	88.3 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.70 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	713.3 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4546		CDR119	Sandy Grenville	07/20/2017	Temperature	04448

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.18	0.27		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.30	0.15	0.000	0.1	C	-0.05
primary	Temp Mid Range	25.63	25.29	0.000	25.5	C	0.21
primary	Temp High Range	49.58	49.06	0.000	48.8	C	-0.27

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	CDR119	Sandy Grenville	07/20/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.18	0.35		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	31.27	30.89	0.000	31.0	C	0.14
primary	Temp Mid Range	31.65	31.27	0.000	31.6	C	0.35
primary	Temp Mid Range	33.66	33.26	0.000	33.3	C	0.05

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	CDR119	Sandy Grenville	07/20/2017	22.5 degree rule	ThermoElectron	3532	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Trees violate the 22.5 degree clearance rule for the ozone sample inlet.								

Field Systems Comments

1 Parameter: SiteOpsProcComm

The filter handling procedures have again improved since the previous site audit visit.

2 Parameter: SitingCriteriaCom

Site is in a wooded valley, within 30 meters of a lightly traveled road. Large diesel trucks use the road. Trees are taller than the sample tower and within 20 meters of the sample tower.

3 Parameter: ShelterCleanNotes

The shelter is in good condition with only a small amount of rot on the walls below the air conditioner.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Glennville"/>
Operating Group	<input type="text" value="private, WV parks dept"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="54-021-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="38.879503"/>
Site Address 1	<input type="text" value="Cedar Creek St. Park"/>	Audit Longitude	<input type="text" value="-80.847677"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="240"/>
County	<input type="text" value="Gilmer"/>	Audit Declination	<input type="text" value="-8"/>
City, State	<input type="text" value="Glennville, WV"/>		
Zip Code	<input type="text" value="26351"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Oct 2015"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes	<input type="text" value="The shelter is in good condition with only a small amount of rot on the walls below the air conditioner."/>	
Site OK <input checked="" type="checkbox"/>	Notes	<input type="text"/>	
Driving Directions	<input type="text"/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	30 m	<input type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m	20 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Site is in a wooded valley, within 30 meters of a lightly traveled road. Large diesel trucks use the road. Trees are taller than the sample tower and within 20 meters of the sample tower.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|----------------------|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | 20 meters from trees |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 12 meters |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 12 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input checked="" type="checkbox"/> | Flow line only |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | Clean and dry |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|---|-------------------|-----------------|--------------------------|--------------------------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 10 | Is the sample tower stable and grounded? | | | | | | | | |
| 11 | Tower comments? | | Met tower removed | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	no longer on site	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed afternoons
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The filter handling procedures have again improved since the previous site audit visit.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID Technician Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07071
DAS	Campbell	CR3000	4935	None
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	060400022672	06027
Flow Rate	Apex	AXMC105LPMDPC	54747	000660
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0844350437	06592
Ozone	ThermoElectron Inc	49i A1NAA	1009241790	000623
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124688	000365
Sample Tower	Aluma Tower	B	AT-51060-56	928376
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	4546	04448
Zero air pump	Werther International	C 70/4	000899159	06903

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PAR107-Sandy Grenville-07/21/2017</i>						
1	7/21/2017	Computer	Dell	07072	Inspiron 15	Unknown
2	7/21/2017	DAS	Campbell	000333	CR3000	2112
3	7/21/2017	Elevation	Elevation	None	1	None
4	7/21/2017	Filter pack flow pump	Thomas	00859	107CA18	missing
5	7/21/2017	Flow Rate	Apex	000803	AXMC105LPMDPCV	50752
6	7/21/2017	Infrastructure	Infrastructure	none	none	none
7	7/21/2017	Modem	Raven	06607	H4222-C	0844356054
8	7/21/2017	Ozone	ThermoElectron Inc	000685	49i A1NAA	1030244789
9	7/21/2017	Ozone Standard	ThermoElectron Inc	000436	49i A3NAA	CM08200012
10	7/21/2017	Sample Tower	Aluma Tower	000838	B	unknown
11	7/21/2017	Shelter Temperature	Campbell	none	107-L	none
12	7/21/2017	Siting Criteria	Siting Criteria	None	1	None
13	7/21/2017	Temperature	RM Young	04316	41342VO	4013
14	7/21/2017	Zero air pump	Werther International	06932	C 70/4	000829174

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2112	PAR107	Sandy Grenville	07/21/2017	DAS	Primary

Das Date:	<input type="text" value="7 /21/2017"/>	Audit Date:	<input type="text" value="7 /21/2017"/>
Das Time:	<input type="text" value="12:30:35"/>	Audit Time:	<input type="text" value="12:30:36"/>
Das Day:	<input type="text" value="202"/>	Audit Day:	<input type="text" value="202"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0000"/>	Max Diff:	<input type="text" value="0.0001"/>
		Avg Diff:	<input type="text" value="0.0000"/>
		Max Diff:	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2997	0.2998	V	V	0.0001
7	0.5000	0.4996	0.4996	V	V	0.0000
7	0.7000	0.6995	0.6995	V	V	0.0000
7	0.9000	0.8994	0.8994	V	V	0.0000
7	1.0000	0.9992	0.9992	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	50752		PAR107	Sandy Grenville	07/21/2017	Flow Rate	000803

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
2.82%	3.25%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.02
Cal Factor Full Scale	0.964
Rotometer Reading:	1.5

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	-0.02	0.000	-0.02	l/m	l/m	
primary	test pt 1	1.544	1.540	1.54	0.000	1.50	l/m	l/m	-2.60%
primary	test pt 2	1.543	1.540	1.54	0.000	1.49	l/m	l/m	-3.25%
primary	test pt 3	1.542	1.540	1.54	0.000	1.50	l/m	l/m	-2.60%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244789		PAR107	Sandy Grenville	07/21/2017	Ozone	000685

Slope:	0.99332	Slope:	0.00000
Intercept	0.51699	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.3%	4.3%		

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.07	-0.38	0.04	ppb	
primary	2	15.04	14.54	15.16	ppb	4.26%
primary	3	34.94	34.39	34.54	ppb	0.44%
primary	4	68.06	67.43	67.55	ppb	0.18%
primary	5	110.07	109.33	109.10	ppb	-0.21%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.009	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	90.9 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.55 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	693.1 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.3 C	Status	pass
Sensor Component	Cell B Freq.	Condition	89.0 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.47 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	692.8 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	4013		PAR107	Sandy Grenville	07/21/2017	Temperature	04316

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.06	0.08		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.17	0.02	0.000	0.1	C	0.08
primary	Temp Mid Range	25.28	24.94	0.000	25.0	C	0.01
primary	Temp High Range	49.14	48.62	0.000	48.7	C	0.08

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	PAR107	Sandy Grenville	07/21/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.49	0.60		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	28.37	28.01	0.000	27.5	C	-0.5
primary	Temp Mid Range	28.00	27.64	0.000	27.3	C	-0.37
primary	Temp Mid Range	24.08	23.75	0.000	24.4	C	0.6

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** SitingCriteriaCom

The city of Parsons, estimated population 1500, is within 5 km of the site.

2 **Parameter:** ShelterCleanNotes

The shelter is in good condition, clean, neat, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA/USFS"/>	USGS Map	<input type="text" value="Parsons"/>
Operating Group	<input type="text" value="USFS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="54-093-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="39.090434"/>
Site Address 1	<input type="text" value="USFS Timber & Watershed Lab"/>	Audit Longitude	<input type="text" value="-79.661742"/>
Site Address 2	<input type="text" value="Rt. 219, Nursery Bottom"/>	Audit Elevation	<input type="text" value="510"/>
County	<input type="text" value="Parsons"/>	Audit Declination	<input type="text" value="-9"/>
City, State	<input type="text" value="Parsons, WV"/>		
Zip Code	<input type="text" value="26287"/>	Present	
Time Zone	<input type="text" value="Eastern"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected Nov 2015"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in good condition, clean, neat, and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	2.5 km	<input type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|-------------------------------------|--------------------------|--------------------------|--------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | Met tower removed | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	July 1990	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? Minimal information
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07072
DAS	Campbell	CR3000	2112	000333
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	missing	00859
Flow Rate	Apex	AXMC105LPMDPC	50752	000803
Infrastructure	Infrastructure	none	none	none
Modem	Raven	H4222-C	0844356054	06607
Ozone	ThermoElectron Inc	49i A1NAA	1030244789	000685
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200012	000436
Sample Tower	Aluma Tower	B	unknown	000838
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	4013	04316
Zero air pump	Werther International	C 70/4	000829174	06932

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>CNT169-Martin Valvur-07/21/2017</i>						
1	7/21/2017	Computer	Dell	07038	Inspiron 15	Unknown
2	7/21/2017	DAS	Campbell	000417	CR3000	2515
3	7/21/2017	Elevation	Elevation	None	1	None
4	7/21/2017	Filter pack flow pump	Thomas	02753	107CAB18	1192001900
5	7/21/2017	Flow Rate	Apex	000559	AXMC105LPMDPCV	illegible
6	7/21/2017	Infrastructure	Infrastructure	none	none	none
7	7/21/2017	Modem	Raven	06600	V4221-V	0844349098
8	7/21/2017	Ozone	ThermoElectron Inc	000620	49i A1NAA	1009241793
9	7/21/2017	Ozone Standard	ThermoElectron Inc	000215	49i A3NAA	0622717856
10	7/21/2017	Sample Tower	Aluma Tower	000179	B	unknown
11	7/21/2017	Shelter Temperature	Campbell	none	107-L	none
12	7/21/2017	Siting Criteria	Siting Criteria	None	1	None
13	7/21/2017	Temperature	RM Young	06501	41342	14606
14	7/21/2017	Zero air pump	Werther International	06925	C 70/4	000836220

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2515	CNT169	Martin Valvur	07/21/2017	DAS	Primary

Das Date:	<input type="text" value="7/22/2017"/>	Audit Date:	<input type="text" value="7/22/2017"/>
Das Time:	<input type="text" value="7:39:00"/>	Audit Time:	<input type="text" value="7:39:00"/>
Das Day:	<input type="text" value="203"/>	Audit Day:	<input type="text" value="203"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0006	0.0005	V	V	-0.0001
7	0.1000	0.0995	0.0993	V	V	-0.0002
7	0.3000	0.2997	0.2997	V	V	0.0000
7	0.5000	0.4991	0.4992	V	V	0.0001
7	0.7000	0.6997	0.6996	V	V	-0.0001
7	0.9000	0.8993	0.8993	V	V	0.0000
7	1.0000	0.9994	0.9994	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		CNT169	Martin Valvur	07/21/2017	Flow Rate	000559

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.55%	0.99%

Cal Factor Zero	-0.06
Cal Factor Full Scale	0.97
Rotometer Reading:	3.7

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.06	l/m	l/m	
primary	leak check	0.000	0.000	0.05	0.000	0.00	l/m	l/m	
primary	test pt 1	3.030	3.020	2.99	0.000	3.01	l/m	l/m	-0.33%
primary	test pt 2	3.040	3.030	2.97	0.000	3.02	l/m	l/m	-0.33%
primary	test pt 3	3.040	3.030	3.00	0.000	3.00	l/m	l/m	-0.99%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241793		CNT169	Martin Valvur	07/21/2017	Ozone	000620

Slope:	1.05083	Slope:	0.00000
Intercept	0.66404	Intercept	0.00000
CorrCoff	0.99992	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
7.1%	8.2%		

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.30	0.28	0.59	ppb	
primary	2	14.83	14.74	15.87	ppb	7.67%
primary	3	34.96	34.78	37.63	ppb	8.19%
primary	4	68.26	67.93	72.88	ppb	7.29%
primary	5	112.01	111.47	117.20	ppb	5.14%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	-0.30	Status	pass
Sensor Component	Span	Condition	1.011	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	91.0 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.61 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	508.6 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.1 C	Status	pass
Sensor Component	Cell B Freq.	Condition	91.0 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.61 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	508.3 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14606		CNT169	Martin Valvur	07/21/2017	Temperature	06501

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.11	0.21		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.26	0.23	0.000	0.3	C	0.08
primary	Temp Mid Range	19.02	18.99	0.000	19.0	C	0.03
primary	Temp High Range	47.07	47.04	0.000	46.8	C	-0.21

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	CNT169	Martin Valvur	07/21/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.74	1.92		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.68	25.65	0.000	24.1	C	-1.51
primary	Temp Mid Range	25.71	25.68	0.000	23.8	C	-1.92
primary	Temp Mid Range	27.61	27.58	0.000	25.8	C	-1.8

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-19)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone inlet filter is changed once each month and the ozone sample line is leak tested every two weeks.

2 **Parameter:** ShelterCleanNotes

The shelter is dirty. Some floor tiles are old and broken

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Centennial"/>
Operating Group	<input type="text" value="Forest Service"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="56-001-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text" value="41.3722"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-106.2422"/>
Land Use	<input type="text" value="woodland - evergreen"/>	QAPP Elevation Meters	<input type="text" value="3178"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="10.9"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text" value="12/28/2004"/>
Site Telephone	<input type="text" value="(307) 742-7229"/>	Audit Latitude	<input type="text" value="41.364531"/>
Site Address 1	<input type="text" value="Brooklyn Lake Guard Station"/>	Audit Longitude	<input type="text" value="-106.24002"/>
Site Address 2	<input type="text" value="Medicine Bow National Forest"/>	Audit Elevation	<input type="text" value="3175"/>
County	<input type="text" value="Albany"/>	Audit Declination	<input type="text" value="9.5"/>
City, State	<input type="text" value="Centennial, WY"/>		
Zip Code	<input type="text" value="82055"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2015"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810 (s/n 2149-19)"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input type="checkbox"/>	Notes <input type="text" value="The shelter is dirty. Some floor tiles are old and broken"/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Laramie take route 130 west to Centennial. Continue through town and into the Medicine Bow National Forest. Turn right near the summit onto a dirt road at the sign for Brooklyn Lake Campground. Continue approximately 1.5 miles to Little Brooklyn Lake. There will be a small chapel on the right. Park at the chapel and walk approximately 200 meters up the hill past the chapel to the site.

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|---|----------------------|--|----------|-------------------------------------|--|--------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table> | Stable | | Grounded | <input type="checkbox"/> | | <input type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input type="checkbox"/> | | <input type="checkbox"/> | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input type="checkbox"/> | | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Monthly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	filter changed afternoons, 80% of the time
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07038
DAS	Campbell	CR3000	2515	000417
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	1192001900	02753
Flow Rate	Apex	AXMC105LPMDPC	illegible	000559
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0844349098	06600
Ozone	ThermoElectron Inc	49i A1NAA	1009241793	000620
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717856	000215
Sample Tower	Aluma Tower	B	unknown	000179
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	14606	06501
Zero air pump	Werther International	C 70/4	000836220	06925

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>NEC602-Martin Valvur-07/21/2017</i>						
1	7/21/2017	DAS	Campbell	none	CR1000	41007
2	7/21/2017	elevation	Elevation	none	none	none
3	7/21/2017	Filter pack flow pump	Thomas	none	107CAB18	061200041880
4	7/21/2017	Flow Rate	Omega	none	FMA6518ST-RS232	324333-1
5	7/21/2017	Infrastructure	Infrastructure	none	none	none
6	7/21/2017	MFC power supply	Sceptre	none	FMA65PWC	295106-8
7	7/21/2017	Ozone	ThermoElectron Inc	none	49i A1NAA	1214552974
8	7/21/2017	Ozone Standard	ThermoElectron Inc	L0534683	49i E3CAA	1214552972
9	7/21/2017	Precipitation	Met One	none	375	T15381
10	7/21/2017	Relative Humidity	Vaisala	none	HMP45AC	C2730143
11	7/21/2017	Sample Tower	Unknown	none	Unknown	None
12	7/21/2017	Shelter Temperature	ARS	none	Thermocouple	none
13	7/21/2017	siting criteria	Siting Criteria	none	none	None
14	7/21/2017	Solar Radiation	Licor	none	Pyranometer	Illegible
15	7/21/2017	Temperature2meter	Vaisala	none	HMP45AC	C2730143
16	7/21/2017	Wind Direction	Met One	none	024	D3049
17	7/21/2017	Wind Speed	Met One	none	014	K2275
18	7/21/2017	Zero air pump	Thomas	none	107CAB18	081000036785

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	41007	NEC602	Martin Valvur	07/21/2017	DAS	Primary

Das Date:	<input type="text" value="7 /21/2017"/>	Audit Date	<input type="text" value="7 /21/2017"/>
Das Time:	<input type="text" value="12:05:44"/>	Audit Time	<input type="text" value="11:57:35"/>
Das Day:	<input type="text" value="202"/>	Audit Day	<input type="text" value="202"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0000"/>	Max Diff:	<input type="text" value="0.0000"/>
		Avg Diff:	<input type="text" value="0.0000"/>
		Max Diff:	<input type="text" value="0.0000"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	1.0000	0.0000	0.0000	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Omega	324333-1		NEC602	Martin Valvur	07/21/2017	Flow Rate	none

Mfg	Sceptre	
SN/Owner ID	295106-8	none
Parameter	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
3.01%	4.16%

Cal Factor Zero	0.29
Cal Factor Full Scale	1.118
Rotometer Reading:	0

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.29	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.29	l/m	l/m	
primary	test pt 1	3.709	3.700	0.00	0.000	3.64	l/m	l/m	-1.51%
primary	test pt 2	3.766	3.760	0.00	0.000	3.63	l/m	l/m	-3.35%
primary	test pt 3	3.812	3.800	0.00	0.000	3.64	l/m	l/m	-4.16%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Poor	Status	Fail
Sensor Component	Rotometer Condition	Condition	N/A	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	-6.0 cm	Status	Fail
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1214552974		NEC602	Martin Valvur	07/21/2017	Ozone	none

Slope:	0.96612	Slope:	0.00000
Intercept	-0.15807	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
4.3%	6.1%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.17	0.15	0.26	ppb	
primary	2	15.21	15.12	14.20	ppb	-6.08%
primary	3	37.16	36.97	35.53	ppb	-3.90%
primary	4	65.59	65.27	62.80	ppb	-3.78%
primary	5	107.60	107.08	103.40	ppb	-3.44%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	-0.6	Status	pass
Sensor Component	Span	Condition	1.013	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	98.8 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.63 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	628.9 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.0 C	Status	pass
Sensor Component	Cell B Freq.	Condition	82.5 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.65 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	628.9 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Wind Speed Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	K2275		NEC602	Martin Valvur	07/21/2017	Wind Speed	none

Prop or Cups SN

Prop or Cups Torque to

Prop Correction Fact

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind speed motor (l"/>
Tfer ID	<input type="text" value="01261"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/26/2017"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind speed"/>
Serial Number	<input type="text" value="CA4353"/>	Tfer Desc.	<input type="text" value="wind speed motor (h"/>
Tfer ID	<input type="text" value="01457"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="4/13/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

	DAS 1:		DAS 2:	
	Low Range	High Range	Low Range	High Range
Abs Avg Err	<input type="text" value="0.15"/>	<input type="text" value="0.89%"/>	<input type="text"/>	<input type="text"/>
Abs Max Er	<input type="text" value="0.25"/>	<input type="text" value="1.94%"/>	<input type="text"/>	<input type="text"/>

UseDescription:	Input Device	Input RPM	Input m/s	Out V	DAS m/s	Diff/ %Diff	Diff	WsM
primary	none	0	0.20	0.0	0.5		0.25	
primary	01261	40	1.67	0.0	1.6		-0.03	
primary	01261	80	2.75	0.0	2.9		0.10	
primary	01261	140	4.26	0.0	4.1		-0.21	
primary	01261	210	6.07	0.0	6.1	-0.33%		
primary	01457	400	11.11	0.0	11.3	1.26%		
primary	01457	800	22.22	0.0	22.7	1.94%		
primary	01457	1800	48.44	0.0	48.5	0.02%		

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Prop or Cups Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value="Not tested"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text" value="See comments"/>	Status	<input type="text" value="pass"/>

Wind Direction Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	D3049		NEC602	Martin Valvur	07/21/2017	Wind Direction	none

Vane SN: C. A. Align. deg. true:

Vane Torque to

Mfg	<input type="text" value="RM Young"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text"/>	Tfer Desc.	<input type="text" value="wind direction wheel"/>
Tfer ID	<input type="text" value="01266"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/1/2006"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Ushikata"/>	Parameter	<input type="text" value="wind direction"/>
Serial Number	<input type="text" value="190037"/>	Tfer Desc.	<input type="text" value="transit"/>
Tfer ID	<input type="text" value="01265"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/8/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

DAS 1:	DAS 2:
Orientation	Orientation
Linearity:	Linearity:
Abs Avg Err <input type="text" value="18.3"/>	<input type="text"/>
Abs Max Er <input type="text" value="21"/>	<input type="text"/>

UseDescription	TferID	Input Raw	Linearity	Output V	Output Deg.	Difference	Change	Error
primary	01265	82	<input type="checkbox"/>	0.000	65	17		17
primary	01265	172	<input type="checkbox"/>	0.000	157	15		15
primary	01265	262	<input type="checkbox"/>	0.000	241	21		21
primary	01265	352	<input type="checkbox"/>	0.000	332	20		20

Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Mast"/>	Condition	<input type="text" value="Poor"/>	Status	<input type="text" value="Fail"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Plumb"/>	Condition	<input type="text" value="Plumb"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Torque"/>	Condition	<input type="text" value="Not tested"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Vane Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text" value="See comments"/>	Status	<input type="text" value="pass"/>

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2730143		NEC602	Martin Valvur	07/21/2017	Temperature	none

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.63	1.10		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.16	0.13	0.000	1.2	C	1.1
primary	Temp Mid Range	24.20	24.17	0.000	24.8	C	0.63
primary	Temp High Range	47.80	47.77	0.000	47.9	C	0.17

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

Humidity Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Vaisala	C2730143		NEC602	Martin Valvur	07/21/2017	Relative Humidity	none

Mfg	Rotronic	Parameter	Relative Humidity
Serial Number	75296	Tfer Desc.	GTL
Tfer ID	01220		
Slope	0.99780	Intercept	0.06850
Cert Date	1/23/2017	CorrCoff	0.99994

DAS 1:

DAS 2:

	Low Range	High Range	Low Range	High Range
Abs Avg Err	0.9	1.2		
Abs Max Er	1.6	1.2		

UseDesc.	Test type	Device	Input RH	GTL Raw	RH Corr.	DAS Volts	DAS %RH	Difference
primary	RH Low Range	GTL	32.8	40.6	32.8	0.000	33.0	0.2
primary	RH Low Range	GTL	52.9	55.0	52.9	0.000	54.5	1.6
primary	RH High Range	GTL	93.6	88.5	93.6	0.000	92.4	-1.2

Sensor Component	RH Filter	Condition	Clean	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Solar Radiation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Licor	Illegible		NEC602	Martin Valvur	07/21/2017	Solar Radiation	none

Mfg	Eppley	Parameter	solar radiation
Serial Number	23824	Tfer Desc.	SR transfer sensor
Tfer ID	01247		
Slope	1.00000	Intercept	0.00000
Cert Date	2/16/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
% Diff of Avg	%Diff of Max	%Diff of Avg	%Diff of Max
3.6%	6.5%	0.0%	0.0%

UseDescription	Measure Date	MeasureTime	Tfer Raw	Tfer Corr	DAS w/m2	PctDifference
primary	7/21/2017	10:00	583	583	521	-10.7%
primary	7/21/2017	11:00	736	736	747	1.5%
primary	7/21/2017	12:00	672	672	677	0.7%
primary	7/21/2017	13:00	821	821	768	-6.5%

Sensor Component	Sensor Clean	Condition	Clean	Status	pass
Sensor Component	Sensor Level	Condition	Level	Status	pass
Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Precipitation Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Met One	T15381		NEC602	Martin Valvur	07/21/2017	Precipitation	none

DAS 1:

A Avg % Diff: **A Max % Di**

DAS 2:

A Avg % Dif **A Max % Di**

Mfg	<input type="text" value="PMP"/>	Parameter	<input type="text" value="Precipitation"/>
Serial Number	<input type="text" value="None"/>	Tfer Desc.	<input type="text" value="250ml graduate"/>
Tfer ID	<input type="text" value="01249"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="4/26/2013"/>	CorrCoff	<input type="text" value="1.00000"/>

UseDesc.	Test type	TferVolume	Iteration	TimePerTip	Eq.Ht	DAS eng	Eq.HtUnit	OSE Unit	TferUnits	PctDifference
primary	test 1	231.5	1	13 sec	7.11	7.11	mm	mm	ml	0.0%
primary	test 2	231.5	2	15 sec	7.11	7.36	mm	mm	ml	3.5%

Sensor Component	<input type="text" value="Properly Sited"/>	Condition	<input type="text" value="Properly sited"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Gauge Drain Screen"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Funnel Clean"/>	Condition	<input type="text" value="Clean"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Gauge Screen"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Gauge Clean"/>	Condition	<input type="text" value="Clean"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Level"/>	Condition	<input type="text" value="Level"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sensor Heater"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="System Memo"/>	Condition	<input type="text"/>	Status	<input type="text" value="pass"/>

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	NEC602	Martin Valvur	07/21/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.49	0.97		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	26.88	26.85	0.000	25.9	C	-0.97
primary	Temp Mid Range	27.50	27.47	0.000	27.7	C	0.23
primary	Temp Mid Range	28.02	27.99	0.000	27.7	C	-0.28

Sensor Component	System Memo	Condition		Status	pass
------------------	-------------	-----------	--	--------	------

Infrastructure Data For

Site ID **Technician** **Site Visit Date**

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Shelter One"/>	<input type="text" value="AR 263648"/>	<input type="text" value="24 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Other"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	NEC602	Martin Valvur	07/21/2017	Filter Position	Omega	3842	<input type="checkbox"/>	<input checked="" type="checkbox"/>
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.								
Wind Direction	NEC602	Martin Valvur	07/21/2017	System Memo	Met One	4367	<input type="checkbox"/>	<input type="checkbox"/>
The wind direction sensor mast is loose on the tower causing inaccurate wind direction measurement.								
Wind Speed	NEC602	Martin Valvur	07/21/2017	System Memo	Met One	4368	<input type="checkbox"/>	<input type="checkbox"/>
One set screw is stripped.								

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

The site operator is doing a good job with filter change and filter handling. The site operator reported that sometimes it requires a few requests to ARS before assistance is received.

2 **Parameter:** SiteOpsProcedures

The site operator is aware that the desiccant is in need of replacement. Some of the items on the SSRF were discussed and the site operator's questions were answered regarding the correct procedures.

3 **Parameter:** DocumentationCo

The site operator received a disc with the current QAPP which is kept at his office.

4 **Parameter:** SitingCriteriaCom

The site is located approximately 2 km northeast of Newcastle WY which has a population of approximately 3500. There is an oil refinery in Newcastle. A heavily traveled road is approximately 100m west of the site.

5 **Parameter:** ShelterCleanNotes

The shelter houses the ozone, DAS, and MFC only.

6 **Parameter:** MetSensorComme

Some objects violate the 45 degree rule for the tipping bucket rain gage. The wind sensor mast is loose on the sample tower. The site operator reported that the tower was dropped a couple of weeks before by the backup site operator. This may have caused the damage to the wind sensor mast.

7 **Parameter:** MetOpMaintCom

The temperature / humidity sensor had fallen out of the naturally aspirated shield and was hanging by the signal cable from the top of the tower. The site operator reported that it had been that way probably since the tower was dropped by the backup site operator a couple of weeks before. It was reinstalled in the shield by the audit team following the audit.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text"/>
Operating Group	<input type="text" value="BLM"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="560450003"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Met One"/>		
Air Pollutant Analyzer	<input type="text"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="43.8731"/>
Site Address 1	<input type="text"/>	Audit Longitude	<input type="text" value="-104.192009"/>
Site Address 2	<input type="text"/>	Audit Elevation	<input type="text" value="1469"/>
County	<input type="text" value="Weston"/>	Audit Declination	<input type="text" value="8.2"/>
City, State	<input type="text" value="Newcastle, WY"/>		
Zip Code	<input type="text" value="82701"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text"/>
Time Zone	<input type="text" value="Mountain"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input type="checkbox"/>	Make <input type="text" value="Shelter One"/>	Model <input type="text" value="AR 263648"/>	Shelter Size <input type="text" value="24 cuft"/>
Shelter Clean <input type="checkbox"/>	Notes <input type="text" value="The shelter houses the ozone, DAS, and MFC only."/>		
Site OK <input type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text"/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	< 10 km	<input type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	2 km	<input type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	100 m	<input type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located approximately 2 km northeast of Newcastle WY which has a population of approximately 3500. There is an oil refinery in Newcastle. A heavily traveled road is approximately 100m west of the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|--------------------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input type="checkbox"/> | 45 degree rule violation |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Some objects violate the 45 degree rule for the tipping bucket rain gage. The wind sensor mast is loose on the sample tower. The site operator reported that the tower was dropped a couple of weeks before by the backup site operator. This may have caused the damage to the wind sensor mast.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature / humidity sensor had fallen out of the naturally aspirated shield and was hanging by the signal cable from the top of the tower. The site operator reported that it had been that way probably since the tower was dropped by the backup site operator a couple of weeks before. It was reinstalled in the shield by the audit team following the audit.

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 10 meters
3/8 Nylon by 10 meters
Not present

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|--|----------------------|--|----------|-------------------------------------|--|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input type="checkbox"/> | Not present | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table> | Stable | | Grounded | <input type="checkbox"/> | | <input type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input type="checkbox"/> | | <input type="checkbox"/> | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="2013"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text" value="Not present"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	<input type="text" value="Not performed"/>	<input type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is aware that the desiccant is in need of replacement. Some of the items on the SSRF were discussed and the site operator's questions were answered regarding the correct procedures.

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input type="checkbox"/> Not present	<input type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The site operator is doing a good job with filter change and filter handling. The site operator reported that sometimes it requires a few requests to ARS before assistance is received.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR1000	41007	none
elevation	Elevation	none	none	none
Filter pack flow pump	Thomas	107CAB18	061200041880	none
Flow Rate	Omega	FMA6518ST-RS232	324333-1	none
Infrastructure	Infrastructure	none	none	none
MFC power supply	Sceptre	FMA65PWC	295106-8	none
Ozone	ThermoElectron Inc	49i A1NAA	1214552974	none
Ozone Standard	ThermoElectron Inc	49i E3CAA	1214552972	L0534683
Precipitation	Met One	375	T15381	none
Relative Humidity	Vaisala	HMP45AC	C2730143	none
Sample Tower	Unknown	Unknown	None	none
Shelter Temperature	ARS	Thermocouple	none	none
siting criteria	Siting Criteria	none	None	none
Solar Radiation	Licor	Pyranometer	Illegible	none
Temperature	Vaisala	HMP45A	C2730143	none
Wind Direction	Met One	024	D3049	none
Wind Speed	Met One	014	K2275	none
Zero air pump	Thomas	107CAB18	081000036785	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>PED108-Sandy Grenville-07/25/2017</i>						
1	7/25/2017	Computer	Dell	07013	Inspiron 15	Unknown
2	7/25/2017	DAS	Campbell	000406	CR3000	2511
3	7/25/2017	Elevation	Elevation	None	1	None
4	7/25/2017	Filter pack flow pump	Thomas	00564	107CA18	1088003022
5	7/25/2017	Flow Rate	Apex	000461	AXMC105LPMDPCV	illegible
6	7/25/2017	Infrastructure	Infrastructure	none	none	none
7	7/25/2017	Modem	Raven	06587	V4221-V	0844353122
8	7/25/2017	Ozone	ThermoElectron Inc	000732	49i A1NAA	1105347319
9	7/25/2017	Ozone Standard	ThermoElectron Inc	000214	49i A3NAA	0622717855
10	7/25/2017	Sample Tower	Aluma Tower	000788	B	unknown
11	7/25/2017	Shelter Temperature	Campbell	none	107-L	none
12	7/25/2017	Siting Criteria	Siting Criteria	None	1	None
13	7/25/2017	Temperature	RM Young	06408	41342	14041
14	7/25/2017	Zero air pump	Werther International	06883	C 70/4	000815257

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2511	PED108	Sandy Grenville	07/25/2017	DAS	Primary

Das Date:	<input type="text" value="7 /25/2017"/>	Audit Date	<input type="text" value="7 /25/2017"/>
Das Time:	<input type="text" value="11:28:51"/>	Audit Time	<input type="text" value="11:28:51"/>
Das Day:	<input type="text" value="206"/>	Audit Day	<input type="text" value="206"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2998	0.2997	V	V	-0.0001
7	0.5000	0.4996	0.4995	V	V	-0.0001
7	0.7000	0.6996	0.6994	V	V	-0.0002
7	0.9000	0.8994	0.8992	V	V	-0.0002
7	1.0000	0.9993	0.9991	V	V	-0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		PED108	Sandy Grenville	07/25/2017	Flow Rate	000461

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
2.04%	2.04%
A Avg %Dif	A Max % Di

Cal Factor Zero	0
Cal Factor Full Scale	1.01
Rotometer Reading:	1.35

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.01	l/m	l/m	
primary	test pt 1	1.476	1.470	1.49	0.000	1.50	l/m	l/m	2.04%
primary	test pt 2	1.474	1.470	1.49	0.000	1.50	l/m	l/m	2.04%
primary	test pt 3	1.473	1.470	1.49	0.000	1.50	l/m	l/m	2.04%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347319		PED108	Sandy Grenville	07/25/2017	Ozone	000732

Slope:	0.97661	Slope:	0.00000
Intercept	0.77925	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.3%	1.7%		

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.00	-0.45	0.30	ppb	
primary	2	15.01	14.51	14.70	ppb	1.31%
primary	3	35.00	34.45	34.80	ppb	1.02%
primary	4	68.03	67.40	66.60	ppb	-1.19%
primary	5	110.00	109.26	107.40	ppb	-1.70%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	-0.10	Status	pass
Sensor Component	Span	Condition	0.996	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	89.6 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.0 lpm	Status	Fail
Sensor Component	Cell A Pressure	Condition	723.8 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	35.7 C	Status	pass
Sensor Component	Cell B Freq.	Condition	105.4 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.58 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	722.9 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14041		PED108	Sandy Grenville	07/25/2017	Temperature	06408

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.06	0.12		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.17	0.02	0.000	0.1	C	0.12
primary	Temp Mid Range	25.07	24.73	0.000	24.8	C	0.03
primary	Temp High Range	48.11	47.60	0.000	47.6	C	-0.03

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	PED108	Sandy Grenville	07/25/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.41	0.45		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.41	23.09	0.000	23.5	C	0.37
primary	Temp Mid Range	25.35	25.01	0.000	25.4	C	0.42
primary	Temp Mid Range	27.00	26.65	0.000	26.2	C	-0.45

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2116-13)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	PED108	Sandy Grenville	07/25/2017	Cell A Flow	ThermoElectron	3745	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Field Systems Comments

1 **Parameter:** SitingCriteriaCom

The site is in a clearing in an evergreen plantation in the Prince Edward-Gallion State Forest. Trees were cut within the last 11 years to increase the size of the clearing. The tree line is encroaching again and is between 25 and 35 meters from the site.

2 **Parameter:** ShelterCleanNotes

The shelter is in good condition, clean, neat, and well organized.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map
 Operating Group Map Scale
 AQS # Map Date

Meteorological Type
 Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude
 Land Use QAPP Elevation Meters

Terrain QAPP Declination
 Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State

Zip Code Fire Extinguisher Present

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	25 - 35 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is in a clearing in an evergreen plantation in the Prince Edward-Gallion State Forest. Trees were cut within the last 11 years to increase the size of the clearing. The tree line is encroaching again and is between 25 and 35 meters from the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 18 meters |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 18 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input checked="" type="checkbox"/> | Flow line only |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | Clean and dry |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|---|-------------------|-----------------|--------------------------|--------------------------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | | | |
| 11 | Tower comments? | | Met tower removed | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Oct 2001	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	July 1999	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="As needed"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input type="checkbox"/> Unknown	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07013
DAS	Campbell	CR3000	2511	000406
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	1088003022	00564
Flow Rate	Apex	AXMC105LPMDPC	illegible	000461
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0844353122	06587
Ozone	ThermoElectron Inc	49i A1NAA	1105347319	000732
Ozone Standard	ThermoElectron Inc	49i A3NAA	0622717855	000214
Sample Tower	Aluma Tower	B	unknown	000788
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	14041	06408
Zero air pump	Werther International	C 70/4	000815257	06883

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ROM406-Martin Valvur-08/01/2017

1	8/1/2017	Computer	Hewlett Packard	none	6730b	USH01700BR
2	8/1/2017	DAS	Environmental Sys Corp	90535	8816	2025
3	8/1/2017	Elevation	Elevation	None	1	None
4	8/1/2017	flow rate	Tylan	03393	FC280AV	AW9403024
5	8/1/2017	Infrastructure	Infrastructure	none	none	none
6	8/1/2017	Met tower	Rohn	none	unknown	none
7	8/1/2017	MFC power supply	Tylan	none	RO-32	illegible
8	8/1/2017	Ozone	ThermoElectron Inc	none	49i A3NAA	0733726103
9	8/1/2017	Ozone Standard	ThermoElectron Inc	none	49i A1NAA	CM08460008
10	8/1/2017	Sample Tower	Aluma Tower	illegible	B	none
11	8/1/2017	Shelter Temperature	ARS	none	unknown	051
12	8/1/2017	Shield (2 meter)	RM Young	none	unknown	none
13	8/1/2017	Siting Criteria	Siting Criteria	None	1	None
14	8/1/2017	Temperature2meter	RM Young	none	41342	17079
15	8/1/2017	Zero air pump	Werther International	none	PC 70/4	05-2017-112

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2025	ROM406	Martin Valvur	08/01/2017	DAS	Primary

Das Date:	<input type="text" value="8 /1 /2017"/>	Audit Date	<input type="text" value="8 /1 /2017"/>
Das Time:	<input type="text" value="14:48:06"/>	Audit Time	<input type="text" value="14:49:00"/>
Das Day:	<input type="text" value="213"/>	Audit Day	<input type="text" value="213"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0002"/>	Max Diff:	<input type="text" value="0.0011"/>
		Avg Diff:	<input type="text" value="0.0002"/>
		Max Diff:	<input type="text" value="0.0011"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
4	0.0000	-0.0002	0.0009	V	V	0.0011
4	0.1000	0.0998	0.0998	V	V	0.0000
4	0.3000	0.2994	0.2991	V	V	-0.0003
4	0.5000	0.4996	0.4994	V	V	-0.0002
4	0.7000	0.6997	0.6997	V	V	0.0000
4	0.9000	0.8997	0.8997	V	V	0.0000
4	1.0000	1.0001	1.0002	V	V	0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403024		ROM406	Martin Valvur	08/01/2017	flow rate	03393

Mfg	Tylan
SN/Owner ID	illegible none
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.17%	1.28%

Cal Factor Zero	0.094
Cal Factor Full Scale	5.456
Rotometer Reading:	3.75

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	-0.07	0.0000	0.06	l/m	l/m	
primary	leak check	0.000	0.000	-0.06	0.0000	0.06	l/m	l/m	
primary	test pt 1	3.037	3.030	3.02	0.0000	3.00	l/m	l/m	-0.96%
primary	test pt 2	3.048	3.040	3.02	0.0000	3.00	l/m	l/m	-1.28%
primary	test pt 3	3.049	3.040	3.02	0.0000	3.00	l/m	l/m	-1.28%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	160 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	0733726103		ROM406	Martin Valvur	08/01/2017	Ozone	none

Slope:	0.96260	Slope:	0.00000
Intercept	-0.14012	Intercept	0.00000
CorrCoff	0.99997	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
4.7%	7.2%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.46	0.44	0.47	ppb	
primary	2	14.81	14.72	13.66	ppb	-7.20%
primary	3	36.17	35.98	34.46	ppb	-4.22%
primary	4	64.14	63.82	61.68	ppb	-3.35%
primary	5	106.90	106.39	102.10	ppb	-4.03%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.1	Status	pass
Sensor Component	Span	Condition	0.990	Status	pass
Sensor Component	Zero Voltage	Condition	0.0010	Status	pass
Sensor Component	Fullscale Voltage	Condition	1.0010	Status	pass
Sensor Component	Cell A Freq.	Condition	114.2 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	1.6 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.62 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	545.6 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	38.9 C	Status	pass
Sensor Component	Cell B Freq.	Condition	83.0 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	1.3 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.59 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	545.0 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	17079		ROM406	Martin Valvur	08/01/2017	Temperature2meter	none

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.35	0.37		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary		0.23	0.20	0.0000	0.53	C	0.33
primary		24.32	24.29	0.0000	24.66	C	0.37
primary		47.35	47.32	0.0000	47.68	C	0.36

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	051	ROM406	Martin Valvur	08/01/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.62	1.86		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.08	25.05	0.000	26.9	C	1.86
primary	Temp Mid Range	25.05	25.02	0.000	26.8	C	1.81
primary	Temp Mid Range	24.97	24.94	0.000	26.1	C	1.18

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8814 (s/n 3062-1)"/>	<input type="text" value="896 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: DasComments

Only RH, temperature, and AMoN are mounted on the meteorological tower at approximately 2 meters.

2 Parameter: ShelterCleanNotes

The shelter is clean, neat, organized, and well maintained.

3 Parameter: MetSensorComme

The recorded temperature is being measured at 2.5 meters above the ground and < 1 foot above the AMoN enclosure.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map

Operating Group Map Scale

AQS # Map Date

Meteorological Type

Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude

Land Use QAPP Elevation Meters

Terrain QAPP Declination

Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State

Zip Code Fire Extinguisher Present

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID Technician Site Visit Date

- | | | | |
|----|--|-------------------------------------|-------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | South |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The recorded temperature is being measured at 2.5 meters above the ground and < 1 foot above the AMoN enclosure.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 10 meters
3/8 teflon by 10 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|--|----------------------|--|----------|-------------------------------------|--|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input type="checkbox"/> | | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	no longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	6730b	USH01700BR	none
DAS	Environmental Sys Corp	8816	2025	90535
Elevation	Elevation	1	None	None
flow rate	Tylan	FC280AV	AW9403024	03393
Infrastructure	Infrastructure	none	none	none
Met tower	Rohn	unknown	none	none
MFC power supply	Tylan	RO-32	illegible	none
Ozone	ThermoElectron Inc	49i A3NAA	0733726103	none
Ozone Standard	ThermoElectron Inc	49i A1NAA	CM08460008	none
Sample Tower	Aluma Tower	B	none	illegible
Shelter Temperature	ARS	unknown	051	none
Shield (2 meter)	RM Young	unknown	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342	17079	none
Zero air pump	Werther International	PC 70/4	05-2017-112	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ROM206-Martin Valvur-08/08/2017

1	8/8/2017	Computer	Dell	07068	Inspiron 15	Unknown
2	8/8/2017	DAS	Campbell	000847	CR3000	1144
3	8/8/2017	Dilution system	Teledyne	000791	T700U	111
4	8/8/2017	Elevation	Elevation	None	1	None
5	8/8/2017	Filter pack flow pump	Thomas	04986	107CA18	040400022185
6	8/8/2017	Flow Rate	Apex	000598	AXMC105LPMDPCV	unknown
7	8/8/2017	Infrastructure	Infrastructure	none	none	none
8	8/8/2017	Modem	Raven	06473	H4222-C	0808311135
9	8/8/2017	Noy	Teledyne	000798	T200U	103
10	8/8/2017	Ozone	ThermoElectron Inc	000676	49i A1NAA	1030244794
11	8/8/2017	Ozone Standard	ThermoElectron Inc	000514	49i A3NAA	0922236892
12	8/8/2017	Sample Tower	Aluma Tower	000810	C	Unknownm
13	8/8/2017	Shelter Temperature	Campbell	none	107-L	none
14	8/8/2017	Siting Criteria	Siting Criteria	None	1	None
15	8/8/2017	Temperature	RM Young	02679	41342	none
16	8/8/2017	Zero air pump	Werther International	06917	PC70/4	000829166
17	8/8/2017	Zero air system	Teledyne	000777	701H	607

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	1144	ROM206	Martin Valvur	08/08/2017	DAS	Primary

Das Date:	<input type="text" value="8 / 8 / 2017"/>	Audit Date:	<input type="text" value="8 / 8 / 2017"/>
Das Time:	<input type="text" value="13:42:00"/>	Audit Time:	<input type="text" value="13:41:35"/>
Das Day:	<input type="text" value="220"/>	Audit Day:	<input type="text" value="220"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0003"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0003	-0.0004	V	V	-0.0001
7	0.1000	0.0991	0.0991	V	V	0.0000
7	0.3000	0.2999	0.2996	V	V	-0.0003
7	0.5000	0.4997	0.4997	V	V	0.0000
7	0.7000	0.7000	0.6998	V	V	-0.0002
7	0.9000	0.8998	0.8998	V	V	0.0000
7	1.0000	1.0002	0.9999	V	V	-0.0003

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		ROM206	Martin Valvur	08/08/2017	Flow Rate	000598

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.77%	0.99%

Cal Factor Zero	-0.05
Cal Factor Full Scale	0.95
Rotometer Reading:	3.55

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.05	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.05	l/m	l/m	
primary	test pt 1	3.020	3.010	3.05	0.000	2.99	l/m	l/m	-0.66%
primary	test pt 2	3.030	3.020	3.05	0.000	2.99	l/m	l/m	-0.99%
primary	test pt 3	3.030	3.020	3.03	0.000	3.00	l/m	l/m	-0.66%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244794		ROM206	Martin Valvur	08/08/2017	Ozone	000676

Slope:	0.99240	Slope:	0.00000
Intercept	-0.04905	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.0%	2.4%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.24	0.22	0.05	ppb	
primary	2	15.51	15.42	15.05	ppb	-2.40%
primary	3	35.43	35.25	35.14	ppb	-0.31%
primary	4	66.68	66.35	66.17	ppb	-0.27%
primary	5	113.00	112.46	111.30	ppb	-1.03%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.1	Status	pass
Sensor Component	Span	Condition	1.006	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	90.7 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.0 lpm	Status	Fail
Sensor Component	Cell A Pressure	Condition	524.2 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	37.7 C	Status	pass
Sensor Component	Cell B Freq.	Condition	93.6 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.38 lpm	Status	Fail
Sensor Component	Cell B Pressure	Condition	525.6 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	none		ROM206	Martin Valvur	08/08/2017	Temperature	02679

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.15	0.22		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.13	0.10	0.000	0.3	C	0.17
primary	Temp Mid Range	24.40	24.37	0.000	24.4	C	0.06
primary	Temp High Range	48.27	48.24	0.000	48.0	C	-0.22

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ROM206	Martin Valvur	08/08/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.84	0.99		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	24.36	24.33	0.000	25.1	C	0.73
primary	Temp Mid Range	22.94	22.91	0.000	23.9	C	0.99
primary	Temp Mid Range	22.31	22.28	0.000	23.1	C	0.79

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2182-1)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	ROM206	Martin Valvur	08/08/2017	Cell B Flow	ThermoElectron	3725	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Ozone	ROM206	Martin Valvur	08/08/2017	Cell A Flow	ThermoElectron	3725	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Field Systems Comments

1 Parameter: SiteOpsProcComm

The Noy analyzer has a blinking "fault" light and the message "system service" is displayed.

2 Parameter: ShelterCleanNotes

The shelter is clean, neat, and well organized. There are signs of previous roof leaks, but they have been repaired. The floor and counter top have been replaced.

3 Parameter: MetSensorComme

The temperature sensor has been removed from the met tower and mounted in a naturally aspirated shield on the sample tower, facing south and over the shelter roof.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map
 Operating Group Map Scale
 AQS # Map Date

Meteorological Type
 Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude
 Land Use QAPP Elevation Meters

Terrain QAPP Declination
 Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State Present

Zip Code Fire Extinguisher

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID Technician Site Visit Date

- | | | | |
|----|--|-------------------------------------|-------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | South |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The temperature sensor has been removed from the met tower and mounted in a naturally aspirated shield on the sample tower, facing south and over the shelter roof.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|----------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	Feb 2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID Technician Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed evenings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	one set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The Noy analyzer has a blinking "fault" light and the message "system service" is displayed.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07068
DAS	Campbell	CR3000	1144	000847
Dilution system	Teledyne	T700U	111	000791
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	040400022185	04986
Flow Rate	Apex	AXMC105LPMDPC	unknown	000598
Infrastructure	Infrastructure	none	none	none
Modem	Raven	H4222-C	0808311135	06473
Noy	Teledyne	T200U	103	000798
Ozone	ThermoElectron Inc	49i A1NAA	1030244794	000676
Ozone Standard	ThermoElectron Inc	49i A3NAA	0922236892	000514
Sample Tower	Aluma Tower	C	Unknowm	000810
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	none	02679
Zero air pump	Werther International	PC70/4	000829166	06917
Zero air system	Teledyne	701H	607	000777

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>YELA08-Martin Valvur-08/16/2017</i>						
1	8/16/2017	DAS	Environmental Sys Corp	90632	8816	2505
2	8/16/2017	Elevation	Elevation	None	1	None
3	8/16/2017	Filter pack flow pump	Thomas	none	107CA18B	049800008583
4	8/16/2017	Flow Rate	Tylan	none	FC280	AW9403021
5	8/16/2017	Infrastructure	Infrastructure	none	none	none
6	8/16/2017	Mainframe	Climatronics	none	100081	1380
7	8/16/2017	Mainframe power supply	Climatronics	none	101074	688
8	8/16/2017	Met tower	Climatronics	01362	14 inch taper	illegible
9	8/16/2017	MFC power supply	Tylan	00045	RO-32	FP902028
10	8/16/2017	Ozone	ThermoElectron Inc	90607	49C	49C-61985-333
11	8/16/2017	Ozone Standard	ThermoElectron Inc	90606	49C	49C-61991-333
12	8/16/2017	Printer	Hewlett Packard	none	840C	unknown
13	8/16/2017	Sample Tower	Aluma Tower	illegible	B	none
14	8/16/2017	Shelter Temperature	ARS	none	none	none
15	8/16/2017	Shield (2 meter)	Climatronics	01050	100325	illegible
16	8/16/2017	Siting Criteria	Siting Criteria	None	1	None
17	8/16/2017	Temperature Translator	Climatronics	03626	100088-2	396
18	8/16/2017	Temperature2meter	Climatronics	ARS100	100093	none
19	8/16/2017	Zero air pump	Werther International	none	PC70/4	531393

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2505	YEL408	Martin Valvur	08/16/2017	DAS	Primary

Das Date:	<input type="text" value="8 /16/2017"/>	Audit Date	<input type="text" value="8 /16/2017"/>
Das Time:	<input type="text" value="7:39:32"/>	Audit Time	<input type="text" value="7:37:00"/>
Das Day:	<input type="text" value="228"/>	Audit Day	<input type="text" value="228"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
11	0.0000	-0.0005	-0.0006	V	V	-0.0001
11	0.1000	0.0997	0.0996	V	V	-0.0001
11	0.3000	0.2998	0.2997	V	V	-0.0001
11	0.5000	0.4995	0.4996	V	V	0.0001
11	0.7000	0.6996	0.6995	V	V	-0.0001
11	0.9000	0.8993	0.8994	V	V	0.0001
11	1.0000	0.9996	0.9998	V	V	0.0002

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9403021		YEL408	Martin Valvur	08/16/2017	Flow Rate	none

Mfg	Tylan	
SN/Owner ID	FP902028	00045
Parameter	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.57%	1.03%

Cal Factor Zero	0.029
Cal Factor Full Scale	5.558
Rotometer Reading:	4.05

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	0.07	0.0000	0.02	l/m	l/m	
primary	leak check	0.000	0.000	0.14	0.0000	0.08	l/m	l/m	
primary	test pt 1	2.890	2.880	2.55	0.0000	2.89	l/m	l/m	0.35%
primary	test pt 2	2.910	2.900	2.56	0.0000	2.89	l/m	l/m	-0.34%
primary	test pt 3	2.930	2.920	2.55	0.0000	2.89	l/m	l/m	-1.03%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	90 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-61985-333		YEL408	Martin Valvur	08/16/2017	Ozone	90607

Slope:	0.99392	Slope:	0.00000
Intercept	-0.33439	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.0%	4.7%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.27	0.25	0.19	ppb	
primary	2	15.19	15.10	14.39	ppb	-4.70%
primary	3	38.29	38.09	37.66	ppb	-1.13%
primary	4	65.79	65.47	64.44	ppb	-1.57%
primary	5	109.86	109.33	108.50	ppb	-0.76%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.08	Status	pass
Sensor Component	Span	Condition	1.001	Status	pass
Sensor Component	Zero Voltage	Condition	0.0040	Status	pass
Sensor Component	Fullscale Voltage	Condition	1.0035	Status	pass
Sensor Component	Cell A Freq.	Condition	87.9 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.59 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	555.5 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	34.7 C	Status	pass
Sensor Component	Cell B Freq.	Condition	101.9 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.60 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	555.0 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	none		YEL408	Martin Valvur	08/16/2017	Temperature2meter	ARS100

Mfg	Climatronics
SN/Owner ID	396 03626
Parameter	Temperature Translator

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.17	0.26		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.04	0.01	0.0000	0.05 C		0.04
primary	Temp Mid Rang	24.08	24.05	0.0000	23.79 C		-0.26
primary	Temp High Rang	48.18	48.15	0.0000	47.94 C		-0.21

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	YEL408	Martin Valvur	08/16/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.74	1.07		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	27.15	27.12	0.000	26.8	C	-0.32
primary	Temp Mid Range	28.45	28.42	0.000	27.4	C	-1.07
primary	Temp Mid Range	24.21	24.18	0.000	23.4	C	-0.83

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2880-1)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="Pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** SiteOpsProcComm

Gloves are not used to handle the filter pack.

2 **Parameter:** SiteOpsProcedures

The ozone inlet filter is replaced and the system is leak tested every two weeks.

3 **Parameter:** SitingCriteriaCom

The site is located at the edge of a tree line. Trees as tall as 8 meters are near the sample inlet. Trees taller than 10 meters are 15 meters from the inlet.

4 **Parameter:** ShelterCleanNotes

The shelter is organized and well maintained.

5 **Parameter:** MetOpMaintCom

The recorded temperature is now being measured at approximately 2 meters above the ground.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Lake"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="56-039-1011"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="44.5597"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text" value="-110.4006"/>
Land Use	<input type="text" value="woodland - evergreen"/>	QAPP Elevation Meters	<input type="text" value="2400"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text" value="(307) 242-2410"/>	Audit Latitude	<input type="text" value="44.565356"/>
Site Address 1	<input type="text" value="Lake Ranger Station"/>	Audit Longitude	<input type="text" value="-110.400338"/>
Site Address 2	<input type="text" value="route 14"/>	Audit Elevation	<input type="text" value="2430"/>
County	<input type="text" value="Teton"/>	Audit Declination	<input type="text" value="11.9"/>
City, State	<input type="text" value="Yellowstone National Park, WY"/>		
Zip Code	<input type="text" value="82190"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2017"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions From Jackson take route 191 / 89 north to Yellowstone National Park. At Thumb Junction take 14 east around Yellowstone Lake. Turn left just past the Lake Area (and hotel) into the park residence and office compound. Continue through the compound past the housing area. The site is up the hill through the gate to the water supply tank for the compound.

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	15 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located at the edge of a tree line. Trees as tall as 8 meters are near the sample inlet. Trees taller than 10 meters are 15 meters from the inlet.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | West |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Now at 2 meters
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|----------------------------|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input type="checkbox"/> | 10 to 15 meters from trees |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 12 meters |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 9 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input checked="" type="checkbox"/> | Flow line only |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | Clean and dry |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|----------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="DataView2"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="July 2009"/>	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	<input type="text" value="July 2009"/>	<input checked="" type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="July 2009"/>	<input checked="" type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text" value="Not current"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview, SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input type="checkbox"/>	
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input type="checkbox"/>	<input type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Gloves are not used to handle the filter pack.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8816	2505	90632
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18B	049800008583	none
Flow Rate	Tylan	FC280	AW9403021	none
Infrastructure	Infrastructure	none	none	none
Mainframe	Climatronics	100081	1380	none
Mainframe power supply	Climatronics	101074	688	none
Met tower	Climatronics	14 inch taper	illegible	01362
MFC power supply	Tylan	RO-32	FP902028	00045
Ozone	ThermoElectron Inc	49C	49C-61985-333	90607
Ozone Standard	ThermoElectron Inc	49C	49C-61991-333	90606
Printer	Hewlett Packard	840C	unknown	none
Sample Tower	Aluma Tower	B	none	illegible
Shelter Temperature	ARS	none	none	none
Shield (2 meter)	Climatronics	100325	illegible	01050
Siting Criteria	Siting Criteria	1	None	None
Temperature Translator	Climatronics	100088-2	396	03626
Temperature2meter	Climatronics	100093	none	ARS100
Zero air pump	Werther International	PC70/4	531393	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

LRL117-Sandy Grenville-08/17/2017

1	8/17/2017	Computer	Dell	07010	D520	unknown
2	8/17/2017	DAS	Campbell	000402	CR3000	2514
3	8/17/2017	Elevation	Elevation	None	1	None
4	8/17/2017	Filter pack flow pump	Thomas	02741	107CA18	Unknown
5	8/17/2017	Flow Rate	Apex	000591	AXMC105LPM DPCV	illegible
6	8/17/2017	Infrastructure	Infrastructure	none	none	none
7	8/17/2017	Ozone	ThermoElectron Inc	000701	49i A1NAA	1030244808
8	8/17/2017	Ozone Standard	ThermoElectron Inc	000444	49i A3NAA	CM08200020
9	8/17/2017	Sample Tower	Aluma Tower	000783	B	none
10	8/17/2017	Shelter Temperature	Campbell	none	107-L	none
11	8/17/2017	Siting Criteria	Siting Criteria	None	1	None
12	8/17/2017	Temperature	RM Young	06245	41342VC	12792
13	8/17/2017	Zero air pump	Werther International	06904	C 70/4	000821901

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2514	LRL117	Sandy Grenville	08/17/2017	DAS	Primary

Das Date:	<input type="text" value="8 /17/2017"/>	Audit Date	<input type="text" value="8 /17/2017"/>
Das Time:	<input type="text" value="16:09:17"/>	Audit Time	<input type="text" value="16:09:17"/>
Das Day:	<input type="text" value="229"/>	Audit Day	<input type="text" value="229"/>

Low Channel:	High Channel:		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0000"/>	<input type="text" value="0.0001"/>

Mfg	<input type="text" value="Datel"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="15510194"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01320"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="2/13/2012"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740135"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01311"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	0.0000	0.0000	V	V	0.0000
7	0.1000	0.0999	0.0999	V	V	0.0000
7	0.3000	0.2997	0.2997	V	V	0.0000
7	0.5000	0.4997	0.4996	V	V	-0.0001
7	0.7000	0.6996	0.6995	V	V	-0.0001
7	0.9000	0.8994	0.8994	V	V	0.0000
7	1.0000	0.9993	0.9992	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		LRL117	Sandy Grenville	08/17/2017	Flow Rate	000591

Mfg	BIOS	Parameter	Flow Rate
Serial Number	103471	Tfer Desc.	nexus
Tfer ID	01420		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991
Mfg	BIOS	Parameter	Flow Rate
Serial Number	103424	Tfer Desc.	BIOS cell
Tfer ID	01410		
Slope	0.99825	Intercept	0.00497
Cert Date	2/7/2017	CorrCoff	0.99991

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.45%	0.67%
A Avg %Dif	A Max % Di

Cal Factor Zero	-0.005
Cal Factor Full Scale	0.982
Rotometer Reading:	1.45

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.00	l/m	l/m	
primary	test pt 1	1.496	1.490	1.52	0.000	1.50	l/m	l/m	0.67%
primary	test pt 2	1.494	1.490	1.52	0.000	1.50	l/m	l/m	0.67%
primary	test pt 3	1.500	1.500	1.52	0.000	1.50	l/m	l/m	0.00%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	3.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244808		LRL117	Sandy Grenville	08/17/2017	Ozone	000701

Slope:	0.99010	Slope:	0.00000
Intercept	0.82411	Intercept	0.00000
CorrCoff	1.00000	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.4%	3.7%		

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.25	-0.20	0.70	ppb	
primary	2	14.99	14.49	15.02	ppb	3.66%
primary	3	35.00	34.45	35.02	ppb	1.65%
primary	4	68.01	67.38	67.53	ppb	0.22%
primary	5	110.00	109.26	109.00	ppb	-0.24%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	-0.10	Status	pass
Sensor Component	Span	Condition	1.011	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	124.7 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	2.5 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	688.0 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	32.8 C	Status	pass
Sensor Component	Cell B Freq.	Condition	96.3 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	2.0 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	687.7 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	12792		LRL117	Sandy Grenville	08/17/2017	Temperature	06245

Mfg	Extech	Parameter	Temperature
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.15	0.26		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.20	0.05	0.000	0.3	C	0.26
primary	Temp Mid Range	25.23	24.89	0.000	25.1	C	0.16
primary	Temp High Range	49.32	48.80	0.000	48.8	C	0.02

Sensor Component	Shield	Condition	Moderately clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	LRL117	Sandy Grenville	08/17/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.61	0.92		

Mfg	Extech	Parameter	Shelter Temperatur
Serial Number	H232734	Tfer Desc.	RTD
Tfer ID	01227		
Slope	1.00759	Intercept	0.14754
Cert Date	2/4/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.72	23.39	0.000	23.7	C	0.26
primary	Temp Mid Range	20.81	20.51	0.000	21.2	C	0.65
primary	Temp Mid Range	26.16	25.82	0.000	24.9	C	-0.92

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** DasComments

The meteorological tower has been removed and the temperature sensor has been installed on the sample tower in a naturally aspirated shield.

2 **Parameter:** SiteOpsProcedures

Ozone sample line leak checks conducted every other week following the inlet filter replacements.

3 **Parameter:** SitingCriteriaCom

Logging activities are underway surrounding the site. The site is being used as a loading area.

4 **Parameter:** ShelterCleanNotes

The shelter has been repaired and is in very good condition. A new peaked roof has been installed.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text"/>
Operating Group	<input type="text" value="private/PADNR"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="42-111-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="39.988309"/>
Site Address 1	<input type="text" value="Laurel Hill State Park"/>	Audit Longitude	<input type="text" value="-79.251573"/>
Site Address 2	<input type="text" value="1447 Laurel Hill State Park Rd."/>	Audit Elevation	<input type="text" value="609"/>
County	<input type="text"/>	Audit Declination	<input type="text" value="-9"/>
City, State	<input type="text" value="Somerset, PA"/>		
Zip Code	<input type="text" value="15501"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="New in 2015"/>
Time Zone	<input type="text" value="Eastern"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text" value="Locked gate"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8810"/>	Shelter Size <input type="text" value="640 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter has been repaired and is in very good condition. A new peaked roof has been installed."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="From Somerset take 30 west"/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	Moderately clean
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 12 meters
3/8 teflon by 12 meters
At inlet only
Flow line only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|--|----------------------|--|----------|-------------------------------------|--|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table> | Stable | | Grounded | <input type="checkbox"/> | | <input type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input type="checkbox"/> | | <input type="checkbox"/> | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The meteorological tower has been removed and the temperature sensor has been installed on the sample tower in a naturally aspirated shield.

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	Not present	<input type="checkbox"/>
HASP	<input type="checkbox"/>	Not present	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how? Logbook, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Ozone sample line leak checks conducted every other week following the inlet filter replacements.

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	D520	unknown	07010
DAS	Campbell	CR3000	2514	000402
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	Unknown	02741
Flow Rate	Apex	AXMC105LPMDPC	illegible	000591
Infrastructure	Infrastructure	none	none	none
Ozone	ThermoElectron Inc	49i A1NAA	1030244808	000701
Ozone Standard	ThermoElectron Inc	49i A3NAA	CM08200020	000444
Sample Tower	Aluma Tower	B	none	000783
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	12792	06245
Zero air pump	Werther International	C 70/4	000821901	06904

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>GLR468-Martin Valvur-08/17/2017</i>						
1	8/17/2017	Computer	Hewlett Packard	none	6560 b	5CB1520H65
2	8/17/2017	DAS	Environmental Sys Corp	90647	8816	2560
3	8/17/2017	Elevation	Elevation	None	1	None
4	8/17/2017	Filter pack flow pump	Thomas	none	107CAB11A	109500000039
5	8/17/2017	Flow Rate	Tylan	none	FC280	AW9710138
6	8/17/2017	Infrastructure	Infrastructure	none	none	none
7	8/17/2017	MFC power supply	Tylan	03687	RO-32	FP9403014
8	8/17/2017	Modem	US Robotics	none	56k	unknown
9	8/17/2017	Ozone	ThermoElectron Inc	none	49i A3NAA	1023943901
10	8/17/2017	Ozone Standard	ThermoElectron Inc	none	49i A3NAA	0733726104
11	8/17/2017	Sample Tower	Aluma Tower	none	B	none
12	8/17/2017	Shelter Temperature	ARS	77	none	none
13	8/17/2017	Siting Criteria	Siting Criteria	None	1	None
14	8/17/2017	Temperature2meter	RM Young	none	41342	17625
15	8/17/2017	Zero air pump	Werther International	none	PC70/4	000756725

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2560	GLR468	Martin Valvur	08/17/2017	DAS	Primary

Das Date:	<input type="text" value="8 /17/2017"/>	Audit Date	<input type="text" value="8 /17/2017"/>
Das Time:	<input type="text" value="8:39:00"/>	Audit Time	<input type="text" value="8:40:10"/>
Das Day:	<input type="text" value="229"/>	Audit Day	<input type="text" value="229"/>

Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0002"/>	<input type="text" value="0.0003"/>	<input type="text" value="0.0002"/>	<input type="text" value="0.0003"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
15	0.0000	-0.0002	-0.0003	V	V	-0.0001
15	0.1000	0.0998	0.0995	V	V	-0.0003
15	0.3000	0.2995	0.2997	V	V	0.0002
15	0.5000	0.4997	0.4994	V	V	-0.0003
15	0.7000	0.7001	0.6998	V	V	-0.0003
15	0.9000	0.9003	0.9002	V	V	-0.0001
15	1.0000	1.0000	1.0003	V	V	0.0003

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9710138		GLR468	Martin Valvur	08/17/2017	Flow Rate	none

Mfg	Tylan
SN/Owner ID	FP9403014 03687
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
2.38%	2.38%

Cal Factor Zero	0.37
Cal Factor Full Scale	6.01
Rotometer Reading:	3.2

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	-0.36	0.0000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	-0.36	0.0000	0.00	l/m	l/m	
primary	test pt 1	2.950	2.940	2.34	0.0000	3.01	l/m	l/m	2.38%
primary	test pt 2	2.950	2.940	2.34	0.0000	3.01	l/m	l/m	2.38%
primary	test pt 3	2.950	2.940	2.34	0.0000	3.01	l/m	l/m	2.38%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	360 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1023943901		GLR468	Martin Valvur	08/17/2017	Ozone	none

Slope:	1.05210	Slope:	0.00000
Intercept	0.44679	Intercept	0.00000
CorrCoff	0.99994	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
6.3%	7.9%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.40	0.38	1.15	ppb	
primary	2	15.07	14.98	16.16	ppb	7.88%
primary	3	35.04	34.86	37.26	ppb	6.88%
primary	4	65.60	65.28	68.27	ppb	4.58%
primary	5	112.02	111.48	118.20	ppb	6.03%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	-0.4	Status	pass
Sensor Component	Span	Condition	1.007	Status	pass
Sensor Component	Zero Voltage	Condition	0.000	Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9999	Status	pass
Sensor Component	Cell A Freq.	Condition	61.3 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.65 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	668.2 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	29.7 C	Status	pass
Sensor Component	Cell B Freq.	Condition	56.1 kHz	Status	Fail
Sensor Component	Cell B Noise	Condition	0.5 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.56 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	668.2 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	17625		GLR468	Martin Valvur	08/17/2017	Temperature2meter	none

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.15	1.65		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.06	0.03	0.0000	-0.62	C	-0.65
primary	Temp Mid Rang	24.23	24.20	0.0000	25.34	C	1.14
primary	Temp High Rang	47.77	47.74	0.0000	46.09	C	-1.65

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	GLR468	Martin Valvur	08/17/2017	Shelter Temperature	77

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.86	1.28		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.30	25.27	0.000	24.0	C	-1.28
primary	Temp Mid Range	25.39	25.36	0.000	24.2	C	-1.21
primary	Temp Mid Range	25.01	24.98	0.000	25.1	C	0.09

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2149-20)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Fair"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	GLR468	Martin Valvur	08/17/2017	Cell B Freq.	ThermoElectron	3383	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone inlet filter is being changed weekly while smoke from forest fires is present.

2 **Parameter:** SitingCriteriaCom

The site is located in a small clearing within 100 meters of a horse stable. There is a plywood and aluminum processing plant within 20 km of the site.

3 **Parameter:** ShelterCleanNotes

The shelter is in good condition. Evidence of repairs to roof leaks attempted. Some floor tiles are loose.

4 **Parameter:** MetSensorComme

The recorded temperature data at this site is measured at approximately 2 meters above the ground.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Lake McDonald West"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="30-029-8001"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="48.5103"/>
Deposition Measurement	<input type="text" value="dry, wet, Hg"/>	QAPP Longitude	<input type="text" value="-113.9956"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="976"/>
Terrain	<input type="text" value="complex"/>	QAPP Declination	<input type="text" value="18"/>
Conforms to MLM	<input type="text" value="No"/>	QAPP Declination Date	<input type="text" value="12/27/2004"/>
Site Telephone	<input type="text" value="(406) 888-7983"/>	Audit Latitude	<input type="text" value="48.510301"/>
Site Address 1	<input type="text" value="Horse Stables"/>	Audit Longitude	<input type="text" value="-113.996807"/>
Site Address 2	<input type="text" value="Quarter Circle Bridge Rd"/>	Audit Elevation	<input type="text" value="964"/>
County	<input type="text" value="Flathead"/>	Audit Declination	<input type="text" value="14.1"/>
City, State	<input type="text" value="West Glacier, MT"/>		
Zip Code	<input type="text" value="59936"/>	Present	
Time Zone	<input type="text" value="Mountain"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="Inspected June 2011"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	20 km	<input type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m	30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located in a small clearing within 100 meters of a horse stable. There is a plywood and aluminum processing plant within 20 km of the site.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----------------------------|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | Temperature now at 2 meters |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The recorded temperature data at this site is measured at approximately 2 meters above the ground.

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

1/4 teflon by 15 meters
3/8 Teflon by 12 meters
At inlet only
Clean and dry

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

--

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="Dataview"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Jan 2006"/>	<input type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	<input type="text" value="April 2004"/>	<input type="checkbox"/>
Field Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="April 2004"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	Dataview
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	6560 b	5CB1520H65	none
DAS	Environmental Sys Corp	8816	2560	90647
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB11A	109500000039	none
Flow Rate	Tylan	FC280	AW9710138	none
Infrastructure	Infrastructure	none	none	none
MFC power supply	Tylan	RO-32	FP9403014	03687
Modem	US Robotics	56k	unknown	none
Ozone	ThermoElectron Inc	49i A3NAA	1023943901	none
Ozone Standard	ThermoElectron Inc	49i A3NAA	0733726104	none
Sample Tower	Aluma Tower	B	none	none
Shelter Temperature	ARS	none	none	77
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342	17625	none
Zero air pump	Werther International	PC70/4	000756725	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>THR422-Martin Valvur-08/29/2017</i>						
1	8/29/2017	Computer	Hewlett Packard	none	65606	5CB1520H68
2	8/29/2017	DAS	Environmental Sys Corp	90656	8816	2600
3	8/29/2017	Elevation	Elevation	None	1	None
4	8/29/2017	Filter pack flow pump	Thomas	03634	107CAB18	049400004441
5	8/29/2017	flow rate	Tylan	none	FC280SAV	AW02213004
6	8/29/2017	Infrastructure	Infrastructure	none	none	none
7	8/29/2017	Mainframe	Climatronics	none	100081	1911
8	8/29/2017	Mainframe power supply	Climatronics	none	101074	unknown
9	8/29/2017	Met tower	Rohn	none	unknown	none
10	8/29/2017	MFC power supply	Tylan	00042	RO-32	FP902022
11	8/29/2017	Ozone	ThermoElectron Inc	E00051	49i A1NAA	1153170017
12	8/29/2017	Sample Tower	Aluma Tower	none	B	AT-81077-J5
13	8/29/2017	Shelter Temperature	ARS	none	none	none
14	8/29/2017	Siting Criteria	Siting Criteria	None	1	None
15	8/29/2017	Temperature Translator	Climatronics	01545	100088-2	217
16	8/29/2017	Temperature2meter	Climatronics	none	100093	7974
17	8/29/2017	Zero air pump	Thomas	none	607CA22C	039500000348

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	2600	THR422	Martin Valvur	08/29/2017	DAS	Primary

Das Date:	<input type="text" value="8 /29/2017"/>	Audit Date	<input type="text" value="8 /29/2017"/>
Das Time:	<input type="text" value="7:14:15"/>	Audit Time	<input type="text" value="7:15:30"/>
Das Day:	<input type="text" value="241"/>	Audit Day	<input type="text" value="241"/>
Low Channel:		High Channel:	
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:
<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>	<input type="text" value="0.0001"/>	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0005	-0.0005	V	V	0.0000
7	0.1000	0.0996	0.0996	V	V	0.0000
7	0.3000	0.2991	0.2992	V	V	0.0001
7	0.5000	0.5000	0.4998	V	V	-0.0002
7	0.7000	0.6998	0.6996	V	V	-0.0002
7	0.9000	0.8999	0.9001	V	V	0.0002
7	1.0000	1.0004	1.0004	V	V	0.0000

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW02213004		THR422	Martin Valvur	08/29/2017	flow rate	none

Mfg	Tylan	
SN/Owner ID	FP902022	00042
Parameter	MFC power supply	

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.22%	0.33%

Cal Factor Zero	0.171
Cal Factor Full Scale	11
Rotometer Reading:	3.25

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	-0.22	0.0000	-0.02	l/m	l/m	
primary	leak check	0.000	0.000	-0.22	0.0000	-0.03	l/m	l/m	
primary	test pt 1	2.999	2.990	2.61	0.0000	3.00	l/m	l/m	0.33%
primary	test pt 2	3.007	3.000	2.61	0.0000	3.00	l/m	l/m	0.00%
primary	test pt 3	3.002	2.990	2.60	0.0000	3.00	l/m	l/m	0.33%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Fair	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	135 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1153170017		THR422	Martin Valvur	08/29/2017	Ozone	E00051

Slope:	0.95995	Slope:	0.00000
Intercept	-0.27325	Intercept	0.00000
CorrCoff	0.99995	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
5.2%	5.8%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.18	0.16	0.33	ppb	
primary	2	15.86	15.77	14.85	ppb	-5.83%
primary	3	35.31	35.13	33.14	ppb	-5.66%
primary	4	67.24	66.91	63.40	ppb	-5.25%
primary	5	112.36	111.82	107.50	ppb	-3.86%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.30	Status	pass
Sensor Component	Span	Condition	0.969	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	48.1 kHz	Status	Fail
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	670.1 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	32.8 C	Status	pass
Sensor Component	Cell B Freq.	Condition	72.4 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.67 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	669.8 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	7974		THR422	Martin Valvur	08/29/2017	Temperature2meter	none

Mfg	Climatronics	
SN/Owner ID	217	01545
Parameter	Temperature Translator	

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.11	0.15		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.11	0.08	0.0000	0.23 C		0.15
primary	Temp Mid Rang	24.61	24.58	0.0000	24.63 C		0.05
primary	Temp High Rang	46.93	46.90	0.0000	47.03 C		0.13

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	THR422	Martin Valvur	08/29/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
1.93	2.17		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.00	22.97	0.000	24.4	C	1.47
primary	Temp Mid Range	25.53	25.50	0.000	27.7	C	2.16
primary	Temp Mid Range	26.49	26.46	0.000	28.6	C	2.17

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8814 (s/n 3028-1)"/>	<input type="text" value="896 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	THR422	Martin Valvur	08/29/2017	Cell A Freq.	ThermoElectron	4382	<input type="checkbox"/>	<input type="checkbox"/>
-------	--------	---------------	------------	--------------	----------------	------	--------------------------	--------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests.

2 Parameter: SitingCriteriaCom

The site is located 200 meters from an interstate rest area, and 300 meters from interstate 94. The rest area can have parked and idling vehicles for extended periods.

3 Parameter: ShelterCleanNotes

The shelter is in good condition, clean and well organized.

4 Parameter: PollAnalyzerCom

The ozone analyzer is operated by the state of North Dakota. The sample train contains a glass manifold. There is no means to introduce on-site generated test gas at the sample inlet. A through-the-probe audit was conducted using the EEMS system.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Fryburg NW"/>
Operating Group	<input type="text" value="NPS and state of ND"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="38-007-0002"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, SO2, IMPROVE, PM2.5"/>	QAPP Latitude	<input type="text" value="46.8947"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-103.3778"/>
Land Use	<input type="text" value="prairie"/>	QAPP Elevation Meters	<input type="text" value="850"/>
Terrain	<input type="text" value="rolling - complex"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="46.894844"/>
Site Address 1	<input type="text" value="Painted Canyon Visitor Center"/>	Audit Longitude	<input type="text" value="-103.377719"/>
Site Address 2	<input type="text" value="Exit 32 Interstate 94"/>	Audit Elevation	<input type="text" value="840"/>
County	<input type="text" value="Billings"/>	Audit Declination	<input type="text" value="8.2"/>
City, State	<input type="text" value="Medora, ND"/>		
Zip Code	<input type="text" value="58645"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text"/>
Time Zone	<input type="text" value="Mountain"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Ekto"/>	Model <input type="text" value="8814 (s/n 3028-1)"/>	Shelter Size <input type="text" value="896 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in good condition, clean and well organized."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		
Driving Directions	<input type="text" value="From Interstate 94 take exit 32 to the Painted Canyon rest area and visitor center. The site is just east of the parking lot on a gravel road."/>		

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	300 m	<input type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m	200 m	<input type="checkbox"/>
Small parking lot	100 m		<input checked="" type="checkbox"/>
Tree line	50 m		<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located 200 meters from an interstate rest area, and 300 meters from interstate 94. The rest area can have parked and idling vehicles for extended periods.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Signs of wear
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|--|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 3/8 teflon by 10 meters and glass manifold |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 12 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet and analyzer |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input type="checkbox"/> | |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | Clean and dry |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone analyzer is operated by the state of North Dakota. The sample train contains a glass manifold. There is no means to introduce on-site generated test gas at the sample inlet. A through-the-probe audit was conducted using the EEMS system.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- 1 Do the DAS instruments appear to be in good condition and well maintained?
- 2 Are all the components of the DAS operational? (printers, modem, backup, etc)
- 3 Do the analyzer and sensor signal leads pass through lightning protection circuitry?
- 4 Are the signal connections protected from the weather and well maintained?
- 5 Are the signal leads connected to the correct DAS channel?
- 6 Are the DAS, sensor translators, and shelter properly grounded?
- 7 Does the instrument shelter have a stable power source?
- 8 Is the instrument shelter temperature controlled?
- 9 Is the met tower stable and grounded?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 10 Is the sample tower stable and grounded?

Stable	Grounded
<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
- 11 Tower comments?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="Dataview"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Quarterly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests.

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	One set of gloves only
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	65606	5CB1520H68	none
DAS	Environmental Sys Corp	8816	2600	90656
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	049400004441	03634
flow rate	Tylan	FC280SAV	AW02213004	none
Infrastructure	Infrastructure	none	none	none
Mainframe	Climatronics	100081	1911	none
Mainframe power supply	Climatronics	101074	unknown	none
Met tower	Rohn	unknown	none	none
MFC power supply	Tylan	RO-32	FP902022	00042
Ozone	ThermoElectron Inc	49i A1NAA	1153170017	E00051
Sample Tower	Aluma Tower	B	AT-81077-J5	none
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature Translator	Climatronics	100088-2	217	01545
Temperature2meter	Climatronics	100093	7974	none
Zero air pump	Thomas	607CA22C	039500000348	none

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>VOY413-Martin Valvur-09/01/2017</i>						
1	9/1/2017	DAS	Environmental Sys Corp	none	8816	4059
2	9/1/2017	Elevation	Elevation	None	1	None
3	9/1/2017	Filter pack flow pump	Thomas	none	107CAB18	111500052144
4	9/1/2017	flow rate	Tylan	none	FC280SAV	AW9806012
5	9/1/2017	Infrastructure	Infrastructure	none	none	none
6	9/1/2017	MFC power supply	Tylan	none	RO-32	FP9806001
7	9/1/2017	Ozone	ThermoElectron Inc	90730	49C	49C-70522-366
8	9/1/2017	Ozone Standard	ThermoElectron Inc	90569	49C	49C-59260-322
9	9/1/2017	Sample Tower	Aluma Tower	none	B	AT-51159-11-G
10	9/1/2017	Shelter Temperature	ARS	none	none	none
11	9/1/2017	Siting Criteria	Siting Criteria	None	1	None
12	9/1/2017	Temperature Translator	Climatronics	01341	100088-2	229
13	9/1/2017	Temperature2meter	Climatronics	none	100093	04767
14	9/1/2017	Zero air pump	Twin Tower Engineering	90719	TT70/E4	526294

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Environmental Sys	4059	VOY413	Martin Valvur	09/01/2017	DAS	Primary

Das Date: **Audit Date:**
Das Time: **Audit Time:**
Das Day: **Audit Day:**

Low Channel: **High Channel:**
Avg Diff: **Max Diff:** **Avg Diff:** **Max Diff:**

Mfg **Parameter**
Serial Number **Tfer Desc.**
Tfer ID
Slope **Intercept**
Cert Date **CorrCoff**
Mfg **Parameter**
Serial Number **Tfer Desc.**
Tfer ID
Slope **Intercept**
Cert Date **CorrCoff**

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
15	0.0000	-0.0002	0.0001	V	V	0.0003
15	0.1000	0.0998	0.0997	V	V	-0.0001
15	0.3000	0.2999	0.2998	V	V	-0.0001
15	0.5000	0.4998	0.4998	V	V	0.0000
15	0.7000	0.7000	0.7000	V	V	0.0000
15	0.9000	0.8996	0.8997	V	V	0.0001
15	1.0000	1.0000	0.9999	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Tylan	AW9806012		VOY413	Martin Valvur	09/01/2017	flow rate	none

Mfg	Tylan
SN/Owner ID	FP9806001 none
Parameter	MFC power supply

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.33%	0.33%

Cal Factor Zero	0.12
Cal Factor Full Scale	5.606
Rotometer Reading:	3

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignalI	PctDifference
primary	pump off	0.000	0.000	-0.15	0.0000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	-0.11	0.0000	0.03	l/m	l/m	
primary	test pt 1	2.996	2.990	2.62	0.0000	3.00	l/m	l/m	0.33%
primary	test pt 2	2.997	2.990	2.63	0.0000	3.00	l/m	l/m	0.33%
primary	test pt 3	2.996	2.990	2.62	0.0000	3.00	l/m	l/m	0.33%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	0.25 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	270 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-70522-366		VOY413	Martin Valvur	09/01/2017	Ozone	90730

Slope:	1.03949	Slope:	0.00000
Intercept	-0.12822	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
3.5%	4.2%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.40	0.38	0.20	ppb	
primary	2	15.05	14.96	15.35	ppb	2.61%
primary	3	35.03	34.85	36.10	ppb	3.59%
primary	4	65.03	64.71	67.45	ppb	4.23%
primary	5	110.01	109.48	113.50	ppb	3.67%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	Fail
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.40	Status	pass
Sensor Component	Span	Condition	1.009	Status	pass
Sensor Component	Zero Voltage	Condition	-0.0002	Status	pass
Sensor Component	Fullscale Voltage	Condition	0.9996	Status	pass
Sensor Component	Cell A Freq.	Condition	88.9 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.89 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	714.0 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	31.8 C	Status	pass
Sensor Component	Cell B Freq.	Condition	105.9 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.75 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	713.4 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition	See comments	Status	pass

2 Meter Temperature Data Form

Calc. Difference

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Climatronics	04767		VOY413	Martin Valvur	09/01/2017	Temperature2meter	none

Mfg	Climatronics
SN/Owner ID	229 01341
Parameter	Temperature Translator

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.38	0.52		

UseDescription	Test type	InputTmpRaw	InputTmpCorrected	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Rang	0.12	0.09	0.0000	0.42 C		0.33
primary	Temp Mid Rang	23.84	23.81	0.0000	24.09 C		0.28
primary	Temp High Rang	44.64	44.61	0.0000	45.13 C		0.52

Sensor Component	Properly Sited	Condition	Properly sited	Status	pass
Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	Functioning	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	VOY413	Martin Valvur	09/01/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.73	0.80		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.09	23.06	0.000	22.3	C	-0.74
primary	Temp Mid Range	21.95	21.92	0.000	22.7	C	0.8
primary	Temp Mid Range	23.74	23.71	0.000	24.4	C	0.66

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Ekto"/>	<input type="text" value="8810 (s/n 2880-2)"/>	<input type="text" value="640 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: DasComments

The sample tower itself is not grounded, however it is bolted to the shelter which is grounded.

2 Parameter: DocumentationCo

Correctly completing the general observations section of the SSRF on the day of filter installation was discussed with the operator.

3 Parameter: SitingCriteriaCom

The site is located at the top of a hill in a forest. There are trees surrounding the site which are below the tower height.

4 Parameter: ShelterCleanNotes

The shelter is clean, neat, and well organized. The shelter is in good condition.

5 Parameter: PollAnalyzerCom

There are no trees violating the 22.5 degree cone above the ozone sample inlet. However, there is a communication tower which is above the 22.5 degree threshold.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="NPS"/>	USGS Map	<input type="text" value="Ash River NE"/>
Operating Group	<input type="text" value="NPS"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="27-137-0034"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="Climatronics"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, IMPROVE"/>	QAPP Latitude	<input type="text" value="48.4128"/>
Deposition Measurement	<input type="text" value="dry, wet"/>	QAPP Longitude	<input type="text" value="-92.8292"/>
Land Use	<input type="text" value="woodland - mixed"/>	QAPP Elevation Meters	<input type="text" value="429"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Marginally"/>	QAPP Declination Date	<input type="text"/>
Site Telephone	<input type="text"/>	Audit Latitude	<input type="text" value="48.412518"/>
Site Address 1	<input type="text" value="CR 129"/>	Audit Longitude	<input type="text" value="-92.829225"/>
Site Address 2	<input type="text" value="Ash River Visitor Center Rd."/>	Audit Elevation	<input type="text" value="427"/>
County	<input type="text" value="St. Louis"/>	Audit Declination	<input type="text" value="0.5"/>
City, State	<input type="text" value="Orr, MN"/>		
Zip Code	<input type="text" value="55771"/>	Fire Extinguisher <input type="checkbox"/>	<input type="text"/>
Time Zone	<input type="text" value="Central"/>	First Aid Kit <input type="checkbox"/>	<input type="text"/>
Primary Operator	<input type="text"/>	Safety Glasses <input type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Climbing Belt <input checked="" type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	5 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located at the top of a hill in a forest. There are trees surrounding the site which are below the tower height.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|-----------------------|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input type="checkbox"/> | Trees within 5 meters |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 12 meters |
| 4 | Describe dry dep sample tube. | | 3/8 teflon by 9 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input checked="" type="checkbox"/> | |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | Clean and dry |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There are no trees violating the 22.5 degree cone above the ozone sample inlet. However, there is a communication tower which is above the 22.5 degree threshold.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text" value="Dataview"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	<input type="text" value="Jan 2006"/>	<input checked="" type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Monthly and semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Alarm values only"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed various times
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8816	4059	none
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	111500052144	none
flow rate	Tylan	FC280SAV	AW9806012	none
Infrastructure	Infrastructure	none	none	none
MFC power supply	Tylan	RO-32	FP9806001	none
Ozone	ThermoElectron Inc	49C	49C-70522-366	90730
Ozone Standard	ThermoElectron Inc	49C	49C-59260-322	90569
Sample Tower	Aluma Tower	B	AT-51159-11-G	none
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature Translator	Climatronics	100088-2	229	01341
Temperature2meter	Climatronics	100093	04767	none
Zero air pump	Twin Tower Engineering	TT70/E4	526294	90719

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>	
<i>SAN189-Martin Valvur-09/07/2017</i>						
1	9/7/2017	Computer	Dell	07051	Inspiron 15	Unknown
2	9/7/2017	DAS	Campbell	000360	CR3000	2138
3	9/7/2017	Elevation	Elevation	None	1	None
4	9/7/2017	Filter pack flow pump	Thomas	06019	107CAB18	050400022576
5	9/7/2017	Flow Rate	Apex	000861	AXMC105LPMDPCV	illegible
6	9/7/2017	Infrastructure	Infrastructure	none	none	none
7	9/7/2017	Modem	Raven	06453	V4221-V	0808337397
8	9/7/2017	Ozone	ThermoElectron Inc	000729	49i A1NAA	1105347323
9	9/7/2017	Ozone Standard	ThermoElectron Inc	000367	49i A3NAA	0726124683
10	9/7/2017	Sample Tower	Aluma Tower	000207	B	none
11	9/7/2017	Shelter Temperature	Campbell	none	107-L	223461
12	9/7/2017	Siting Criteria	Siting Criteria	None	1	None
13	9/7/2017	Temperature	RM Young	06537	41342VC	14798
14	9/7/2017	Zero air pump	Werther International	06875	C 70/4	000814272

DAS Data Form

DAS Time Max Error:

Mfg	Serial Number	Site	Technician	Site Visit Date	Parameter	Use Desc.
Campbell	2138	SAN189	Martin Valvur	09/07/2017	DAS	Primary

Das Date:	<input type="text" value="9/7/2017"/>	Audit Date:	<input type="text" value="9/7/2017"/>
Das Time:	<input type="text" value="8:22:00"/>	Audit Time:	<input type="text" value="8:22:00"/>
Das Day:	<input type="text" value="250"/>	Audit Day:	<input type="text" value="250"/>
Low Channel:		High Channel:	
Avg Diff:	<input type="text" value="0.0001"/>	Max Diff:	<input type="text" value="0.0002"/>
		Avg Diff:	<input type="text" value="0.0001"/>
		Max Diff:	<input type="text" value="0.0002"/>

Mfg	<input type="text" value="HY"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="12010039329"/>	Tfer Desc.	<input type="text" value="Source generator (D"/>
Tfer ID	<input type="text" value="01322"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="6/15/2014"/>	CorrCoff	<input type="text" value="1.00000"/>
Mfg	<input type="text" value="Fluke"/>	Parameter	<input type="text" value="DAS"/>
Serial Number	<input type="text" value="95740243"/>	Tfer Desc.	<input type="text" value="DVM"/>
Tfer ID	<input type="text" value="01312"/>		
Slope	<input type="text" value="1.00000"/>	Intercept	<input type="text" value="0.00000"/>
Cert Date	<input type="text" value="1/23/2017"/>	CorrCoff	<input type="text" value="1.00000"/>

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference
7	0.0000	-0.0004	-0.0002	V	V	0.0002
7	0.1000	0.0998	0.0997	V	V	-0.0001
7	0.3000	0.2997	0.2998	V	V	0.0001
7	0.5000	0.5004	0.5004	V	V	0.0000
7	0.7000	0.6993	0.6995	V	V	0.0002
7	0.9000	0.8995	0.8995	V	V	0.0000
7	1.0000	0.9993	0.9992	V	V	-0.0001

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		SAN189	Martin Valvur	09/07/2017	Flow Rate	000861

Mfg	BIOS	Parameter	Flow Rate
Serial Number	148613	Tfer Desc.	BIOS 220-H
Tfer ID	01421		
Slope	1.00153	Intercept	0.00366
Cert Date	1/25/2017	CorrCoff	1.00000

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.78%	1.01%

Cal Factor Zero	-0.01
Cal Factor Full Scale	1
Rotometer Reading:	3.2

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.01	0.000	0.00	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.02	l/m	l/m	
primary	test pt 1	2.990	2.980	2.97	0.000	3.00	l/m	l/m	0.67%
primary	test pt 2	2.990	2.980	2.97	0.000	3.01	l/m	l/m	1.01%
primary	test pt 3	2.990	2.980	2.97	0.000	3.00	l/m	l/m	0.67%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	4.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347323		SAN189	Martin Valvur	09/07/2017	Ozone	000729

Slope:	0.93780	Slope:	0.00000
Intercept	-2.35573	Intercept	0.00000
CorrCoff	0.99979	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
11.6%	16.9%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.16	0.14	-3.28	ppb	
primary	2	15.32	15.23	12.65	ppb	-16.94%
primary	3	36.66	36.47	32.75	ppb	-10.20%
primary	4	65.21	64.89	58.09	ppb	-10.48%
primary	5	106.63	106.12	97.00	ppb	-8.59%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.001	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	90.9 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.71 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	659.8 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.8 C	Status	pass
Sensor Component	Cell B Freq.	Condition	83.8 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	695.2 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	14798		SAN189	Martin Valvur	09/07/2017	Temperature	06537

Mfg	Fluke	Parameter	Temperature
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.06	0.13		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.30	0.27	0.000	0.3	C	0.02
primary	Temp Mid Range	22.36	22.33	0.000	22.5	C	0.13
primary	Temp High Range	47.87	47.84	0.000	47.9	C	0.02

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Shelter Temperature Data For

Mfg	Serial Number	Ta Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	223461	SAN189	Martin Valvur	09/07/2017	Shelter Temperature	none

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.75	1.11		

Mfg	Fluke	Parameter	Shelter Temperatur
Serial Number	3275143	Tfer Desc.	RTD
Tfer ID	01229		
Slope	1.00006	Intercept	0.03191
Cert Date	1/23/2017	CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	25.30	25.27	0.000	24.2	C	-1.11
primary	Temp Mid Range	25.79	25.76	0.000	24.9	C	-0.88
primary	Temp Mid Range	25.83	25.80	0.000	25.5	C	-0.26

Sensor Component	System Memo	Condition		Status	pass
-------------------------	-------------	------------------	--	---------------	------

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text" value="Shelter One"/>	<input type="text" value="E8109-26012"/>	<input type="text" value="720 cuft"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="Functioning"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 teflon"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 **Parameter:** ShelterCleanNotes

The shelter is in very good condition, however somewhat cluttered.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency)	<input type="text" value="EPA"/>	USGS Map	<input type="text" value="Santee"/>
Operating Group	<input type="text" value="Santee Sioux Nation"/>	Map Scale	<input type="text"/>
AQS #	<input type="text" value="31-107-9991"/>	Map Date	<input type="text"/>
Meteorological Type	<input type="text" value="R.M. Young"/>		
Air Pollutant Analyzer	<input type="text" value="Ozone, SO2, NOx, CO"/>	QAPP Latitude	<input type="text"/>
Deposition Measurement	<input type="text" value="dry"/>	QAPP Longitude	<input type="text"/>
Land Use	<input type="text" value="range"/>	QAPP Elevation Meters	<input type="text" value="429"/>
Terrain	<input type="text" value="rolling"/>	QAPP Declination	<input type="text"/>
Conforms to MLM	<input type="text" value="Yes"/>	QAPP Declination Date	<input type="text" value="6/21/2006"/>
Site Telephone	<input type="text" value="(402) 857-2546"/>	Audit Latitude	<input type="text" value="42.829154"/>
Site Address 1	<input type="text" value="SR S54D"/>	Audit Longitude	<input type="text" value="-97.854128"/>
Site Address 2	<input type="text" value="Santee Sioux Indian Reservation"/>	Audit Elevation	<input type="text" value="434"/>
County	<input type="text" value="Knox"/>	Audit Declination	<input type="text" value="5.0"/>
City, State	<input type="text" value="Niobrara, NE"/>		
Zip Code	<input type="text" value="68760"/>	Present	
Time Zone	<input type="text" value="Central"/>	Fire Extinguisher <input checked="" type="checkbox"/>	<input type="text" value="No inspection date"/>
Primary Operator	<input type="text"/>	First Aid Kit <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. Phone #	<input type="text"/>	Safety Glasses <input checked="" type="checkbox"/>	<input type="text"/>
Primary Op. E-mail	<input type="text"/>	Safety Hard Hat <input type="checkbox"/>	<input type="text"/>
Backup Operator	<input type="text"/>	Climbing Belt <input type="checkbox"/>	<input type="text"/>
Backup Op. Phone #	<input type="text"/>	Security Fence <input type="checkbox"/>	<input type="text"/>
Backup Op. E-mail	<input type="text"/>	Secure Shelter <input checked="" type="checkbox"/>	<input type="text"/>
		Stable Entry Step <input checked="" type="checkbox"/>	<input type="text"/>
Shelter Working Room <input checked="" type="checkbox"/>	Make <input type="text" value="Shelter One"/>	Model <input type="text" value="E8109-26012"/>	Shelter Size <input type="text" value="720 cuft"/>
Shelter Clean <input checked="" type="checkbox"/>	Notes <input type="text" value="The shelter is in very good condition, however somewhat cluttered."/>		
Site OK <input checked="" type="checkbox"/>	Notes <input type="text"/>		

Driving Directions From Yankton, South Dakota go south on route 81. Turn right (south) at the intersection of route 12 and continue approximately 26 miles. Just past the casino and gas station, turn right (north) onto SR 54 toward Santee. Continue approximately 6.5 miles. The site will be visible through the farm gate on the left at the top of a hill just before reaching Santee.

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	N/A
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|-------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | 1/4 teflon by 16 meters |
| 4 | Describe dry dep sample tube. | | 1/4 teflon by 16 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | At inlet only |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | |
| 8 | Are there moisture traps in the sample lines? | <input checked="" type="checkbox"/> | |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | |
|-------------------------------------|--|--|----------------------|----------|-------------------------------------|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input type="checkbox"/> | Met sensors only | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | Grounded | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | |
| Stable | Grounded | | | | | | |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | | | | | | |
| 11 | Tower comments? | | <input type="text"/> | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input checked="" type="checkbox"/>	2014	<input checked="" type="checkbox"/>
HASP	<input checked="" type="checkbox"/>	2014	<input checked="" type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? Control charts not used

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="Semiannually"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Automatic Precision Level Tests	<input checked="" type="checkbox"/>	<input type="text" value="Daily"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Analyzer Diagnostics Tests	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input checked="" type="checkbox"/>	<input type="text" value="Every 2 weeks"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Zero Air Desiccant Check	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed morinings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF, logbook, call-in
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input type="checkbox"/>	<input type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07051
DAS	Campbell	CR3000	2138	000360
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	050400022576	06019
Flow Rate	Apex	AXMC105LPMDPC	illegible	000861
Infrastructure	Infrastructure	none	none	none
Modem	Raven	V4221-V	0808337397	06453
Ozone	ThermoElectron Inc	49i A1NAA	1105347323	000729
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124683	000367
Sample Tower	Aluma Tower	B	none	000207
Shelter Temperature	Campbell	107-L	223461	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VC	14798	06537
Zero air pump	Werther International	C 70/4	000814272	06875

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

NIC001-Eric Hebert-09/26/2017

1	9/26/2017	DAS	Campbell	000801	CR850	23268
2	9/26/2017	elevation	Elevation	none	none	none
3	9/26/2017	Filter pack flow pump	Permotec	none	BL30EB	Illegible
4	9/26/2017	Flow Rate	Apex	000594	AXMC105LPMDCV	unknown
5	9/26/2017	Infrastructure	Infrastructure	none	none	none
6	9/26/2017	Modem	Sierra wireless	06989	GX440	Unknown
7	9/26/2017	Sample Tower	Aluma Tower	000785	B	AT-212125X73
8	9/26/2017	siting criteria	Siting Criteria	none	none	None
9	9/26/2017	Temperature	RM Young	04943	41342	none

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		NIC001	Eric Hebert	09/26/2017	Flow Rate	000594

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00732	Intercept	-0.02202
Cert Date	3/8/2017	CorrCoff	0.99970

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
0.89%	0.89%

Cal Factor Zero	-0.055
Cal Factor Full Scale	0.964
Rotometer Reading:	2.95

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.06	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.06	l/m	l/m	
primary	test pt 1	3.031	3.030	3.00	0.000	3.00	l/m	l/m	-0.89%
primary	test pt 2	3.035	3.030	3.00	0.000	3.00	l/m	l/m	-0.89%
primary	test pt 3	3.032	3.030	3.00	0.000	3.00	l/m	l/m	-0.89%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	See comments	Status	pass
Sensor Component	Filter Distance	Condition	4.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	2.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	45 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	none		NIC001	Eric Hebert	09/26/2017	Temperature	04943

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00656	Intercept	-0.03341
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.20	0.35		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.01	0.04	0.000	0.4	C	0.35
primary	Temp Mid Range	26.39	26.25	0.000	26.2	C	-0.07
primary	Temp High Range	49.46	49.17	0.000	49.0	C	-0.18

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 Bevline"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Flow Rate	NIC001	Eric Hebert	09/26/2017	Moisture Present	Apex	3963	<input type="checkbox"/>	<input type="checkbox"/>
The filter sample tubing has drops of moisture in low sections outside the shelter.								

Field Systems Comments

1 **Parameter:** DasComments

Single tower with filter pack mounted at 10 meters and temperature mounted at 9 meters.

2 **Parameter:** DocumentationCo

There is no logbook onsite to record information regarding site status or filter information.

3 **Parameter:** ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower. The NY DEC operators a full monitoring shelter at the same location.

4 **Parameter:** PollAnalyzerCom

There is water accumulating in a low section of the filter pack tubing below the enclosure. It was pointed out to the site operator so corrective action can be taken before winter and the water freezes causing blockage.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map
 Operating Group Map Scale
 AQS # Map Date

Meteorological Type
 Air Pollutant Analyzer QAPP Latitude
 Deposition Measurement QAPP Longitude
 Land Use QAPP Elevation Meters
 Terrain QAPP Declination
 Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude
 Site Address 1 Audit Longitude
 Site Address 2 Audit Elevation
 County Audit Declination

City, State Present
 Zip Code Fire Extinguisher
 Time Zone First Aid Kit

Primary Operator Safety Glasses
 Primary Op. Phone # Safety Hard Hat
 Primary Op. E-mail Climbing Belt
 Backup Operator Security Fence
 Backup Op. Phone # Secure Shelter
 Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	20 m	<input type="checkbox"/>
Tree line	50 m	<input type="text"/>	<input checked="" type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- 1 Do the sample inlets have at least a 270 degree arc of unrestricted airflow?
- 2 Are the sample inlets 3 - 15 meters above the ground?
- 3 Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?

Pollutant analyzers and deposition equipment operations and maintenance

- 1 Do the analyzers and equipment appear to be in good condition and well maintained?
- 2 Are the analyzers and monitors operational, on-line, and reporting data?
- 3 Describe ozone sample tube.
- 4 Describe dry dep sample tube.
- 5 Are in-line filters used in the ozone sample line? (if yes indicate location)
- 6 Are sample lines clean, free of kinks, moisture, and obstructions?
- 7 Is the zero air supply desiccant unsaturated?
- 8 Are there moisture traps in the sample lines?
- 9 Is there a rotometer in the dry deposition filter line, and is it clean?

N/A
3/8 Bevline by 10 meters
N/A
Water in low section of tubing
N/A
Not present

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is water accumulating in a low section of the filter pack tubing below the enclosure. It was pointed out to the site operator so corrective action can be taken before winter and the water freezes causing blockage.

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | |
|----|--|-------------------------------------|-------------------------------------|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is the met tower stable and grounded? | <input type="checkbox"/> | <input type="checkbox"/> |
| 10 | Is the sample tower stable and grounded? | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| 11 | Tower comments? | <input type="text"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID Technician Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	No logbook	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>		<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? No logbook
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is no logbook onsite to record information regarding site status or filter information.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR850	23268	000801
elevation	Elevation	none	none	none
Filter pack flow pump	Permotec	BL30EB	Illegible	none
Flow Rate	Apex	AXMC105LPMDPC	unknown	000594
Infrastructure	Infrastructure	none	none	none
Modem	Sierra wireless	GX440	Unknown	06989
Sample Tower	Aluma Tower	B	AT-212125X73	000785
siting criteria	Siting Criteria	none	None	none
Temperature	RM Young	41342	none	04943

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

WFM105-Eric Hebert-09/27/2017

1	9/27/2017	DAS	Campbell	none	CR850	23270
2	9/27/2017	elevation	Elevation	none	none	none
3	9/27/2017	Filter pack flow pump	Permotec	none	BL30EB	Illegible
4	9/27/2017	Flow Rate	Apex	000651	AXMC105LPMDCV	illegible
5	9/27/2017	Infrastructure	Infrastructure	none	none	none
6	9/27/2017	Modem	Sierra wireless	06983	unknown	unknown
7	9/27/2017	Sample Tower	Aluma Tower	000748	B	AT-212125X75
8	9/27/2017	siting criteria	Siting Criteria	none	none	None
9	9/27/2017	Temperature	RM Young	04683	41342VC	6697

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	illegible		WFM105	Eric Hebert	09/27/2017	Flow Rate	000651

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00732	Intercept	-0.02202
Cert Date	3/8/2017	CorrCoff	0.99970

DAS 1:	DAS 2:	Cal Factor Zero	0
A Avg % Diff:	A Max % Di	Cal Factor Full Scale	0
1.43%	1.64%	Rotometer Reading:	3.1

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	-0.04	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	-0.04	l/m	l/m	
primary	test pt 1	3.051	3.050	2.82	0.000	3.00	l/m	l/m	-1.64%
primary	test pt 2	3.039	3.040	2.82	0.000	3.00	l/m	l/m	-1.32%
primary	test pt 3	3.043	3.040	2.82	0.000	3.00	l/m	l/m	-1.32%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	5.0 cm	Status	pass
Sensor Component	Filter Depth	Condition	3.0 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	315 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	6697		WFM105	Eric Hebert	09/27/2017	Temperature	04683

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00656	Intercept	-0.03341
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.18	0.44		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	0.37	0.40	0.000	0.8	C	0.44
primary	Temp Mid Range	26.74	26.60	0.000	26.7	C	0.06
primary	Temp High Range	49.70	49.41	0.000	49.5	C	0.04

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID **Technician** **Site Visit Date**

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 Bevline"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: DasComments

Single tower, with filter pack at 10 meters and temperature at 9 meters.

2 Parameter: DocumentationCo

There is no logbook present to record the status of the site equipment, calibration information, or filter information.

3 Parameter: SitingCriteriaCom

The site is located at the Atmospheric Science Research Center (ASRC) operated by the NY University (SUNY) system.

4 Parameter: ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map

Operating Group Map Scale

AQS # Map Date

Meteorological Type

Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude

Land Use QAPP Elevation Meters

Terrain QAPP Declination

Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State Present

Zip Code Fire Extinguisher

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID Technician Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km		<input checked="" type="checkbox"/>
City > 50,000 population	40 km		<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km		<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km		<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km		<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m		<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m		<input checked="" type="checkbox"/>
Feedlot operations	500 m		<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m		<input checked="" type="checkbox"/>
Limited agricultural operations	200 m		<input checked="" type="checkbox"/>
Large parking lot	200 m		<input checked="" type="checkbox"/>
Small parking lot	100 m	75 m	<input type="checkbox"/>
Tree line	50 m	25 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height		<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

The site is located at the Atmospheric Science Research Center (ASRC) operated by the NY University (SUNY) system.

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|--------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | N/A |
| 4 | Describe dry dep sample tube. | | 3/8 Bevline by 10 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | N/A |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | N/A |
| 8 | Are there moisture traps in the sample lines? | <input type="checkbox"/> | Not present |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | |
|----|--|-------------------------------------|-------------------------------------|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | |
| 8 | Is the instrument shelter temperature controlled? | <input type="checkbox"/> | N/A |
| 9 | Is the met tower stable and grounded? | <input type="checkbox"/> | <input type="checkbox"/> |
| 10 | Is the sample tower stable and grounded? | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| 11 | Tower comments? | <input type="text"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input type="checkbox"/>	No logbook	<input type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>		<input type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
HASP	<input type="checkbox"/>		<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>		<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>		<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>		<input type="checkbox"/>
Preventive maintenance schedul	<input type="checkbox"/>		<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit? No logbook
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

There is no logbook present to record the status of the site equipment, calibration information, or filter information.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed	Frequency	Compliant
Multipoint Calibrations	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/> <input type="text"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed	Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/> <input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR850	23270	none
elevation	Elevation	none	none	none
Filter pack flow pump	Permotec	BL30EB	Illegible	none
Flow Rate	Apex	AXMC105LPMDPC	illegible	000651
Infrastructure	Infrastructure	none	none	none
Modem	Sierra wireless	unknown	unknown	06983
Sample Tower	Aluma Tower	B	AT-212125X75	000748
siting criteria	Siting Criteria	none	None	none
Temperature	RM Young	41342VC	6697	04683

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

UND002-Eric Hebert-09/28/2017

1	9/28/2017	DAS	Campbell	000802	CR850	23269
2	9/28/2017	elevation	Elevation	none	none	none
3	9/28/2017	Filter pack flow pump	Permotec	none	BL30EB	Illegible
4	9/28/2017	Flow Rate	Apex	000658	AXMC105LPMDCV	unknown
5	9/28/2017	Infrastructure	Infrastructure	none	none	none
6	9/28/2017	Modem	Sierra wireless	06982	unknown	unknown
7	9/28/2017	Sample Tower	Aluma Tower	000778	B	AT-212125X77
8	9/28/2017	siting criteria	Siting Criteria	none	none	None
9	9/28/2017	Temperature	RM Young	04688	41342	6702

Flow Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Apex	unknown		UND002	Eric Hebert	09/28/2017	Flow Rate	000658

Mfg	BIOS	Parameter	Flow Rate
Serial Number	122974	Tfer Desc.	BIOS 220-H
Tfer ID	01416		
Slope	1.00732	Intercept	-0.02202
Cert Date	3/8/2017	CorrCoff	0.99970

DAS 1:	DAS 2:
A Avg % Diff:	A Max % Di
1.46%	2.03%

Cal Factor Zero	0.013
Cal Factor Full Scale	1.053
Rotometer Reading:	2.95

Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignal	PctDifference
primary	pump off	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.000	0.01	l/m	l/m	
primary	test pt 1	3.016	3.020	2.88	0.000	3.01	l/m	l/m	-0.33%
primary	test pt 2	2.954	2.950	2.88	0.000	3.01	l/m	l/m	2.03%
primary	test pt 3	2.947	2.950	2.88	0.000	3.01	l/m	l/m	2.03%

Sensor Component	Leak Test	Condition		Status	pass
Sensor Component	Tubing Condition	Condition	Good	Status	pass
Sensor Component	Filter Position	Condition	Good	Status	pass
Sensor Component	Rotometer Condition	Condition	Clean and dry	Status	pass
Sensor Component	Moisture Present	Condition	No moisture present	Status	pass
Sensor Component	Filter Distance	Condition	4.5 cm	Status	pass
Sensor Component	Filter Depth	Condition	1.5 cm	Status	pass
Sensor Component	Filter Azimuth	Condition	180 deg	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Temperature Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
RM Young	6702		UND002	Eric Hebert	09/28/2017	Temperature	04688

Mfg	Extech	Parameter	Temperature
Serial Number	H232679	Tfer Desc.	RTD
Tfer ID	01228		
Slope	1.00656	Intercept	-0.03341
Cert Date	2/4/2017	CorrCoff	1.00000

DAS 1:		DAS 2:	
Abs Avg Err	Abs Max Er	Abs Avg Err	Abs Max Er
0.17	0.19		

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Low Range	-0.03	0.00	0.000	0.2	C	0.18
primary	Temp Mid Range	25.41	25.28	0.000	25.2	C	-0.13
primary	Temp High Range	47.28	47.01	0.000	46.8	C	-0.19

Sensor Component	Shield	Condition	Clean	Status	pass
Sensor Component	Blower	Condition	N/A	Status	pass
Sensor Component	Blower Status Switch	Condition	N/A	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Infrastructure Data For

Site ID Technician Site Visit Date

Shelter Make	Shelter Model	Shelter Size
<input type="text"/>	<input type="text"/>	<input type="text"/>

Sensor Component	<input type="text" value="Sample Tower Type"/>	Condition	<input type="text" value="Type B"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Conduit"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Met Tower"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Moisture Trap"/>	Condition	<input type="text" value="Not installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Power Cables"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Temp Control"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Rotometer"/>	Condition	<input type="text" value="Installed"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Tower"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Condition"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Door"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Roof"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Shelter Floor"/>	Condition	<input type="text" value="N/A"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Signal Cable"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Tubing Type"/>	Condition	<input type="text" value="3/8 Bevline"/>	Status	<input type="text" value="pass"/>
Sensor Component	<input type="text" value="Sample Train"/>	Condition	<input type="text" value="Good"/>	Status	<input type="text" value="pass"/>

Field Systems Comments

1 Parameter: DasComments

Single tower with filter pack mounted at 10 meters and temperature mounted at 9 meters.

2 Parameter: DocumentationCo

Although there is no CASTNET logbook present onsite, the site operator records CASTNET information in the VT Monitoring Coop logbook.

3 Parameter: ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID Technician Site Visit Date

Site Sponsor (agency) USGS Map

Operating Group Map Scale

AQS # Map Date

Meteorological Type

Air Pollutant Analyzer QAPP Latitude

Deposition Measurement QAPP Longitude

Land Use QAPP Elevation Meters

Terrain QAPP Declination

Conforms to MLM QAPP Declination Date

Site Telephone Audit Latitude

Site Address 1 Audit Longitude

Site Address 2 Audit Elevation

County Audit Declination

City, State Present

Zip Code Fire Extinguisher

Time Zone First Aid Kit

Primary Operator Safety Glasses

Primary Op. Phone # Safety Hard Hat

Primary Op. E-mail Climbing Belt

Backup Operator Security Fence

Backup Op. Phone # Secure Shelter

Backup Op. E-mail Stable Entry Step

Shelter Working Room Make Model Shelter Size

Shelter Clean Notes

Site OK Notes

Driving Directions

Field Systems Data Form

F-02058-1500-S2-rev002

Site ID

Technician

Site Visit Date

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major industrial complex	10 to 20 km	<input type="text"/>	<input checked="" type="checkbox"/>
City > 50,000 population	40 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 10,000 to 50,000 population	10 km	<input type="text"/>	<input checked="" type="checkbox"/>
City 1,000 to 10,000 population	5 km	<input type="text"/>	<input checked="" type="checkbox"/>
Major highway, airport or rail yard	2 km	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, heavily traveled	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Secondary road, lightly traveled	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Feedlot operations	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Intensive agricultural ops (including aerial spraying)	500 m	<input type="text"/>	<input checked="" type="checkbox"/>
Limited agricultural operations	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Large parking lot	200 m	<input type="text"/>	<input checked="" type="checkbox"/>
Small parking lot	100 m	<input type="text"/>	<input checked="" type="checkbox"/>
Tree line	50 m	30 m	<input type="checkbox"/>
Obstacles to wind	10 times obstacle height	<input type="text"/>	<input checked="" type="checkbox"/>

Siting Distances OK

Siting Criteria Comment

Field Systems Data Form

F-02058-1500-S3-rev002

Site ID

Technician

Site Visit Date

- | | | | |
|----|--|-------------------------------------|-----|
| 1 | Are wind speed and direction sensors sited so as to avoid being influenced by obstructions? | <input checked="" type="checkbox"/> | N/A |
| 2 | Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind) | <input checked="" type="checkbox"/> | N/A |
| 3 | Are the tower and sensors plumb? | <input checked="" type="checkbox"/> | N/A |
| 4 | Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc? | <input checked="" type="checkbox"/> | |
| 5 | Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided) | <input checked="" type="checkbox"/> | |
| 6 | Is the solar radiation sensor plumb? | <input checked="" type="checkbox"/> | N/A |
| 7 | Is it sited to avoid shading, or any artificial or reflected light? | <input checked="" type="checkbox"/> | N/A |
| 8 | Is the rain gauge plumb? | <input checked="" type="checkbox"/> | N/A |
| 9 | Is it sited to avoid sheltering effects from buildings, trees, towers, etc? | <input checked="" type="checkbox"/> | N/A |
| 10 | Is the surface wetness sensor sited with the grid surface facing north? | <input checked="" type="checkbox"/> | N/A |
| 11 | Is it inclined approximately 30 degrees? | <input checked="" type="checkbox"/> | N/A |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S4-rev002

Site ID

Technician

Site Visit Date

1	Do all the meteorological sensors appear to be intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	Temperature only
2	Are all the meteorological sensors operational online, and reporting data?	<input checked="" type="checkbox"/>	Temperature only
3	Are the shields for the temperature and RH sensors clean?	<input checked="" type="checkbox"/>	
4	Are the aspirated motors working?	<input checked="" type="checkbox"/>	N/A
5	Is the solar radiation sensor's lens clean and free of scratches?	<input checked="" type="checkbox"/>	N/A
6	Is the surface wetness sensor grid clean and undamaged?	<input checked="" type="checkbox"/>	N/A
7	Are the sensor signal and power cables intact, in good condition, and well maintained?	<input checked="" type="checkbox"/>	
8	Are the sensor signal and power cable connections protected from the elements and well maintained?	<input checked="" type="checkbox"/>	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S5-rev002

Site ID

Technician

Site Visit Date

Siting Criteria: Are the pollutant analyzers and deposition equipment sited in accordance with 40 CFR 58, Appendix E

- | | | | |
|---|---|-------------------------------------|--|
| 1 | Do the sample inlets have at least a 270 degree arc of unrestricted airflow? | <input checked="" type="checkbox"/> | |
| 2 | Are the sample inlets 3 - 15 meters above the ground? | <input checked="" type="checkbox"/> | |
| 3 | Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees? | <input checked="" type="checkbox"/> | |

Pollutant analyzers and deposition equipment operations and maintenance

- | | | | |
|---|--|-------------------------------------|--------------------------|
| 1 | Do the analyzers and equipment appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | |
| 2 | Are the analyzers and monitors operational, on-line, and reporting data? | <input checked="" type="checkbox"/> | |
| 3 | Describe ozone sample tube. | | N/A |
| 4 | Describe dry dep sample tube. | | 3/8 Bevline by 10 meters |
| 5 | Are in-line filters used in the ozone sample line? (if yes indicate location) | <input checked="" type="checkbox"/> | N/A |
| 6 | Are sample lines clean, free of kinks, moisture, and obstructions? | <input checked="" type="checkbox"/> | |
| 7 | Is the zero air supply desiccant unsaturated? | <input checked="" type="checkbox"/> | N/A |
| 8 | Are there moisture traps in the sample lines? | <input type="checkbox"/> | Not present |
| 9 | Is there a rotometer in the dry deposition filter line, and is it clean? | <input checked="" type="checkbox"/> | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S6-rev002

Site ID

Technician

Site Visit Date

DAS, sensor translators, and peripheral equipment operations and maintenance

- | | | | | | | | | | |
|-------------------------------------|--|--|--------|--|----------|-------------------------------------|--|-------------------------------------|--|
| 1 | Do the DAS instruments appear to be in good condition and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 2 | Are all the components of the DAS operational? (printers, modem, backup, etc) | <input checked="" type="checkbox"/> | | | | | | | |
| 3 | Do the analyzer and sensor signal leads pass through lightning protection circuitry? | <input checked="" type="checkbox"/> | | | | | | | |
| 4 | Are the signal connections protected from the weather and well maintained? | <input checked="" type="checkbox"/> | | | | | | | |
| 5 | Are the signal leads connected to the correct DAS channel? | <input checked="" type="checkbox"/> | | | | | | | |
| 6 | Are the DAS, sensor translators, and shelter properly grounded? | <input checked="" type="checkbox"/> | | | | | | | |
| 7 | Does the instrument shelter have a stable power source? | <input checked="" type="checkbox"/> | | | | | | | |
| 8 | Is the instrument shelter temperature controlled? | <input checked="" type="checkbox"/> | N/A | | | | | | |
| 9 | Is the met tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input type="checkbox"/></td><td></td><td><input type="checkbox"/></td></tr></table> | Stable | | Grounded | <input type="checkbox"/> | | <input type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input type="checkbox"/> | | <input type="checkbox"/> | | | | | | | |
| 10 | Is the sample tower stable and grounded? | <table border="1"><tr><td>Stable</td><td></td><td>Grounded</td></tr><tr><td><input checked="" type="checkbox"/></td><td></td><td><input checked="" type="checkbox"/></td></tr></table> | Stable | | Grounded | <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | |
| Stable | | Grounded | | | | | | | |
| <input checked="" type="checkbox"/> | | <input checked="" type="checkbox"/> | | | | | | | |
| 11 | Tower comments? | | | | | | | | |

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Single tower with filer pack mounted at 10 meters and temperature mounted at 9 meters.

Field Systems Data Form

F-02058-1500-S7-rev002

Site ID

Technician

Site Visit Date

Documentation

Does the site have the required instrument and equipment manuals?

	Yes	No	N/A		Yes	No	N/A
Wind speed sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Wind direction sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Data logger	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature sensor	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Strip chart recorder	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Relative humidity sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Computer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Modem	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Surface wetness sensor	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Printer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Wind sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Zero air pump	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Temperature translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Filter flow pump	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Humidity sensor translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Surge protector	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Solar radiation translator	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	UPS	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Tipping bucket rain gauge	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lightning protection device	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Ozone analyzer	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Shelter heater	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack flow controller	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Shelter air conditioner	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Filter pack MFC power supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>				

Does the site have the required and most recent QC documents and report forms?

	Present		Current
Station Log	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
SSRF	<input checked="" type="checkbox"/>	<input type="text"/>	<input checked="" type="checkbox"/>
Site Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
HASP	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Field Ops Manual	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Calibration Reports	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Ozone z/s/p Control Charts	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>
Preventive maintenance schedule	<input type="checkbox"/>	<input type="text"/>	<input type="checkbox"/>

- 1 Is the station log properly completed during every site visit?
- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current? N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Although there is no CASTNET logbook present onsite, the site operator records CASTNET information in the VT Monitoring Coop logbook.

Field Systems Data Form

F-02058-1500-S8-rev002

Site ID Technician Site Visit Date

Site operation procedures

- 1 Has the site operator attended a formal CASTNET training course? If yes, when and who instructed?
- 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?
- 3 Is the site visited regularly on the required Tuesday schedule?
- 4 Are the standard CASTNET operational procedures being followed by the site operator?
- 5 Is the site operator(s) knowledgeable of, and able to perform the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Visual Inspections	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Translator Zero/Span Tests (climatronics)	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Rain Gauge Test	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Confirm Reasonableness of Current Values	<input checked="" type="checkbox"/>	<input type="text" value="Weekly"/>	<input checked="" type="checkbox"/>
Test Surface Wetness Response	<input checked="" type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed		Frequency	Compliant
Multi-point Calibrations	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Zero/Span Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Automatic Precision Level Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Manual Precision Level Test	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Analyzer Diagnostics Tests	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at inlet)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
In-line Filter Replacement (at analyze)	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>
Zero Air Desiccant Check	<input type="checkbox"/>	<input type="text" value="N/A"/>	<input checked="" type="checkbox"/>

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- 3 Are the automatic and manual z/s/p checks monitored and reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S9-rev002

Site ID

Technician

Site Visit Date

Site operation procedures

1	Is the filter pack being changed every Tuesday as scheduled?	<input checked="" type="checkbox"/>	Filter changed mornings
2	Are the Site Status Report Forms being completed and filed correctly?	<input checked="" type="checkbox"/>	
3	Are data downloads and backups being performed as scheduled?	<input checked="" type="checkbox"/>	No longer required
4	Are general observations being made and recorded? How?	<input checked="" type="checkbox"/>	SSRF
5	Are site supplies on-hand and replenished in a timely fashion?	<input checked="" type="checkbox"/>	
6	Are sample flow rates recorded? How?	<input checked="" type="checkbox"/>	SSRF
7	Are samples sent to the lab on a regular schedule in a timely fashion?	<input checked="" type="checkbox"/>	
8	Are filters protected from contamination during handling and shipping? How?	<input checked="" type="checkbox"/>	Clean gloves on and off
9	Are the site conditions reported regularly to the field operations manager or staff?	<input checked="" type="checkbox"/>	

QC Check Performed	Frequency	Compliant
Multi-point MFC Calibrations	<input checked="" type="checkbox"/> Semiannually	<input checked="" type="checkbox"/>
Flow System Leak Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Filter Pack Inspection	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Flow Rate Setting Checks	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
Visual Check of Flow Rate Rotometer	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>
In-line Filter Inspection/Replacement	<input checked="" type="checkbox"/> As needed	<input checked="" type="checkbox"/>
Sample Line Check for Dirt/Water	<input checked="" type="checkbox"/> Weekly	<input checked="" type="checkbox"/>

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technician

Site Visit Date

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Campbell	CR850	23269	000802
elevation	Elevation	none	none	none
Filter pack flow pump	Permotec	BL30EB	Illegible	none
Flow Rate	Apex	AXMC105LPMDPC	unknown	000658
Infrastructure	Infrastructure	none	none	none
Modem	Sierra wireless	unknown	unknown	06982
Sample Tower	Aluma Tower	B	AT-212125X77	000778
siting criteria	Siting Criteria	none	None	none
Temperature	RM Young	41342	6702	04688

APPENDIX B

CASTNET Site Spot Report Forms

EEMS Spot Report

Data Compiled: 8/29/2017 9:08:02 PM

SiteVisitDate	Site	Technician
08/21/2017	ABT147	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98064	unitless	P
2	Ozone Intercept	P	0	5	4	0.48616	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	1.1	%	P
5	Ozone % difference max	P	7	10	4	1.6	%	P

EEMS Spot Report

Data Compiled: 7/27/2017 12:51:06 PM

Site Visit Date Site Technician

07/17/2017 BAS601 Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature 2 meter average error	P	5	0.5	3	2.31	c	Fail
2	Temperature 2 meter max error	P	5	0.5	3	3.17	c	Fail
3	Wind Speed average error below 5m/s in m/s	P	3	0.5	8	0.18	m/s	P
4	Wind Speed max error below 5m/s in m/s	P	3	0.5	8	0.30	m/s	P
5	Wind Speed average % difference above 5 m/s	P	3	5	8	1.0	%	P
6	Wind Speed max % difference above 5 m/s	P	3	5	8	2.6	%	P
7	Wind Speed Torque average error	P	3	0.5	1	0.40	g-cm	P
8	Wind Speed Torque max error	P	3	0.5	1	0.4	g-cm	P
9	Wind Direction Input Deg True average error (de	P	2	5	4	1.8	degrees	P
10	Wind Direction Input Deg True max error (deg)	P	2	5	4	3	degrees	P
11	Relative Humidity average above 85%	P	6	10	1	7.4	%	P
12	Relative Humidity max above 85%	P	6	10	1	7.4	%	P
13	Relative Humidity average below 85%	P	6	10	2	1.2	%	P
14	Relative Humidity max below 85%	P	6	10	2	1.4	%	P
15	Solar Radiation % diff of avg	P	9	10	21	2.45	%	P
16	Solar Radiation % diff of max STD value	P	9	10	21	4.4	%	P
17	Precipitation average % difference	P	1	10	3	9.7	%	P
18	Precipitation max % difference	P	1	10	3	14.5	%	Fail
19	Ozone Slope	P	0	1.1	4	0.99633	unitless	P
20	Ozone Intercept	P	0	5	4	0.22520	ppb	P
21	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
22	Ozone % difference avg	P	7	10	4	0.5	%	P
23	Ozone % difference max	P	7	10	4	1.5	%	P
24	Flow Rate average % difference	P	10	5	4	3.98	%	P
25	Flow Rate max % difference	P	10	5	4	4.9	%	P
26	Shelter Temperature average error	P	5	2	9	2.16	c	Fail
27	Shelter Temperature max error	P	5	2	9	2.72	c	Fail

SiteVisitDate	Site	Technician
07/17/2017	BAS601	Martin Valvur

Records without valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Shelter Temperature standard deviation		5	0	9			
2	Temperature2meter Standard Deviation		5	0	3			
3	Precipitation total of % diff		1	0	3			
4	Precipitation total of abs diff mm or in		1	0	3			
5	Precipitation total of DAS mm or in		1	0	3			
6	Precipitation total of equivalent mm or in		1	0	3			
7	DAS Time maximum error		0	5	1			Fail

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** Filter Depth **CommentCode:** 71

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

- 2 **Parameter:** Ozone **SensorComponent:** Cell A Tmp. **CommentCode:** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm

There are no clean spare filter caps or Ziploc filter bags on site as was the case during the previous site audit visit. The bag and caps for the received filter are being used to send the removed filter back to the lab. The importance of keeping the shipping material with each filter was discussed with the operator. Some additional information regarding completion of the SSRF was provided to the site operator.

- 2 **Parameter:** DocumentationCo

The filter pack chain-of-custody labels are not being used.

- 3 **Parameter:** SiteOpsProcedures

The ozone inlet filter is replaced each month.

- 4 **Parameter:** ShelterCleanNotes

The enclosure houses the ozone, DAS, and MFC only.

- 5 **Parameter:** MetSensorComme

Some objects violate the 45 degree rule for the tipping bucket rain gage. The Temperature shield is mounted on the south side of the tower tripod at 2 meters.

- 6 **Parameter:** MetOpMaintCom

The site utilizes a combination sensor for humidity and temperature. It was audited without submersion in a water bath. The temperature sensor is mounted at approximately 2 meters from the ground. The accuracy of the DAS was not tested due to no available channels for the test equipment. The wind direction sensor was not functioning upon arrival for the site audit. The site operator provided a replacement sensor which had been shipped from ARS. EEMS assisted the operator with the installation of the replacement sensor. The wind direction audit results are provided for the replacement sensor.

EEMS Spot Report

Data Compiled: 7/28/2017 2:55:38 PM

Site Visit Date Site Technician

07/19/2017 BUF603 Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	1.62	c	Fail
2	Temperature2meter max error	P	5	0.5	3	4.38	c	Fail
3	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.19	m/s	P
4	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.30	m/s	P
5	Wind Speed average % difference above 5 m/s	P	3	5	4	0.6	%	P
6	Wind Speed max % difference above 5 m/s	P	3	5	4	1.3	%	P
7	Wind Speed Torque average error	P	3	0.5	1	0.20	g-cm	P
8	Wind Speed Torque max error	P	3	0.5	1	0.2	g-cm	P
9	Wind Direction Input Deg True average error (de	P	2	5	4	1.5	degrees	P
10	Wind Direction Input Deg True max error (deg)	P	2	5	4	3	degrees	P
11	Relative Humidity average above 85%	P	6	10	3	5.9	%	P
12	Relative Humidity max above 85%	P	6	10	3	5.9	%	P
13	Relative Humidity average below 85%	P	6	10	6	2.3	%	P
14	Relative Humidity max below 85%	P	6	10	6	3.0	%	P
15	Solar Radiation % diff of avg	P	9	10	6	1.24	%	P
16	Solar Radiation % diff of max STD value	P	9	10	6	0.80	%	P
17	Precipitation average % difference	P	1	10	2	1.5	%	P
18	Precipitation max % difference	P	1	10	2	1.5	%	P
19	Flow Rate average % difference	P	10	5	4	2.11	%	P
20	Flow Rate max % difference	P	10	5	4	3.38	%	P
21	DAS Voltage average error	P	4	0.003	3	0.0000	V	P

Records without valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	DAS Voltage maximum error		4	0	3			
2	Temperature2meter Standard Deviation		5	0	3			
3	Precipitation total of % diff		1	0	2			
4	Precipitation total of abs diff mm or in		1	0	2			
5	Precipitation total of DAS mm or in		1	0	2			
6	Precipitation total of equivalent mm or in		1	0	2			
7	DAS Time maximum error		0	5	1			Fail

Field Performance Comments

- 1 **Parameter:** Wind Speed **SensorComponent:** Condition **CommentCode:** 146
One set screw is stripped.

Field Systems Comments

- 1 **Parameter:** DasComments
The NEMA enclosure has a cooling fan.
- 2 **Parameter:** DocumentationCo
A disc with the current QAPP has been received and is kept at the site operator's office. The site operator completes and files a hardcopy checklist developed by ARS for BLM each week.
- 3 **Parameter:** ShelterCleanNotes
NEMA enclosure, 120 VAC power
- 4 **Parameter:** PollAnalyzerCom
The dry deposition filter pack enclosure is not the standard "pot" size that is used at the other CASTNET sites. The diameter of the enclosure is much smaller and the filter is mounted much deeper inside the opening. The geometry of the filter pack and enclosure is likely to impact particle collection efficiency.
- 5 **Parameter:** MetSensorComme
The temperature and RH are measured using a combined sensor which cannot be immersed making a temperature audit difficult. The temperature and RH are measured at 2.5 meters above the ground.
- 6 **Parameter:** MetOpMaintCom
Some of the signal cables are beginning to show signs of wear.

EEMS Spot Report

Data Compiled: 8/6/2017 6:00:41 PM

SiteVisitDate	Site	Technician
07/20/2017	CDR119	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	18	0.18	c	P
2	Temperature max error	P	4	0.5	18	0.27	c	P
3	Ozone Slope	P	0	1.1	4	0.97705	unitless	P
4	Ozone Intercept	P	0	5	4	0.99177	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99996	unitless	P
6	Ozone % difference avg	P	7	10	4	1.6	%	P
7	Ozone % difference max	P	7	10	4	3.7	%	P
8	Flow Rate average % difference	P	10	5	4	1.09	%	P
9	Flow Rate max % difference	P	10	5	4	1.31	%	P
10	DAS Voltage average error	P	7	0.003	7	0.0001	V	P
11	Shelter Temperature average error	P	5	2	15	0.18	c	P
12	Shelter Temperature max error	P	5	2	15	0.35	c	P

Field Performance Comments

- 1 **Parameter:** Ozone **SensorComponent:** 22.5 degree rule **CommentCode** 216
Trees violate the 22.5 degree clearance rule for the ozone sample inlet.

Field Systems Comments

- 1 **Parameter:** SiteOpsProcComm
The filter handling procedures have again improved since the previous site audit visit.
- 2 **Parameter:** SitingCriteriaCom
Site is in a wooded valley, within 30 meters of a lightly traveled road. Large diesel trucks use the road. Trees are taller than the sample tower and within 20 meters of the sample tower.
- 3 **Parameter:** ShelterCleanNotes
The shelter is in good condition with only a small amount of rot on the walls below the air conditioner.

EEMS Spot Report

Data Compiled: 10/8/2017 5:41:18 PM

SiteVisitDate	Site	Technician
07/21/2017	CNT169	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.11	c	P
2	Temperature max error	P	4	0.5	6	0.21	c	P
3	Ozone Slope	P	0	1.1	4	1.05083	unitless	P
4	Ozone Intercept	P	0	5	4	0.66404	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99992	unitless	P
6	Ozone % difference avg	P	7	10	4	7.1	%	P
7	Ozone % difference max	P	7	10	4	8.2	%	P
8	Flow Rate average % difference	P	10	5	6	0.55	%	P
9	Flow Rate max % difference	P	10	5	6	0.99	%	P
10	DAS Voltage average error	P	7	0.003	56	0.0001	V	P
11	Shelter Temperature average error	P	5	2	15	1.74	c	P
12	Shelter Temperature max error	P	5	2	15	1.92	c	P

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone inlet filter is changed once each month and the ozone sample line is leak tested every two weeks.

2 Parameter: ShelterCleanNotes

The shelter is dirty. Some floor tiles are old and broken

EEMS Spot Report

Data Compiled: 8/29/2017 9:01:19 PM

SiteVisitDate	Site	Technician
08/17/2017	GLR468	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	1.15	c	Fail
2	Temperature2meter max error	P	5	0.5	3	1.65	c	Fail
3	Ozone Slope	P	0	1.1	4	1.0521	unitless	P
4	Ozone Intercept	P	0	5	4	0.44679	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99994	unitless	P
6	Ozone % difference avg	P	7	10	4	6.3	%	P
7	Ozone % difference max	P	7	10	4	7.9	%	P
8	Flow Rate average % difference	P	10	5	3	2.38	%	P
9	Flow Rate max % difference	P	10	5	3	2.38	%	P
10	DAS Voltage average error	P	15	0.003	49	0.0002	V	P
11	Shelter Temperature average error	P	5	2	15	0.86	c	P
12	Shelter Temperature max error	P	5	2	15	1.28	c	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell B Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone inlet filter is being changed weekly while smoke from forest fires is present.

2 **Parameter:** SitingCriteriaCom

The site is located in a small clearing within 100 meters of a horse stable. There is a plywood and aluminum processing plant within 20 km of the site.

3 **Parameter:** ShelterCleanNotes

The shelter is in good condition. Evidence of repairs to roof leaks attempted. Some floor tiles are loose.

4 **Parameter:** MetSensorComme

The recorded temperature data at this site is measured at approximately 2 meters above the ground.

EEMS Spot Report

Data Compiled: 8/29/2017 7:03:58 PM

SiteVisitDate	Site	Technician
08/16/2017	KEF112	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.99672	unitless	P
2	Ozone Intercept	P	0	5	4	1.07383	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
4	Ozone % difference avg	P	7	10	4	2.4	%	P
5	Ozone % difference max	P	7	10	4	5.1	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 8/29/2017 8:28:46 PM

SiteVisitDate	Site	Technician
08/17/2017	LRL117	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.15	c	P
2	Temperature max error	P	4	0.5	12	0.26	c	P
3	Ozone Slope	P	0	1.1	4	0.99010	unitless	P
4	Ozone Intercept	P	0	5	4	0.82411	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.4	%	P
7	Ozone % difference max	P	7	10	4	3.7	%	P
8	Flow Rate average % difference	P	10	5	4	0.45	%	P
9	Flow Rate max % difference	P	10	5	4	0.67	%	P
10	DAS Voltage average error	P	7	0.003	63	0.0000	V	P
11	Shelter Temperature average error	P	5	2	15	0.61	c	P
12	Shelter Temperature max error	P	5	2	15	0.92	c	P

Field Systems Comments

1 Parameter: DasComments

The meteorological tower has been removed and the temperature sensor has been installed on the sample tower in a naturally aspirated shield.

2 Parameter: SiteOpsProcedures

Ozone sample line leak checks conducted every other week following the inlet filter replacements.

3 Parameter: SitingCriteriaCom

Logging activities are underway surrounding the site. The site is being used as a loading area.

4 Parameter: ShelterCleanNotes

The shelter has been repaired and is in very good condition. A new peaked roof has been installed.

EEMS Spot Report

Data Compiled: 8/29/2017 7:10:57 PM

SiteVisitDate	Site	Technician
08/17/2017	MKG113	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98678	unitless	P
2	Ozone Intercept	P	0	5	4	0.92740	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99993	unitless	P
4	Ozone % difference avg	P	7	10	4	1.1	%	P
5	Ozone % difference max	P	7	10	4	3.5	%	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 7/29/2017 9:03:30 AM

Site Visit Date Site Technician

07/21/2017 NEC602 Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.15	m/s	P
2	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.25	m/s	P
3	Wind Speed average % difference above 5 m/s	P	3	5	4	0.9	%	P
4	Wind Speed max % difference above 5 m/s	P	3	5	4	1.9	%	P
5	Wind Speed Torque average error	P	3	0.5	1	0.00	g-cm	P
6	Wind Speed Torque max error	P	3	0.5	1	0.0	g-cm	P
7	Wind Direction Input Deg True average error (de	P	2	5	4	18.2	degrees	Fail
8	Wind Direction Input Deg True max error (deg)	P	2	5	4	21	degrees	Fail
9	Temperature average error	P	4	0.5	3	0.63	c	Fail
10	Temperature max error	P	4	0.5	3	1.1	c	Fail
11	Relative Humidity average above 85%	P	6	10	1	1.2	%	P
12	Relative Humidity max above 85%	P	6	10	1	1.2	%	P
13	Relative Humidity average below 85%	P	6	10	2	0.9	%	P
14	Relative Humidity max below 85%	P	6	10	2	1.6	%	P
15	Solar Radiation % diff of avg	P	9	10	4	3.56	%	P
16	Solar Radiation % diff of max STD value	P	9	10	4	6.5	%	P
17	Precipitation average % difference	P	1	10	2	1.8	%	P
18	Precipitation max % difference	P	1	10	2	3.5	%	P
19	Ozone Slope	P	0	1.1	4	0.96612	unitless	P
20	Ozone Intercept	P	0	5	4	-0.15807	ppb	P
21	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
22	Ozone % difference avg	P	7	10	4	4.3	%	P
23	Ozone % difference max	P	7	10	4	6.1	%	P
24	Flow Rate average % difference	P	10	5	4	3.01	%	P
25	Flow Rate max % difference	P	10	5	4	4.16	%	P
26	DAS Voltage average error	P	7	0.003	5	0.0000	V	P
27	Shelter Temperature average error	P	5	2	9	0.49	c	P
28	Shelter Temperature max error	P	5	2	9	0.97	c	P

Records without valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	DAS Voltage maximum error		7	0	5			
2	Shelter Temperature standard deviation		5	0	9			
3	Temperature standard deviation		4	0	3			
4	Precipitation total of % diff		1	0	2			
5	Precipitation total of abs diff mm or in		1	0	2			
6	Precipitation total of DAS mm or in		1	0	2			
7	Precipitation total of equivalent mm or in		1	0	2			
8	DAS Time maximum error		0	5	1			Fail

Field Performance Comments

- Parameter:** Flow Rate **SensorComponent:** Filter Position **CommentCode:** 71
The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.
- Parameter:** Wind Direction **SensorComponent:** System Memo **CommentCode:** 155
The wind direction sensor mast is loose on the tower causing inaccurate wind direction measurement.
- Parameter:** Wind Speed **SensorComponent:** System Memo **CommentCode:** 146
One set screw is stripped.

Field Systems Comments

- Parameter:** SiteOpsProcComm
The site operator is doing a good job with filter change and filter handling. The site operator reported that sometimes it requires a few requests to ARS before assistance is received.
- Parameter:** SiteOpsProcedures
The site operator is aware that the desiccant is in need of replacement. Some of the items on the SSRF were discussed and the site operator's questions were answered regarding the correct procedures.
- Parameter:** DocumentationCo
The site operator received a disc with the current QAPP which is kept at his office.
- Parameter:** SitingCriteriaCom
The site is located approximately 2 km northeast of Newcastle WY which has a population of approximately 3500. There is an oil refinery in Newcastle. A heavily traveled road is approximately 100m west of the site.
- Parameter:** ShelterCleanNotes
The shelter houses the ozone, DAS, and MFC only.
- Parameter:** MetSensorComme
Some objects violate the 45 degree rule for the tipping bucket rain gage. The wind sensor mast is loose on the sample tower. The site operator reported that the tower was dropped a couple of weeks before by the backup site operator. This may have caused the damage to the wind sensor mast.
- Parameter:** MetOpMaintCom
The temperature / humidity sensor had fallen out of the naturally aspirated shield and was hanging by the signal cable from the top of the tower. The site operator reported that it had been that way probably since the tower was dropped by the backup site operator a couple of weeks before. It was reinstalled in the shield by the audit team following the audit.

EEMS Spot Report

Data Compiled: 10/9/2017 9:21:03 PM

Site Visit Date Site Technician

09/26/2017 NIC001 Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.20	c	P
2	Temperature max error	P	4	0.5	9	0.35	c	P
3	Flow Rate average % difference	P	10	5	4	0.89	%	P
4	Flow Rate max % difference	P	10	5	4	0.89	%	P

Field Performance Comments

- 1 **Parameter:** Flow Rate **SensorComponent:** Moisture Present **CommentCode** 72
The filter sample tubing has drops of moisture in low sections outside the shelter.

Field Systems Comments

- 1 **Parameter:** DasComments
Single tower with filter pack mounted at 10 meters and temperature mounted at 9 meters.
- 2 **Parameter:** DocumentationCo
There is no logbook onsite to record information regarding site status or filter information.
- 3 **Parameter:** ShelterCleanNotes
Small footprint site with no shelter. Equipment housed in enclosure on sample tower. The NY DEC operators a full monitoring shelter at the same location.
- 4 **Parameter:** PollAnalyzerCom
There is water accumulating in a low section of the filter pack tubing below the enclosure. It was pointed out to the site operator so corrective action can be taken before winter and the water freezes causing blockage.

EEMS Spot Report

Data Compiled: 8/29/2017 9:15:39 PM

SiteVisitDate	Site	Technician
08/22/2017	NPT006	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	P	0	1.1	4	0.98264	unitless	P
2	Ozone Intercept	P	0	5	4	-0.30433	ppb	P
3	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
4	Ozone % difference avg	P	7	10	4	2.8	%	P
5	Ozone % difference max	P	7	10	4	3.6	%	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

EEMS Spot Report

Data Compiled: 8/6/2017 7:25:32 PM

SiteVisitDate	Site	Technician
07/21/2017	PAR107	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	15	0.06	c	P
2	Temperature max error	P	4	0.5	15	0.08	c	P
3	Ozone Slope	P	0	1.1	4	0.99332	unitless	P
4	Ozone Intercept	P	0	5	4	0.51699	ppb	P
5	Ozone correlation	P	0	0.995	4	1.00000	unitless	P
6	Ozone % difference avg	P	7	10	4	1.3	%	P
7	Ozone % difference max	P	7	10	4	4.3	%	P
8	Flow Rate average % difference	P	10	5	4	2.81	%	P
9	Flow Rate max % difference	P	10	5	4	3.25	%	P
10	DAS Voltage average error	P	7	0.003	56	0.0000	V	P
11	Shelter Temperature average error	P	5	2	15	0.49	c	P
12	Shelter Temperature max error	P	5	2	15	0.60	c	P

Field Systems Comments

1 Parameter: SitingCriteriaCom

The city of Parsons, estimated population 1500, is within 5 km of the site.

2 Parameter: ShelterCleanNotes

The shelter is in good condition, clean, neat, and well organized.

EEMS Spot Report

Data Compiled: 8/6/2017 7:57:40 PM

SiteVisitDate	Site	Technician
07/25/2017	PED108	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	6	0.06	c	P
2	Temperature max error	P	4	0.5	6	0.12	c	P
3	Ozone Slope	P	0	1.1	4	0.97661	unitless	P
4	Ozone Intercept	P	0	5	4	0.77925	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	1.3	%	P
7	Ozone % difference max	P	7	10	4	1.7	%	P
8	Flow Rate average % difference	P	10	5	3	2.04	%	P
9	Flow Rate max % difference	P	10	5	3	2.04	%	P
10	DAS Voltage average error	P	7	0.003	56	0.0001	V	P
11	Shelter Temperature average error	P	5	2	15	0.41	c	P
12	Shelter Temperature max error	P	5	2	15	0.45	c	P

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 **Parameter:** SitingCriteriaCom

The site is in a clearing in an evergreen plantation in the Prince Edward-Gallion State Forest. Trees were cut within the last 11 years to increase the size of the clearing. The tree line is encroaching again and is between 25 and 35 meters from the site.

2 **Parameter:** ShelterCleanNotes

The shelter is in good condition, clean, neat, and well organized.

EEMS Spot Report

Data Compiled: 7/24/2017 12:46:15 PM

Site Visit Date Site Technician

07/15/2017 PND165 Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature 2 meter average error	P	5	0.5	3	0.21	c	P
2	Temperature 2 meter max error	P	5	0.5	3	0.48	c	P
3	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.05	m/s	P
4	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.20	m/s	P
5	Wind Speed average % difference above 5 m/s	P	3	5	4	0.0	%	P
6	Wind Speed max % difference above 5 m/s	P	3	5	4	0.0	%	P
7	Wind Speed Torque average error	P	3	0.5	1	0.30	g-cm	P
8	Wind Speed Torque max error	P	3	0.5	1	0.3	g-cm	P
9	Wind Direction Input Deg True average error (de	P	2	5	4	2.8	degrees	P
10	Wind Direction Input Deg True max error (deg)	P	2	5	4	4	degrees	P
11	Wind Direction Linearity average error (deg)	P	2	5	8	0.7	degrees	P
12	Wind Direction Linearity max error (deg)	P	2	5	8	2	degrees	P
13	Wind Direction Torque average error	P	2	30	1	10	g-cm	P
14	Wind Direction Torque max error	P	2	30	1	10	g-cm	P
15	Temperature average error	P	4	0.5	12	0.20	c	P
16	Temperature max error	P	4	0.5	12	0.30	c	P
17	Relative Humidity average above 85%	P	6	10	3	0.7	%	P
18	Relative Humidity max above 85%	P	6	10	3	0.7	%	P
19	Relative Humidity average below 85%	P	6	10	6	3.6	%	P
20	Relative Humidity max below 85%	P	6	10	6	4.6	%	P
21	Solar Radiation % diff of avg	P	9	10	4	2.6	%	P
22	Solar Radiation % diff of max STD value	P	9	10	4	3.00	%	P
23	Precipitation average % difference	P	1	10	2	4.6	%	P
24	Precipitation max % difference	P	1	10	2	5.6	%	P
25	Ozone Slope	P	0	1.1	4	0.97341	unitless	P
26	Ozone Intercept	P	0	5	4	-0.24393	ppb	P
27	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
28	Ozone % difference avg	P	7	10	4	4.2	%	P
29	Ozone % difference max	P	7	10	4	6.4	%	P
30	Flow Rate average % difference	P	10	5	3	1.31	%	P
31	Flow Rate max % difference	P	10	5	3	1.31	%	P
32	Surface Wetness Response	P	12	0.5	1	1.01		P
33	Shelter Temperature average error	P	5	2	15	0.60	c	P

Site	VisitDate	Technician
PND165	07/15/2017	Martin Valvur

34	Shelter Temperature max error	P	5	2	15	1.12	c	P
----	-------------------------------	---	---	---	----	------	---	---

Records without valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Surface Wetness Manual Test		12	0	1			
2	Shelter Temperature standard deviation		5	0	15			
3	Temperature standard deviation		4	0	12			
4	Temperature2meter Standard Deviation		5	0	3			
5	Precipitation total of % diff		1	0	2			
6	Precipitation total of abs diff mm or in		1	0	2			
7	Precipitation total of DAS mm or in		1	0	2			
8	Precipitation total of equivalent mm or in		1	0	2			
9	DAS Time maximum error		0	5	1			Fail

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Flow **CommentCode:** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode:** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Surface Wetness **SensorComponent:** System Memo **CommentCode:** 179
This measurement system is damaged and not functioning.

Field Systems Comments

- Parameter:** SiteOpsProcComm
The site operator was unable to meet the audit team during the site audit. Audit data was obtained by reviewing the on-site documentation and from previous audits.
- Parameter:** SitingCriteriaCom
Construction at the bottom of the hill and entrance to the site access road has been completed.
- Parameter:** ShelterCleanNotes
The shelter is well maintained.
- Parameter:** MetSensorComme
The RH sensor is now mounted in a shield. Both the RH and temperature sensors are mounted above the shelter. The surface wetness sensor is no longer functioning and always indicates a wet response.

EEMS Spot Report

Data Compiled: 8/29/2017 6:09:49 PM

SiteVisitDate	Site	Technician
08/08/2017	ROM206	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	15	0.15	c	P
2	Temperature max error	P	4	0.5	15	0.22	c	P
3	Ozone Slope	P	0	1.1	4	0.99240	unitless	P
4	Ozone Intercept	P	0	5	4	-0.04905	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	1.0	%	P
7	Ozone % difference max	P	7	10	4	2.4	%	P
8	Flow Rate average % difference	P	10	5	8	0.77	%	P
9	Flow Rate max % difference	P	10	5	8	0.99	%	P
10	DAS Voltage average error	P	7	0.003	7	0.0001	V	P
11	Shelter Temperature average error	P	5	2	15	0.84	c	P
12	Shelter Temperature max error	P	5	2	15	0.99	c	P

Field Performance Comments

- Parameter:** Ozone **SensorComponent:** Cell B Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.
- Parameter:** Ozone **SensorComponent:** Cell A Flow **CommentCode** 99
This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

- Parameter:** SiteOpsProcComm
The Noy analyzer has a blinking "fault" light and the message "system service" is displayed.
- Parameter:** ShelterCleanNotes
The shelter is clean, neat, and well organized. There are signs of previous roof leaks, but they have been repaired. The floor and counter top have been replaced.
- Parameter:** MetSensorComme
The temperature sensor has been removed from the met tower and mounted in a naturally aspirated shield on the sample tower, facing south and over the shelter roof.

EEMS Spot Report

Data Compiled: 8/29/2017 5:38:25 PM

SiteVisitDate	Site	Technician
08/01/2017	ROM406	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.35	c	P
2	Temperature2meter max error	P	5	0.5	3	0.37	c	P
3	Ozone Slope	P	0	1.1	4	0.96260	unitless	P
4	Ozone Intercept	P	0	5	4	-0.14012	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99997	unitless	P
6	Ozone % difference avg	P	7	10	4	4.7	%	P
7	Ozone % difference max	P	7	10	4	7.2	%	P
8	Flow Rate average % difference	P	10	5	9	1.17	%	P
9	Flow Rate max % difference	P	10	5	9	1.28	%	P
10	DAS Voltage average error	P	4	0.003	56	0.0002	V	P
11	Shelter Temperature average error	P	5	2	6	1.62	c	P
12	Shelter Temperature max error	P	5	2	6	1.86	c	P

Field Systems Comments

1 Parameter: DasComments

Only RH, temperature, and AMoN are mounted on the meteorological tower at approximately 2 meters.

2 Parameter: ShelterCleanNotes

The shelter is clean, neat, organized, and well maintained.

3 Parameter: MetSensorComme

The recorded temperature is being measured at 2.5 meters above the ground and < 1 foot above the AMoN enclosure.

EEMS Spot Report

Data Compiled: 10/9/2017 6:35:47 PM

SiteVisitDate	Site	Technician
09/07/2017	SAN189	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.06	c	P
2	Temperature max error	P	4	0.5	12	0.13	c	P
3	Ozone Slope	P	0	1.1	4	0.93780	unitless	P
4	Ozone Intercept	P	0	5	4	-2.35573	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99979	unitless	P
6	Ozone % difference avg	P	7	10	4	11.6	%	Fail
7	Ozone % difference max	P	7	10	4	16.9	%	Fail
8	Flow Rate average % difference	P	10	5	2	0.78	%	P
9	Flow Rate max % difference	P	10	5	2	1.01	%	P
10	DAS Voltage average error	P	7	0.003	49	0.0001	V	P
11	Shelter Temperature average error	P	5	2	15	0.75	c	P
12	Shelter Temperature max error	P	5	2	15	1.11	c	P

SiteVisitDate	Site	Technician
09/07/2017	SAN189	Martin Valvur

Field Systems Comments

1 Parameter: ShelterCleanNotes

The shelter is in very good condition, however somewhat cluttered.

EEMS Spot Report

Data Compiled: 7/27/2017 5:07:50 PM

Site Visit Date Site Technician

07/18/2017 SHE604 Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.56	c	Fail
2	Temperature2meter max error	P	5	0.5	3	0.83	c	Fail
3	Wind Speed average error below 5m/s in m/s	P	3	0.5	4	0.22	m/s	P
4	Wind Speed max error below 5m/s in m/s	P	3	0.5	4	0.40	m/s	P
5	Wind Speed average % difference above 5 m/s	P	3	5	4	0.8	%	P
6	Wind Speed max % difference above 5 m/s	P	3	5	4	1.2	%	P
7	Wind Speed Torque average error	P	3	0.5	1	0.30	g-cm	P
8	Wind Speed Torque max error	P	3	0.5	1	0.3	g-cm	P
9	Wind Direction Input Deg True average error (de	P	2	5	4	2.0	degrees	P
10	Wind Direction Input Deg True max error (deg)	P	2	5	4	5	degrees	P
11	Relative Humidity average above 85%	P	6	10	2	6.0	%	P
12	Relative Humidity max above 85%	P	6	10	2	6.0	%	P
13	Relative Humidity average below 85%	P	6	10	4	0.6	%	P
14	Relative Humidity max below 85%	P	6	10	4	0.7	%	P
15	Solar Radiation % diff of avg	P	9	10	12	0.80	%	P
16	Solar Radiation % diff of max STD value	P	9	10	12	1.7	%	P
17	Precipitation average % difference	P	1	10	2	5.4	%	P
18	Precipitation max % difference	P	1	10	2	7.2	%	P
19	Flow Rate average % difference	P	10	5	4	1.36	%	P
20	Flow Rate max % difference	P	10	5	4	2.37	%	P

Records without valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter Standard Deviation		5	0	3			
2	Precipitation total of % diff		1	0	2			
3	Precipitation total of abs diff mm or in		1	0	2			
4	Precipitation total of DAS mm or in		1	0	2			
5	Precipitation total of equivalent mm or in		1	0	2			
6	DAS Time maximum error		0	5	1			Fail

Field Performance Comments

- 1 **Parameter:** Wind Speed **SensorComponent:** Prop or Cups Cond **CommentCode:** 146
One set screw is stripped.

Field Systems Comments

- 1 **Parameter:** DasComments
The site power source is solar and wind with battery storage. The NEMA enclosure has a cooling fan.
- 2 **Parameter:** SiteOpsProcedures
observations of current meteorological measurements are recorded on a hardcopy checklist for ARS and not on the SSRF.
- 3 **Parameter:** DocumentationCo
The site operator received a disc with the 2013 QAPP, operating procedures, and HASP which is kept at his office. A hard copy BLM check list developed by ARS is completed and sent to ARS each week.
- 4 **Parameter:** SitingCriteriaCom
The site is located in range land. There is an active rail line with coal trains within one kilometer of the site.
- 5 **Parameter:** ShelterCleanNotes
NEMA enclosure, solar power
- 6 **Parameter:** PollAnalyzerCom
The dry deposition filter pack enclosure is not the standard "pot" size as at the other CASTNET sites. The diameter is much smaller. It is not clear if this will impact particle collection efficiency.
- 7 **Parameter:** MetSensorComme
The site is a small footprint solar powered site that has been operating as part of the WARMS network for 10 years. Objects violate the 45 degree rule for the tipping bucket rain gage. Temperature and RH are measured with a combined sensor that cannot be immersed making a temperature audit difficult. The temperature and RH are being measured at 2.5 meters above the ground.
- 8 **Parameter:** MetOpMaintCom
The accuracy of the DAS was not tested with a voltage source since there were no available test channels.

EEMS Spot Report

Data Compiled: 10/8/2017 9:08:33 PM

SiteVisitDate	Site	Technician
08/29/2017	THR422	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.11	c	P
2	Temperature2meter max error	P	5	0.5	3	0.15	c	P
3	Ozone Slope	P	0	1.1	4	0.95995	unitless	P
4	Ozone Intercept	P	0	5	4	-0.27325	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99995	unitless	P
6	Ozone % difference avg	P	7	10	4	5.2	%	P
7	Ozone % difference max	P	7	10	4	5.8	%	P
8	Flow Rate average % difference	P	10	5	9	0.22	%	P
9	Flow Rate max % difference	P	10	5	9	0.33	%	P
10	DAS Voltage average error	P	7	0.003	56	0.0001	V	P
11	Shelter Temperature average error	P	5	2	18	1.93	c	P
12	Shelter Temperature max error	P	5	2	18	2.17	c	Fail

Field Performance Comments

1 **Parameter:** Ozone **SensorComponent:** Cell A Freq. **CommentCode** 99

This analyzer diagnostic check is outside the manufacturer's recommended value.

Field Systems Comments

1 **Parameter:** SiteOpsProcedures

The ozone sample train does not have a means to introduce test gas at the sample inlet. Results of routine zero, span, precision, and any multipoint calibration checks are maintained by the state personnel who perform the tests.

2 **Parameter:** SitingCriteriaCom

The site is located 200 meters from an interstate rest area, and 300 meters from interstate 94. The rest area can have parked and idling vehicles for extended periods.

3 **Parameter:** ShelterCleanNotes

The shelter is in good condition, clean and well organized.

4 **Parameter:** PollAnalyzerCom

The ozone analyzer is operated by the state of North Dakota. The sample train contains a glass manifold. There is no means to introduce on-site generated test gas at the sample inlet. A through-the-probe audit was conducted using the EEMS system.

EEMS Spot Report

Data Compiled: 10/15/2017 3:29:55 PM

Site Visit Date Site Technician

09/28/2017 UND002 Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	3	0.17	c	P
2	Temperature max error	P	4	0.5	3	0.19	c	P
3	Flow Rate average % difference	P	10	5	4	1.47	%	P
4	Flow Rate max % difference	P	10	5	4	2.03	%	P

Field Systems Comments

1 Parameter: DasComments

Single tower with filer pack mounted at 10 meters and temperature mounted at 9 meters.

2 Parameter: DocumentationCo

Although there is no CASTNET logbook present onsite, the site operator records CASTNET information in the VT Monitoring Coop logbook.

3 Parameter: ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.

EEMS Spot Report

Data Compiled: 10/8/2017 9:06:50 PM

SiteVisitDate	Site	Technician
09/01/2017	VOY413	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.38	c	P
2	Temperature2meter max error	P	5	0.5	3	0.52	c	Fail
3	Ozone Slope	P	0	1.1	4	1.03949	unitless	P
4	Ozone Intercept	P	0	5	4	-0.12822	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	3.5	%	P
7	Ozone % difference max	P	7	10	4	4.2	%	P
8	Flow Rate average % difference	P	10	5	9	0.33	%	P
9	Flow Rate max % difference	P	10	5	9	0.33	%	P
10	DAS Voltage average error	P	15	0.003	49	0.0001	V	P
11	Shelter Temperature average error	P	5	2	18	0.73	c	P
12	Shelter Temperature max error	P	5	2	18	0.80	c	P

Field Systems Comments

1 **Parameter:** DasComments

The sample tower itself is not grounded, however it is bolted to the shelter which is grounded.

2 **Parameter:** DocumentationCo

Correctly completing the general observations section of the SSRF on the day of filter installation was discussed with the operator.

3 **Parameter:** SitingCriteriaCom

The site is located at the top of a hill in a forest. There are trees surrounding the site which are below the tower height.

4 **Parameter:** ShelterCleanNotes

The shelter is clean, neat, and well organized. The shelter is in good condition.

5 **Parameter:** PollAnalyzerCom

There are no trees violating the 22.5 degree cone above the ozone sample inlet. However, there is a communication tower which is above the 22.5 degree threshold.

EEMS Spot Report

Data Compiled: 8/6/2017 4:57:25 PM

SiteVisitDate	Site	Technician
07/18/2017	VPI120	Sandy Grenville

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	9	0.21	c	P
2	Temperature max error	P	4	0.5	9	0.43	c	P
3	Ozone Slope	P	0	1.1	4	0.99078	unitless	P
4	Ozone Intercept	P	0	5	4	0.53153	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99999	unitless	P
6	Ozone % difference avg	P	7	10	4	0.6	%	P
7	Ozone % difference max	P	7	10	4	1.2	%	P
8	Flow Rate average % difference	P	10	5	3	0.67	%	P
9	Flow Rate max % difference	P	10	5	3	0.67	%	P
10	DAS Voltage average error	P	7	0.003	56	0.0000	V	P
11	Shelter Temperature average error	P	5	2	15	0.99	c	P
12	Shelter Temperature max error	P	5	2	15	1.64	c	P

Field Systems Comments

1 Parameter: SitingCriteriaCom

The site is on a wooded hillside. The temperature sensor and sample inlet are at the tree tops of the downhill trees. The uphill tree line is 30 meters away.

2 Parameter: ShelterCleanNotes

The shelter is clean, neat, and well organized.

EEMS Spot Report

Data Compiled: 10/15/2017 3:11:36 PM

Site Visit Date Site Technician

09/27/2017 WFM105 Eric Hebert

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	P	4	0.5	12	0.18	c	P
2	Temperature max error	P	4	0.5	12	0.44	c	P
3	Flow Rate average % difference	P	10	5	3	1.42	%	P
4	Flow Rate max % difference	P	10	5	3	1.64	%	P

Field Systems Comments

1 Parameter: DasComments

Single tower, with filter pack at 10 meters and temperature at 9 meters.

2 Parameter: DocumentationCo

There is no logbook present to record the status of the site equipment, calibration information, or filter information.

3 Parameter: SitingCriteriaCom

The site is located at the Atmospheric Science Research Center (ASRC) operated by the NY University (SUNY) system.

4 Parameter: ShelterCleanNotes

Small footprint site with no shelter. Equipment housed in enclosure on sample tower.

EEMS Spot Report

Data Compiled: 8/29/2017 6:44:06 PM

SiteVisitDate	Site	Technician
08/16/2017	YEL408	Martin Valvur

Records with valid pass/fail criteria

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	P	5	0.5	3	0.17	c	P
2	Temperature2meter max error	P	5	0.5	3	0.26	c	P
3	Ozone Slope	P	0	1.1	4	0.99392	unitless	P
4	Ozone Intercept	P	0	5	4	-0.33439	ppb	P
5	Ozone correlation	P	0	0.995	4	0.99998	unitless	P
6	Ozone % difference avg	P	7	10	4	2.0	%	P
7	Ozone % difference max	P	7	10	4	4.7	%	P
8	Flow Rate average % difference	P	10	5	3	0.57	%	P
9	Flow Rate max % difference	P	10	5	3	1.03	%	P
10	DAS Voltage average error	P	11	0.003	49	0.0001	V	P
11	Shelter Temperature average error	P	5	2	18	0.74	c	P
12	Shelter Temperature max error	P	5	2	18	1.07	c	P

Field Systems Comments

1 Parameter: SiteOpsProcComm

Gloves are not used to handle the filter pack.

2 Parameter: SiteOpsProcedures

The ozone inlet filter is replaced and the system is leak tested every two weeks.

3 Parameter: SitingCriteriaCom

The site is located at the edge of a tree line. Trees as tall as 8 meters are near the sample inlet. Trees taller than 10 meters are 15 meters from the inlet.

4 Parameter: ShelterCleanNotes

The shelter is organized and well maintained.

5 Parameter: MetOpMaintCom

The recorded temperature is now being measured at approximately 2 meters above the ground.

APPENDIX C

CASTNET Ozone Performance Evaluation Forms

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

KEF112-Sandy Grenville-08/16/2017

1	8/16/2017	DAS	Campbell	000414	CR3000	2537
2	8/16/2017	Ozone	ThermoElectron Inc	000728	49i A1NAA	1105347306
3	8/16/2017	Ozone Standard	ThermoElectron Inc	000432	49i A3NAA	CM08200008
4	8/16/2017	Zero air pump	Werther International	06922	C 70/4	000836217

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347306		KEF112	Sandy Grenville	08/16/2017	Ozone	000728

Slope:	0.99672	Slope:	0.00000
Intercept	1.07383	Intercept	0.00000
CorrCoff	0.99998	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.4%	5.1%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.00	-0.45	0.93	ppb	
primary	2	15.00	14.50	15.24	ppb	5.10%
primary	3	34.85	34.30	35.05	ppb	2.19%
primary	4	68.04	67.41	68.49	ppb	1.60%
primary	5	110.06	109.32	110.00	ppb	0.62%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.000	Status	pass
Sensor Component	Span	Condition	1.011	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	92.6 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.0 lpm	Status	Fail
Sensor Component	Cell A Pressure	Condition	683.0 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	37.6 C	Status	pass
Sensor Component	Cell B Freq.	Condition	89.8 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.72 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	682.7 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	KEF112	Sandy Grenville	08/16/2017	Cell A Flow	ThermoElectron	4128	<input type="checkbox"/>	<input type="checkbox"/>
-------	--------	-----------------	------------	-------------	----------------	------	--------------------------	--------------------------

This analyzer diagnostic check is outside the manufacturer's recommended value.

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

MKG113-Sandy Grenville-08/17/2017

1	8/17/2017	DAS	Campbell	000404	CR3000	2521
2	8/17/2017	Ozone	ThermoElectron Inc	000703	49i A1NAA	1030244805
3	8/17/2017	Ozone Standard	ThermoElectron Inc	000374	49i A3NAA	0726124694
4	8/17/2017	Zero air pump	Werther International	06937	C 70/4	000821896

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1030244805		MKG113	Sandy Grenville	08/17/2017	Ozone	000703

Slope:	0.98678	Slope:	0.00000
Intercept	0.92740	Intercept	0.00000
CorrCoff	0.99993	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.1%	3.5%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.03	-0.42	0.67	ppb	
primary	2	15.57	15.07	15.10	ppb	0.20%
primary	3	34.99	34.44	35.66	ppb	3.54%
primary	4	68.00	67.37	67.23	ppb	-0.21%
primary	5	110.29	109.55	109.00	ppb	-0.50%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.010	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	97.3 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	1.42 lpm	Status	Fail
Sensor Component	Cell A Pressure	Condition	701.3 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.46 C	Status	pass
Sensor Component	Cell B Freq.	Condition	87.9 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.7 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.0 lpm	Status	Fail
Sensor Component	Cell B Pressure	Condition	701.6 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
------------------	-------------	-------------------	------------------	------------------	------------	-------------------	---------------	----------------

Ozone	MKG113	Sandy Grenville	08/17/2017	Cell B Flow	ThermoElectron	3408	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Ozone	MKG113	Sandy Grenville	08/17/2017	Cell A Flow	ThermoElectron	3408	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

ABT147-Sandy Grenville-08/21/2017

1	8/21/2017	DAS	Campbell	000413	CR3000	2519
2	8/21/2017	Ozone	ThermoElectron Inc	000627	49i A1NAA	1009241772
3	8/21/2017	Ozone Standard	ThermoElectron Inc	000449	49i A3NAA	CM08200025
4	8/21/2017	UPS	APC	06795	RS900	unknown
5	8/21/2017	Zero air pump	Werther International	06930	P 70/4	000829168

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241772		ABT147	Sandy Grenville	08/21/2017	Ozone	000627

Slope:	0.98064	Slope:	0.00000
Intercept	0.48616	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	517112175	Tfer Desc.	Ozone primary stan
Tfer ID	01111		
Slope	1.00250	Intercept	0.45870
Cert Date	3/21/2017	CorrCoff	1.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
1.1%	1.6%		

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.14	-0.31	0.31	ppb	
primary	2	15.00	14.50	14.65	ppb	1.03%
primary	3	35.00	34.45	34.31	ppb	-0.41%
primary	4	68.03	67.40	66.30	ppb	-1.63%
primary	5	110.00	109.26	107.80	ppb	-1.34%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	Not functioning	Status	Fail
Sensor Component	Offset	Condition	0.20	Status	pass
Sensor Component	Span	Condition	0.997	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	82.2 kHz	Status	pass
Sensor Component	Cell A Noise	Condition	0.8 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.69 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	715.9 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	33.6 C	Status	pass
Sensor Component	Cell B Freq.	Condition	88.1 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.4 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.66 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	Not tested	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Inventory by Site Visit

<i>Site Visit Date</i>	<i>Parameter</i>	<i>Mfg</i>	<i>Owner ID</i>	<i>Model Number</i>	<i>Serial Number</i>
------------------------	------------------	------------	-----------------	---------------------	----------------------

NPT006-Martin Valvur-08/22/2017

1	8/22/2017	DAS	Campbell	none	CR850	28381
2	8/22/2017	Ozone	ThermoElectron Inc	000612	49i A1NAA	1009241779
3	8/22/2017	Ozone Standard	ThermoElectron Inc	000448	49i A3NAA	CM08200024
4	8/22/2017	Zero air pump	Werther International	000626	PC 70/4	000815300

Ozone Data Form

Mfg	Serial Number	Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241779		NPT006	Martin Valvur	08/22/2017	Ozone	000612

Slope:	0.98264	Slope:	0.00000
Intercept	-0.30433	Intercept	0.00000
CorrCoff	0.99999	CorrCoff	0.00000

DAS 1:	DAS 2:		
A Avg % Diff:	A Max % Di	A Avg %Dif	A Max % Di
2.8%	3.6%		

Mfg	ThermoElectron Inc	Parameter	ozone
Serial Number	49CPS-70008-364	Tfer Desc.	Ozone primary stan
Tfer ID	01110		
Slope	1.00466	Intercept	0.01298
Cert Date	1/1/2017	CorrCoff	1.00000

UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	PctDifference
primary	1	0.19	0.17	0.06	ppb	
primary	2	15.44	15.35	14.80	ppb	-3.58%
primary	3	36.89	36.70	35.50	ppb	-3.27%
primary	4	66.39	66.06	64.49	ppb	-2.38%
primary	5	107.32	106.80	104.80	ppb	-1.87%

Sensor Component	Sample Train	Condition	Good	Status	pass
Sensor Component	22.5 degree rule	Condition		Status	pass
Sensor Component	Inlet Filter Condition	Condition	Clean	Status	pass
Sensor Component	Battery Backup	Condition	N/A	Status	pass
Sensor Component	Offset	Condition	0.10	Status	pass
Sensor Component	Span	Condition	1.019	Status	pass
Sensor Component	Zero Voltage	Condition	N/A	Status	pass
Sensor Component	Fullscale Voltage	Condition	N/A	Status	pass
Sensor Component	Cell A Freq.	Condition	57.1 kHz	Status	Fail
Sensor Component	Cell A Noise	Condition	0.6 ppb	Status	pass
Sensor Component	Cell A Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell A Pressure	Condition	675.1 mmHg	Status	pass
Sensor Component	Cell A Tmp.	Condition	36.6 C	Status	pass
Sensor Component	Cell B Freq.	Condition	89.5 kHz	Status	pass
Sensor Component	Cell B Noise	Condition	0.9 ppb	Status	pass
Sensor Component	Cell B Flow	Condition	0.68 lpm	Status	pass
Sensor Component	Cell B Pressure	Condition	674.5 mmHg	Status	pass
Sensor Component	Cell B Tmp.	Condition		Status	pass
Sensor Component	Line Loss	Condition	Not tested	Status	pass
Sensor Component	System Memo	Condition		Status	pass

Site Visit Comments

Parameter	Site	Technician	S.V. Date	Component	Mfg	Serial No.	Hazard	Problem
Ozone	NPT006	Martin Valvur	08/22/2017	Cell A Freq.	ThermoElectron	3362	<input type="checkbox"/>	<input type="checkbox"/>
This analyzer diagnostic check is outside the manufacturer's recommended value.								