



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
 REGION III
 1650 Arch Street
 Philadelphia, Pennsylvania 19103-2029

**AUTHORIZATION TO DISCHARGE UNDER THE
 NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
 NPDES Permit No. DC0000035**

In compliance with the provisions of the Clean Water Act, 33 U.S.C. §1251 *et seq.*, as amended by the Water Quality Act of 1987, P.L. 100-4, the "Act",

**Georgetown 29K Acquisition LLC
 500 Park Avenue, 10th Floor
 New York, NY 100652**

is authorized to discharge from a facility located at

**Former General Services Administration West Heating Plant
 1051 29th Street NW
 Washington, D.C. 20007**

to receiving waters named

Rock Creek

in accordance with discharge point(s), effluent limitation, monitoring requirements and other conditions set forth herein.

This permit shall become effective on SEPTEMBER 11, 2018
 This permit and the authorization to discharge shall expire at midnight, SEPTEMBER 10, 2023

This permit and the authorization to discharge shall expire five (5) years from the date of issuance, unless the Permittee has submitted a complete and timely application for a new permit, and the U.S. Environmental Protection Agency (EPA), through no fault of the Permittee, does not issue a new permit before the expiration date of this permit. In such a case, the permit will be administratively extended until such time as EPA issues a new permit.

The Permittee shall apply for permit reissuance on or before MARCH 15, 2023, 180 days before the expiration of this permit if the Permittee intends to continue operations and discharges at the facility beyond the term of this permit.

Signed this 11 day of SEPTEMBER 2018

Catherine A. Libertz
 Catherine Libertz, Director
 Water Protection Division

TABLE OF CONTENTS

PART I. LIMITATIONS AND MONITORING REQUIREMENTS.....	3
Section A. AUTHORIZED DISCHARGES.....	3
Section B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS.....	3
Section C. MONITORING AND REPORTING.....	5
PART II. STANDARD CONDITIONS	6
Section A. GENERAL CONDITIONS.....	7
Section B. OPERATION & MAINTENANCE OF POLLUTION CONTROLS.....	9
Section C. MONITORING REQUIREMENTS	11
Section D. REPORTING REQUIREMENTS	12
Section E. DEFINITIONS	14
Section F. COMMONLY USED ABBREVIATIONS.....	19
PART III. SPECIAL CONDITIONS.....	21
Section A. NOTIFICATION OF CHANGES TO THE DISCHARGE	21
Section B. MAINTAINING A CURRENT NO-EXPOSURE CERTIFICATION (NOE).....	21

PART I. LIMITATIONS AND MONITORING REQUIREMENTS

PART I. A. AUTHORIZED DISCHARGES

This permit only authorizes the discharge of uncontaminated groundwater and surface water infiltration, and roof drain stormwater runoff from the former General Services Administration West Heating Plant to Rock Creek via Outfall 002. This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

PART I. B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning with the effective date and lasting through the expiration date of this permit, the Permittee is authorized to discharge uncontaminated groundwater and surface water infiltration, and stormwater runoff from roof drains, through Outfall 002 to Rock Creek.

As specified below, the discharge shall be monitored and sampled by the Permittee at the discharge pipe, Outfall No. 002, which is located at Latitude: N 38° 54' 12"; Longitude: W 77° 3' 25"

Parameter	Discharge Limitation			Monitoring Requirements ²	
	Mass Units (lbs/day)			Sample Frequency	Sample Type
	Average Monthly	Maximum Daily	Concentration (mg/L) Average Monthly		
Flow (MGD)	N/A	N/A	N/A	Quarterly ¹	Estimate
Total Suspended Solids	N/A	N/A	N/A	Quarterly ¹	Grab
pH (Std units)	6.0 - 8.5			Quarterly ¹	Grab

See page 4 for explanation of endnotes.

Endnotes for Outfall 002

- (1) A measurement of quarterly is defined as the recording of one measurement for each calendar quarter. Calendar quarters are defined as January through March, inclusive, April through June, inclusive, July through September, inclusive and October through December, inclusive.
- (2) In accordance with 40 CFR § 122.44(i)(1)(iv), the Permittee shall use sufficiently sensitive test procedures (i.e., methods) approved under 40 CFR Part 136 or required under 40 CFR Chapter I, Subchapter N or O, for the analysis of pollutants or pollutant parameters limited in this permit. A method is considered “sufficiently sensitive” when either: (1) the method minimum level (ML) is at or below the level of the effluent limit established in this permit for the measured pollutant or pollutant parameter; or (2) the method has the lowest ML of the analytical methods approved under 40 CFR Part 136 or required under 40 CFR Chapter I, Subchapter N or O for the measured pollutant or pollutant parameter. The ML is not the minimum level of detection, but rather the lowest level at which the test equipment produces a recognizable signal and acceptable calibration point for a pollutant or pollutant parameter, representative of the lowest concentration at which a pollutant or pollutant parameter can be measured with a known level of confidence. For the purposes of this permit, the detection limit is the lowest concentration that can be reliably measured within specified limits of precision and accuracy for a specific laboratory analytical method during routine laboratory operating conditions (i.e., the level above which an actual value is reported for an analyte, and the level below which an analyte is reported as non-detect).

PART I. C. MONITORING AND REPORTING

1. Submittal of DMRs Using NetDMR

All reports and forms submitted in compliance with this section must be submitted electronically by the Permittee to the Director or initial recipient, as defined in 40 CFR § 127.2(b), in compliance with this section and 40 CFR Part 3 (including, in all cases, subpart D to Part 3), 40 CFR § 122.22, and 40 CFR Part 127. Part 127 is not intended to undo existing requirements for electronic reporting.

The Permittee must electronically submit Discharge Monitoring Reports (DMRs) using EPA's NetDMR electronic reporting tool found at: (<https://netdmr.epa.gov/netdmr/public/login.htm>). The Permittee must also submit analytical data sheets from any laboratory it uses through the NetDMR system as attachments to the DMR. The Permittee shall continue to submit its monitoring data in DMRs to EPA and DOEE no later than the 25th day of the month electronically using NetDMR. When the Permittee submits DMRs using NetDMR, it is not required to submit hard copies of DMRs to EPA or DOEE.

NPDES STANDARD CONDITIONS
(June 2018)

PART II. STANDARD CONDITIONS

TABLE OF CONTENTS

	Page
A. GENERAL CONDITIONS	
1. <u>Duty to Comply</u>	7
2. <u>Permit Actions</u>	7
3. <u>Duty to Provide Information</u>	7
4. <u>Reopener Clause</u>	8
5. <u>Oil and Hazardous Substance Liability</u>	8
6. <u>Property Rights</u>	8
7. <u>Confidentiality of Information</u>	8
8. <u>Duty to Reapply</u>	9
9. <u>State Authorities</u>	9
10. <u>Other laws</u>	9
B. OPERATION AND MAINTENANCE OF POLLUTION CONTROLS	
1. <u>Proper Operation and Maintenance</u>	9
2. <u>Need to Halt or Reduce Not a Defense</u>	9
3. <u>Duty to Mitigate</u>	9
4. <u>Bypass</u>	9
5. <u>Upset</u>	10
C. MONITORING AND RECORDS	
1. <u>Monitoring and Records</u>	11
2. <u>Inspection and Entry</u>	12
D. REPORTING REQUIREMENTS	
1. <u>Reporting Requirements</u>	12
a. Planned changes	12
b. Anticipated noncompliance	13
c. Transfers	13
d. Monitoring reports	13
e. Twenty-four hour reporting	13
f. Compliance schedules	14
g. Other noncompliance	14
h. Other information	14
2. <u>Signatory Requirement</u>	14
3. <u>Availability of Reports</u>	14
E. DEFINITIONS	
1. <u>Definitions for Individual NPDES Permits</u>	14
2. <u>Commonly Used Abbreviations</u>	19

NPDES STANDARD CONDITIONS
(June 2018)

PART II. A. GENERAL CONDITIONS

This permit is issued subject to all applicable federal regulations. Failure to set forth the full language of any applicable regulation or requirement below, however, does not change or waive its applicability in any way.

1. Duty to Comply

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act (CWA) and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

- a. The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- b. The CWA provides that any person who violates Section 301, 302, 306, 307, 308, 318, or 405 of the CWA, or any permit condition or limitation implementing any such sections in a permit issued under Section 402, or any requirement imposed in a pretreatment program approved under Sections 402 (a)(3) or 402 (b)(8) of the CWA, is subject to a civil penalty. Any person who negligently or knowingly violates such sections of the CWA or such permit requirements is subject to criminal penalties or by imprisonment, or both.
- c. Any person may be assessed an administrative penalty by the Administrator for violating Section 301, 302, 306, 307, 308, 318, or 405 of the CWA, or any permit condition or limitation implementing any of such sections in a permit issued under Section 402 of the CWA.

2. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or notification of planned changes or anticipated noncompliance does not stay any permit condition. [40 CFR § 122.41(f)]

3. Duty to Provide Information

The Permittee shall furnish to the Regional Administrator, within a reasonable time, any information which the Regional Administrator may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The Permittee shall also furnish to the Regional Administrator, upon request, copies of records required to be kept by this permit. [40 CFR § 122.41(h)]

NPDES STANDARD CONDITIONS
(June 2018)

4. Reopener Clause

The effluent limitations in this permit are based on the District of Columbia's water quality standards and TMDL documents prepared in accordance with the Clean Water Act and applicable regulations. In the event of a revision of the District of Columbia's water quality standards and/or the TMDLs, this permit may be modified by EPA to reflect this revision. The Regional Administrator reserves the right to make appropriate revisions to this permit in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the CWA in order to bring all discharges into compliance with the CWA.

Federal regulations pertaining to permit modification, revocation and reissuance, and termination are found at 40 CFR §§ 122.62, 122.63, 122.64, and 124.5.

5. Oil and Hazardous Substance Liability

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from responsibilities, liabilities or penalties to which the Permittee is or may be subject under Section 311 of the CWA, or Section 106 of the Comprehensive Environmental Response, Compensation and Liability Act of 1980 (CERCLA).

6. Property Rights

The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges. [40 CFR § 122.41(g)]

7. Confidentiality of Information

- a. In accordance with 40 CFR Part 2, any information submitted to EPA pursuant to these regulations may be claimed as confidential by the submitter. Any such claim must be asserted at the time of submission in the manner prescribed on the application form or instructions or, in the case of other submissions, by stamping the words "confidential business information" on each page containing such information. If no claim is made at the time of submission, EPA may make the information available to the public without further notice. If a claim is asserted, the information will be treated in accordance with the procedures in 40 CFR Part 2 (Public Information).
- b. Claims of confidentiality for the following information will be denied:
 - (1) The name and address of any permit applicant or Permittee;
 - (2) Permit applications, permits, and effluent data as defined in 40 CFR §2.302(a)(2).
- c. Information required by NPDES application forms provided by the Regional Administrator under 40 CFR § 122.21 may not be claimed confidential. This includes information submitted on the forms themselves and any attachments used to supply information required by the forms.

NPDES STANDARD CONDITIONS
(June 2018)

8. Duty to Reapply

If the Permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the Permittee must apply for and obtain a new permit. The Permittee shall submit a new application at least 180 days before the expiration date of the existing permit, unless permission for a later date has been granted by the Regional Administrator. (The Regional Administrator shall not grant permission for applications to be submitted later than the expiration date of the existing permit.) [40 CFR § 122.41(b)]

9. State Authorities

Nothing in 40 CFR Parts 122, 123, or 124 precludes more stringent State regulation of any activity covered by these regulations, whether or not under an authorized State program. [40 CFR § 122.1(a)(5)]

10. Other Laws

The issuance of a permit does not authorize any injury to persons or property or invasion of other private rights, nor does it relieve the Permittee of its obligation to comply with any other applicable Federal, State, or local laws and regulations. [40 CFR § 122.5(c)]

PART II. B. OPERATION & MAINTENANCE OF POLLUTION CONTROLS

1. Proper Operation and Maintenance

The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of the permit. [40 CFR § 122.41(e)]

2. Need to Halt or Reduce Not a Defense

It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [40 CFR § 122.41(c)]

3. Duty to Mitigate

The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment. [40 CFR § 122.41(d)]

4. Bypass

a. Definitions

(1) *Bypass* means the intentional diversion of waste streams from any

NPDES STANDARD CONDITIONS
(June 2018)

portion of a treatment facility.

- (2) *Severe property damage* means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

b. Bypass not exceeding limitations

The Permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Paragraphs B.4.c. and 4.d. of this section.

c. Notice

- (1) Anticipated bypass. If the Permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
- (2) Unanticipated bypass. The Permittee shall submit notice of an unanticipated bypass as required in paragraph D.1.e of this part (Twenty-four hour reporting).

d. Prohibition of bypass

- (1) Bypass is prohibited, and the Regional Administrator may take enforcement action against a Permittee for bypass, unless:
 - (A) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (B) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance; and
 - (C) The Permittee submitted notices as required under Paragraph 4.c. of this section.
- (2) The Regional Administrator may approve an anticipated bypass, after considering its adverse effects, if the Regional Administrator determines that it will meet the three conditions listed above in paragraph 4.d(1). of this section.

5. Upset

- a. Definition. *Upset* means an exceptional incident in which there is an

NPDES STANDARD CONDITIONS
(June 2018)

unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

- b. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of paragraph B.5.c. of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- c. Conditions necessary for a demonstration of upset. A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (1) An upset occurred and that the Permittee can identify the cause(s) of the upset;
 - (2) The permitted facility was at the time being properly operated;
 - (3) The Permittee submitted notice of the upset as required in paragraph D.1.e. (Twenty-four hour notice); and
 - (4) The Permittee complied with any remedial measures required under B.3. above.
- d. Burden of proof. In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.

PART II. C. MONITORING REQUIREMENTS

1. Monitoring and Records

- a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- b. Except for records of monitoring information required by this permit related to the Permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application except for the information concerning storm water discharges which must be retained for a total of 6 years. This retention period may be extended by request of the Regional Administrator at any time.
- c. Records of monitoring information shall include:
 - (1) The date, exact place, and time of sampling or measurements;

NPDES STANDARD CONDITIONS
(June 2018)

- (2) The individual(s) who performed the sampling or measurements;
 - (3) The date(s) analyses were performed;
 - (4) The individual(s) who performed the analyses;
 - (5) The analytical techniques or methods used; and
 - (6) The results of such analyses.
- d. Monitoring results must be conducted according to test procedures approved under 40 CFR Part 136 unless another method is required under 40 CFR Subchapters N or O.
- e. The CWA provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine or by imprisonment, or both.

2. Inspection and Entry

The Permittee shall allow the Regional Administrator or an authorized representative (including an authorized contractor acting as a representative of the Regional Administrator), upon presentation of credentials and other documents as may be required by law, to:

- a. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the CWA, any substances or parameters at any location.

PART II. D. REPORTING REQUIREMENTS

1. Reporting Requirements

- a. **Planned Changes.** The Permittee shall give notice to the Regional Administrator as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is only required when:
- (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR § 122.29(b); or
 - (2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under 40 CFR § 122.42(a)(1).
 - (3) The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during

NPDES STANDARD CONDITIONS
(June 2018)

the permit application process or not reported pursuant to an approved land application plan.

- b. Anticipated noncompliance. The Permittee shall give advance notice to the Regional Administrator of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- c. Transfers. This permit is not transferable to any person except after notice to the Regional Administrator. The Regional Administrator may require modification or revocation and reissuance of the permit to change the name of the Permittee and incorporate such other requirements as may be necessary under the CWA. (See 40 CFR § 122.61; in some cases, modification or revocation and reissuance is mandatory.)
- d. Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
 - (1) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Regional Administrator for reporting results of monitoring of sludge use or disposal practices.
 - (2) If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136 or, another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of the monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Administrator.
 - (3) Calculations for all limitations which require averaging or measurements shall utilize an arithmetic mean unless otherwise specified by the Regional Administrator in the permit.
- e. Twenty-four hour reporting
 - (1) The Permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances.

A written submission shall also be provided within 5 days of the time the Permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
 - (2) The following shall be included as information which must be reported within 24 hours under this paragraph.
 - (a) Any unanticipated bypass which exceeds any effluent limitation in the permit. (See 40 CFR § 122.41(g).)

NPDES STANDARD CONDITIONS
(June 2018)

- (b) Any upset which exceeds any effluent limitation in the permit.
 - (c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Regional Administrator in the permit to be reported within 24 hours. (See 40 CFR § 122.44(g).)
- (3) The Regional Administrator may waive the written report on a case-by-case basis for reports under Paragraph D.1.e. if the oral report has been received within 24 hours.
- f. Compliance Schedules. Reports of compliance or noncompliance with, any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
 - g. Other noncompliance. The Permittee shall report all instances of noncompliance not reported under Paragraphs D.1.a, D.1.d., D.1.e., and D.1.f. of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in Paragraph D.1.e. of this section.
 - h. Other information. Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Administrator, it shall promptly submit such facts or information.
2. Signatory Requirement
- a. All applications, reports, or information submitted to the Regional Administrator shall be signed and certified. (See 40 CFR § 122.22)
 - b. The CWA provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine or by imprisonment, or by both.
3. Availability of Reports

Except for data determined to be confidential under Paragraph A.7 above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the State water pollution control agency and the Regional Administrator. As required by the CWA, effluent data shall not be considered confidential. Knowingly making any false statements on any such report may result in the imposition of criminal penalties as provided for in Section 309 of the CWA. [40 CFR § 2.302(f)]

PART II. E. DEFINITIONS

1. Definitions for Individual NPDES Permits including Storm Water Requirements

NPDES STANDARD CONDITIONS
(June 2018)

Administrator means the Administrator of the United States Environmental Protection Agency, or an authorized representative.

Applicable standards and limitations means all, State, interstate, and Federal standards and limitations to which a “discharge”, a “sewage sludge use or disposal practice”, or a related activity is subject to, including “effluent limitations”, water quality standards, standards of performance, toxic effluent standards or prohibitions, “best management practices”, pretreatment standards, and “standards for sewage sludge use and disposal” under Sections 301, 302, 303, 304, 306, 307, 308, 403, and 405 of the CWA.

Application means the EPA standard national forms for applying for a permit, including any additions, revisions, or modifications to the forms; or forms approved by EPA for use in “authorized States”, including any approved modifications or revisions.

Average means the arithmetic mean of values taken at the frequency required for each parameter over the specified period. For total and/or fecal coliforms and *Escherichia coli*, the average shall be the geometric mean.

Average monthly discharge limitation means the highest allowable average of “daily discharges” over a calendar month calculated as the sum of all “daily discharges” measured during a calendar month divided by the number of “daily discharges” measured during that month.

Average weekly discharge limitation means the highest allowable average of “daily discharges” measured during the calendar week divided by the number of “daily discharges” measured during the week.

Best Management Practices (BMPs) means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of “waters of the United States.” BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Best Professional Judgment (BPJ) means a case-by-case determination of Best Practicable Treatment (BPT), Best Available Treatment (BAT), or other appropriate technology-based standard based on an evaluation of the available technology to achieve a particular pollutant reduction and other factors set forth in 40 CFR §125.3 (d).

Composite Sample means a sample consisting of a minimum of eight grab samples of equal volume collected at equal intervals during a 24-hour period (or lesser period as specified in the section on Monitoring and Reporting) and combined proportional to flow, or a sample consisting of the same number of grab samples, or greater, collected proportionally to flow over that same time period.

Construction activities – the following definitions apply to construction activities:

- (a) *Commencement of construction* is the initial disturbance of soils associated with clearing, grading, or excavating activities or other

NPDES STANDARD CONDITIONS
(June 2018)

construction activities.

- (b) *Dedicated portable asphalt plant* is a portable asphalt plant located on or contiguous to a construction site and that provides asphalt only to the construction site that the plant is located on or adjacent to. The term portable asphalt plant does not include facilities that are subject to the asphalt emulsion effluent limitation guideline at 40 CFR Part 443.
- (c) *Dedicated portable concrete plant* is a portable concrete plant located on or contiguous to a construction site and that provides concrete only to the construction site that the plant is located on or adjacent to.
- (d) *Final stabilization* means that all soil disturbing activities at the site have been complete, and that a uniform perennial vegetative cover with a density of 70% of the cover for unpaved areas and areas not covered by permanent structures has been established or equivalent permanent stabilization measures (such as the use of riprap, gabions, or geotextiles) have been employed.
- (e) *Runoff coefficient* means the fraction of total rainfall that will appear at the conveyance as runoff.

Contiguous zone means the entire zone established by the United States under Article 24 of the Convention on the Territorial Sea and the Contiguous Zone.

Continuous discharge means a “discharge” which occurs without interruption throughout the operating hours of the facility except for infrequent shutdowns for maintenance, process changes, or similar activities.

CWA means the Clean Water Act (formerly referred to as the Federal Water Pollution Control Act or Federal Water Pollution Control Act Amendments of 1972) Pub. L. 92-500, as amended by Pub. L. 95-217, Pub. L. 95-576, Pub. L. 96-483, and Pub. L. 97-117; 33 USC §§1251 et seq.

Daily Discharge means the discharge of a pollutant measured during the calendar day or any other 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the “daily discharge” is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurements, the “daily discharge” is calculated as the average measurement of the pollutant over the day.

Director normally means the person authorized to sign NPDES permits by EPA or the State or an authorized representative. Conversely, it also could mean the Regional Administrator or the State Director as the context requires.

Discharge Monitoring Report Form (DMR) means the EPA standard national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by Permittees. DMRs must be used by “authorized States” as well as by EPA. EPA will supply DMRs to any authorized State upon request. The EPA

NPDES STANDARD CONDITIONS
(June 2018)

national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA's.

Discharge of a pollutant means:

- (a) Any addition of any "pollutant" or combination of pollutants to "waters of the United States" from any "point source", or
- (b) Any addition of any pollutant or combination of pollutants to the waters of the "contiguous zone" or the ocean from any point source other than a vessel or other floating craft which is being used as a means of transportation (See "Point Source" definition).

This definition includes additions of pollutants into waters of the United States from: surface runoff which is collected or channeled by man; discharges through pipes, sewers, or other conveyances owned by a State, municipality, or other person which do not lead to a treatment works; and discharges through pipes, sewers, or other conveyances leading into privately owned treatment works.

This term does not include an addition of pollutants by any "indirect discharger."

Effluent limitation means any restriction imposed by the Regional Administrator on quantities, discharge rates, and concentrations of "pollutants" which are "discharged" from "point sources" into "waters of the United States", the waters of the "contiguous zone", or the ocean.

Effluent limitation guidelines means a regulation published by the Administrator under Section 304(b) of CWA to adopt or revise "effluent limitations".

EPA means the United States Environmental Protection Agency.

Flow-weighted composite sample means a composite sample consisting of a mixture of aliquots where the volume of each aliquot is proportional to the flow rate of the discharge.

Grab Sample – An individual sample collected in a period of less than 15 minutes.

Hazardous Substance means any substance designated under 40 CFR Part 116 pursuant to Section 311 of the CWA.

Maximum daily discharge limitation means the highest allowable "daily discharge" concentration that occurs only during a normal day (24-hour duration).

Municipality means a city, town, borough, county, parish, district, association, or other public body created by or under State law and having jurisdiction over disposal of sewage, industrial wastes, or other wastes, or an Indian tribe or an authorized Indian

NPDES STANDARD CONDITIONS
(June 2018)

tribe organization, or a designated and approved management agency under Section 208 of the CWA.

National Pollutant Discharge Elimination System (NPDES) means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 318, 402, and 405 of the CWA. The term includes an “authorized program”.

Owner or operator means the owner or operator of any “facility or activity” subject to regulation under the NPDES programs.

Pass through means a “discharge” which exits the POTW into waters of the United States in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW’s NPDES permit (including an increase in the magnitude or duration of a violation).

Permit means an authorization, license, or equivalent control document issued by EPA or an “authorized” State.

Person means an individual, association, partnership, corporation, municipality, State or Federal agency, or an agent or employee thereof.

Point Source means any discernible, confined, and discrete conveyance, including but not limited to any pipe ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation, landfill leachate collection system, vessel, or other floating craft, from which pollutants are or may be discharged. This term does not include return flows from irrigated agriculture or agricultural storm water runoff (see 40 CFR §122.2).

Pollutant means dredged spoil, solid waste, incinerator residue, filter backwash, sewage, garbage, sewage sludge, munitions, chemical wastes, biological materials, radioactive materials (except those regulated under the Atomic Energy Act of 1954, as amended (42 U.S.C. §§2011 et seq.)), heat, wrecked or discarded equipment, rock, sand, cellar dirt and industrial, municipal, and agricultural waste discharged into water. It does not mean:

- (a) Sewage from vessels; or
- (b) Water, gas, or other material which is injected into a well to facilitate production of oil or gas, or water derived in association with oil and gas production and disposed of in a well, if the well is used either to facilitate production or for disposal purposes is approved by the authority of the State in which the well is located, and if the State determines that the injection or disposal will not result in the degradation of ground or surface water resources.

NPDES STANDARD CONDITIONS
(June 2018)

Process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

Regional Administrator means the Regional Administrator, EPA, Region III, Philadelphia, Pennsylvania.

Significant spills includes, but is not limited to, releases of oil or hazardous substances in excess of reportable quantities under Section 311 of the CWA (see 40 CFR §110.10 and §117.21) or Section 102 of CERCLA (see 40 CFR § 302.4).

State means any of the 50 States, the District of Columbia, Guam, the Commonwealth of Puerto Rico, the Virgin Islands, American Samoa, the Trust Territory of the Pacific Islands.

Stormwater means storm water runoff, snow melt runoff, and surface runoff and drainage.

Stormwater discharge associated with industrial activity means the discharge from any conveyance which is used for collecting and conveying stormwater and which is directly related to manufacturing, processing, or raw materials storage areas at an industrial plant. (See 40 CFR § 122.26 (b)(14) for specifics of this definition).

Time-weighted composite means a composite sample consisting of a mixture of equal volume aliquots collected at a constant time interval.

Toxic pollutants means any pollutant listed as toxic under Section 307 (a)(1) or, in the case of “sludge use or disposal practices” any pollutant identified in regulations implementing Section 405(d) of the CWA.

Runoff is rainwater, leachate, or other liquid that drains overland on any part of a land surface and runs off the land surface.

State is one of the United States of America, the District of Columbia, the Commonwealth of Puerto Rico, the Virgin Islands, Guam, American Samoa, the Trust Territory of the Pacific Islands, the Commonwealth of the Northern Mariana Islands, and an Indian tribe eligible for treatment as a State pursuant to regulations promulgated under the authority of section 518(e) of the CWA.

2. Commonly Used Abbreviations

lbs/day	pounds per day
mg/L or mg/l	milligram(s) per liter
ml/L or ml/l	milliliters per liter
MGD	million gallons per day

NPDES STANDARD CONDITIONS
(June 2018)

- pH a measure of hydrogen ion concentration. A measure of acidity or alkalinity of a liquid or material
- °C temperature in degrees Centigrade
- °F temperature in degrees Fahrenheit
- µg/L or µg/l microgram(s) per liter

PART III. SPECIAL CONDITIONS**PART III. A. NOTIFICATION OF CHANGES TO THE DISCHARGE**

As of the issuance date of this permit the facility remains shutdown with no industrial activity occurring on site. This permit authorizes discharges of uncontaminated groundwater and surface water infiltration, and stormwater runoff from roof drains, into the former steam tunnel that ultimately discharges to Rock Creek. Should the nature of this discharge change, the Permittee shall notify EPA no later than 90 days prior to the proposed change or commencement of the discharge. At that time EPA may request an effluent characterization to re-evaluate the discharge to ensure it meets applicable D.C. water quality standards. Depending on the results from the effluent characterization, a permit modification may be required to ensure the provisions of the permit accurately reflect the current nature of the discharge as well as site activity. Until EPA has made that determination, this permit only authorizes discharges of uncontaminated groundwater and surface water infiltration, and stormwater runoff from roof drains, to Rock Creek. Any other discharge is not authorized under this permit.

PART III. B. MAINTAINING A CURRENT NO-EXPOSURE CERTIFICATION (NOE)

The Permittee must maintain a current NOE for the discharge associated with stormwater on the site as long as it accurately reflects the current conditions of the site. If the NOE is no longer applicable, then the Permittee must notify EPA no later than 30 days after becoming aware of the change in conditions¹. If EPA determines that the no-exposure exclusion no longer applies, then Permittee will need to submit either a Notice of Intent under EPA's Multi-Sector General Permit or an application for a permit modification to obtain NPDES coverage for the stormwater discharges, depending on eligibility.

¹ Condition changes may include, but are not limited to, the site changing from inactive to active status or stormwater runoff not covered under a no exposure certification

