2019 – 1st Quarter Report Support for Conducting Systems & Performance Audits of Clean Air Status and Trends Network (CASTNET) Sites and National Atmospheric Deposition Program (NADP) Monitoring Stations - II EPA Contract No. EP-W-18-005

Prepared for:

U. S. Environmental Protection Agency

Prepared by:



1128 NW 39th Drive Gainesville, FL 32605

April 2019

Table of Contents

1.0 CAS	TNET Quarterly Report	.1
1.1	Introduction	.1
1.2	Project Objectives	.1
1.3	CASTNET Sites Visited First Quarter 2019	.4
1.4	Audit Results	.5
2.0 NAL	DP Quarterly Report	.6
2.0 NAL 2.1	PP Quarterly Report Introduction	.6
2.0 NAL 2.1 2.2	PP Quarterly Report Introduction Project Objectives	6
2.0 NAL 2.1 2.2 2.3	P Quarterly Report Introduction Project Objectives NADP Sites Visited First Quarter 2019	6 6

List of Appendices

Appendix A	CASNTET Audit Report Forms
Appendix B	CASTNET Site Spot Report Forms
Appendix C	CASTNET Ozone Performance Evaluation Forms

List of Tables

Table 1.	Performance Audit Challenge and Acceptance Criteria	2
Table 2.	Site Audit Visits	4
Table 3.	TTP Pollutant PE Visits	5
Table 4.	Sites Surveyed – First Quarter 2019	7

List of Acronyms and Abbreviations

% diff	percent difference
A/D	analog to digital converter
ARS	Air Resource Specialist, Inc.
ASTM	American Society for Testing and Materials
BLM	Bureau of Land Management
CASTNET	Clean Air Status and Trends Network
CMAQ	Community Multiscale Air Quality
DAS	data acquisition system
DC	direct current
deg	degree
DVM	digital voltmeter
ECCC	Environment and Climate Change Canada
EEMS	Environmental, Engineering & Measurement Services, Inc.
EPA	U.S. Environmental Protection Agency
ESC	Environmental Systems Corporation
FSA	Field Systems Audit
FSAD	Field Site Audit Database
GPS	geographical positioning system
lpm	liters per minute
MLM	Multilayer Model
m/s	meters per second
mv	millivolt
NIST	National Institute of Standards and Technology
NOAA	National Oceanic and Atmospheric Administration
NPS	National Park Service
PE	Performance Evaluation
QAPP	Quality Assurance Project Plan
SOP	standard operating procedure
TDEP	Total Deposition
TEI	Thermo Environmental Instruments
USNO	United States Naval Observatory
V	volts
WRR	World Radiation Reference
WSO	Wyoming State Office

1.0 CASTNET Quarterly Report

1.1 Introduction

The Clean Air Status and Trends Network (CASTNET) is a national air monitoring program developed under mandate of the 1990 Clean Air Act Amendments. Each site in the network measures acidic gases and particles and other forms of atmospheric pollution using a continuous collection filter aggregated over a one week period. Hourly averages of surface ozone concentrations and selected meteorological variables are also measured.

Site measurements are used to estimate deposition rates of the various pollutants with the objective of determining relationships between emissions, air quality, deposition, and ecological effects. In conjunction with other national monitoring networks, CASTNET data are used to determine the effectiveness of national emissions control programs and to assess temporal trends and spatial deposition patterns in atmospheric pollutants. CASTNET data are also used for long-range transport model evaluations and effects research.

CASTNET pollutant flux estimates are calculated as the aggregate product of weekly measured chemical concentrations and model-estimated deposition velocities. Total deposition is assessed using the NADP's Total Deposition Hybrid Method (TDEP; EPA, 2015c; Schwede and Lear, 2014), which combines data from established ambient monitoring networks and chemical-transport models. To estimate dry deposition, ambient measurement data from CASTNET and other networks were merged with dry deposition rates and flux output from the Community Multiscale Air Quality (CMAQ) modeling system.

As of December 2018, the network is comprised of 95 active rural sampling sites across the United States and Canada, cooperatively operated by the Environmental Protection Agency (EPA), the National Park Service (NPS), Environment and Climate Change Canada (ECCC), Bureau of Land Management – Wyoming State Office (BLM-WSO) and several independent partners. Wood is responsible for operating the EPA and ECCC sponsored sites, and Air Resource Specialist, Inc. (ARS) is responsible for operating the NPS and BLM-WSO sponsored sites.

1.2 Project Objectives

The objectives of this project are to establish an independent and unbiased program of performance and systems audits for all CASTNET sampling sites. Ongoing Quality Assurance (QA) programs are an essential part of any long-term monitoring network. Performance audits verify that all evaluated variables are consistent with the accuracy goals as defined in the CASTNET Quality Assurance Project Plan (QAPP). The parameter specific accuracy goals are presented in Table 1. Two EPA sponsored sites that are operated by Wood continue to operate meteorological sensors. Those sites are BEL116 and BVL130. PND165 and four sites sponsored by BLM-WSO also operate meteorological sensors. The NPS operates meteorological sensors at many of their air quality monitoring sites. No meteorological sensors other than temperature were audited during this reporting period.

Some or all of the additional monitored variables, NOy, CO, and SO₂ have been added to the EPA sponsored sites BVL130, HWF187, PND165, PNF126, GRS420, MAC426, and ROM206. None of those variables were audited during this reporting period.

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Precipitation	Response	10 manual tips	1 DAS count per tip
Precipitation	Accuracy	2 introductions of known amounts of water	$\leq \pm 10.0\%$ of input amount
Relative Humidity	Accuracy	Compared to reference instrument or standard solution	$\leq \pm 10.0\%$ RH
Solar Radiation	Accuracy	Compared to WRR traceable standard	$\leq \pm 10.0\%$ of daytime average
Surface Wetness	Response	Distilled water spray mist	Positive response
Surface Wetness	Sensitivity	1% decade resistance	N/A
Temperature	Accuracy	Comparison to 3 NIST measured baths (~ 0° C, ambient, ~ full-scale)	$\leq \pm 0.5^{\circ} \mathrm{C}$
Temperature Difference	Accuracy	Comparison to station temperature sensor	$\leq \pm 0.50^{\circ} \mathrm{C}$
Shelter Temperature	Accuracy	Comparison to station temperature sensor	$\leq \pm 2.0^{\circ} \mathrm{C}$
Wind Direction	Orientation Accuracy	Parallel to alignment rod/crossarm, or sighted to distant point	$\leq \pm 5^{\circ}$ from degrees true
Wind Direction	Linearity	Eight cardinal points on test fixture	≤±5° mean absolute error
Wind Direction	Response Threshold	Starting torque tested with torque gauge	< 10 g-cm Climatronics; < 20 g-cm R.M. Young

 Table 1. Performance Audit Challenge and Acceptance Criteria

Sensor	Parameter	Audit Challenge	Acceptance Criteria
Wind Speed	Accuracy	Shaft rotational speed generated and measured with certified synchronous motor	$\leq \pm 0.5$ mps below 5.0 mps input; $\leq \pm 5.0\%$ of input at or above 5.0 mps
Wind Speed	Starting Threshold	Starting torque tested with torque gauge	< 0.5 g-cm
Mass Flow Controller	Flow Rate	Comparison with Primary Standard	$\leq \pm 5.0\%$ of designated rate
Ozone	Slope	Linear regression of multi-	$0.9000 \le m \le 1.1000$
Ozone	Intercept	point test gas concentration as	-5.0 ppb \leq b \leq 5.0 ppb
Ozone	Correlation Coefficient	transfer standard	$0.9950 \le r$
Ozone	Percent Difference	Comparison with Level 2 standard concentration	$\leq \pm 15.1\%$ of test gas concentration
DAS	Accuracy	Comparison with certified standard	$\leq \pm 0.003 \text{ VDC}$

Performance audits are conducted using standards that are traceable to the National Institute of Standards and Technology (NIST), or another authoritative organization, and certified as current.

Site systems audits are intended to provide a qualitative appraisal of the total measurement system. Site planning, organization, and operation are evaluated to ensure that good Quality Assurance/Quality Control (QA/QC) practices are being applied. At a minimum the following audit issues were addressed at each site systems audit:

- Site locations and configurations match those provided in the CASTNET QAPP.
- Meteorological instruments are in good physical and operational condition and are sited to meet EPA ambient monitoring guidelines (EPA-600/4-82-060).
- Sites are accessible, orderly, and if applicable, compliant with OSHA safety standards.
- Sampling lines are free of leaks, kinks, visible contamination, weathering, and moisture.
- Site shelters provide adequate temperature control.
- All ambient air quality instruments are functional, being operated in the appropriate range, and the zero air supply desiccant is unsaturated.
- All instruments are in current calibration.
- Site documentation (maintenance schedules, on-site SOPs, etc.) is current and log book records are complete.
- All maintenance and on-site SOPs are performed on schedule.

- Corrective actions are documented and appropriate for required maintenance/repair activity.
- Site operators demonstrate an adequate knowledge and ability to perform required site activities, including documentation and maintenance activities.

1.3 CASTNET Sites Visited First Quarter 2019

This report consists of the systems and performance and other audit results from the CASTNET sites visited during the first quarter (January through March) of 2019. The locations and dates of the site visits for complete audits are presented in Table 2.

<u>Side ID</u>	<u>Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	Station Name
ALC188	FSA	EPA	2/25/2019	Alabama-Coushatta
ALC188	O3 PE	EPA	2/25/2019	Alabama-Coushatta
ALC188	Flow	EPA	2/25/2019	Alabama-Coushatta
BBE401	FSA	NPS	2/27/2019	Big Bend National Park – K-Bar
BBE401	O ₃ PE	NPS	2/27/2019	Big Bend National Park – K-Bar
BBE401	Flow	NPS	2/27/2019	Big Bend National Park – K-Bar
PAL190	FSA	EPA	3/1/2019	Palo Duro
PAL190	O3 PE	EPA	3/1/2019	Palo Duro
PAL190	Flow	EPA	3/1/2019	Palo Duro
EVE419	FSA	NPS	3/19/2019	Everglades NP
EVE419	Flow	NPS	3/19/2019	Everglades NP

Table 2. Site Audit Visits

In addition to the sites listed in Table 2 that were visited for complete audits, the sites listed in Table 3 were visited to conduct Through-The-Probe (TTP) pollutant Performance Evaluations (PE).

<u>Side ID</u>	<u>PE Audit Type</u>	<u>Sponsor</u>	<u>Site Visit Date</u>	Station Name
IRL141	O ₃	EPA	3/19/2019	Indian River Lagoon
GAS153	O3	EPA	3/26/2019	Georgia Station
SUM156	O3	EPA	3/26/2019	Sumatra

Table 3. TTP Pollutant PE Visits

1.4 Audit Results

The observations and results of the systems and performance audits are included in Appendix A, *CASTNET Audit Report Forms* by site, arranged by audit date. Photographs of site conditions are included within each systems report where necessary. Copies of the spot reports that were sent immediately following the audit of each site are included as Appendix B, *CASTNET Site Spot Report Forms*. The Ozone PE results and observations are included in Appendix C, *CASTNET Ozone Performance Evaluation Forms*.

2.0 NADP Quarterly Report

2.1 Introduction

The National Atmospheric Deposition Program (NADP) operates three precipitation chemistry networks and two atmospheric concentration networks. The National Trends Network (NTN) has been measuring acidic precipitation since 1978. The network currently has more than 250 sites. The Atmospheric Integrated Research Monitoring Network (AIRMoN) began operation in 1992 and currently measures event based precipitation events at 3 sites. The Mercury Deposition Network (MDN) measures total mercury in precipitation samples from more than 120 stations. The MDN began operation in 1996 and includes sites throughout the US and Canada. The Atmospheric Mercury Network (AMNet) and the Ammonia Monitoring Network (AMoN) measure ambient concentrations of mercury and ammonia, respectively.

The NADP and other long-term monitoring networks provide critical information to the EPA regarding evaluating the effectiveness of emission reduction control programs from the power industry.

The NADP Program Office (PO) operates and administers the three precipitation chemistry networks (NTN, MDN and AIRMoN), two atmospheric concentration networks (AMNet and AMoN), two analytical laboratories, the Wisconsin State Lab of Hygiene (WSLH) located at the University of Wisconsin in Madison and the Mercury Analytical Laboratory (HAL) located at Frontier Global Sciences), and the network equipment depot (NED).

2.2 Project Objectives

The objective of this project is to perform independent and unbiased evaluations of the sites along with its operations. These evaluations provide quality assurance pertaining to siting, sample collection and handling, equipment operation and maintenance, record keeping and field laboratory procedures.

More specifically, the surveys determine and report findings based on an established methodology consisting of completing a site questionnaire, testing the equipment and documenting with photographs the location, siting criteria, existing equipment, and any issues encountered that require such documentation.

2.3 NADP Sites Visited First Quarter 2019

This report presents the NADP sites surveyed during the first quarter (January through March) of 2019. The station names and dates of the surveys are presented in Table 4.

Side ID	<u>Network</u>	<u>Visit Date</u>	Station Name	
TX41	AMoN	2/25/2019	Alabama-Coushatta	
TX43	AMoN	3/1/2019	Canonceta	
FL11	AMoN	3/19/2019	Everglades National Park – Research Center	
FL19	AMoN	3/19/2019	Indian River	
GA41	AMoN	3/26/2019	Georgia Station	
FL23	AMoN	3/27/2019	Sumatra	

Table 4. Sites Surveyed – First Quarter 2019

2.4 Survey Results

Site survey results are entered into a relational database. The database in turn generates Site Spot Reports which are distributed among the interested parties as soon as all the site data has been entered. Database tables with all the data collected and reviewed are then sent to the NADP Program Office and to the U.S. EPA Project Officers.

Other items gathered during the surveys (i.e., photographs, Belfort charts, etc.) are uploaded to EEMS' server where the NADP PO and the U.S. EPA POs can access them and download them as needed by login into the server site.

Given the volume of data generated, and the fact that data is distributed and/or is available through EEMS' server, no survey results are included in this report.

APPENDIX A

CASTNET Audit Report Forms

Site Inventory by Site Visit

Site	Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
ALC	188-Martin	Valvur-02/25/2019				
1	2/25/2019	Computer	Dell	07006	Inspiron 15	373MC12
2	2/25/2019	DAS	Campbell	000422	CR3000	2523
3	2/25/2019	Elevation	Elevation	None	1	None
4	2/25/2019	Filter pack flow pump	Thomas	02976	107CAB18	0493002475
5	2/25/2019	Flow Rate	Арех	000683	AXMC105LPMDPCV	illegible
6	2/25/2019	Infrastructure	Infrastructure	none	none	none
7	2/25/2019	Modem	Raven	06583	H4223-C	08443555843
8	2/25/2019	Ozone	ThermoElectron Inc	000745	49i A1NAA	1105347310
9	2/25/2019	Ozone Standard	ThermoElectron Inc	000694	49i A3NAA	1030244815
10	2/25/2019	Sample Tower	Aluma Tower	000136	В	none
11	2/25/2019	Shelter Temperature	Campbell	none	107-L	none
12	2/25/2019	Siting Criteria	Siting Criteria	None	1	None
13	2/25/2019	Temperature	RM Young	04942	41342	8894
14	2/25/2019	Zero air pump	Werther International	06878	C 70/4	000815254

DAS Data Form

Mfg

Campbell

Das Date: Das Time: Das Day:

Low Channel: Avg Diff:

0.0002

DAS Time Max Error:

0

Serial Num	ber Site	ſ	Fechnician	Site Visit Date	Parameter	Use Desc.
2523	ALC1	88	Martin Valvur	02/25/2019	DAS	Primary
2 /25/2019	Audit Date	2 /25/2019	Mfg	HY	Parameter	DAS
56	Audit Time	56	Serial Number	12010039329	Tfer Desc.	Source generator (D
]	High Channel:		Tfer ID	01322		
Max Diff:	Avg Diff:	Max Diff:	Slope	1.0000	D Intercept	0.00000
0.0004	0.0002	0.0004	Cert Date	6/15/201	4 CorrCoff	1.00000
			Mfg	Fluke	Parameter	DAS
			Serial Number	95740243	Tfer Desc.	DVM
			Tfer ID	01312		
			Slope	1.0000	D Intercept	0.00000
			Cert Date	1/25/201	9 CorrCoff	1.00000

Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	-0.0002	-0.0003	V	V	-0.0001	
7	0.1000	0.0997	0.0999	V	V	0.0002	
7	0.3000	0.2997	0.2999	V	V	0.0002	
7	0.5000	0.4996	0.5000	V	V	0.0004	
7	0.7000	0.7002	0.7002	V	V	0.0000	
7	0.9000	0.8996	0.8995	V	V	-0.0001	
7	1.0000	1.0004	1.0002	V	V	-0.0002	

Flow Data Form

Mfg	Serial Nun	nber Ta	Site	Тес	chnician	Site Visit Da	te Visit Date Parameter		Owner ID	
Apex	illegible		ALC188	Ma	artin Valvur	02/25/2019	Flow R	late	000683	
					Mfg		Р	arameter Flow	v Rate	
					Serial Number	122974	Т	fer Desc. BIO	S 220-H	
					Tfer ID	01416				
					Slope	1.00	178 Inte	ercept	0.00161	
					Cert Date	7/13/2	2018 Cor	rrCoff	1.00000	
DAS 1:		DAS 2:		L	Cal Factor Z	ero		0		
A Avg % Diff:	A Max % Di	A Avg %	Dif A Max	x % Di	Cal Factor F	ull Scale		0		
2.38%	2.60%				Rotometer R	eading:	1.5	55		
Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E I	nputUnit	OutputSignall	PctDifference	
primary	pump off	0.000	0.000	0.00	0.000	0.01 l/m		l/m		
primary	leak check	0.000	0.000	0.00	0.000	0.01	l/m	l/m		
primary	test pt 1	1.541	1.540	1.55	0.000	1.51	l/m	l/m	-1.95%	
primary	test pt 2	1.540	1.540	1.55	0.000	1.50	l/m	l/m	-2.60%	
primary	test pt 3	1.542	1.540	1.55	0.000	1.50	l/m	l/m	-2.60%	
Sensor Comp	onent Leak Tes	st		Conditio	n		Status	pass		
Sensor Comp	onent Tubing C	ondition		Conditio	n Good		Status	pass		
Sensor Comp	onent Filter Pos	sition		Conditio	Good		Status	pass		
Sensor Comp	onent Rotomete	er Conditio	n	Conditio	Clean and dry		Status	itus pass		
Sensor Comp	Moisture	Present		Conditio	n No moisture pr	esent	Status pass			
Sensor Comp	onent Filter Dis	tance		Conditio	n 5.0 cm		Status	pass		
Sensor Comp	onent Filter Dep	oth		Conditio	n 4.5 cm		Status	pass		
Sensor Comp	onent Filter Azi	muth		Conditio	n 190 deg		Status	pass		
Sensor Comp	onent System M	/lemo		Conditio	n		Status	pass		

Ozone Data Form

Mfg	Serial Number 7	Ta Site	Te	chnician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1105347310	ALC188	B Ma	artin Valvur	02/25/2019	Ozone	000745
Slope: Intercept CorrCoff	0.96029 Slope: 0.55012 Interce 0.99988 CorrCe	pt () off ()	0.00000 0.00000 0.00000	Mfg Serial Number Tfer ID	ThermoElectron 49CPS-70008-3 01110	Inc Paramete 64 Tfer Des	er ozone c. Ozone primary stan
DAS 1: DAS 2:			Slope	1.0015	1 Intercept	0.00666	
A Avg % Diff: A	Max % Di A Av	g %Dif A	Max % Di	Cert Date	10/30/201	8 CorrCoff	1.00000
0.0%	0.0%						
UseDescription	ConcGroup	Tfer Raw	Tfer Corr	1 03	Site Unit	RelPerDif	AbsDif 0.84
primary	2	14.94	14.91	14.57	ppb		-0.34
primary	3	32.56	32.50	31.15	ppb	-4.24	
primary	4	67.13	67.02	65.91	ppb	-1.67	
primary	5	109.98	109.80	105.60	ppb	-3.9	
Sensor Compone	ent Sample Train		Conditio	Good		Status pass	
Sensor Compone	ent 22.5 degree ru	е	Conditio	on		Status pass	
Sensor Compone	ent Inlet Filter Con	dition	Conditio	Condition Clean		Status pass	
Sensor Compone	ent Battery Backup	•	Conditio	n N/A	Status pass		
Sensor Compone	ent Offset		Conditio	Condition -0.7		Status pass	
Sensor Compone	ent Span		Conditio	n 1.034		Status pass	
Sensor Compone	ent Zero Voltage		Conditio	n N/A		Status pass	
Sensor Compone	ent Fullscale Volta	ge	Conditio	n N/A		Status pass	
Sensor Compone	ent Cell A Freq.		Conditio	on 105.8 kHz		Status pass	
Sensor Compone	ent Cell A Noise		Conditio	n 1.0 ppb		Status pass	
Sensor Compone	ent Cell A Flow		Conditio	0.57 lpm		Status pass	
Sensor Compone	ent Cell A Pressure	9	Conditio	727.0 mmHg		Status pass	
Sensor Compone	ent Cell A Tmp.		Conditio	32.9 C		Status pass	
Sensor Compone	ent Cell B Freq.		Conditio	93.9 kHz		Status pass	
Sensor Compone	ent Cell B Noise		Conditio	1 .0 ppb		Status pass	
Sensor Compone	ent Cell B Flow		Conditio	0.67 lpm		Status pass	
Sensor Compone	ent Cell B Pressure	9	Conditio	726.4 mmHg		Status pass	
Sensor Compone	ent Cell B Tmp.		Conditio	n N/A		Status pass	
Sensor Compone	ent Line Loss		Conditio	Not tested		Status pass	
Sensor Component System Memo			Conditio	on		Status pass	

Temperature Data Form

Mfg	Serial Number	Fa Site	1	Technician		Site V	isit Date	Param	eter	Owner ID
RM Young	8894	ALC188		Martin Valvur		02/25	5/2019	Temper	rature	04942
				Mfg		Fluke		Ра	arameter Temperature	
				Serial Number		3275143 Tf		er Desc. RTD		
				Tfer ID		01229)			
DAS 1:	DAS	2:		Slo	ре	0.99989 Intercep		rcept	-0.00649	
Abs Avg Err	Abs Max Er Abs	Avg Err Abs	Max Er	Er Cert Date		1/23/2019 Cor		rCoff	1.00000	
0.26	0.42									
UseDesc.	Test type	InputTmpRaw	InputTmp	npCorr. OutputTmpS		Signal OutputSig		gnalEng	OSE Unit	Difference
primary 7	Temp Low Range	0.15	0.16		0.000		0.0)	С	-0.15
primary 7	Temp Mid Range	23.23	23.24		0.000		23.	0	С	-0.22
primary 7	Temp High Range	46.22	46.23		0.000		45.	8	С	-0.42
Sensor Comp	ponent Shield		Condi	tion	Clean			Status	pass	
Sensor Comp	ponent Blower		Condi	tion N	I/A			Status	pass	
Sensor Component Blower Status Switch			Condi	Condition N/A				Status	pass	
Sensor Component System Memo			Condi	tion				Status	pass	

Shelter Temperature Data For

Mfg	Serial Number Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	none	ALC188	Martin Valvur	02/25/2019	Shelter Temperature	none
DAS 1:	DAS 2:		Mfg	Fluke	Parameter She	Iter Temperatur
Abs Avg ErrA0.93	Abs Max Er Abs Avg 0.96	Err Abs Max Er	Serial Number	3275143	Tfer Desc. RTD)
			Tfer ID	01229		
			Slope	0.9998	9 Intercept	-0.00649
			Cert Date	1/23/201	9 CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	23.53	23.54	0.000	22.6	С	-0.92
primary	Temp Mid Range	23.44	23.45	0.000	22.5	С	-0.92
primary	Temp Mid Range	23.74	23.75	0.000	22.8	С	-0.96
Sensor Con	ponent System Memo)	Condition		Status	pass	

Infrastructure Data For

Site ID	ALC188	Technician Martin	/alvur Site Visit Date 02/25/2019
Shelter	Make	Shelter Model	Shelter Size
Shelter (One	8128-2311	1024 cuft

Sensor Component	Sample Tower Type	Condition	Туре В	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass

Field Systems Comments

1 Parameter: SitingCriteriaCom

The site is well located with respect to CASTNET siting criteria, however there is a small campground 0.5 km to the northwest which may be a source of smoke.

2 Parameter: ShelterCleanNotes

The site is clean and neat.

Field Systems Data Form

F-02058-1500-S1-rev002

Site ID ALC188	Technician Martin Valvur	Site Visit Date 02/2	5/2019		
Site Sponsor (agency)	EPA	USGS Map	Dallardsville		
Operating Group	Alabama-Coushatta Environmental Gr	Map Scale			
AQS #	48-373-9991	Map Date			
Meteorological Type	R.M. Young				
Air Pollutant Analyzer	Ozone	QAPP Latitude	30.4210		
Deposition Measurement	dry	QAPP Longitude	-94.4045		
Land Use	woodland - mixed	QAPP Elevation Meters	101		
Terrain	gently rolling	QAPP Declination	3.8		
Conforms to MLM	Yes	QAPP Declination Date	9/16/2005		
Site Telephone	(936) 563-2973	Audit Latitude	30.701577		
Site Address 1	Poncho Rd.	Audit Longitude	-94.674011		
Site Address 2	571 Park Rd. 56	Audit Elevation	105		
County	Polk	Audit Declination	2.5		
City, State	Livingston, TX	Present			
Zip Code	77351	Fire Extinguisher 🗹	New in 2015		
Time Zone	Central	First Aid Kit			
Primary Operator		Safety Glasses			
Primary Op. Phone #		Safety Hard Hat			
Primary Op. E-mail		Climbing Belt			
Backup Operator		Security Fence			
Backup Op. Phone #		Secure Shelter			
Backup Op. E-mail		Stable Entry Step 🗹			
Shelter Working Room ✓	Make Shelter One M	odel 8128-2311	Shelter Size 1024 cuft		
Shelter Clean	Notes The site is clean and neat.				
Site OK	Notes				
Driving Directions From Livingston proceed east on route 190 approximately 16 miles. Turn right (south) onto Park Road 56 at the sign for Alabama-Coushatta Tribe and the Indain Village. Continue past the facility and campground by the small lake on the left. Just past the campground entrance, turn left onto a dirt road. Continue approximately 0.6 miles bearing right at the first fork and left at the second. You will see the site in the clearing.					

Field Systems Data Form

ALC188

F-02058-1500-S2-rev002

Site ID

Technician Martin Valvur

Site Visit Date 02/25/2019

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		
Major industrial complex	10 to 20 km		
City > 50,000 population	40 km		
City 10,000 to 50,000 population	10 km		
City 1,000 to 10,000 population	5 km		
Major highway, airport or rail yard	2 km		\checkmark
Secondary road, heavily traveled	500 m		\checkmark
Secondary road, lightly traveled	200 m		\checkmark
Feedlot operations	500 m		\checkmark
Intensive agricultural ops (including aerial spraying)	500 m		\checkmark
Limited agricultural operations	200 m		\checkmark
Large parking lot	200 m		\checkmark
Small parking lot	100 m		\checkmark
Tree line	50 m		\checkmark
Obstacles to wind	10 times obstacle height		\checkmark

Siting Distances OK

Siting Criteria Comment

The site is well located with respect to CASTNET siting criteria, however there is a small campground 0.5 km to the northwest which may be a source of smoke.

Fi	eld Systems Data Form		F-02058-1500-S3-rev002				
Site	ALC188 Technician Martin Valvur		Site Visit Date 02/25/2019				
1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?		N/A				
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)		N/A				
3	Are the tower and sensors plumb?		N/A				
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?		Temperature sensor facing west				
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)						
6	Is the solar radiation sensor plumb?		N/A				
7	Is it sited to avoid shading, or any artificial or reflected light?		N/A				
8	Is the rain gauge plumb?		N/A				
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?		N/A				
10	Is the surface wetness sensor sited with the grid surface facing north?		N/A				
11	Is it inclined approximately 30 degrees?		N/A				
Pro	wide any additional explanation (photograph or sketch if nece	sarv) regarding conditions listed above, or any other features.				

Field Systems Data Form

F-02058-1500-S4-rev002

Site	e ID	ALC188	Technician	Martin Valvur		Site Visit Date 02/25/2019
1 2 3	 Do all the meterological sensors appear to be intact, in good condition, and well maintained? Are all the meteorological sensors operational online, and reporting data? Are the shields for the temperature and RH sensors clean? Are the aspirated motors working? 					Temperature only Temperature only
4	Are the a	spirated motors worl	king?			N/A
5	Is the sol scratches	ar radiation sensor's s?	lens clean and t	free of		N/A
6	Is the su	rface wetness sensor g	grid clean and u	indamaged?	\checkmark	N/A
7 8	Are the s condition Are the s	ensor signal and pow n, and well maintained sensor signal and pow	er cables intact 1? er cable connec	, in good ctions protected		
	from the	elements and well ma	aintained?			

Fi	eld Systems Data Form		F-02058-1500-S5-rev002
Site	ID ALC188 Technician Martin Valvur		Site Visit Date 02/25/2019
	Siting Criteria: Are the pollutant analyzers and deposition e	quipı	nent sited in accordance with 40 CFR 58, Appendix E
1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	✓	
2	Are the sample inlets 3 - 15 meters above the ground?	✓	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?		
	Pollutant analyzers and deposition equipment operations and	d ma	intenance
1	Do the analyzers and equipment appear to be in good condition and well maintained?	✓	
2	Are the analyzers and monitors operational, on-line, and reporting data?	✓	
3	Describe ozone sample tube.		1/4 teflon by 12 meters
4	Describe dry dep sample tube.		3/8 teflon by 12 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	✓	At inlet
6	Are sample lines clean, free of kinks, moisture, and obstructions?		
7	Is the zero air supply desiccant unsaturated?	✓	
8	Are there moisture traps in the sample lines?	✓	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?		Clean and dry

Fi	eld Sy	stems Data Fo	orm			F-02058-1500-S6-rev002			
Site	e ID	ALC188	Technician	Martin Valvur		Site Visit Da	1te 02/25/201	9	
	DAS, sei	nsor translators, and p	eripheral equi	pment operatio	ns ai	nd maintenance			
1	Do the D well mai	AS instruments appea ntained?	ar to be in good	l condition and					
2	Are all t modem,	he components of the I backup, etc)	DAS operation	al? (printers,	✓				
3	Do the a lightning	nalyzer and sensor sig g protection circuitry?	nal leads pass	through		Met sensors only	,		
4	Are the swell mai	signal connections prot ntained?	tected from the	e weather and	✓				
5	Are the	signal leads connected	to the correct	DAS channel?	✓				
6	Are the grounde	DAS, sensor translator d?	rs, and shelter	properly	✓				
7	Does the	instrument shelter ha	we a stable pov	ver source?	✓				
8	Is the in	strument shelter tempo	erature control	lled?					
9	Is the m	et tower stable and gro	ounded?			Stable		Grounded	
10	Is the sa	mple tower stable and	grounded?						
11	Tower c	omments?				Met tower remov	ed		

Field Sy	ystems Data	For	·m				F-02	058-	1500-S7-rev00
Site ID	ALC188		Techn	lician	Martin Valvur	Site Visit Date	02/25/2019		
Documer	<u>itation</u>								
Does the	<u>site have the requi</u>	red ins	strumer	<u>nt and</u>	equipment manuals?	•			
Wind speed	sensor	Yes	No	N/.	A Data logg	er	Yes	No ✓	N/A
Temperatur	e sensor				Strip chai	er rt recorder			
Relative hun Solar radiat	midity sensor ion sensor			 <td>Computer Modem</td><td>r</td><td></td><td></td><td></td>	Computer Modem	r			
Surface wet	ness sensor				Printer				
Temperatur	r translator e translator			✓	Zero air p Filter flov	oump v pump			
Humidity se Solar radiat	ensor translator ion translator				Surge pro UPS	tector			
Tipping buc	ket rain gauge				Lightning	protection devic	e 🗌		
Ozone analy Filter pack	zer flow controller				Shelter he Shelter ai	eater r conditioner			
Filter pack	MFC power supply	y 🗌		✓					
Does th	<u>e site have the requ</u>	<u>iired a</u>	nd mos	st rece	nt QC documents and	<u>l report forms?</u>			
		Pres	ent				Curre	nt	
Station Log									

Station Log	\checkmark		\checkmark
SSRF	\checkmark		\checkmark
Site Ops Manual	\checkmark	Oct 2011	\checkmark
HASP	\checkmark	Oct 2014	\checkmark
Field Ops Manual			
Calibration Reports	\checkmark		\checkmark
Ozone z/s/p Control Charts			
Preventive maintenance schedul	\checkmark		

1 Is the station log properly completed during every site visit? ✓ Minimal information

- 2 Are the Site Status Report Forms being completed and current?
- 3 Are the chain-of-custody forms properly used to document sample transfer to and from lab?
- 4 Are ozone z/s/p control charts properly completed and current?

✓	
✓	
✓	Control charts not used

2

Field Systems Data Form

ALC188 Technician Martin Valvur Site Visit Date 02/25/2019 Site ID Site operation procedures Trained by previous site operator Has the site operator attended a formal CASTNET training 1 course? If yes, when and who instructed? 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed? Is the site visited regularly on the required Tuesday ✓ 3 schedule? \checkmark Are the standard CASTNET operational procedures being 4 flollowed by the site operator? Is the site operator(s) knowledgeable of, and able to perform 5 the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check	Performed
----------	-----------

Frequency

Multipoint Calibrations	\checkmark	Semiannually	\checkmark
Visual Inspections	\checkmark	Weekly	\checkmark
Translator Zero/Span Tests (climatronics)		N/A	\checkmark
Manual Rain Gauge Test	\checkmark	N/A	\checkmark
Confirm Reasonableness of Current Values	\checkmark	Weekly	\checkmark
Test Surface Wetness Response	\checkmark	N/A	\checkmark

Are regular operational QA/QC checks performed on the ozone analyzer?

QC Check Performed

Multi-point Calibrations Automatic Zero/Span Tests Manual Zero/Span Tests **Automatic Precision Level Tests Manual Precision Level Test Analyzer Diagnostics Tests In-line Filter Replacement (at inlet) In-line Filter Replacement (at analyze** Sample Line Check for Dirt/Water **Zero Air Desiccant Check**

	Frequency	Co
✓	Semiannually	\checkmark
✓	Daily	\checkmark
	As needed	\checkmark
✓	Daily	\checkmark
	As needed	\checkmark
✓	Weekly	\checkmark
✓	Every 2 weeks	\checkmark
✓	N/A	\checkmark
✓	Weekly	\checkmark
\checkmark	Weekly	\checkmark

- Do multi-point calibration gases go through the complete 1 sample train including all filters?
- Do automatic and manual z/s/p gasses go through the 2 complete sample train including all filters?

3	Are the automatic and manual z/s/p checks monitored and
	reported? If yes, how?

	Unknown
∕	SSRF, call-in

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

ompliant

Compliant

F-02058-1500-S8-rev002

Field Systems Data Form							F-02058-1500-S9-r				
Sit	e ID	ALC188	Technic	ian	Martin Valvur		Site Visit Date	02/25/2019			
	<u>Site ope</u>	eration procedures									
1	Is the fi	lter pack being changed e	every Tu	esda	ay as scheduled	<mark>?</mark> ✓	Filter changed after	noons			
2	Are the correctl	Site Status Report Form y?	s being o	omj	pleted and filed						
3	Are dat schedul	a downloads and backup ed?	s being p	oerf	ormed as		No longer required				
4	Are gen	neral observations being n	nade and	l ree	corded? How?	✓	SSRF				
5	Are site fashion	supplies on-hand and re	plenishe	d in	a timely						
6	Are san	nple flow rates recorded?	How?			✓	SSRF, call-in				
7	Are san fashion	nples sent to the lab on a p ?	regular s	sche	dule in a timely						
8	Are filte and shij	ers protected from contar pping? How?	nination	du	ring handling		Clean gloves on an	d off			
9	Are the operation	site conditions reported a ons manager or staff?	regularly	y to	the field						
QC	Check P	erformed		Fre	quency			Compliant			
I	Multi-poi	nt MFC Calibrations		Sem	niannually						
J	Flow Syst	em Leak Checks		Wee	ekly			\checkmark			
]	Filter Pac	k Inspection									
]	Flow Rate	e Setting Checks		Wee	ekly			\checkmark			
	Visual Ch	eck of Flow Rate Rotome	eter 🗹	Wee	ekly			\checkmark			
]	In-line Fil	ter Inspection/Replaceme	ent 🗹	Sem	niannually			\checkmark			
5	Sample Li	ine Check for Dirt/Water	•	Wee	ekly			\checkmark			
Deser	de en-	dditional aunionation (n)	hotom	ha	n alrotok if nasaa) maganding age dit	onglisted obers	n one other features		

Field Systems Data Form

ALC188

F-02058-1500-S10-rev002

Site ID

Techni

Technician Martin Valvur

Site Visit Date 02/25/2019

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	373MC12	07006
DAS	Campbell	CR3000	2523	000422
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	0493002475	02976
Flow Rate	Apex	AXMC105LPMDPC	illegible	000683
Infrastructure	Infrastructure	none	none	none
Modem	Raven	H4223-C	08443555843	06583
Ozone	ThermoElectron Inc	49i A1NAA	1105347310	000745
Ozone Standard	ThermoElectron Inc	49i A3NAA	1030244815	000694
Sample Tower	Aluma Tower	В	none	000136
Shelter Temperature	Campbell	107-L	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342	8894	04942
Zero air pump	Werther International	C 70/4	000815254	06878

Site Inventory by Site Visit

Site	Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
BBE	401-Martin	v Valvur-02/27/2019				
1	2/27/2019	Computer	Hewlett Packard	none	6730b	CNU9335N72
2	2/27/2019	DAS	Environmental Sys Corp	90767	8816	4592
3	2/27/2019	Elevation	Elevation	None	1	None
4	2/27/2019	Filter pack flow pump	Thomas	none	107CA18	0688001784
5	2/27/2019	Flow Rate	Alicat	none	Unknown	Unknown
6	2/27/2019	Infrastructure	Infrastructure	none	none	none
7	2/27/2019	Mainframe	Climatronics	01847	100081	1426
8	2/27/2019	Mainframe power supply	Climatronics	none	101074	unknown
9	2/27/2019	Modem	US Robotics	none	56k	22SBB9FA71K4
10	2/27/2019	Ozone	ThermoElectron Inc	90517	49C	49C-58468-318
11	2/27/2019	Ozone Standard	ThermoElectron Inc	90831	49C	0520012325
12	2/27/2019	Printer	Hewlett Packard	none	842C	unknown
13	2/27/2019	Sample Tower	Aluma Tower	none	В	AT-5381-F9-1
14	2/27/2019	Shelter Temperature	ARS	none	none	none
15	2/27/2019	Siting Criteria	Siting Criteria	None	1	None
16	2/27/2019	Temperature2meter	RM Young	none	41342VC	14961
17	2/27/2019	Zero air pump	Twin Tower Engineering	none	TT70/4E	526293

DAS Data Form

DAS Time Max Error: 1.85

Mfg	Serial	Number Site	e I	echnician	Site Visit Date	Parameter	Use Desc.			
Environmenta	al Sys 4592	BB	E401	Martin Valvur	02/27/2019	DAS	Primary			
Das Date:	2 /27/2019	Audit Date	2 /27/2019	Mfg	HY	Parameter	DAS			
Das Time: Das Day:	58	Audit Time Audit Day	58	Serial Number	12010039329	Tfer Desc.	Source generator (D			
Low Channe	d:	High Channe	el:	Tfer ID	01322					
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:	Slope	1.0000	0 Intercept	0.00000			
0.000	1 0.0	0.000	1 0.0003	Cert Date	6/15/201	4 CorrCoff	1.00000			
				Mfg	Fluke	Parameter	DAS			
				Serial Number	95740243	95740243 Tfer Desc. DVM				
				Tfer ID	01312					
				Slope	1.0000	0 Intercept	0.00000			
				Cert Date	1/25/201	9 CorrCoff	1.00000			
Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference				
14	0.0000	-0.0003	-0.0003	V	V	0.0000				
14	0.1000	0.0999	0.0997	V	V	-0.0002				
14	0.3000	0.2998	0.2999	V	V	0.0001				
14	0.5000	0.5001	0.4998	V	V	-0.0003				
14	0.7000	0.7000	0.7002	V	V	0.0002				
14	0.9000	0.8999	0.9000	V	V	0.0001				
14	1.0000	1.0000	1.0001	V	V	0.0001				

Flow Data Form

Mfg	fg Serial Number Ta Site		Тес	chnician	Site Visit D	ate Paran	neter	Owner ID	
Alicat	Unknown		BBE401	Ma	artin Valvur	02/27/2019	Flow R	late	none
					Mfg	BIOS	P	arameter Flow	v Rate
					Serial Number	122974	Т	fer Desc. BIO	S 220-H
					Tfer ID	01416			
					Slope	1.0	0178 Int	ercept	0.00161
					Cert Date	7/13	/2018 Co	rrCoff	1.00000
DAS 1:		DAS 2:		L	Cal Factor Z	ero	0.01	16	
A Avg % Diff:	A Max % Di	A Avg %	Dif A Max	x % Di	Cal Factor F	ull Scale	5.01	17	
0.69%	0.81%				Rotometer R	eading:	3	.3	
Desc.	Test type	Input l/n	n Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignall	PctDifference
primary	pump off	0.000	0.000	-0.03	0.0000	0.02	l/m	l/m	
primary	leak check	0.000	0.000	-0.01	0.0000	0.02	l/m	l/m	
primary	test pt 1	2.983	2.980	2.99	0.0000	3.00	l/m	l/m	0.81%
primary	test pt 2	2.984	2.980	2.99	0.0000	3.00	l/m	l/m	0.77%
primary	test pt 3	2.997	2.990	2.99	0.0000	3.01	l/m	l/m	0.50%
Sensor Compo	onent Leak Tes	t		Conditio	n		Status	pass	
Sensor Compo	onent Tubing C	ondition		Conditio	n Good		Status	pass	
Sensor Compo	onent Filter Pos	sition		Conditio	n Good		Status	pass	
Sensor Compo	onent Rotomete	er Conditic	n	Conditio	n Clean and dry		Status	pass	
Sensor Compo	onent Moisture	Present		Conditio	n No moisture p	resent	Status	pass	
Sensor Compo	onent Filter Dis	tance		Conditio	n 6.0 cm		Status	pass	
Sensor Compo	onent Filter Dep	oth		Conditio	n 1.0 cm		Status	pass	
Sensor Compo	onent Filter Azi	muth		Conditio	n 165 deg		Status	pass	
Sensor Compo	onent System M	/lemo		Conditio	n		Status	pass	

Ozone Data Form

Mfg	Serial Number Ta	Site	Т	echnician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	49C-58468-318	BBE40	1	lartin Valvur	02/27/2019	Ozone	90517
Slope: Intercept CorrCoff DAS 1: A Avg % Diff: A I	0.99057 Slope: 0.23958 Intercep 0.99999 CorrCof DAS 2 Max % Di A Avg	t(f(: %Dif A	0.00000 0.00000 0.00000 Max % Di	Mfg Serial Number Tfer ID Slope	ThermoElectron 49CPS-70008-3 01110 1.0015	Inc Parame 364 Tfer De 51 Intercept	eter ozone esc. Ozone primary stan 0.00666
0.0%	0.0%			Cert Date	10/30/20	o CorrCoff	1.00000
UseDescription primary primary primary primary primary	ConcGroup T 1 2 3 4 5 5	fer Raw 0.30 16.31 35.71 65.23 116.90	Tfer Corr 0.29 16.27 35.64 65.12 116.71	Site 0.85 16.05 35.43 64.79 115.90	Site Unit ppb ppb ppb ppb ppb	RelPerDif -0.5 -0.5 -0.5	AbsDif 0.56 -0.22 9 1 7
Sensor Compone	ent Sample Train		Conditi	ion Good		Status pass	;
Sensor Compone	ent 22.5 degree rule		Conditi	ion		Status pass	;
Sensor Compone	ent Inlet Filter Condi	tion	Conditi	ion Clean		Status pass	;
Sensor Compone	ent Battery Backup		Conditi	ion N/A		Status pass	;
Sensor Compone	ent Offset		Conditi	ion 0.10		Status pass	;
Sensor Compone	ent Span		Conditi	ion 0.995		Status pass	3
Sensor Compone	ent Zero Voltage		Conditi	ion 0.0015		Status pass	3
Sensor Compone	ent Fullscale Voltage)	Conditi	ion 1.0018		Status pass	\$
Sensor Compone	ent Cell A Freq.		Conditi	ion 101.3 kHz		Status pass	\$
Sensor Compone	ent Cell A Noise		Conditi	ion 0.5 ppb		Status pass	\$
Sensor Compone	Cell A Flow		Conditi	ion 0.58 lpm		Status pass	\$
Sensor Compone	ent Cell A Pressure		Conditi	ion 661.3 mmHg		Status pass	\$
Sensor Compone	ent Cell A Tmp.		Conditi	ion 36.8 C		Status pass	\$
Sensor Compone	ent Cell B Freq.		Conditi	ion 85.7 kHz		Status pass	\$
Sensor Compone	ent Cell B Noise		Conditi	ion 0.4 ppb		Status pass	;
Sensor Compone	Cell B Flow		Conditi	ion 0.60 lpm		Status pass	3
Sensor Compone	ent Cell B Pressure		Conditi	ion 661.2 mmHg		Status pass	;
Sensor Compone	ent Cell B Tmp.		Conditi	ion N/A		Status pass	3
Sensor Compone	ent Line Loss		Conditi	ion Not tested		Status pass	3
Sensor Compone	ent System Memo		Conditi	ion		Status pass	;

2 Meter Temperature Data Form

Calc. Difference

Mfg	Se	erial Numbe	r Ta Site		Те	chnicia	in	Site Vis	sit Date	Paramet	er	Owner ID
RM Young	1	4961	BBE40	1	Ма	artin Va	alvur	02/27/2	2019	Temperat	ure2meter	none
						Mfg		Fluke		Par	ameter Tem	perature
						Serial	Number	327514	3	Tfe	Desc. RTD	1
						Tfer I	D	01229]		
DAS 1:		DA	AS 2:			Slope			0.99989	Interc	ept	-0.00649
Abs Avg Err	Abs M	lax Er Ab	os Avg Err A	Abs Max E	2 r	Cert l	Date		1/23/2019	O Corr(Coff	1.00000
0.26		0.29										
UseDescription	Г	Test type	InputTmpRav	/ InputTn	npCorr	rected	OutputTm	pSignal	OutputS	ignalEng	OSE Unit	Difference
primary	Temp	b Low Rang	0.0	9		0.10		0.0000		0.37	С	0.27
primary	Temp	o Mid Rang	25.0	8		25.09		0.0000		25.38	С	0.29
primary	Temp	o High Rang	47.3	5		47.36		0.0000		47.57	С	0.21
Sensor Compo	nent	Properly Site	d	Co	onditio	n Pro	perly sited			Status P	ass	
Sensor Compo	nent	Shield		Co	onditio	n Clea	an			Status P	ass	
Sensor Compo	nent	Blower		Co	onditio	n Fun	ctioning			Status P	ass	
Sensor Component Blower Status Switch		Co	Condition N/A			Status pass		ass				
Sensor Component S		System Men	וס	Co	onditio	on				Status P	ass	

Shelter Temperature Data For

Mfg	Serial Number Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
ARS	none	BBE401	Martin Valvur	02/27/2019	Shelter Temperature	none
DAS 1:	DAS 2:		Mfg	Fluke	Parameter She	Iter Temperatur
Abs Avg Err A 0.66	Abs Max Er Abs Avg 1.08	Err Abs Max Er	Serial Number	3275143	Tfer Desc. RTD)
			Tfer ID	01229		
			Slope	0.9998	9 Intercept	-0.00649
			Cert Date	1/23/201	9 CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	17.78	17.79	0.000	18.9	С	1.08
primary	Temp Mid Range	20.30	20.31	0.000	19.8	С	-0.54
primary	Temp Mid Range	21.68	21.69	0.000	22.0	С	0.35
Sensor Component System Memo			Condition	status pass			

Infrastructure Data For

Site ID	BBE401	Technician Martin	Valvur Site Visit Date 02/27/2019
Shelter	Make	Shelter Model	Shelter Size
Ekto		8814	896 cuft

Sensor Component	Sample Tower Type	Condition	Туре В	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Good	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass
Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample line is leak tested every two weeks when the inlet filter is replaced.

2 Parameter: ShelterCleanNotes

The shelter is clean, neat, and well organized.

3 Parameter: MetSensorComme

The two meter temperature sensor has been moved from 1.6 to 2.0 meters above the ground.

4 Parameter: MetOpMaintCom

The signal cables have been replaced since the previous audit visit.

F-02058-1500-S1-rev002

Site ID BBE401	Technician Martin Valvur	Site Visit Date 02/2	7/2019	
		UCCO Mart	Donthor Junction	
Site Sponsor (agency)	NPS/EPA	USGS Map		
Operating Group	NPS	Map Scale		
AQS #	48-043-0101	Map Date		
Meteorological Type	Climatronics			
Air Pollutant Analyzer	Ozone, IMPROVE, PM2.5	QAPP Latitude	29.3022	
Deposition Measurement	dry, wet	QAPP Longitude	-103.1772	
Land Use	desert	QAPP Elevation Meters	1052	
Terrain	complex	QAPP Declination		
Conforms to MLM	Marginally	QAPP Declination Date		
Site Telephone	(432) 477-2258	Audit Latitude	29.302651	
Site Address 1	K-Bar Ranch	Audit Longitude	-103.177813	
Site Address 2	Big Bend National Park	Audit Elevation	1057	
County	Brewster	Audit Declination	7.0	
City, State	Big Bend National Park, TX	Present		
Zip Code	79834	Fire Extinguisher 🔽	Inspected April 2018	
Time Zone	Central	First Aid Kit		
Primary Operator		Safety Glasses		
Primary Op. Phone #		Safety Hard Hat		
Primary Op. E-mail		Climbing Belt		
Backup Operator		Security Fence		
Backup Op. Phone #		Secure Shelter		
Backup Op. E-mail		Stable Entry Step 🔽		
Shelter Working Room ✓	Make Ekto M	odel 8814	Shelter Size 896 cuft	
Shelter Clean	Notes The shelter is clean, neat, and	well organized.		
Site OK	Notes			
Driving Directions From Nation near t and c Station	interstate 10 in Fort Stockton, turn south nal Park. Continue on the park road past he visitor center. Turn left (east) and con ontinue approximately 0.5 miles. Turn rig n (old house) on the right. The site is 400	on highway 385 and drive appro the entrance station 26 miles to tinue approximately 2.5 miles. ht on the service road just past meters at the end of the road.	oximately 120 miles to Big Bend the stop sign at Panther Junction Turn left on the dirt road marked K-Bar the Chihuahuan Desert Research	

BBE401

F-02058-1500-S2-rev002

Site ID

Technician Martin Valvur

Site Visit Date 02/27/2019

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		✓
Major industrial complex	10 to 20 km		\checkmark
City > 50,000 population	40 km		\checkmark
City 10,000 to 50,000 population	10 km		\checkmark
City 1,000 to 10,000 population	5 km		\checkmark
Major highway, airport or rail yard	2 km		\checkmark
Secondary road, heavily traveled	500 m		\checkmark
Secondary road, lightly traveled	200 m		\checkmark
Feedlot operations	500 m		\checkmark
Intensive agricultural ops (including aerial spraying)	500 m		\checkmark
Limited agricultural operations	200 m		\checkmark
Large parking lot	200 m		\checkmark
Small parking lot	100 m		\checkmark
Tree line	50 m		\checkmark
Obstacles to wind	10 times obstacle height		\checkmark

Siting Distances OK

Siting Criteria Comment

Fi	eld Systems Data Form		F-02058-1500-S3-rev00				
Site	BBE401 Technician Martin Valvur		Site Visit Date 02/27/2019				
1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	✓	N/A				
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)		N/A				
3	Are the tower and sensors plumb?	✓	N/A				
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?	✓					
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)						
6	Is the solar radiation sensor plumb?	✓	N/A				
7	Is it sited to avoid shading, or any artificial or reflected light?	✓	N/A				
8	Is the rain gauge plumb?	✓	N/A				
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	✓	N/A				
10	Is the surface wetness sensor sited with the grid surface facing north?	✓	N/A				
11	Is it inclined approximately 30 degrees?	✓	N/A				
Pro nat	wide any additional explanation (photograph or sketch if neco ural or man-made, that may affect the monitoring parameter	essar s:	y) regarding conditions listed above, or any other features,				

The two meter temperature sensor has been moved from 1.6 to 2.0 meters above the ground.

F-02058-1500-S4-rev002

Site	e ID	BBE401	Technician	Martin Valvur		Site Visit Date 02/27/2019
1	Do all th	e meterological senso	rs appear to be	intact, in good		Temperature only
2	Are all the reporting	i, and wen maintaine ie meteorological sen g data?	sors operationa	l online, and		Temperature only
3	Are the s	hields for the temper	ature and RH s	ensors clean?	✓	Temperature only
4	Are the a	aspirated motors wor	king?			
5	Is the sol scratches	ar radiation sensor's s?	lens clean and f	ree of	✓	N/A
6	Is the su	rface wetness sensor g	grid clean and u	indamaged?	✓	N/A
7 8	Are the s condition Are the s from the	eensor signal and pow n, and well maintaine eensor signal and pow elements and well ma	rer cables intact d? rer cable connec aintained?	, in good tions protected	✓	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The signal cables have been replaced since the previous audit visit.

Fi	eld Sy	stems Data Fo	orm			F-02058-1500-S5-rev002	ŗ
Site	e ID	BBE401	Technician	Martin Valvur		Site Visit Date 02/27/2019	
	<u>Siting C</u>	riteria: Are the pollut	ant analyzers a	nd deposition eq	<u>uipr</u>	pment sited in accordance with 40 CFR 58, Appendix E	
1	Do the s unrestri	ample inlets have at le cted airflow?	east a 270 degre	e arc of]
2	Are the	sample inlets 3 - 15 mo	eters above the	ground?	✓		_
3	Are the and 20 n	sample inlets > 1 mete neters from trees?	r from any maj	or obstruction,			_
	<u>Pollutan</u>	t analyzers and depos	ition equipmen	t operations and	mai	aintenance	
1	Do the a conditio	nalyzers and equipme n and well maintained	ent appear to be ?	in good	✓]
2	Are the reportin	analyzers and monitor g data?	rs operational, o	on-line, and			
3	Describe	e ozone sample tube.				1/4 teflon by 12 meters	
4	Describe	e dry dep sample tube.				1/2 teflon by 12 meters	_
5	Are in-li indicate	ine filters used in the o location)	zone sample lin	ne? (if yes		At inlet only	_
6	Are sam obstruct	ple lines clean, free of ions?	kinks, moistur	e, and			
7	Is the ze	ro air supply desiccan	t unsaturated?		✓		
8	Are then	re moisture traps in th	e sample lines?				
9	Is there clean?	a rotometer in the dry	deposition filte	er line, and is it		Clean and dry	_

Fi	eld Sy	stems Data F	orm				F-0 2	2058-15	00-S6-rev002
Site	e ID	BBE401	Technician	Martin Valvur		Site Visit Date	02/27/2019	9	
	DAS, se	nsor translators, and	peripheral equi	pment operatio	ns ai	nd maintenance			
1	Do the l well ma	DAS instruments appe intained?	ear to be in good	l condition and					
2	Are all t modem,	the components of the backup, etc)	DAS operation	al? (printers,	✓				
3	Do the a lightnin	analyzer and sensor si g protection circuitry	gnal leads pass † ?	through	✓	Met sensors only			
4	Are the well ma	signal connections pro intained?	otected from the	e weather and	✓				
5	Are the	signal leads connected	d to the correct	DAS channel?	✓				
6	Are the grounde	DAS, sensor translate ed?	ors, and shelter	properly	✓				
7	Does the	e instrument shelter h	ave a stable pov	ver source?	✓				
8	Is the in	strument shelter temj	perature control	lled?					
9	Is the m	et tower stable and g	counded?			Stable		Grounded	
10	Is the sa	mple tower stable and	d grounded?						
11	Tower o	comments?							

Fiel	d Sy	stems Data	Fo	rm					F-0 2	.058-	-1500-S7-rev	002
Site I	D	BBE401		Tech	nician	Martin Valv	ur	Site Visit Date	02/27/2019)		
Do	<u>cumen</u>	tation										
Do	es the s	site have the requi	red in	strum	ent and	equipment	manuals?					
		_	Yes	No	N/ .	A			Yes	No	N/A	
Wind	speed	sensor			✓		Data logger	r				
Wind	direct	ion sensor			✓		Data logger	r				
Temp	eratur	e sensor					Strip chart	recorder				
Relati	ve hun	nidity sensor			\checkmark		Computer					
Solar	radiati	ion sensor			\checkmark		Modem			\checkmark		
Surfa	ce weti	iess sensor			\checkmark		Printer					
Wind	sensor	translator			\checkmark		Zero air pu	ımp				
Temp	eratur	e translator			\checkmark		Filter flow	pump				
Humi	dity se	nsor translator			\checkmark		Surge prote	ector				
Solar	radiati	ion translator			\checkmark		UPS					
Tippiı	ng buc	ket rain gauge			\checkmark		Lightning p	protection device				
Ozone	e analy	zer					Shelter hea	ter				
Filter	pack f	low controller					Shelter air	conditioner		\checkmark		
Filter	pack N	AFC power supply	7		✓							
D	oes the	site have the requ	ired a	und mo	ost rece	nt QC docu	ments and	<u>report forms?</u>				
			Pres	sent					Curre	ent		
Statio	n Log		[✓	Datavie	W			\checkmark			
SSRF			[✓					\checkmark			
Site O	ps Ma	nual	[✓					\checkmark			
HASP	•		[
Field	Ops M	anual	[
Calib	ration 1	Reports	[✓	Electro	nic copy			\checkmark			
Ozone	e z/s/p	Control Charts	[
Preve	ntive n	naintenance sched	ul (
1 I	s the st	ation log properly	comp	oleted	during	every site v	isit? ☑ Da	ataview				
2 A c	Are the urrent	Site Status Repor ?	t Forn	ns beiı	ng comj	pleted and	✓ Floor	ow and observatio	on sections			
3 A s	Are the ample	chain-of-custody transfer to and fro	forms om lab	prope ?	rly use	d to docume	ent 🗸					
4 A c	Are ozo urrent	ne z/s/p control ch ?	arts p	roper	y comp	oleted and	Co	ontrol charts not u	sed			
Provio natura	de any al or m	additional explana aan-made, that ma	ation (y affeo	photo ct the	graph o nonito	or sketch if a ring paramo	necessary) i eters:	regarding condit	ions listed	above,	or any other feature	es,

BBE401 Technician Martin Valvur Site Visit Date 02/27/2019 Site ID Site operation procedures Has the site operator attended a formal CASTNET training 1 course? If yes, when and who instructed? 2 Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed? Is the site visited regularly on the required Tuesday ✓ 3 schedule? \checkmark Are the standard CASTNET operational procedures being 4 flollowed by the site operator? Is the site operator(s) knowledgeable of, and able to perform 5 the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed

Frequency

Multipoint Calibrations	\checkmark	Semiannually
Visual Inspections	\checkmark	Weekly
Translator Zero/Span Tests (climatronics)	\checkmark	Weekly
Manual Rain Gauge Test	\checkmark	N/A
Confirm Reasonableness of Current Values	\checkmark	Weekly
Test Surface Wetness Response	\checkmark	N/A

Frequency

Are regular operational QA/QC checks performed on the ozone analyzer?

 \checkmark

✓

 \checkmark

~

V

~

 \checkmark

QC Check Performed

Multi-point Calibrations
Automatic Zero/Span Tests
Manual Zero/Span Tests
Automatic Precision Level Tests
Manual Precision Level Test
Analyzer Diagnostics Tests
In-line Filter Replacement (at inlet)
In-line Filter Replacement (at analyze
Sample Line Check for Dirt/Water
Zero Air Desiccant Check

- Do multi-point calibration gases go through the complete 1 sample train including all filters?
- Do automatic and manual z/s/p gasses go through the 2 complete sample train including all filters?

3	Are the automatic and manual z/s/p checks monitored and
	reported? If yes, how?

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

✓

✓

The ozone sample line is leak tested every two weeks when the inlet filter is replaced.

Compliant

Compliant

 \checkmark

 \checkmark

 \checkmark

 \checkmark

✓

 \checkmark

 \checkmark

 \checkmark \checkmark

 \checkmark

 \checkmark

 \checkmark

 \checkmark

 \checkmark

Semiannually	
Daily	
Monthly	
Daily	
Monthly	
Alarm values only	
Every 2 weeks	
N/A	

Unknown

Dataview

F-02058-1500-S8-rev002

Field Systems Data Form							F-02058-1500-S9-rev00				
Sit	e ID	BBE401	Technici	chnician Martin Valvur			Site Visit Date	02/27/2019			
	<u>Site ope</u>	ration procedures									
1	Is the fi	lter pack being changed	every Tue	esd	ay as scheduled		Filter changed morir	nings (90%)			
2	Are the correctl	Site Status Report Forn y?	ns being c	om	pleted and filed						
3	Are dat schedul	a downloads and backuj ed?	ps being p	erf	ormed as		No longer required				
4	Are gen	eral observations being	made and	re	corded? How?	✓	SSRF				
5	Are site supplies on-hand and replenished in a timely fashion?										
6	Are san	ple flow rates recorded	? How?			✓	SSRF				
7	Are san fashion	nples sent to the lab on a ?	regular s	che	dule in a timely	✓					
8	Are filte and shij	ers protected from conta pping? How?	mination	du	ring handling	✓	Clean gloves on and	d off			
9	Are the operation	site conditions reported ons manager or staff?	regularly	to	the field						
QC	Check P	erformed	I	re	quency			Compliant			
I	Multi-poi	nt MFC Calibrations	✓ 5	Sen	niannually						
I	Flow System Leak Checks							\checkmark			
1	Filter Pack Inspection										
I	Flow Rate Setting Checks Veekly							\checkmark			
	Visual Check of Flow Rate Rotometer Weekly							\checkmark			
]	n-line Fil	ter Inspection/Replacem	nent 🗹 🗧	Sen	niannually			\checkmark			
5	Sample Li	ine Check for Dirt/Wate	r 🗆								
-					1 . 1 . 0						

BBE401

F-02058-1500-S10-rev002

Site ID

Techni

Technician Martin Valvur

Site Visit Date 02/27/2019

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Hewlett Packard	6730b	CNU9335N72	none
DAS	Environmental Sys Corp	8816	4592	90767
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA18	0688001784	none
Flow Rate	Alicat	Unknown	Unknown	none
Infrastructure	Infrastructure	none	none	none
Mainframe	Climatronics	100081	1426	01847
Mainframe power supply	Climatronics	101074	unknown	none
Modem	US Robotics	56k	22SBB9FA71K4	none
Ozone	ThermoElectron Inc	49C	49C-58468-318	90517
Ozone Standard	ThermoElectron Inc	49C	0520012325	90831
Printer	Hewlett Packard	842C	unknown	none
Sample Tower	Aluma Tower	В	AT-5381-F9-1	none
Shelter Temperature	ARS	none	none	none
Siting Criteria	Siting Criteria	1	None	None
Temperature2meter	RM Young	41342VC	14961	none
Zero air pump	Twin Tower Engineering	TT70/4E	526293	none

Site Inventory by Site Visit

Site V	isit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
PAL1	90-Martin	Valvur-03/01/2019				
1	3/1/2019	Computer	Dell	07056	Inspiron 15	Unknown
2	3/1/2019	DAS	Campbell	000343	CR3000	2122
3	3/1/2019	Elevation	Elevation	None	1	None
4	3/1/2019	Filter pack flow pump	Thomas	02752	107CA110	11920011905
5	3/1/2019	Flow Rate	Арех	000654	AXMC105LPMDPCV	54774
6	3/1/2019	Infrastructure	Infrastructure	none	none	none
7	3/1/2019	Modem	Raven	06808	H4223-C	0934411667
8	3/1/2019	Ozone	ThermoElectron Inc	000613	49i A1NAA	1009241783
9	3/1/2019	Ozone Standard	ThermoElectron Inc	000735	49i A3NAA	0726124696
10	3/1/2019	Sample Tower	Aluma Tower	missing	В	AT-7200-582
11	3/1/2019	Shelter Temperature	Campbell	none	107-L	10755-148
12	3/1/2019	Siting Criteria	Siting Criteria	None	1	None
13	3/1/2019	Temperature	RM Young	06303	41342VO	12542
14	3/1/2019	Zero air pump	Werther International	06922	C 70/4	000836217

DAS Data Form

DAS Time Max Error:

1
1

Mfg	Serial Nu	mber Site	ſ	Fechnician	Site Visit Date	Parameter	Use Desc.
Campbell	2122	PAL	.190	Martin Valvur	03/01/2019	DAS	Primary
Das Date:	3 /1 /2019	Audit Date	3 /1 /2019	Mfg	HY	Parameter	DAS
Das Time: Das Day:	60	Audit Time Audit Day	60	Serial Number	12010039329	Tfer Desc.	Source generator (D
Low Channel	l:	High Channel	l:	Tfer ID	01322		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:	Slope	1.0000	0 Intercept	0.00000
0.0001	0.0002	0.0001	0.0002	Cert Date	6/15/201	4 CorrCoff	1.00000
				Mfg	Fluke	Parameter	DAS
				Serial Number	95740243	Tfer Desc.	DVM
				Tfer ID	01312		
				Slope	1.0000	0 Intercept	0.00000
				Cert Date	1/25/201	9 CorrCoff	1.00000
Channel	Input D	VM Output	DAS Output	InputUnit	OutputUnit	Difference	
7	0.0000	0.0001	0.0002	2 V	V	0.0001	
7	0.1000	0.0998	0.0998	B V	V	0.0000	
7	0.3000	0.2999	0.3001	V	V	0.0002	
7	0.5000	0.4998	0.4999	V	V	0.0001	
7	0.7000	0.6993	0.6995	5 V	V	0.0002	
7	0.9000	0.8996	0.8995	5 V	V	-0.0001	
7	1.0000	0.9993	0.9995	5 V	V	0.0002	

Flow Data Form

Mfg	Serial Nun	nber Ta	Site	Тес	hnician	Site Visit D	ate Paran	neter	Owner ID
Apex	54774		PAL190	Ма	irtin Valvur	03/01/2019	Flow R	ate	000654
					Mfg	BIOS	P	arameter Flow	/ Rate
					Serial Number	122974	Т	fer Desc. BIO	S 220-H
					Tfer ID	01416			
					Slope	1.0	0178 Inte	ercept	0.00161
					Cert Date	7/13	/2018 Co	rCoff	1.00000
DAS 1:		DAS 2:		_	Cal Factor Z	ero	0.0)5	
A Avg % Diff:	A Max % Di	A Avg %	Dif A Max	: % Di	Cal Factor F	ull Scale	1.()4	
0.55%	0.66%				Rotometer R	eading:	3.1	15	
Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignall	PctDifference
primary	pump off	0.000	0.000	-0.03	0.000	0.01	l/m	l/m	
primary	leak check	0.000	0.000	0.01	0.000	0.06	l/m	l/m	
primary	test pt 1	3.030	3.020	2.97	0.000	3.00	l/m	l/m	-0.66%
primary	test pt 2	3.020	3.010	2.98	0.000	3.00	l/m	l/m	-0.33%
primary	test pt 3	3.030	3.020	2.98	0.000	3.00	l/m	l/m	-0.66%
Sensor Compo	onent Leak Tes	st		Conditio	n		Status	pass	
Sensor Compo	onent Tubing C	ondition		Conditio	n Good		Status	pass	
Sensor Compo	onent Filter Pos	sition		Conditio	n Good		Status	pass	
Sensor Compo	onent Rotomete	er Conditio	n	Conditio	n Clean and dry		Status	pass	
Sensor Compo	onent Moisture	Present		Conditio	n No moisture pr	resent	Status	pass	
Sensor Compo	onent Filter Dis	tance		Conditio	n 5.5 cm		Status	pass	
Sensor Comp	onent Filter Dep	oth		Conditio	n 0.5 cm		Status	pass	
Sensor Compo	onent Filter Azi	muth		Conditio	n 200 deg		Status	pass	
Sensor Compo	onent System M	/lemo		Conditio	n		Status	pass	

Ozone Data Form

Mfg	Serial Number	Ta Site	Тес	chnician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241783	PAL190	Ма	artin Valvur	03/01/2019	Ozone	000613
Slope: Intercept CorrCoff DAS 1:	0.99603 Slope: 0.33515 Interc 0.999999 CorrC	ept C coff C	.00000 .00000 .00000	Mfg Serial Number Tfer ID Slope	ThermoElectron 49CPS-70008-3 01110 1.0015	Inc Paramet	er ozone c. Ozone primary stan
A Avg % Diff: A I	Max % Di A A	vg %Dif A	Max % Di	Cert Date	10/30/201	8 CorrCoff	1.00000
0.0%	0.0%						
UseDescription	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif
primary	2	16.02	15.98	15.58	dad		-0.11
primary	3	36.04	35.97	35.33	ppb	-1.8	
primary	4	65.10	64.99	64.14	ppb	-1.32	
primary	5	115.89	115.70	115.10	ppb	-0.52	
Sensor Compone	ent Sample Train		Conditio	Good		Status pass	
Sensor Compone	ent 22.5 degree ru	le	Conditio	n		Status pass	
Sensor Compone	ent Inlet Filter Cor	ndition	Conditio	n Clean		Status pass	
Sensor Compone	ent Battery Backu	p	Conditio	n N/A		Status pass	
Sensor Compone	ent Offset		Conditio	n 0.40		Status pass	
Sensor Compone	ent Span		Conditio	n 1.009		Status pass	
Sensor Compone	ent Zero Voltage		Conditio	n N/A		Status pass	
Sensor Compone	ent Fullscale Volta	age	Conditio	n N/A		Status pass	
Sensor Compone	ent Cell A Freq.		Conditio	n 88.4 kHz		Status pass	
Sensor Compone	ent Cell A Noise		Conditio	n 0.6 ppb		Status pass	
Sensor Compone	ent Cell A Flow		Conditio	n 0.60 lpm		Status pass	
Sensor Compone	ent Cell A Pressu	ſe	Conditio	on 651.8 mmHg		Status pass	
Sensor Compone	ent Cell A Tmp.		Conditio	n 29.8 C		Status pass	
Sensor Compone	ent Cell B Freq.		Conditio	n 83.6 kHz		Status pass	
Sensor Compone	ent Cell B Noise		Conditio	n 0.8 ppb		Status pass	
Sensor Compone	ent Cell B Flow		Conditio	0.62 lpm		Status pass	
Sensor Compone	ent Cell B Pressu	re	Conditio	651.3 mmHg		Status pass	
Sensor Compone	ent Cell B Tmp.		Conditio	n N/A		Status pass	
Sensor Compone	ent Line Loss		Conditio	Not tested		Status pass	
Sensor Compone	ent System Memo)	Conditio	on		Status pass	

Temperature Data Form

Mfg	Serial Number	Fa Site	I	echni	ician	Site V	isit Date	Param	eter	Owner ID
RM Young	12542	PAL190		Martin	Valvur	03/01	1/2019	Temper	rature	06303
				Mf	g	Fluke		Ра	arameter Te	emperature
				Ser	ial Number	32751	143	Tf	fer Desc. R	٢D
				Tfe	er ID	01229)			
DAS 1.	DAS	2.		Slo	pe		0.9998	9 Inte	rcept	-0.00649
Abs Avg Err	Abs Max Er Abs	Avg Err Abs	Max Er	Ce	rt Date		1/23/201	9 Cor	rCoff	1.00000
0.03	0.04									
UseDesc.	Test type	InputTmpRaw	InputTmp	Corr.	OutputTmpS	Signal	OutputSig	gnalEng	OSE Unit	Difference
primary '	Temp Low Range	0.11	0.12		0.000		0.1	l	С	-0.04
primary '	Temp Mid Range	23.39	23.40		0.000		23.	4	С	-0.02
primary 7	Temp High Range	46.64	46.65		0.000		46.	6	C	-0.04
Sensor Comj	ponent Shield		Condit	tion	Clean			Status	pass	
Sensor Comj	ponent Blower		Condi	tion N	I/A			Status	pass	
Sensor Comj	ponent Blower Status	Switch	Condit	tion N	I/A			Status	pass	
Sensor Comj	ponent System Memo		Condit	tion				Status	pass	

Shelter Temperature Data For

Mfg	Serial Number Ta	Site	Technician	Site Visit Date	Parameter	Owner ID
Campbell	10755-148	PAL190	Martin Valvur	03/01/2019	Shelter Temperature	none
DAS 1:	DAS 2:		Mfg	Fluke	Parameter She	Iter Temperatur
Abs Avg ErrA1.66	Abs Max Er Abs Avg 1.99	Err Abs Max Er	Serial Number	3275143	Tfer Desc. RTD)
			Tfer ID	01229		
			Slope	0.9998	9 Intercept	-0.00649
			Cert Date	1/23/201	9 CorrCoff	1.00000

UseDesc.	Test type	InputTmpRaw	InputTmpCorr.	OutputTmpSignal	OutputSignalEng	OSE Unit	Difference
primary	Temp Mid Range	22.00	22.01	0.000	24.0	С	1.99
primary	Temp Mid Range	25.65	25.66	0.000	24.1	С	-1.55
primary	Temp Mid Range	25.35	25.36	0.000	23.9	С	-1.45
Sensor Component System Memo Condition Status pass							

Infrastructure Data For

Site ID	PAL190	Technician Martin V	alvur Site Visit Date 03/01/2019
Shelter 1	Make	Shelter Model	Shelter Size
Shelter C	Dne	E-8109-26012-2	720 cuft
A CONTRACTOR OF THE OWNER			

Sensor Component	Sample Tower Type	Condition	Туре В	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	N/A	Status	pass
Sensor Component	Moisture Trap	Condition	Installed	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Good	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Good	Status	pass
Sensor Component	Shelter Floor	Condition	Good	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is located 40 km southeast of Amarillo TX which has a population of approximately 178,000.

3 Parameter: ShelterCleanNotes

The shelter is in good condition.

4 Parameter: MetSensorComme

The meteorological tower and sensors have been removed.

F-02058-1500-S1-rev002

Site ID PAL190	Technician Martin Valvur	Site Visit Date 03/0	1/2019
GH G (())		USCS Man	Fortress Cliff
Site Sponsor (agency)			
Operating Group	TX A&M University	Map Scale	
AQS #	48-381-9991	Map Date	
Meteorological Type	R.M. Young		
Air Pollutant Analyzer	Ozone	QAPP Latitude	
Deposition Measurement	dry, wet	QAPP Longitude	
Land Use	agriculture	QAPP Elevation Meters	
Terrain	Complex	QAPP Declination	
Conforms to MLM	Marginally	QAPP Declination Date	
Site Telephone		Audit Latitude	34.88061
Site Address 1		Audit Longitude	-101.664703
Site Address 2		Audit Elevation	1053
County	Randall	Audit Declination	6.6
City, State	Canyon, TX	Present	
Zip Code	79015	Fire Extinguisher 🔽	No inspection date
Time Zone	Central	First Aid Kit	
Primary Operator		Safety Glasses	
Primary Op. Phone #		Safety Hard Hat	
Primary Op. E-mail		Climbing Belt	
Backup Operator		Security Fence	
Backup Op. Phone #		Secure Shelter	
Backup Op. E-mail		Stable Entry Step 🔽	
Shelter Working Room ✓	Make Shelter One M	odel E-8109-26012-2	Shelter Size 720 cuft
Shelter Clean	Notes The shelter is in good condition	on.	
Site OK	Notes		
Driving Directions From dirt ros Pullma buildir	I27 take exit 99 and go east on Hungate ad. At the next intersection turn left (east an. Continue and follow sharp right turn ng. Site will be visible on the left.	road to the first stop sign. Turn) on Lawrence (also dirt). Cont onto game lands. Continue thro	right (south) onto Eastern which is a inue and follow sharp left turn onto bugh two gates and past storage

PAL190

F-02058-1500-S2-rev002

Site ID

Technician Martin Valvur

Site Visit Date 03/01/2019

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		✓
Major industrial complex	10 to 20 km		\checkmark
City > 50,000 population	40 km		\checkmark
City 10,000 to 50,000 population	10 km		\checkmark
City 1,000 to 10,000 population	5 km		\checkmark
Major highway, airport or rail yard	2 km		\checkmark
Secondary road, heavily traveled	500 m		\checkmark
Secondary road, lightly traveled	200 m		\checkmark
Feedlot operations	500 m		\checkmark
Intensive agricultural ops (including aerial spraying)	500 m		\checkmark
Limited agricultural operations	200 m		\checkmark
Large parking lot	200 m		\checkmark
Small parking lot	100 m		\checkmark
Tree line	50 m		\checkmark
Obstacles to wind	10 times obstacle height		

Siting Distances OK

Siting Criteria Comment

The site is located 40 km southeast of Amarillo TX which has a population of approximately 178,000.

Fi	eld Systems Data Form	F-02058-1500-S3-rev00				
Site	PAL190 Technician Martin Valvur	Site Visit Date 03/01/2019				
1	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?	✓ N/A				
2	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)	✓ N/A				
3	Are the tower and sensors plumb?	✓ N/A				
4	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?					
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)					
6	Is the solar radiation sensor plumb?	✓ N/A				
7	Is it sited to avoid shading, or any artificial or reflected light?	✓ N/A				
8	Is the rain gauge plumb?	✓ N/A				
9	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?	✓ N/A				
10	Is the surface wetness sensor sited with the grid surface facing north?	✓ N/A				
11	Is it inclined approximately 30 degrees?	☑ N/A				

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features natural or man-made, that may affect the monitoring parameters:

The meteorological tower and sensors have been removed.

F-02058-1500-S4-rev002

Site	ID	PAL190	Technician	Martin Valvur		Site Visit Date	03/01/2019	
 Do all the meterological sensors appear to be intact, in good condition, and well maintained? Are all the meteorological sensors operational online, and reporting data? 						Temperature only Temperature only		
3	3 Are the shields for the temperature and RH sensors clean?							
4	Are the aspirated motors working?					N/A		
5	5 Is the solar radiation sensor's lens clean and free of scratches?				✓	N/A		
6	Is the su	rface wetness sensor g	grid clean and u	indamaged?	✓	N/A		
7 8	Are the s condition Are the s from the	sensor signal and pow n, and well maintained sensor signal and pow elements and well ma	er cables intact d? er cable connec aintained?	, in good ctions protected	✓			

Fi	eld Systems Data Form		F-02058-1500-S5-rev002
Site	ID PAL190 Technician Martin Valvur		Site Visit Date 03/01/2019
	Siting Criteria: Are the pollutant analyzers and deposition e	quipi	nent sited in accordance with 40 CFR 58, Appendix E
1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	✓	
2	Are the sample inlets 3 - 15 meters above the ground?	✓	
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	✓	
	Pollutant analyzers and deposition equipment operations and	d ma	intenance
1	Do the analyzers and equipment appear to be in good condition and well maintained?	✓	
2	Are the analyzers and monitors operational, on-line, and reporting data?	✓	
3	Describe ozone sample tube.		1/4 teflon by 15 meters
4	Describe dry dep sample tube.		3/8 teflon by 15 meters
5	Are in-line filters used in the ozone sample line? (if yes indicate location)	✓	At inlet only
6	Are sample lines clean, free of kinks, moisture, and obstructions?	✓	
7	Is the zero air supply desiccant unsaturated?	✓	
8	Are there moisture traps in the sample lines?	✓	Flow line only
9	Is there a rotometer in the dry deposition filter line, and is it clean?	✓	Clean and dry

Fi	eld Sy	stems Data Fo	orm				F-0 2	2058-15	00-S6-rev002
Site	e ID	PAL190	Technician	Martin Valvur		Site Visi	it Date 03/01/201	9	
	<u>DAS, se</u>	nsor translators, and p	peripheral equi	pment operation	ns an	<u>d maintena</u>	nce		
1	Do the I well mai	DAS instruments appeart	ar to be in good	l condition and					
2	Are all t modem,	he components of the backup, etc)	DAS operation	al? (printers,					
3	Do the a lightnin	nalyzer and sensor sig g protection circuitry?	gnal leads pass	through					
4	Are the well mai	signal connections pro intained?	otected from the	e weather and					
5	Are the	signal leads connected	to the correct	DAS channel?					
6	Are the grounde	DAS, sensor translato cd?	rs, and shelter	properly					
7	Does the	e instrument shelter ha	ave a stable pov	ver source?					
8	Is the in	strument shelter temp	erature contro	lled?					
9	Is the m	et tower stable and gr	ounded?			Stable		Grounded	
10	Is the sa	mple tower stable and	grounded?						
11	Tower c	omments?			-	✓ met tower re	moved		

Field Sys	stems Data			F-02058-1500-						
Site ID	PAL190		Technic	cian	Martin Valvur	Site Visit Date	03/01/2019)		
Document a	<u>ntion</u>									
Does the sit	te have the requir	ed ins	strument	and	equipment manuals?					
Wind speed so Wind directio	ensor n sensor	Yes	No	N//	A Data logge Data logge	er	Yes	No ✓	N/A □ ☑	
Temperature Relative humi	sensor dity sensor				Strip char Computer	t recorder				
Solar radiatio Surface wetne	n sensor ess sensor			 	Modem Printer					
Wind sensor t Temperature	ranslator translator			 <td>Zero air p Filter flow</td><td>ump 7 pump teater</td><td>✓</td><td></td><td></td><td></td>	Zero air p Filter flow	ump 7 pump teater	✓			
Solar radiatio	n translator et rain gauge			 <td>UPS Lightning</td><td>protection device</td><td></td><td></td><td></td><td></td>	UPS Lightning	protection device				
Ozone analyze Filter pack flo	er ow controller	✓ ✓			Shelter he Shelter air	ater conditioner	✓			
Filter pack M <u>Does the s</u>	FC power supply site have the requi	red a	nd most	✓ rece	nt QC documents and	report forms?				

	Present		Current
Station Log			
SSRF	\checkmark		
Site Ops Manual	\checkmark	Oct 2014	
HASP	\checkmark	Oct 2014	
Field Ops Manual		Oct 2014	
Calibration Reports	\checkmark	Electronic copy	
Ozone z/s/p Control Charts			
Preventive maintenance schedu	l 🗌		

1

2

3

4

Is the station log properly completed during every site visit?	✓	
Are the Site Status Report Forms being completed and current?	✓	
Are the chain-of-custody forms properly used to document sample transfer to and from lab?	✓	
Are ozone z/s/p control charts properly completed and current?		Control charts not used

PAL190 Site Visit Date 03/01/2019 Site ID Technician Martin Valvur Site operation procedures Trained by AMEC Has the site operator attended a formal CASTNET training 1 course? If yes, when and who instructed? 2 Has the backup operator attended a formal CASTNET Trained on site by MACTEC during site installation \checkmark training course? If yes, when and who instructed? Is the site visited regularly on the required Tuesday ✓ 3 schedule? \checkmark 4 Are the standard CASTNET operational procedures being flollowed by the site operator? Is the site operator(s) knowledgeable of, and able to perform 5 the required site activities? (including documentation)

Are regular operational QA/QC checks performed on meteorological instruments?

QC Cho	eck Per	rformed
--------	---------	---------

Frequency

Multipoint Calibrations	\checkmark	Semiannually	\checkmark
Visual Inspections	\checkmark	Weekly	✓
Translator Zero/Span Tests (climatronics)		N/A	\checkmark
Manual Rain Gauge Test	\checkmark	N/A	\checkmark
Confirm Reasonableness of Current Values	\checkmark	Weekly	\checkmark
Test Surface Wetness Response	\checkmark	N/A	\checkmark

Are regular operational QA/QC checks performed on the ozone analyzer?

OC	Check	Perf	ormed
VV.	Chick	I UII	ormeu

Multi-point Calibrations Automatic Zero/Span Tests Manual Zero/Span Tests **Automatic Precision Level Tests Manual Precision Level Test Analyzer Diagnostics Tests In-line Filter Replacement (at inlet) In-line Filter Replacement (at analyze** Sample Line Check for Dirt/Water **Zero Air Desiccant Check**

	Frequency	Co
✓	Semiannually	
✓	Daily	
✓	As needed	
✓	Daily	
✓	As needed	
✓	Weekly	
✓	Every 2 weeks	
	N/A	
✓	Weekly	
✓	Weekly	

- 1 Do multi-point calibration gases go through the complete sample train including all filters?
- 2 Do automatic and manual z/s/p gasses go through the complete sample train including all filters?
- Are the automatic and manual z/s/p checks monitored and 3 reported? If yes, how?

	Unknown	
✓		
✓	SSRF	

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The ozone sample train is leak tested every two weeks.

mpliant

Compliant

F-02058-1500-S8-rev002

Fi	eld Sy	stems Data Fo	rm					F-02058-1	500-S9-rev002
Sit	e ID	PAL190	Techni	cian	Martin Valvur		Site Visit Date	03/01/2019	
	<u>Site ope</u>	ration procedures							
1	Is the fil	ter pack being changed	l every T	uesd	ay as scheduled?		Filter changed mori	nings	
2	Are the correctly	Site Status Report For y?	ms being	com	pleted and filed				
3	Are data schedule	a downloads and backu ed?	ıps being	perf	ormed as		No longer required		
4	Are gen	eral observations being	g made an	d re	corded? How?	✓	SSRF, logbook		
5	Are site fashion	supplies on-hand and 1	replenish	ed in	a timely				
6	Are sam	ple flow rates recorded	l? How?			✓	SSRF		
7	Are sam fashion?	ples sent to the lab on a	a regular	sche	edule in a timely				
8	Are filte and ship	ers protected from cont oping? How?	aminatio	n du	ring handling	✓	Clean gloves on and	d off	
9	Are the operation	site conditions reported ons manager or staff?	d regular	ly to	the field				
QC	Check Po	erformed		Fre	quency			Compliant	
I	Multi-poir	nt MFC Calibrations	\checkmark	Sen	niannually				
I	Flow Syste	em Leak Checks	\checkmark	Wee	ekly				
I	Filter Pac	k Inspection							
1	Flow Rate	Setting Checks	\checkmark	Wee	ekly				
	Visual Ch	eck of Flow Rate Roton	neter 🗹	Wee	ekly				
1	n-line Fil	ter Inspection/Replacer	ment 🗹	As r	needed			\checkmark	
5	Sample Li	ne Check for Dirt/Wat	er 🗸	Wee	əkly			\checkmark	
D	de envie	dditional amplemation (nhotomo	nh o	n alzatah if naaaa	~~~~) maganding canditi	and listed above on	any other features

PAL190

F-02058-1500-S10-rev002

Site ID

Techn

Technician Martin Valvur

Site Visit Date 03/01/2019

Site Visit Sensors

Parameter	Manufacturer	Model	S/N	Client ID
Computer	Dell	Inspiron 15	Unknown	07056
DAS	Campbell	CR3000	2122	000343
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CA110	11920011905	02752
Flow Rate	Apex	AXMC105LPMDPC	54774	000654
Infrastructure	Infrastructure	none	none	none
Modem	Raven	H4223-C	0934411667	06808
Ozone	ThermoElectron Inc	49i A1NAA	1009241783	000613
Ozone Standard	ThermoElectron Inc	49i A3NAA	0726124696	000735
Sample Tower	Aluma Tower	В	AT-7200-582	missing
Shelter Temperature	Campbell	107-L	10755-148	none
Siting Criteria	Siting Criteria	1	None	None
Temperature	RM Young	41342VO	12542	06303
Zero air pump	Werther International	C 70/4	000836217	06922

Site Inventory by Site Visit

Site	Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
EVE	419-Sandy	Grenville-03/19/2019				
1	3/19/2019	DAS	Environmental Sys Corp	90642	8816	2527
2	3/19/2019	Elevation	Elevation	None	1	None
3	3/19/2019	Filter pack flow pump	Thomas	none	107CAB18	081700057785
4	3/19/2019	Flow Rate	Alicat	none	MC-10SLPM-D-PCV	150339
5	3/19/2019	Infrastructure	Infrastructure	none	none	none
6	3/19/2019	Modem	US Robotics	none	56k	unknown
7	3/19/2019	Sample Tower	Aluma Tower	none	В	illegible
8	3/19/2019	Siting Criteria	Siting Criteria	None	1	None

DAS Data Form

DAS Time Max Error: 1.72

Mfg	Serial N	umber Site	Т	echnician	Site Visit Date	Parameter	Use Desc.
Environmental	l Sys 2527	EVE	419	Sandy Grenville	03/19/2019	DAS	Primary
Das Date:	3 /19/2019	Audit Date	3 /19/2019	Mfg	Datel	Parameter	DAS
Das Time: Das Day:	9.05.50	Audit Time	9.07.33	Serial Number	15510194	Tfer Desc.	Source generator (D
Low Channel	l:	High Channel	l:	Tfer ID	01320		
Avg Diff:	Max Diff:	Avg Diff:	Max Diff:	Slope	1.0000	0 Intercept	0.00000
0.0001	0.000	2 0.0001	0.0002	Cert Date	2/13/201	2 CorrCoff	1.00000
				Mfg	Fluke	Parameter	DAS
				Serial Number	95740135	Tfer Desc.	DVM
				Tfer ID	01311		
				Slope	1.0000	0 Intercept	0.00000
				Cert Date	1/25/201	9 CorrCoff	1.00000
Channel	Input	DVM Output	DAS Output	InputUnit	OutputUnit	Difference	
8	0.0000	0.0000	0.0000	V	V	0.0000	
8	0.1000	0.0999	0.0999	V	V	0.0000	
8	0.3000	0.2997	0.2999	V	V	0.0002	
8	0.5000	0.4996	0.4996	V	V	0.0000	
8	0.7000	0.6995	0.6996	V	V	0.0001	
8	0.9000	0.8994	0.8994	V	V	0.0000	
8	1.0000	0.9993	0.9992	V	V	-0.0001	

Flow Data Form

Mfg	Serial Nun	nber Ta	Site	Tec	chnician	Site Visit D	ate Paran	ieter	Owner ID
Alicat	150339		EVE419	Sa	ndy Grenville	03/19/2019	Flow R	ate	none
					Mfg	BIOS	P	arameter Flow	v Rate
					Serial Number		T	fer Desc. BIO	S 530-H
					Tfer ID	01414			
					Slope	0.9	99332 Inte	ercept	0.00935
					Cert Date	2/8	/2019 Co	rCoff	0.99999
DAS 1:		DAS 2:		_	Cal Factor Z	ero	-0.01	1	
A Avg % Diff:	A Max % Di	A Avg %	Dif A Max	: % D i	Cal Factor F	ull Scale	5.06	33	
0.56%	0.79%				Rotometer R	eading:		3	
Desc.	Test type	Input l/m	Input Corr_	MfcDisp.	OutputSignal	Output S E	InputUnit	OutputSignall	PctDifference
primary	pump off	0.000	0.000	0.00	0.0000	0.04	l/m	l/m	
primary	leak check	0.000	0.000	0.00	0.0000	0.03	l/m	l/m	
primary	test pt 1	3.006	3.020	2.98	0.0000	3.01	l/m	l/m	-0.46%
primary	test pt 2	3.008	3.020	2.98	0.0000	3.01	l/m	l/m	-0.43%
primary	test pt 3	3.015	3.030	2.98	0.0000	3.01	l/m	l/m	-0.79%
Sensor Compo	onent Leak Tes	st		Conditio	n		Status	pass	
Sensor Compo	onent Tubing C	ondition		Conditio	n Good		Status	pass	
Sensor Compo	onent Filter Pos	sition		Conditio	n Poor		Status	Fail	
Sensor Compo	onent Rotomete	er Conditio	n	Conditio	n Clean and dry		Status	pass	
Sensor Compo	onent Moisture	Present		Conditio	n See comments	3	Status	pass	
Sensor Compo	nent Filter Dis	tance		Conditio	n 6.0 cm		Status	pass	
Sensor Compo	onent Filter Dep	oth		Conditio	n -0.5 cm		Status	Fail	
Sensor Compo	onent Filter Azi	muth		Conditio	n 360 deg		Status	pass	
Sensor Compo	onent System M	/lemo		Conditio	n		Status	pass	

Infrastructure Data For

Site ID	EVE419	Technician Sandy	/ Grenville Site Visit Date 03/19/2019
Shelte	r Make	Shelter Model	Shelter Size
Ekto		8810	640 cuft
AND AND A TYPE			

Sensor Component	Sample Tower Type	Condition	Туре В	Status	pass
Sensor Component	Conduit	Condition	Good	Status	pass
Sensor Component	Met Tower	Condition	Fair	Status	pass
Sensor Component	Moisture Trap	Condition	Not installed	Status	pass
Sensor Component	Power Cables	Condition	Good	Status	pass
Sensor Component	Shelter Temp Control	Condition	Functioning	Status	pass
Sensor Component	Rotometer	Condition	Installed	Status	pass
Sensor Component	Sample Tower	Condition	Good	Status	pass
Sensor Component	Shelter Condition	Condition	Fair	Status	pass
Sensor Component	Shelter Door	Condition	Good	Status	pass
Sensor Component	Shelter Roof	Condition	Fair	Status	pass
Sensor Component	Shelter Floor	Condition	Fair	Status	pass
Sensor Component	Signal Cable	Condition	Good	Status	pass
Sensor Component	Tubing Type	Condition	3/8 teflon	Status	pass
Sensor Component	Sample Train	Condition	Good	Status	pass

F-02058-1500-S1-rev002

Site ID EVE419	Technician Sandy Grenvill	e Site Visit Date 03/1	9/2019	
Site Sponsor (agency)	NPS/EPA	USGS Map	Long Pine Key	
Operating Group	NPS	Map Scale		
AQS #		Map Date		
Meteorological Type	R.M. Young			
Air Pollutant Analyzer		QAPP Latitude		
Deposition Measurement	dry, wet, Hg, IMPROVE	QAPP Longitude		
Land Use	wetlands	QAPP Elevation Meters		
Terrain	flat	QAPP Declination		
Conforms to MLM	Yes	QAPP Declination Date		
Site Telephone	(305) 242-7838	Audit Latitude	25.391223	
Site Address 1	Everglades National Park	Audit Longitude	-80.680819	
Site Address 2	40001 State Road 9336	Audit Elevation	1	
County	Dade	Audit Declination -5.1		
City, State	Homestead, FL	Present		
Zip Code	33034	Fire Extinguisher 🗹	Inspected July 2017	
Time Zone	Eastern	First Aid Kit		
Primary Operator		Safety Glasses		
Primary Op. Phone #		Safety Hard Hat		
Primary Op. E-mail		Climbing Belt		
Backup Operator		Security Fence		
Backup Op. Phone #		Secure Shelter		
Backup Op. E-mail		Stable Entry Step 🗹		
Shelter Working Room	Make Ekto M	odel 8810	Shelter Size 640 cuft	
Shelter Clean	Notes The shelter is very clean, neat audit.	and well organized. Repairs h	ave been made since the previous	
Site OK	Notes			
Driving Directions Take t mile to Check and co	he Florida Turnpike (Rat 821) south to th the intersection of East Palm Drive (Rat -in at the guard station. Take the Main F ontinue to the research facility. The site i	e end and junction with Rat 1. 9336). Turn right (west) on 93 Park Road to Long Pine Key Ro s on the right at the fire station.	Continue south on Rat 1 about 1/4 36 and continue to the park entrance. ad. Turn left on Long Pine Key Rd.	

EVE419

F-02058-1500-S2-rev002

Site ID

Tech

Technician Sandy Grenville

Site Visit Date 03/19/2019

Potential Interferent	Minimum Distance From Measurement Apparatus	Distance	Pass = Checked
Large Point Source of SO2 or NOx	20 to 40 km		✓
Major industrial complex	10 to 20 km		
City > 50,000 population	40 km		\checkmark
City 10,000 to 50,000 population	10 km		\checkmark
City 1,000 to 10,000 population	5 km		\checkmark
Major highway, airport or rail yard	2 km		\checkmark
Secondary road, heavily traveled	500 m		\checkmark
Secondary road, lightly traveled	200 m		\checkmark
Feedlot operations	500 m		\checkmark
Intensive agricultural ops (including aerial spraying)	500 m		\checkmark
Limited agricultural operations	200 m		\checkmark
Large parking lot	200 m		\checkmark
Small parking lot	100 m	50 m	
Tree line	50 m		\checkmark
Obstacles to wind	10 times obstacle height		

Siting Distances OK

Siting Criteria Comment

Small parking lot for park employees and fire fighting equipment is within 100 meters of the site.

lite	ID EVE419 Technician Sandy Grenville		Site Visit Date 03/19/2019
	Are wind speed and direction sensors sited so as to avoid being influenced by obstructions?		N/A
	Are wind sensors mounted so as to minimize tower effects? (i.e. wind sensors should be mounted atop the tower or on a horizontally extended boom >2x the max diameter of the tower into the prevailing wind)		N/A
	Are the tower and sensors plumb?	✓	N/A
	Are the temperature shields pointed north or positioned to avoid radiated heat sources such as buildings, walls, etc?		
5	Are temperature and RH sensors sited to avoid unnatural conditions? (i.e. ground below sensors should be natural surface and not steeply sloped. Ridges, hollows, and areas of standing water should be avoided)		
	Is the solar radiation sensor plumb?	✓	N/A
	Is it sited to avoid shading, or any artificial or reflected light?		N/A
	Is the rain gauge plumb?	✓	N/A
	Is it sited to avoid sheltering effects from buildings, trees, towers, etc?		N/A
0	Is the surface wetness sensor sited with the grid surface facing north?	✓	N/A
1	Is it inclined approximately 30 degrees?	✓	N/A

F-02058-1500-S3-rev002

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The 10 meter temperature sensor has been removed and temperature is now being measured using a combination RH/temperature sensor mounted in a naturally aspirated shield at approximately 2 meters above the ground. The temperature measurement system was not challenged with an audit standard.
Field Systems Data Form

F-02058-1500-S4-rev002

Site	ID	EVE419	Technician	Sandy Grenville		Site Visit Date 03/19/2019
1	Do all the condition	e meterological senso a, and well maintained	rs appear to be 1?	intact, in good	✓	
2	Are all th reporting	ne meteorological sens g data?	sors operational	l online, and		
3	Are the s	hields for the temper	ature and RH s	ensors clean?		
4	Are the a	spirated motors worl	king?		✓	N/A
5	Is the sol scratches	ar radiation sensor's s?	lens clean and f	ree of		N/A
6	Is the sur	face wetness sensor g	rid clean and u	ndamaged?	✓	N/A
7	Are the s condition	ensor signal and pow a, and well maintained	er cables intact, 1?	, in good		N/A
8	Are the s from the	ensor signal and pow elements and well ma	er cable connec aintained?	tions protected	✓	N/A

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Fi	eld Systems Data Form		F-02058-1500-S5-rev002				
Site	EVE419 Technician Sandy Grenville		Site Visit Date 03/19/2019				
	Siting Criteria: Are the pollutant analyzers and deposition ed	<u>quip</u> i	<u>nent sited in accordance with 40 CFR 58, Appendix E</u>				
1	Do the sample inlets have at least a 270 degree arc of unrestricted airflow?	✓					
2	Are the sample inlets 3 - 15 meters above the ground?	✓					
3	Are the sample inlets > 1 meter from any major obstruction, and 20 meters from trees?	✓					
	Pollutant analyzers and deposition equipment operations and	d ma	intenance				
1	Do the analyzers and equipment appear to be in good condition and well maintained?	✓					
2	Are the analyzers and monitors operational, on-line, and reporting data?	✓					
3	Describe ozone sample tube.		N/A				
4	Describe dry dep sample tube.		3/8 teflon by 9 meters				
5	Are in-line filters used in the ozone sample line? (if yes indicate location)		N/A				
6	Are sample lines clean, free of kinks, moisture, and obstructions?	✓					
7	Is the zero air supply desiccant unsaturated?		N/A				
8	Are there moisture traps in the sample lines?		No moisture trap installed				
9	Is there a rotometer in the dry deposition filter line, and is it clean?		Clean and dry				

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

The dry deposition flow controller was recently replaced by the site operator. It has not been calibrated onsite.

Fi	eld Sy	stems Data Fo			F-02058-1500-S6-rev002					
Site	e ID	EVE419	Technician	Sandy Grenville		Site Visit	Date	03/19/2019		
	DAS, se	nsor translators, and j	peripheral equip	oment operation	ns ai	nd maintenan	<u>ice</u>			
1	Do the I well mai	DAS instruments appe intained?	ar to be in good	condition and						
2	Are all the components of the DAS operational? (printers, modem, backup, etc)				✓					
3	Do the analyzer and sensor signal leads pass through lightning protection circuitry?				✓	Met sensors o	only			
4	Are the signal connections protected from the weather and well maintained?				✓					
5	Are the signal leads connected to the correct DAS channel?			✓						
6	Are the grounde	DAS, sensor translato ed?	rs, and shelter j	properly	✓					
7	Does the	e instrument shelter ha	ave a stable pow	ver source?	✓					
8	Is the in	strument shelter temp	oerature control	led?						
9	Is the m	et tower stable and gr	ounded?			Stable		(Grounded	
10	Is the sa	mple tower stable and	l grounded?						V	
11	Tower c	omments?								

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

Fie	ld Sy	vstems Data	For	m					F-0 2	2058-	-1500-S7-rev002
Site	ID	EVE419		Tech	nician	Sandy Grenvill	le	Site Visit Date	03/19/201	9	
Do	ocumen	tation									
De	oes the s	site have the requir	ed ins	trum	ent and	equipment m	anuals?				
		<u>ne nave me requir</u>	Yes	No	N//	4			Yes	No	N/A
Wind	l speed	sensor				Da	ta logger	•			
Wind	l direct	ion sensor			\checkmark	Da	ta logger	•			\checkmark
Temj	peratur	e sensor			\checkmark	Str	rip chart	recorder			\checkmark
Relat	tive hur	nidity sensor			\checkmark	Со	mputer			\checkmark	
Solar	• radiat	ion sensor			\checkmark	Mo	odem		\checkmark		
Surfa	ace wetı	iess sensor			\checkmark	Pri	inter				\checkmark
Wind	l sensor	translator			\checkmark	Zei	ro air pu	mp			\checkmark
Temj	peratur	e translator			\checkmark	Fil	ter flow j	pump		\checkmark	
Hum	idity se	nsor translator			\checkmark	Su	rge prote	ector		\checkmark	
Solar	radiat i	ion translator			\checkmark	UP	S			\checkmark	
Tippi	ing buc	ket rain gauge			\checkmark	Lig	ghtning p	protection device		\checkmark	
Ozon	e analy	zer			\checkmark	She	elter hea	ter	\checkmark		
Filter	r pack f	low controller		\checkmark		She	elter air (conditioner	\checkmark		
Filter	r pack N	AFC power supply			\checkmark						
I	Does the	site have the requ	ired a	nd me	ost recei	nt QC docume	ents and i	<u>report forms?</u>			
		-	Pres	ent					Curr	ent	
Stati	on Log				Datavie	w			\checkmark		
SSRI	<u>?</u>								\checkmark		
Site (Ops Ma	nual							\checkmark		
HAS	Р										
Field	Ops M	anual									
Calib	oration	Reports			not curr	rent					
Ozon	e z/s/p	Control Charts			N/A				\checkmark		
Preve	entive n	naintenance schedu	ıl [
1	Is the st	ation log properly	comp	leted	during	every site visit	? 🗸 Da	ataview			
2	Are the current	Site Status Report ?	t Forn	ıs beiı	ng comp	pleted and	✓ Ob	oservations compl	eted during	g filter of	f day
3	Are the sample	chain-of-custody f transfer to and fro	òrms om lab	prope ?	rly used	d to document					
4	Are ozo current	ne z/s/p control ch ?	arts p	roper	ly comp	leted and	□ N//	A			
Provi natur	Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:										
Elect	ronic ch	ecklists within Datav	iew for	the d	ry depos	sition filter proce	edures ar	e not completed c	luring site v	/isits.	

Field Systems Data Form

Site	ID	EVE419	Technician	Sandy Grenville	 Site Visit Date	03/19/2019]
1	<u>Site ope</u> Has the course?	<u>ration procedures</u> site operator attende If yes, when and who	d a formal CAS instructed?	TNET training	Trained by ARS		
2	Has the backup operator attended a formal CASTNET training course? If yes, when and who instructed?						
3	Is the sit schedule	e visited regularly on ?	the required Tu	ıesday			
4	Are the s flollowed	standard CASTNET of l by the site operator?	operational proc	cedures being			
5	Is the sit the requ	e operator(s) knowled ired site activities? (in	lgeable of, and a cluding docum	able to perform entation)			

F-02058-1500-S8-rev002

Are regular operational QA/QC checks performed on meteorological instruments?

QC Check Performed		Frequency	Compliant
Multipoint Calibrations	\checkmark	N/A	
Visual Inspections	\checkmark	N/A	
Translator Zero/Span Tests (climatronics)		N/A	\checkmark
Manual Rain Gauge Test	\checkmark	N/A	\checkmark
Confirm Reasonableness of Current Values	✓	N/A	\checkmark
Test Surface Wetness Response	\checkmark	N/A	\checkmark

Are regular operational QA/QC checks performed on the ozone analyzer?

Are the automatic and manual z/s/p checks monitored and

3

reported? If yes, how?

QC Check Performed	Frequency	Compliant				
Multi-point Calibrations	N/A					
Automatic Zero/Span Tests	N/A	\checkmark				
Manual Zero/Span Tests	N/A	\checkmark				
Automatic Precision Level Tests	N/A	\checkmark				
Manual Precision Level Test	N/A	\checkmark				
Analyzer Diagnostics Tests	N/A	\checkmark				
In-line Filter Replacement (at inlet)	N/A	\checkmark				
In-line Filter Replacement (at analyze	N/A	\checkmark				
Sample Line Check for Dirt/Water	N/A	\checkmark				
Zero Air Desiccant Check	N/A					
1 Do multi-point calibration gases go through the complete Sample train including all filters?						
2 Do automatic and manual z/s/p gasses go throu complete sample train including all filters?	gh the					

Provide any additional explanation (photograph or sketch if necessary) regarding conditions listed above, or any other features, natural or man-made, that may affect the monitoring parameters:

□ N/A

Fi	eld Sy	stems Data Fo	orm		F-02058-1500-S9-rev002					
Sit	e ID	EVE419	Technician	Sandy Grenville	Site Visit Date	03/19/2019				
	<u>Site ope</u>	eration procedures								
1	Is the fi	lter pack being change	ed every Tuesda	ay as scheduled?	Filter changed mori	Filter changed morinings				
2	Are the correctl	Site Status Report Fo y?	rms being com	pleted and filed						
3	Are dat schedul	a downloads and back ed?	ups being perf	ormed as	□ No longer required	No longer required				
4	Are gen	eral observations bein	g made and re	corded? How?	SSRF	SSRF				
5	Are site fashion	supplies on-hand and ?	replenished in	a timely						
6	Are sample flow rates recorded? How?				SSRF	SSRF				
7	Are san fashion	nples sent to the lab on ?	a regular sche	dule in a timely 🗖						
8	Are filte and shij	ers protected from con pping? How?	tamination du	ring handling						
9	Are the operation	site conditions report ons manager or staff?	ed regularly to	the field						
QC	Check P	erformed	Fre	quency		Compliant				
I	Multi-poi	nt MFC Calibrations	Sem	niannually						
I	Flow Syst	em Leak Checks	✓ Wee	ekly						
I	Filter Pac	k Inspection								
I	Flow Rate	e Setting Checks	✓ Wee	ekly						
	Visual Check of Flow Rate Rotometer Weekly									
I	In-line Filter Inspection/Replacement									
5	Sample Li	ine Check for Dirt/Wa	iter							
Prov	vide anv a	additional explanation	(photograph o	r sketch if necessa	rv) regarding conditi	ons listed above, or a	any other features.			

natural or man-made, that may affect the monitoring parameters:

Assistance was provided to the site operators regarding questions relating to the SSRF. The rationale and importance of properly recording the vegetation observations was discussed. Gloves were not used when changing the filter and the channels were not flagged as invalid when the tower was lowered.

Field Systems Data Form

F-02058-1500-S10-rev002

Site ID

Technic

Technician Sandy Grenville

Site Visit Date 03/19/2019

Site Visit Sensors

EVE419

Parameter	Manufacturer	Model	S/N	Client ID
DAS	Environmental Sys Corp	8816	2527	90642
Elevation	Elevation	1	None	None
Filter pack flow pump	Thomas	107CAB18	081700057785	none
Flow Rate	Alicat	MC-10SLPM-D-PC	150339	none
Infrastructure	Infrastructure	none	none	none
Modem	US Robotics	56k	unknown	none
Sample Tower	Aluma Tower	В	illegible	none
Siting Criteria	Siting Criteria	1	None	None

APPENDIX B

CASTNET Site Spot Report Forms

Data Compiled: 4/12/2019 8:19:08 AM

SiteVisitDate Site Technician

02/25/2019 ALC188 Martin Valvur

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	Р	4	0.5	9	0.26	с	Р
2	Temperature max error	Р	4	0.5	9	0.42	с	Р
3	Ozone Slope	Р	0	1.1	4	0.96029	unitless	Р
4	Ozone Intercept	Р	0	5	4	0.55012	ppb	Р
5	Ozone correlation	Р	0	0.995	4	0.99988	unitless	Р
6	Ozone % difference avg	Р	7	10	4	3.0	%	Р
7	Ozone Absolute Difference g1	Р	7	3	1	0.84	ppb	Р
8	Ozone Absolute Difference g2	Р	7	1.5	1	-0.34	ppb	Р
9	Flow Rate average % difference	Р	10	5	3	2.38	%	Р
10	Flow Rate max % difference	Р	10	5	3	2.6	%	Р
11	DAS Voltage average error	Р	7	0.003	70	0.0002	V	Р
12	Shelter Temperature average error	Р	5	2	12	0.93	с	Р
13	Shelter Temperature max error	Р	5	2	12	0.96	с	Р

Field Systems Comments

1 Parameter: SitingCriteriaCom

The site is well located with respect to CASTNET siting criteria, however there is a small campground 0.5 km to the northwest which may be a source of smoke.

2 Parameter: ShelterCleanNotes

The site is clean and neat.

Data Compiled: 4/12/2019 8:44:45 AM

SiteVisitDate Site Technician

02/27/2019 BBE401 Martin Valvur

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature2meter average error	Р	5	0.5	3	0.26	с	Р
2	Temperature2meter max error	Р	5	0.5	3	0.29	с	Р
3	Ozone Slope	Р	0	1.1	4	0.99057	unitless	Р
4	Ozone Intercept	Р	0	5	4	0.23958	ppb	Р
5	Ozone correlation	Р	0	0.995	4	0.99999	unitless	Р
6	Ozone % difference avg	Р	7	10	4	0.8	%	Р
7	Ozone Absolute Difference g1	Р	7	3	1	0.56	ppb	Р
8	Ozone Absolute Difference g2	Р	7	1.5	1	-0.22	ppb	Р
9	Flow Rate average % difference	Р	10	5	3	0.69	%	Р
10	Flow Rate max % difference	Р	10	5	3	0.81	%	Р
11	DAS Voltage average error	Р	14	0.003	28	0.0001	V	Р
12	Shelter Temperature average error	Р	5	2	15	0.66	с	Р
13	Shelter Temperature max error	Р	5	2	15	1.08	c	Р

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample line is leak tested every two weeks when the inlet filter is replaced.

2 Parameter: ShelterCleanNotes

The shelter is clean, neat, and well organized.

3 Parameter: MetSensorComme

The two meter temperature sensor has been moved from 1.6 to 2.0 meters above the ground.

4 Parameter: MetOpMaintCom

The signal cables have been replaced since the previous audit visit.

Data Compiled: 4/14/2019 8:51:59 PM

SiteVisitDate	Site	Technician						
03/19/2019	EVE419	Sandy Grenville						
Records with valid pass/fail criteria								

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Flow Rate average % difference	Р	10	5	3	0.56	%	Р
2	Flow Rate max % difference	Р	10	5	3	0.79	%	Р
3	DAS Voltage average error	Р	8	0.003	42	0.0001	V	Р

Sandy Grenville

Field Performance Comments

1	Parameter:	Flow Rate	SensorComponent:	Moisture Present	CommentCode	72

The filter sample tubing has drops of moisture in low sections outside the shelter.

2 Parameter: Flow Rate SensorComponent: Filter Depth CommentCode 71

The filter attachment plate is mounted too low in the enclosure resulting in the filter being exposed to wind-driven rain and in the standard geometric orientation.

Field Systems Comments

Parameter: SiteOpsProcComm 1

Assistance was provided to the site operators regarding questions relating to the SSRF. The rationale and importance of properly recording the vegetation observations was discussed. Gloves were not used when changing the filter and the channels were not flagged as invalid when the tower was lowered.

2 Parameter: DocumentationCo

Electronic checklists within Dataview for the dry deposition filter procedures are not completed during site visits.

Parameter: SitingCriteriaCom 3

Small parking lot for park employees and fire fighting equipment is within 100 meters of the site.

4 Parameter: ShelterCleanNotes

The shelter is very clean, neat and well organized. Repairs have been made since the previous audit.

5 Parameter: PollAnalyzerCom

The dry deposition flow controller was recently replaced by the site operator. It has not been calibrated onsite.

Parameter: MetSensorComme 6

The 10 meter temperature sensor has been removed and temperature is now being measured using a combination RH/temperature sensor mounted in a naturally aspirated shield at approximately 2 meters above the ground. The temperature measurement system was not challenged with an audit standard.

Data Compiled: 4/15/2019 8:39:37 AM

SiteVisitDateSiteTechnician03/26/2019GAS153Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	Р	0	1.1	4	0.98742	unitless	Р
2	Ozone Intercept	Р	0	5	4	-1.85433	ppb	Р
3	Ozone correlation	Р	0	0.995	4	1.00000	unitless	Р
4	Ozone % difference avg	Р	7	10	4	6.7	%	Р
5	Ozone Absolute Difference g1	Р	7	3	1	-1.77	ppb	Р
6	Ozone Absolute Difference g2	Р	7	1.5	1	-1.97	ppb	Fail

Data Compiled: 4/15/2019 8:33:30 AM

SiteVisitDateSiteTechnician03/19/2019IRL141Sandy Grenville

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	Р	0	1.1	4	1.00208	unitless	Р
2	Ozone Intercept	Р	0	5	4	-1.09943	ppb	Р
3	Ozone correlation	Р	0	0.995	4	1.00000	unitless	Р
4	Ozone % difference avg	Р	7	10	4	3.2	%	Р
5	Ozone Absolute Difference g1	Р	7	3	1	-1.07	ppb	Р
6	Ozone Absolute Difference g2	Р	7	1.5	1	-1.12	ppb	Р

Data Compiled: 4/14/2019 8:27:47 PM

SiteVisitDate Site Technician

03/01/2019 PAL190 Martin Valvur

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Temperature average error	Р	4	0.5	18	0.03	с	Р
2	Temperature max error	Р	4	0.5	18	0.04	с	Р
3	Ozone Slope	Р	0	1.1	4	0.99603	unitless	Р
4	Ozone Intercept	Р	0	5	4	-0.33515	ppb	Р
5	Ozone correlation	Р	0	0.995	4	0.99999	unitless	Р
6	Ozone % difference avg	Р	7	10	4	1.5	%	Р
7	Ozone Absolute Difference g1	Р	7	3	1	-0.11	ppb	Р
8	Ozone Absolute Difference g2	Р	7	1.5	1	-0.4	ppb	Р
9	Flow Rate average % difference	Р	10	5	6	0.55	%	Р
10	Flow Rate max % difference	Р	10	5	6	0.66	%	Р
11	DAS Voltage average error	Р	7	0.003	63	0.0001	V	Р
12	Shelter Temperature average error	Р	5	2	18	1.66	с	Р
13	Shelter Temperature max error	Р	5	2	18	1.99	с	Р

Field Systems Comments

1 Parameter: SiteOpsProcedures

The ozone sample train is leak tested every two weeks.

2 Parameter: SitingCriteriaCom

The site is located 40 km southeast of Amarillo TX which has a population of approximately 178,000.

3 Parameter: ShelterCleanNotes

The shelter is in good condition.

4 Parameter: MetSensorComme

The meteorological tower and sensors have been removed.

Data Compiled: 4/15/2019 8:44:50 AM

SiteVisitDateSiteTechnician03/27/2019SUM156Eric Hebert

Line	Audited Parameter	DAS	Ch. #	Criteria +/-	Counts	QaResult	Units	Pass/Fail
1	Ozone Slope	Р	0	1.1	4	1.02263	unitless	Р
2	Ozone Intercept	Р	0	5	4	-2.10227	ppb	Р
3	Ozone correlation	Р	0	0.995	4	1.00000	unitless	Р
4	Ozone % difference avg	Р	7	10	4	3.7	%	Р
5	Ozone Absolute Difference g1	Р	7	3	1	-2.26	ppb	Р
6	Ozone Absolute Difference g2	Р	7	1.5	1	-1.64	ppb	Fail

APPENDIX C

CASTNET Ozone Performance Evaluation Forms

Site Inventory by Site Visit

Site	Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
IRL1	41-Sandy (Grenville-03/19/2019				
1	3/19/2019	DAS	Campbell	000340	CR3000	2119
2	3/19/2019	Ozone	ThermoElectron Inc	000609	49i A1NAA	1009241782
3	3/19/2019	Ozone Standard	ThermoElectron Inc	000446	49i A3NAA	CM08200022
4	3/19/2019	Zero air pump	Werther International	06909	C 70/4	000829161

Ozone Data Form

Mfg	Serial Number	Ta Site	Тес	chnician	Site Visit Date	Parameter	Owner ID
ThermoElectron Inc	1009241782	IRL141	Sa	indy Grenville	03/19/2019	Ozone	000609
Slope: Intercept CorrCoff DAS 1:	1.00208 Slope: 1.09943 Interconstruction 1.00000 CorrC DAS	ept 0 coff 0	.00000 .00000 .00000	Mfg Serial Number Tfer ID Slope	ThermoElectron 1180030022 01114 1.0029	Inc Paramete Tfer Dese 0 Intercept	er ozone c. Ozone primary stan 0.10980
A Avg % Diff: A N 0.0%	0.0%	vg %Dif A	Max % Di	Cert Date	9/7/201	8 CorrCoff	1.00000
UseDescription primary primary primary primary primary	ConcGroup 1 1 2 3 4 5 5	Tfer Raw 0.42 14.21 36.46 69.30 115.36	Tfer Corr 0.30 14.05 36.24 68.99 114.91	Site -0.77 12.93 35.31 67.91 114.10	Site Unit ppb ppb ppb ppb ppb	RelPerDif -2.6 -1.58 -0.71	AbsDif -1.07 -1.12
Sensor Compone	ant Sample Train		Conditio	Good		Status pass	
Sensor Compone	ent 22.5 degree ru	lle	Conditio	on		Status pass	
Sensor Compone	Inlet Filter Cor	ndition	Conditio	n Clean		Status pass	
Sensor Compone	ant Battery Backu	р	Conditio	n N/A		Status pass	
Sensor Compone	ont Offset		Conditio	n 0.20		Status pass	
Sensor Compone	nt Span		Conditio	n 1.016		Status pass	
Sensor Compone	ant Zero Voltage		Conditio	n N/A		Status pass	
Sensor Compone	nt Fullscale Volta	ige	Conditio	n N/A		Status pass	
Sensor Compone	ent Cell A Freq.		Conditio	99.9 kHz		Status pass	
Sensor Compone	nt Cell A Noise		Conditio	0.6 ppb		Status pass	
Sensor Compone	ent Cell A Flow		Conditio	0.73 lpm		Status pass	
Sensor Compone	nt Cell A Pressur	е	Conditio	734.5 mmHg		Status pass	
Sensor Compone	nt Cell A Tmp.		Conditio	n 31.5 C		Status pass	
Sensor Compone	nt Cell B Freq.		Conditio	104.4 kHz		Status pass	
Sensor Compone	nt Cell B Noise		Conditio	0.5 ppb		Status pass	
Sensor Compone	nt Cell B Flow		Conditio	0.73 lpm		Status pass	
Sensor Compone	ent Cell B Pressur	е	Conditio	733.6 mmHg		Status pass	
Sensor Compone	ent Cell B Tmp.		Conditio	n N/A		Status pass	
Sensor Compone	nt Line Loss		Conditio	Not tested		Status pass	
Sensor Compone	ent System Memo	,	Conditio	on		Status pass	

Site Inventory by Site Visit

Site V	isit Date/	Parameter	Mfg	Owner ID	Model Number	Serial Number
GAS	153-Sandy	Grenville-03/26/2019				
1	3/26/2019	DAS	Campbell	000635	CR3000	4934
2	3/26/2019	Ozone	ThermoElectron Inc	000705	49i A1NAA	1030244807
3	3/26/2019	Ozone Standard	ThermoElectron Inc	000371	49i A3NAA	0726124692
4	3/26/2019	UPS	APC	missing	BP6505	NB0009260535
5	3/26/2019	Zero air pump	Werther International	06865	C 70/4	000814277

Ozone Data Form

Mfg		Serial Numb	er Ta Site	Те	echnician	Site Visit Date	Parameter	Owner ID
ThermoElect	tron Inc	1030244807	GAS15	3 S	andy Grenville	03/26/2019	Ozone	000705
Slope: [Intercept [CorrCoff [-	0.98742 Slop 1.85433 Inte 1.00000 Cor	e: () ercept () rCoff ()	0.00000 0.00000 0.00000	Mfg Serial Number Tfer ID	ThermoElectron IncParameter ozone1180030022Tfer Desc. Ozone01114		er ozone c. Ozone primary stan
DAS 1:		D	AS 2:		Slope	1.0029	0 Intercept	0.10980
A Avg % D	iff: A N	Max % Di A	Avg %Dif A	Max % Di	Cert Date	9/7/201	8 CorrCoff	1.00000
0.0	9%	0.0%						
UseDescri	ption	ConcGroup	Tfer Raw	Tfer Corr	Site	Site Unit	RelPerDif	AbsDif
primar	y v	2	15.40	15.24	13.27	ppb		-1.97
primar	y	3	36.85	36.63	34.12	ppb	-7.1	
primar	у	4	67.49	67.18	64.42	ppb	-4.19	
primar	y	5	111.40	110.96	107.80	ppb	-2.89	
Sensor Co	mpone	nt Sample Tra	in	Conditi	on Good		Status pass	
Sensor Co	mpone	ent 22.5 degree	e rule	Conditi	on		Status pass	
Sensor Co	mpone	nt Inlet Filter C	Condition	Conditi	on Clean		Status pass	
Sensor Co	mpone	nt Battery Bac	kup	Conditi	on N/A		Status pass	
Sensor Co	mpone	nt Offset		Conditi	on 0.70		Status pass	
Sensor Co	mpone	nt Span		Conditi	on 1.038		Status pass	
Sensor Co	mpone	nt Zero Voltag	e	Conditi	on N/A		Status pass	
Sensor Co	mpone	nt Fullscale Vo	oltage	Conditi	on N/A		Status pass	
Sensor Co	mpone	ent Cell A Freq		Conditi	on 102.2 kHz		Status pass	
Sensor Co	ompone	ent Cell A Noise	9	Conditi	on 0.9 ppb		Status pass	
Sensor Co	mpone	ent Cell A Flow		Conditi	on 0.64 lpm		Status pass	
Sensor Co	mpone	ent Cell A Pres	sure	Conditi	on 708.9 mmHg		Status pass	
Sensor Co	mpone	ent Cell A Tmp		Conditi	on 35.4 C		Status pass	
Sensor Co	ompone	ent Cell B Freq		Conditi	on 91.5 kHz		Status pass	
Sensor Co	ompone	ent Cell B Noise	e	Conditi	on 0.6 ppb		Status pass	
Sensor Co	ompone	Cell B Flow		Conditi	on 0.66 lpm		Status pass	
Sensor Co	mpone	ent Cell B Pres	sure	Conditi	on 709.5 mmHg		Status pass	
Sensor Co	Sensor Component Cell B Tmp.			Conditi	on N/A		Status pass	
Sensor Co	Sensor Component Line Loss			Conditi	Not tested		Status pass	
Sensor Co	ompone	ent System Me	mo	Conditi	on		Status pass	

Site Inventory by Site Visit

Site V	Visit Date	Parameter	Mfg	Owner ID	Model Number	Serial Number
SUM	156-Eric H	lebert-03/27/2019				
1	3/27/2019	DAS	Campbell	000335	CR3000	2114
2	3/27/2019	Ozone	ThermoElectron Inc	000724	49i A1NAA	1105347328
3	3/27/2019	Ozone Standard	ThermoElectron Inc	000511	49i A3NAA	0922236888
4	3/27/2019	Zero air pump	Werther International	06882	C 70/4	000815255

Ozone Data Form

Mfg		Serial Num	ber Ta Site		Т	Fech	nician	Site Visit Date	Parameter	c Owner ID
ThermoElec	tron Inc	1105347328	3	SUM156	ј	Eric I	Hebert	03/27/2019	Ozone	000724
Slope: Intercept CorrCoff	-	1.02263 Slo 2.10227 Int 1.00000 Co	ope: [tercept [orrCoff [0	.00000 .00000 .00000	Mfg Serial Number Tfer ID		ThermoElectron Inc Parameter of 1180030022 Tfer Desc. C 01114		meter ozone Desc. Ozone primary stan
DAS 1:		I	DAS 2:			SI	one	1.0029) Interce	pt 0.10980
A Avg % D	oiff: A N	Max % Di	A Avg %	Dif A	Max % Di		ort Data	9/7/201		eff 1 00000
0.0)%	0.0%						5/1/201		
UseDescri	ption	ConcGroup	Tfer	Raw	Tfer Corr		Site	Site Unit	RelPerDif	AbsDif
primar	y v	1	0.	45 68	0.33	-	-1.93	ppb		-2.26
primar	v	3	37	.08 .87	37.65	-	36.55	ppb	-2	.96
primar	ry	4	69	.83	69.51		68.90	ppb	-0	.88
primar	ry	5	112	2.13	111.69		112.10	ppb	0	.37
Sensor Co	ompone	nt Sample Tr	ain		Condi	tion	Good		Status pa	SS
Sensor Co	ompone	nt 22.5 degre	e rule		Condi	tion			Status pa	SS
Sensor Co	ompone	nt Inlet Filter	Condition	۱	Condi	tion	Clean		Status pa	SS
Sensor Co	ompone	nt Battery Ba	ickup		Condi	tion	N/A		Status pa	SS
Sensor Co	ompone	nt Offset			Condi	tion	0.70		Status pa	SS
Sensor Co	ompone	nt Span			Condi	tion	1.015		Status pa	SS
Sensor Co	ompone	nt Zero Volta	ige		Condi	tion	N/A		Status pa	SS
Sensor Co	ompone	nt Fullscale \	/oltage		Condi	tion	N/A		Status pa	ISS
Sensor Co	ompone	ent Cell A Free	q.		Condi	tion	101.2 kHz		Status pa	SS
Sensor Co	ompone	ent Cell A Nois	se		Condi	tion	Not tested		Status pa	SS
Sensor Co	ompone	Cell A Flov	N		Condi	tion	0.71 lpm		Status pa	SS
Sensor Co	ompone	ent Cell A Pre	ssure		Condi	tion	718.4 mmHg		Status pa	SS
Sensor Co	ompone	ent Cell A Tm	р.		Condi	tion	37.8 C		Status pa	SS
Sensor Co	ompone	ent Cell B Free	q.		Condi	tion	88.5 kHz		Status pa	SS
Sensor Co	ompone	ent Cell B Nois	se		Condi	tion	Not tested		Status pa	SS
Sensor Co	ompone	Cell B Flov	N		Condi	tion	0.64 lpm		Status pa	SS
Sensor Co	ompone	ent Cell B Pre	ssure		Condi	tion	719.0 mmHg		Status pa	SS
Sensor Co	Sensor Component Cell B Tmp.		Condi	tion	N/A		Status pa	SS		
Sensor Co	ompone	Ent Line Loss			Condi	tion	Not tested		Status pa	SS
Sensor Co	ompone	ent System M	emo		Condi	tion			Status pa	SS