



ACTIVATED SLUDGE PROCESS CONTROL

TROUBLESHOOTING CHART




Part Two: Separation

BASIC CONCEPTS




A. S. PROCESS CONTROL



BOX # 15

**AERATION EFFLUENT:
SETTLEOMETER < 80% IN 5 MINUTES**



- Conversion Complete
- Separation Analysis
 - “Perfect Clarifier”
 - < 80 % in 5 minutes
- Inhibited Settling
 - High concentration mass (too crowded)
 - Low density mass (too buoyant)

BOX # 16

AERATION EFFLUENT: CENTRIFUGE SPIN > 4%



- Centrifuge Spin
 - Aeration Effluent
 - > 4% inhibits settling
 - Measure and know
- 2 Minute Diluted Settleometer
 - 100% vs 50%

BOX # 16

AERATION EFFLUENT: CENTRIFUGE SPIN > 4%



- Centrifuge Spin
 - Aeration Effluent
 - > 4% inhibits settling
 - Measure and know
- 2 Minute Diluted Settleometer
 - 100% vs 50%



The image shows two graduated cylinders filled with a brown, turbid liquid. The cylinders have two scales: a vertical scale on the left (0-100) and a horizontal scale on the right (0-1000). The left cylinder is labeled 'SETTLEOMETER' and 'LOUIS MO'. The right cylinder is labeled 'Settler' and 'PlantPRO'. A semi-transparent brown box with green text is overlaid on the center of the cylinders.

2 Minute Diluted Settleometer Test Concentration


2 Minute Diluted Settleometer Test

Density



BOX # 18

AERATION: TOO MUCH BIOMASS, INCREASE WASTING



Establishing a wasting rate is simply a process of maintaining sufficient biomass to achieve complete conversion in the aeration tank (ammonia < 1 mg/L), while not maintaining an excessive amount of biomass to inhibit the settling rate in the clarifier (< 80% in 5 minutes).

BOX # 17

AERATION / CLARIFIER: BROWN FOAM ON SURFACE



- Filaments
 - >80% in 5 mins.
 - AT spin < 4%
 - 2 min. diluted Settleometer analysis
 - Coning/Jagged
 - Supernatant Clarity
 - Low AT effluent NH₃
 - **Brown Foam**
- Low F/M Environment

BOX # 17

AERATION / CLARIFIER: BROWN FOAM ON SURFACE



- Filaments
 - >80% in 5 mins.
 - AT spin < 4%
 - 2 min. diluted Settleometer analysis
 - Coning/Jagged
 - Supernatant Clarity
 - Low AT effluent NH₃
 - **Brown Foam**
- Low F/M Environment

BOX # 20

AERATION: LOW F/M RATIO, INCREASE WASTING



- Low F/M Filaments
- Waste
 - Stop the madness
 - Clean up the mess

BOX # 19


AERATION: DISSOLVED OXYGEN < 1 MG/L



- Filaments
 - >80% in 5 mins.
 - AT spin < 4%
 - 2 min. diluted
Settleometer analysis
- Low DO
 - Long, low levels
 - 1 mg/L DO
 - Short, deep levels
 - < 1 mg/L DO
 - Measure and know

BOX # 22

AERATION: MATCH AIR SUPPLY TO ORGANIC LOADING



BOX # 21

**AERATION: EVALUATE FOR SEPTICITY,
INFLUENT AND INTERNAL**



- Filaments
 - >80% in 5 mins.
 - AT spin < 4%
- Septic Sources
 - Influent
 - Odor
 - Corrosion
 - Color
 - Internal
 - “aerobic” digester
 - Solids breaking down in clarifier

BOX # 21


**AERATION: EVALUATE FOR SEPTICITY,
INFLUENT AND INTERNAL**



- Filaments
 - >80% in 5 mins.
 - AT spin < 4%
- Septic Sources
 - Influent
 - Odor
 - Corrosion
 - Color
 - Internal
 - “aerobic” digester
 - Solids breaking down in clarifier

BOX # 21

AERATION: EVALUATE FOR SEPTICITY, INFLUENT AND INTERNAL



- Filaments
 - >80% in 5 mins.
 - AT spin < 4%


Septic Sources

- Influent
 - Odor
 - Corrosion
 - Color
- Internal
 - “aerobic” digester
 - Solids breaking down in clarifier

A. S. PROCESS CONTROL


Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU November 2014



BOX # 15


**AERATION EFFLUENT:
SETTLEOMETER < 80% IN 5 MINUTES**



- Conversion Complete
- Separation Analysis
 - “Perfect Clarifier”
 - < 80 % in 5 minutes
- Inhibited Settling
 - High concentration mass (too crowded)
 - Low density mass (too buoyant)

BOX # 23

CLARIFIER EFFLUENT: SOLIDS LOSS OBSERVED



- Observed Loss
 - Clarifier Weir
 - Effluent
- Unobserved Loss
 - Life Expectancy
 - Birth
 - Aged
 - Deceased
 - 2-3 months?

BOX # 23

CLARIFIER EFFLUENT: SOLIDS LOSS OBSERVED



- Observed Loss
 - Clarifier Weir
 - Effluent
- Unobserved Loss
 - Life Expectancy
 - Birth
 - Aged
 - Deceased
 - 2-3 months?

BOX # 23

CLARIFIER EFFLUENT: SOLIDS LOSS OBSERVED



- Observed Loss
 - Clarifier Weir
 - Effluent
- Unobserved Loss
 - Life Expectancy
 - Birth
 - Aged
 - Deceased
 - 2-3 months?

BOX # 23

CLARIFIER EFFLUENT: SOLIDS LOSS OBSERVED



- Observed Loss
 - Clarifier Weir
 - Effluent
- Unobserved Loss
 - Life Expectancy
 - Birth
 - Aged
 - Deceased
 - 2-3 months?

BOX # 23


CLARIFIER EFFLUENT: SOLIDS LOSS OBSERVED



- Observed Loss
 - Clarifier Weir
 - Effluent
- Unobserved Loss
 - Life Expectancy
 - Birth
 - Aged
 - Deceased
 - 2-3 months?


BOX # 24

COMPLIANCE



BOX # 25

**CLARIFIER:
SLUDGE BLANKET < 30% WATER DEPTH**




- Blanket Depth
- High blanket, less capacity
- Range: 20% to 30%
- Reduce blanket
 - RAS rate correct?
 - Too much biomass?




BOX # 25

**CLARIFIER:
SLUDGE BLANKET < 30% WATER DEPTH**



- Blanket Depth
- High blanket, less capacity
- Range: 20% to 30%
- Reduce blanket
 - RAS rate correct?
 - Too much biomass?



BOX # 25

**CLARIFIER:
SLUDGE BLANKET < 30% WATER DEPTH**



- Blanket Depth
- High blanket,
less capacity
- Range: 20% to 30%
- Reduce blanket
 - RAS rate correct?
 - Too much biomass?


BOX # 27

CLARIFIER: HYDRAULIC ISSUE IN CLARIFIER



- Flow Splitting
- Density Currents
- Effluent Weir
 - Location
 - Elevation

















BOX # 27

CLARIFIER: HYDRAULIC ISSUE IN CLARIFIER



- Flow Splitting
- Density Currents
- Effluent Weir
 - Location
 - Elevation

BOX # 27

CLARIFIER: HYDRAULIC ISSUE IN CLARIFIER



- Flow Splitting
- Density Currents
- Effluent Weir
 - Location
 - Elevation

BOX # 27


CLARIFIER: HYDRAULIC ISSUE IN CLARIFIER



- Flow Splitting
- Density Currents
- Effluent Weir
 - Location
 - Elevation

BOX # 26

CLARIFIER: RAS RATE CORRECT



- RAS rate
 - Slow settling/slow rate
 - Fast settling/fast rate
- Chart settling rate
- Locate “knee”
- Spin Aeration & RAS
- Calculate
 - Increase/decrease
 - Adjust

CALCULATING CORRECT RAS RATE


Spins:

AT = 3.2 %

Actual RAS = 8.8 %

Settleometer Results

Time, mins.	SS, %
0	100
5	78
10	64
15	51
20	42
25	39
30	38



CALCULATING CORRECT RAS RATE

Spins:

AT = 3.2 %
Actual RAS = 8.8 %
Target RAS = 6.3 %

Settleometer Results

Time, mins.	SS, %
0	100
5	78
10	64
15	51
20	42
25	39
30	38

Calculating Correct RAS Rate

1. Volume of Settleometer
at start of analysis:

100

2. Aeration Tank Spin

3.2

3. Settled RAS volume (from Chart)

51

Target RAS Spin:

$$\frac{100 \times 3.2}{51} =$$

6.3%

What adjustment is required to the RAS?

BOX # 29

CLARIFIER: SOR OR SLR > DESIGN CAPACITY



- SOR
 - Surface overflow rate

- SLR
 - Solids loading rate

BOX # 29

CLARIFIER: SOR OR SLR > DESIGN CAPACITY



“Ten States Standards” Clarifiers
=1000 gpd/ft²

- SOR
 - Surface overflow rate

Clarifier: 90 ft diameter
= 6361 ft²

Flow Rate 4.6 mgd

$$\frac{4.6 \text{ mgd}}{6361 \text{ ft}^2} = 723 \text{ gpd/ft}^2$$

BOX # 29

CLARIFIER: SOR OR SLR > DESIGN CAPACITY



Ten States Standards Clarifiers
=35 lbs./d/ft²

- SLR

- Solids loading rate

Clarifier 6361 ft²

MLSS 3,250 mg/L

Inf. Flow 4.6 MGD

RAS Flow 2.3 MGD

$$\frac{3,250 \times 6.9 \times 8.34}{6361 \text{ ft}^2} =$$

29.4 lbs./d/ft²

BOX # 28

CLARIFIER: ADJUST RAS RATE




- Evaluate Rate
- $RAS_{spin} \ 2 \times \text{to} \ 3 \times \ AT_{spin}$
- $RAS_{spin} \ 4 \times \ AT_{spin}$
 - Possible
 - Problems can occur
- Confirm with Core

EVALUATE CORRECT RAS RATE

Spins:

AT = 3.2 %
Actual RAS = 8.8 %
Target RAS = 6.3 %



AT % = 2 to 4%

RAS % = 2 to 3x AT%

Clarifier % < AT%

Time, Minutes

Evaluate Correct RAS Rate

Compare ratio of AT, RAS and Clarifier Spins

Typical Spin Ratios

RAS% 2 to 3 x greater than AT%
RAS > 2x could be RAS too slow


Clarifier % greater than AT % ?
indicates solids stored in clarifier
RAS too slow
Too much mass in system

Develop a trend for "standard" operations,
evaluate periodically, calculate if necessary

ACTIVATED SLUDGE PROCESS CONTROL

Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow red arrow to left, if response is "yes" follow green arrow to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**

<http://epa.ohio.gov>

Divisions and Offices

Environmental and Financial Assistance

Wastewater Treatment Plants:

**Get Free Technical Assistance to Improve
Compliance**

Technical Resources

*Activated Sludge Process Control
and Troubleshooting Chart*

Or email me at: jon.vandommelen@epa.ohio.gov

DISINFECTION

A QUICK GUIDE TO TROUBLESHOOTING
DISINFECTION PROBLEMS

DISINFECTION

- **Three Types**
 - **Chlorine**
 - **Tablet Chlorinator / Dechlorinator**
 - **Chemical process**
 - **Peracetic Acid (PAA)**
 - **Newer technology**
 - **Chemical process**
 - **Ultraviolet Light**
 - **Light wavelength disrupts bacterial DNA**
 - **Physical process**

DISINFECTION: CHLORINE

- **Balance**
 - **Chlorine / Dechlor**
 - **Bacterial limit / Chlorine residual limit**
 - **Enough chlorine to get the kill**
 - **Enough dechlorination to meet chlorine residual**

CHLORINE DISINFECTION



CHLORINE DISINFECTION



Tablet Chlorinator



DISINFECTION: CHLORINE

Chlorine Tablets



Dechlorination Tablets

DISINFECTION: CHLORINE




DISINFECTION: CHLORINE

- Check Free Chlorine Concentration
 - After the Chlorinator in the Chlorine Contact Tank
 - Grab Sample (CLEAN tools and containers!)
 - Must have ~ 0.2 mg/L free Chlorine Residual

DISINFECTION: CHLORINE





DISINFECTION: CHLORINE



DISINFECTION: CHLORINE

- Check Total Chlorine Concentration
 - After Dechlorination (effluent)
 - Grab Sample (CLEAN tools and containers!)
 - Must be within Permitted Limit
 - If measured value < 0.05 mg/L, presumed Compliant

DISINFECTION: CHLORINE



CHLORINE DISINFECTION

- **Conversion First**
 - **Incomplete conversion will impact disinfection**
 - **Chlorine is more effective in “clean water”**
- **No tablets, no hypochlorite, no disinfection, no kill**
 - **Tablets must be in the water, not bridged**

CHLORINE DISINFECTION



PERACETIC ACID (PAA)

- **PAA is gaining a following**
 - **Similar contact time as chlorine**
 - **Can test concentration with Chlorine Test Kit**
 - **Multiply meter result by 1.07 to get PAA concentration**
 - **Seems to be effective disinfectant**
 - **Apparently no residual in receiving stream**
 - **Economical?**

PERACETIC ACID (PAA)



PERACETIC ACID (PAA)

Peragreen® 22WW (ANTIMICROBIAL SOLUTION)

Peragreen® 22WW is a peroxyacetic acid-based microbiocide developed for Bacterial and Algae Control in Wastewater Treatment Systems.

ACTIVE INGREDIENT:

Peroxyacetic Acid 21.5%
Hydrogen Peroxide 5.0%

INERT INGREDIENTS:

73.5%
TOTAL 100.0%

EPA Registration No: 63838-20

EPA Est. No. 63838-CA-01: 63838-AR-001

Before Using This Product, Please Read This Entire Label Carefully.

KEEP OUT OF REACH OF CHILDREN
DANGER- PELIGRO

Si usted no entiende la etiqueta, busque a alguien para que se la explique a usted en detalle.
(If you do not understand this label, find someone to explain it to you in detail.)

FIRST AID

IF IN EYES	<ul style="list-style-type: none">• Hold eye open and rinse slowly and gently with water for 15-20 minutes.• Remove contact lenses, if present, after the first 5 minutes, then continue rinsing eye.• Call a poison control center or doctor for treatment advice.
IF ON SKIN OR CLOTHING	<ul style="list-style-type: none">• Take off contaminated clothing.• Rinse skin immediately with plenty of water for 15-20 minutes.• Call a poison control center or doctor for treatment advice.
IF INHALED	<ul style="list-style-type: none">• Move person to fresh air.• If person is not breathing, call 911 or an ambulance, then give artificial respiration, preferably by mouth-to-mouth, if possible.• Call a poison control center or doctor for treatment advice.
IF SWALLOWED	<ul style="list-style-type: none">• Call a poison control center or doctor immediately for treatment advice.• Have person sip a glass of water if able to swallow.• Do not induce vomiting unless told to do so by a poison control center or doctor.• Do not give anything by mouth to an unconscious person.
QUESTIONS? 1-209-581-9576	Have the product container or label with you when calling a poison control center or doctor, or going for treatment.
NOTE TO PHYSICIAN:	Probable mucosal damage may contraindicate the use of gastric lavage.

PERACETIC ACID (PAA)



ULTRAVIOLET DISINFECTION

- **Ultraviolet is very effective...**
 - **If the light can penetrate the water**
- **Problems**
 - **Proper hydraulic design**
 - **Low suspended solids**
 - **Bulbs must be clean**
 - **Unit must be powered**

ULTRAVIOLET DISINFECTION



ULTRAVIOLET DISINFECTION




ULTRAVIOLET DISINFECTION



ULTRAVIOLET DISINFECTION



ULTRAVIOLET DISINFECTION



Ultraviolet Disinfection

- If light doesn't penetrate the water?
- Substances that impact UV Transmission:
 - Iron
 - Nitrate
 - Dissolved organic matter
 - A variety of chemicals (rare in large quantities)

ULTRAVIOLET DISINFECTION

- How good is your effluent?
- How do you know?



ULTRAVIOLET DISINFECTION



ULTRAVIOLET DISINFECTION



Zero with DI Water



**Read with the
Sample**

DISINFECTION

Measure...



...Don't guess

DISINFECTION

Questions?

jon.vandommelen@epa.ohio.gov

(614) 580-5069

What if . . . ?


Troubleshooting oxidic issues



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.2</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u> </u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.2</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u>65</u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**





What if . . . ?

Clarifier, NH ₃	<u>0.2</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u>65</u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u>No</u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**


Continue until all issues are eliminated and directed to **Box 24: Compliance**



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>11.2</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u> </u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Is the problem in the clarifier or the aeration tank?

Clarifier, NH ₃	<u>11.2</u> mg/L	AT, dissolved oxygen	_____ mg/L
AT, effluent NH ₃	<u>13.8</u> mg/L	AT, concentration	_____ %
AT, water temperature	_____ °C	AT, OLR > design	_____ y/n
AT, total alkalinity	_____ mg/L	AT, toxicity evaluation	_____ y/n

Settleometer, < 80%	_____ %	AT, dissolved oxygen	_____ mg/L
AT, concentration	_____ %	AT, corrosion/septicity	_____ y/n
AT, excess brown foam	_____ y/n		


Clarifier, solids loss observed	_____ y/n	Clarifier, SOR/SLR over design	_____ y/n
Clarifier, blanket depth	_____ %	Clarifier, RAS rate correct	_____ y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**





What if . . . ?

Clarifier, NH ₃	<u>11.2</u> mg/L	AT, dissolved oxygen	_____ mg/L
AT, effluent NH ₃	<u>13.8</u> mg/L	AT, concentration	_____ %
AT, water temperature	<u>21.9</u> °C	AT, OLR > design	_____ y/n
AT, total alkalinity	_____ mg/L	AT, toxicity evaluation	_____ y/n

Settleometer, < 80%	_____ %	AT, dissolved oxygen	_____ mg/L
AT, concentration	_____ %	AT, corrosion/septicity	_____ y/n
AT, excess brown foam	_____ y/n		


Clarifier, solids loss observed	_____ y/n	Clarifier, SOR/SLR over design	_____ y/n
Clarifier, blanket depth	_____ %	Clarifier, RAS rate correct	_____ y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:


Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**





What if . . . ?

Clarifier, NH ₃	<u>11.2</u> mg/L	AT, dissolved oxygen	_____ mg/L
AT, effluent NH ₃	<u>13.8</u> mg/L	AT, concentration	_____ %
AT, water temperature	<u>21.9</u> °C	AT, OLR > design	_____ y/n
AT, total alkalinity	<u>60</u> mg/L	AT, toxicity evaluation	_____ y/n

Settleometer, < 80%	_____ %	AT, dissolved oxygen	_____ mg/L
AT, concentration	_____ %	AT, corrosion/septicity	_____ y/n
AT, excess brown foam	_____ y/n		


Clarifier, solids loss observed	_____ y/n	Clarifier, SOR/SLR over design	_____ y/n
Clarifier, blanket depth	_____ %	Clarifier, RAS rate correct	_____ y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**


Continue until all issues are eliminated and directed to **Box 24: Compliance**



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.3</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u> </u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.3</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u>85</u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.3</u> mg/L	AT, dissolved oxygen	_____ mg/L
AT, effluent NH ₃	_____ mg/L	AT, concentration	_____ %
AT, water temperature	_____ °C	AT, OLR > design	_____ y/n
AT, total alkalinity	_____ mg/L	AT, toxicity evaluation	_____ y/n

Settleometer, < 80%	<u>85</u> %	AT, dissolved oxygen	_____ mg/L
AT, concentration	<u>6.4</u> %	AT, corrosion/septicity	_____ y/n
AT, excess brown foam	_____ y/n		


Clarifier, solids loss observed	_____ y/n	Clarifier, SOR/SLR over design	_____ y/n
Clarifier, blanket depth	_____ %	Clarifier, RAS rate correct	_____ y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**


Continue until all issues are eliminated and directed to **Box 24: Compliance**



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.1</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u> </u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.1</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u>95</u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		


Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . . ?

Clarifier, NH ₃	<u>0.1</u> mg/L	AT, dissolved oxygen	_____ mg/L
AT, effluent NH ₃	_____ mg/L	AT, concentration	_____ %
AT, water temperature	_____ °C	AT, OLR > design	_____ y/n
AT, total alkalinity	_____ mg/L	AT, toxicity evaluation	_____ y/n

Settleometer, < 80%	<u>95</u> %	AT, dissolved oxygen	_____ mg/L
AT, concentration	<u>3.2</u> %	AT, corrosion/septicity	_____ y/n
AT, excess brown foam	_____ y/n		


Clarifier, solids loss observed	_____ y/n	Clarifier, SOR/SLR over design	_____ y/n
Clarifier, blanket depth	_____ %	Clarifier, RAS rate correct	_____ y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**





What if . . . ?

Clarifier, NH ₃	<u>0.1</u> mg/L	AT, dissolved oxygen	_____ mg/L
AT, effluent NH ₃	_____ mg/L	AT, concentration	_____ %
AT, water temperature	_____ °C	AT, OLR > design	_____ y/n
AT, total alkalinity	_____ mg/L	AT, toxicity evaluation	_____ y/n

Settleometer, < 80%	<u>95</u> %	AT, dissolved oxygen	_____ mg/L
AT, concentration	<u>3.2</u> %	AT, corrosion/septicity	_____ y/n
AT, excess brown foam	<u>Yes</u> y/n		


Clarifier, solids loss observed	_____ y/n	Clarifier, SOR/SLR over design	_____ y/n
Clarifier, blanket depth	_____ %	Clarifier, RAS rate correct	_____ y/n



Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left , if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



Other signs of filaments



What if . . . ?

Clarifier, NH ₃	<u>6.4</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u> </u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u> </u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		

Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n



What if . . . ?

Clarifier, NH ₃	<u>6.4</u> mg/L	AT, dissolved oxygen	<u> </u> mg/L
AT, effluent NH ₃	<u>0.5</u> mg/L	AT, concentration	<u> </u> %
AT, water temperature	<u> </u> °C	AT, OLR > design	<u> </u> y/n
AT, total alkalinity	<u> </u> mg/L	AT, toxicity evaluation	<u> </u> y/n

Settleometer, < 80%	<u> </u> %	AT, dissolved oxygen	<u> </u> mg/L
AT, concentration	<u> </u> %	AT, corrosion/septicity	<u> </u> y/n
AT, excess brown foam	<u> </u> y/n		

Clarifier, solids loss observed	<u> </u> y/n	Clarifier, SOR/SLR over design	<u> </u> y/n
Clarifier, blanket depth	<u> </u> %	Clarifier, RAS rate correct	<u> </u> y/n






Activated Sludge Process Control and Troubleshooting Chart

Ohio EPA, DSW, CAU

November 2014



Directions:

Begin with **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

If response is "no" follow **red arrow** to left, if response is "yes" follow **green arrow** to right.

Apply corrective action then return to **Box 1: Clarifier Effluent: Ammonia < 1 mg/L**

Continue until all issues are eliminated and directed to **Box 24: Compliance**



What if . . .

