

# IPM Model – Revisions to Cost and Performance for APC Technologies

## Wet FGD Cost Development Methodology

**FINAL**

August 2010

Project 12301-007

Perrin Quarles Associates, Inc.

Prepared by



55 East Monroe Street • Chicago, IL 60603 USA • 312-269-2000

## **LEGAL NOTICE**

*This analysis ("Deliverable") was prepared by Sargent & Lundy, L.L.C. ("S&L"), expressly for the sole use of Perrin Quarles Associates, Inc. ("Client") in accordance with the agreement between S&L and Client. This Deliverable was prepared using the degree of skill and care ordinarily exercised by engineers practicing under similar circumstances. Client acknowledges: (1) S&L prepared this Deliverable subject to the particular scope limitations, budgetary and time constraints, and business objectives of the Client; (2) information and data provided by others may not have been independently verified by S&L; and (3) the information and data contained in this Deliverable are time sensitive and changes in the data, applicable codes, standards, and acceptable engineering practices may invalidate the findings of this Deliverable. Any use or reliance upon this Deliverable by third parties shall be at their sole risk.*

*This work was funded and reviewed by the U.S. Environmental Protection Agency under the supervision of William A. Stevens, Senior Advisor – Power Technologies. Additional input and review was provided by Dr. Jim Staudt, President of Andover Technology Partners.*

## Wet FGD Cost Development Methodology – Final

### Establishment of Cost Basis

The 2004 to 2006 industry cost estimates for wet FGD units from the "Analysis of MOG and Ladco's FGD and SCR Capacity and Cost Assumptions in the Evaluation of Proposed EGU 1 and EGU 2 Emission Controls" prepared for Midwest Ozone Group (MOG) were compared to the Sargent & Lundy LLC (S&L) in-house database. Agreement of the data was confirmed between the industry estimates and the S&L data.

The MOG and S&L cost data from 2004 to 2006 were converted to 2007 dollars based on the Chemical Engineering Plant Index (CEPI) data. Additional proprietary S&L in-house data from 2007 were included to confirm the index validity.

Cost data from the various sources showed similar trends versus generating capacity. Escalation based on the CEPI was deemed acceptable. All three data sources were combined so as to provide a representative wet FGD cost basis.

The 2004 through 2007 data were escalated to 2009 to represent market conditions.

The least squares curve fit of the data was defined as a "typical" wet FGD retrofit for removal of 98% of the inlet sulfur. It should be noted that the lowest available SO<sub>2</sub> emission guarantees, from the original equipment manufactures of wet FGD systems, are 0.04 lb/MMBtu. The typical wet FGD retrofit was based on:

- Retrofit Difficulty = 1 (Average retrofit difficulty) ;
- Gross Heat Rate = 9500 Btu/kWh;
- SO<sub>2</sub> Rate = 3.0 lb/MMBtu;
- Type of Coal = Bituminous;
- Project Execution = Multiple lump sum contracts; and
- Recommended SO<sub>2</sub> emission floor = 98% removal efficiency or 0.06 lb/MMBtu.

Units below 100 MW will typically not install a wet FGD system. Sulfur reductions for the small units would be accomplished by; treating smaller units at a single site with one wet FGD system, switching to a lower sulfur coal, repowering with natural gas, dry sorbent injection, and/or a reduction in operating hours. Capital costs of approximately \$750/kW may be used for units below 100 MW under the premise that these will be combined.

## Wet FGD Cost Development Methodology – Final

### Methodology

#### Inputs

Several input variables are required in order to predict future retrofit costs. The gross unit size in MW (equivalent acfm) and sulfur content of the fuel are the major variables for the capital estimation. A retrofit factor that equates to difficulty in construction of the system must be defined. The costs herein could increase significantly for congested sites. The gross unit heat rate will factor into the amount of flue gas generated and ultimately the size of the absorber, reagent preparation, waste handling, and balance of plant costs. The SO<sub>2</sub> rate will have the greatest influence on the reagent handling and waste handling facilities. The type of fuel (Bituminous, PRB, or Lignite) will influence the flue gas quantities as a result of the different typical heating values.

The evaluation includes a user selected option for a wastewater treatment facility. The base capital cost includes minor physical and chemical wastewater treatment. However, in the future more extensive wastewater handling may be required. Although an option for wastewater treatment is provided, no logic has been developed to accommodate the additional wastewater treatment costs.

#### Outputs

##### **Total Project Costs (TPC)**

First the base installed costs are calculated for each required module (BM<sub>i</sub>). The base installed costs include:

- All equipment;
- Installation;
- Buildings;
- Foundations;
- Electrical;
- Minor physical and chemical wastewater treatment (WWT); and
- Average retrofit difficulty.

The modules are:

BMR =	Base absorber island cost
BMF =	Base reagent preparation cost
BMW =	Base waste handling cost
BMB =	Base balance of plan costs including: ID or booster fans, new wet chimney, piping, ductwork, minor WWT, etc.
BMWW =	Base wastewater treatment facility for future use.
BM =	BMR + BMF + BMW + BMB

## **Wet FGD Cost Development Methodology – Final**

The total base installed cost (BM) is then increased by:

- Engineering and construction management costs at 10% of the BM cost;
- Labor adjustment for 6 x 10 hour shift premium, per diem, etc., at 10% of the BM cost; and
- Contractor profit and fees at 10% of the BM cost.

A capital, engineering, and construction cost subtotal (CECC) is established as the sum of the BM and the additional engineering and construction fees.

Additional costs and financing expenditures for the project are computed based on the CECC. Financing and additional project costs include:

- Owner's home office costs (owner's engineering, management, and procurement) at 5% of the CECC; and
- Allowance for Funds Used During Construction (AFUDC) at 10% of the CECC and owner's costs. The AFUDC is based on a three-year engineering and construction cycle.

The total project cost is based on a multiple lump sum contract approach. Should a turnkey engineering procurement construction (EPC) contract be executed, the total project cost could be 10 to 15% higher than what is currently estimated.

Escalation is not included in the estimate. The total project cost (TPC) is the sum of the CECC and the additional costs and financing expenditures. Table 1 contains an example capital cost estimation.

### Wet FGD Cost Development Methodology – Final

**Table 1. Example Capital Cost Estimate for the Wet FGD System (Costs are all based on 2009 dollars)**

Variable	Designation	Units	Value	Calculation
Wastewater Treatment		Minor physical/chemical		
Unit Size (Gross)	A	(MW)	500	<--- User Input (Greater than 100 MW)
Retrofit Factor	B		1	<--- User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	<--- User Input
SO2 Rate	D	(lb/MMBtu)	3	<--- User Input
Type of Coal	E		Bituminuous	<--- User Input
Coal Factor	F		1	Bit=1, PRB=1.05, Lig=1.07
Heat Rate Factor	G		0.95	C/10000
Heat Input	H	(Btu/hr)	4.75E+09	A*C*1000

**Capital Cost Calculation**

Includes - Equipment, installation, buildings, foundations, electrical, minor physical/chemical wastewater treatment and retrofit difficulty

BMR (\$) =  $550000 \cdot (B) \cdot ((F \cdot G)^{0.6}) \cdot ((D/2)^{0.02}) \cdot (A^{0.716})$

BMF (\$) =  $190000 \cdot (B) \cdot ((D \cdot G)^{0.3}) \cdot (A^{0.716})$

BMW (\$) =  $100000 \cdot (B) \cdot ((D \cdot G)^{0.45}) \cdot (A^{0.716})$

BMB (\$) =  $1010000 \cdot (B) \cdot ((F \cdot G)^{0.4}) \cdot (A^{0.716})$

BMWW (\$) =

BM (\$) = BMR + BMF + BMW + BMB + BMWW

BM (\$/kW) =

**Total Project Cost**

A1 = 10% of BM

A2 = 10% of BM

A3 = 10% of BM

CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3

CECC (\$/kW) - Excludes Owner's Costs =

B1 = 5% of CECC

TPC' (\$) - Includes Owner's Costs = CECC + B1

TPC' (\$/kW) - Includes Owner's Costs =

B2 = 10% of (CECC + B1)

TPC (\$) - Includes Owner's Costs and AFUDC = CECC + B1 + B2

TPC (\$/kW) - Includes Owner's Costs and AFUDC =

**Example**

**Comments**

\$ 46,024,000

Base absorber island cost

\$ 22,267,000

Base reagent preparation cost

\$ 13,713,000

Base waste handling cost

\$ 84,698,000

Base balance of plan costs including:  
ID or booster fans, new wet chimney, piping, ductwork, minor WWT, etc...

\$ -

Base wastewater treatment facility, beyond minor physical/chemical  
treatment

\$ 166,702,000

Total base cost including retrofit factor

333

Base cost per kW

\$ 16,670,000

Engineering and Construction Management costs

\$ 16,670,000

Labor adjustment for 6 x 10 hour shift premium, per diem, etc...

\$ 16,670,000

Contractor profit and fees

\$ 216,712,000

Capital, engineering and construction cost subtotal

433

Capital, engineering and construction cost subtotal per kW

\$ 10,836,000

Owners costs including all "home office" costs (owners engineering,  
management, and procurement activities)

\$ 227,548,000

Total project cost without AFUDC

455

Total project cost per kW without AFUDC

\$ 22,755,000

AFUDC (Based on a 3 year engineering and construction cycle)

\$ 250,303,000

Total project cost

501

Total project cost per kW

## **Wet FGD Cost Development Methodology – Final**

### ***Fixed O&M (FOM)***

The fixed operating and maintenance (O&M) cost is a function of the additional operations staff (FOMO), maintenance labor and materials (FOMM), and administrative labor (FOMA) associated with the wet FGD installation. A future fixed O&M cost category is included to account for an extensive wastewater treatment facility. At this time, the wastewater treatment fixed O&M (FOMWW) is not estimated and is included at zero dollars. The FOM is the sum of the FOMO, FOMM, FOMA, and FOMWW.

The following factors and assumptions underlie calculations of the FOM:

- All of the FOM costs were tabulated on a per kilowatt-year (kW yr) basis.
- In general, 12 additional operators are required for a 500 MW or smaller installation. Units larger than 500 MW require a total of 16 additional operators. The FOMO was based on the number of additional operations staff required as a function of generating capacity.
- The fixed maintenance materials and labor is a direct function of the process capital cost (BM).
- The administrative labor is a function of the FOMO and FOMM.

### ***Variable O&M (VOM)***

Variable O&M is a function of:

- Reagent use and unit costs;
- Waste production and unit disposal costs;
- Additional power required and unit power cost; and
- Makeup water required and unit water cost.

### **Wet FGD Cost Development Methodology – Final**

The following factors and assumptions underlie calculations of the VOM:

- All of the VOM costs were tabulated on a per megawatt-hour (MWh) basis.
- The reagent usage is a function of gross unit size, SO<sub>2</sub> feed rate, and removal efficiency. The estimated reagent usage was based on a sulfur removal efficiency of 98% and a calcium-to-sulfur stoichiometric ratio of 1.03. The basis for the limestone purity was 90% CaCO<sub>3</sub> with the balance being inert material.
- The waste generation rate is directly proportional to the reagent usage and is estimated based on 10% moisture in the by-product.
- The additional power required includes increased fan power to account for the added wet FGD pressure drop. This requirement is a function of gross unit size (actual gas flow rate) and sulfur rate.
- The makeup water rate is a function of gross unit size (actual gas flow rate) and sulfur feed rate.

Input options are provided for the user to adjust the variable O&M costs per unit. Average default values are included in the base estimate. The variable O&M costs per unit options are:

- Limestone cost in \$/ton;
- Waste disposal costs in \$/ton;
- Auxiliary power cost in \$/kWh;
- Makeup water costs in \$/1000 gallon; and
- Operating labor rate (including all benefits) in \$/hr.



**Wet FGD Cost Development Methodology – Final**

The variables that contribute to the overall VOM are:

VOMR =	Variable O&M costs for limestone reagent
VOMW =	Variable O&M costs for waste disposal
VOMP =	Variable O&M costs for additional auxiliary power
VOMM =	Variable O&M costs for makeup water
VOMWW =	Variable O&M costs for wastewater treatment

A future variable O&M cost category is included to account for an extensive wastewater treatment facility. At this time, the wastewater treatment variable O&M (VOMWW) is not estimated and is included at zero dollars.

The total VOM is the sum of VOMR, VOMW, VOMP, VOMM, and VOMWW. Table 2 contains an example O&M cost estimate, while Table 3 is a complete capital and O&M cost estimate worksheet.

### Wet FGD Cost Development Methodology – Final

**Table 2. Example O&M Cost Estimate for the Wet FGD System (Costs are all based on 2009 dollars)**

Variable	Designation	Units	Value	Calculation
Wastewater Treatment		Minor physical/chemical		
Unit Size (Gross)	A	(MW)	500	<--- User Input (Greater than 100 MW)
Retrofit Factor	B		1	<--- User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	<--- User Input
SO2 Rate	D	(lb/MMBtu)	3	<--- User Input
Type of Coal	E	Bituminuous		<--- User Input
Coal Factor	F		1	Bit=1, PPR=1.05, Lig=1.07
Heat Rate Factor	G		0.95	C/10000
Heat Input	H	(Btu/hr)	4.75E+09	A*C*1000
Limestone Rate	K	(ton/hr)	12	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	23	1.811*K
<b>Aux Power</b>	<b>M</b>	(%)	<b>1.59</b>	<b>(1.05e^(0.155*D))*F*G Should be used for model input.</b>
Makeup Water Rate	N	(1000 gph)	38	(1.674*D+74.68)*A*F*G/1000
Limestone Cost	P	(\$/ton)	15	
Waste Disposal Cost	Q	(\$/ton)	30	
Aux Power Cost	R	(\$/kWh)	0.06	
Makeup Water Cost	S	(\$/1000)	1	
Operating Labor Rate	T	(\$/hr)	60	Labor cost including all benefits

**Fixed O&M Cost**

FOMO (\$/kW yr) = (if MW>500 then 16 additional operators else 12 operators)*2080*T/(A*1000)	\$	3.00	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.015/(B*A*1000)	\$	5.00	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	\$	0.15	Fixed O&M additional administrative labor costs
FOMWW (\$/kW yr) =	\$	-	Fixed O&M costs for wastewater treatment facility
<b>FOM (\$/kW yr) = FOMO + FOMM + FOMA + FOMWW</b>	<b>\$</b>	<b>8.15</b>	<b>Total Fixed O&amp;M costs</b>

**Variable O&M Cost**

VOMR (\$/MWh) = K*P/A	\$	0.37	Variable O&M costs for limestone reagent
VOMW (\$/MWh) = L*Q/A	\$	1.36	Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	\$	-	Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	\$	0.08	Variable O&M costs for makeup water
VOMWW (\$/MWh) =	\$	-	Variable O&M costs for wastewater treatment facility
<b>VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW</b>	<b>\$</b>	<b>1.81</b>	



IPM Model – Revisions to Cost and Performance for  
APC Technologies

Project No. 12301-007  
August 20, 2010

### Wet FGD Cost Development Methodology – Final

**Table 3. Example Complete Cost Estimate for the Wet FGD System (Costs are all based on 2009 dollars)**

Variable	Designation	Units	Value	Calculation
Wastewater Treatment		Minor physical/chemical		
Unit Size (Gross)	A	(MW)	500	<--- User Input (Greater than 100 MW)
Retrofit Factor	B		1	<--- User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	<--- User Input
SO2 Rate	D	(lb/MMBtu)	3	<--- User Input
Type of Coal	E		Bituminous	<--- User Input
Coal Factor	F		1	Bit=1, PRB=1.05, Lig=1.07
Heat Rate Factor	G		0.95	C/10000
Heat Input	H	(Btu/hr)	4.75E+09	A*C*1000
Limestone Rate	K	(ton/hr)	12	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	23	1.811*K
<b>Aux Power</b>	<b>M</b>	(%)	<b>1.59</b>	<b>(1.05e^(0.155*D))*F*G Should be used for model input.</b>
Makeup Water Rate	N	(1000 gph)	38	(1.674*D+74.68)*A*F*G/1000
Limestone Cost	P	(\$/ton)	15	
Waste Disposal Cost	Q	(\$/ton)	30	
Aux Power Cost	R	(\$/kWh)	0.06	
Makeup Water Cost	S	(\$/1000)	1	
Operating Labor Rate	T	(\$/hr)	60	Labor cost including all benefits

**Capital Cost Calculation**

Includes - Equipment, installation, buildings, foundations, electrical, minor physical/chemical wastewater treatment and retrofit difficulty

BMR (\$) =  $550000*(B)*((F*G)^{0.6})*((D/2)^{0.02})*(A^{0.716})$

BMF (\$) =  $190000*(B)*((D*G)^{0.3})*(A^{0.716})$

BMW (\$) =  $100000*(B)*((D*G)^{0.45})*(A^{0.716})$

BMB (\$) =  $1010000*(B)*((F*G)^{0.4})*(A^{0.716})$

BMWW (\$) =

BM (\$) = BMR + BMF + BMW + BMB + BMWW

BM (\$/KW) =

**Example**

\$ 46,024,000

\$ 22,267,000

\$ 13,713,000

\$ 84,698,000

\$ -

\$ 166,702,000

333

**Comments**

Base absorber island cost

Base reagent preparation cost

Base waste handling cost

Base balance of plan costs including:  
ID or booster fans, new wet chimney, piping, ductwork, minor WWT, etc...

Base wastewater treatment facility, beyond minor physical/chemical treatment

Total base cost including retrofit factor

Base cost per kW

**Total Project Cost**

A1 = 10% of BM

A2 = 10% of BM

A3 = 10% of BM

**CECC (\$) - Excludes Owner's Costs = BM+A1+A2+A3**

**CECC (\$/kW) - Excludes Owner's Costs =**

B1 = 5% of CECC

**TPC' (\$) - Includes Owner's Costs = CECC + B1**

**TPC' (\$/kW) - Includes Owner's Costs =**

B2 = 10% of (CECC + B1)

**TPC (\$) - Includes Owner's Costs and AFUDC = CECC + B1 + B2**

**TPC (\$/kW) - Includes Owner's Costs and AFUDC =**

\$ 16,670,000

\$ 16,670,000

\$ 16,670,000

\$ **216,712,000**

**433**

\$ 10,836,000

\$ **227,548,000**

**455**

\$ 22,755,000

\$ **250,303,000**

**501**

Engineering and Construction Management costs

Labor adjustment for 6 x 10 hour shift premium, per diem, etc...

Contractor profit and fees

Capital, engineering and construction cost subtotal

Capital, engineering and construction cost subtotal per kW

Owners costs including all "home office" costs (owners engineering, management, and procurement activities)

Total project cost without AFUDC

Total project cost per kW without AFUDC

AFUDC (Based on a 3 year engineering and construction cycle)

Total project cost

Total project cost per kW



IPM Model – Revisions to Cost and Performance for  
APC Technologies

Project No. 12301-007  
August 20, 2010

### Wet FGD Cost Development Methodology – Final

Variable	Designation	Units	Value	Calculation
Wastewater Treatment		Minor physical/chemical		
Unit Size (Gross)	A	(MW)	500	<--- User Input (Greater than 100 MW)
Retrofit Factor	B		1	<--- User Input (An "average" retrofit has a factor = 1.0)
Gross Heat Rate	C	(Btu/kWh)	9500	<--- User Input
SO2 Rate	D	(lb/MMBtu)	3	<--- User Input
Type of Coal	E		Bituminous	<--- User Input
Coal Factor	F		1	Bit=1, PRB=1.05, Lig=1.07
Heat Rate Factor	G		0.95	C/10000
Heat Input	H	(Btu/hr)	4.75E+09	A*C*1000
Limestone Rate	K	(ton/hr)	12	17.52*A*D*G/2000
Waste Rate	L	(ton/hr)	23	1.811*K
<b>Aux Power</b>	<b>M</b>	<b>(%)</b>	<b>1.59</b>	<b>(1.05e^(0.155*D))*F*G Should be used for model input.</b>
Makeup Water Rate	N	(1000 gph)	38	(1.674*D+74.68)*A*F*G/1000
Limestone Cost	P	(\$/ton)	15	
Waste Disposal Cost	Q	(\$/ton)	30	
Aux Power Cost	R	(\$/kWh)	0.06	
Makeup Water Cost	S	(\$/1000)	1	
Operating Labor Rate	T	(\$/hr)	60	Labor cost including all benefits

**Fixed O&M Cost**

FOMO (\$/kW yr) = (if MW>500 then 16 additional operators else 12 operators)*2080*T/(A*1000)	\$	3.00	Fixed O&M additional operating labor costs
FOMM (\$/kW yr) = BM*0.015/(B*A*1000)	\$	5.00	Fixed O&M additional maintenance material and labor costs
FOMA (\$/kW yr) = 0.03*(FOMO+0.4*FOMM)	\$	0.15	Fixed O&M additional administrative labor costs
FOMWW (\$/kW yr) =	\$	-	Fixed O&M costs for wastewater treatment facility
<b>FOM (\$/kW yr) = FOMO + FOMM + FOMA + FOMWW</b>	<b>\$</b>	<b>8.15</b>	<b>Total Fixed O&amp;M costs</b>

**Variable O&M Cost**

VOMR (\$/MWh) = K*P/A	\$	0.37	Variable O&M costs for limestone reagent
VOMW (\$/MWh) = L*Q/A	\$	1.36	Variable O&M costs for waste disposal
VOMP (\$/MWh) = M*R*10	\$	-	Variable O&M costs for additional auxiliary power required including additional fan power (Refer to Aux Power % above)
VOMM (\$/MWh) = N*S/A	\$	0.08	Variable O&M costs for makeup water
VOMWW (\$/MWh) =	\$	-	Variable O&M costs for wastewater treatment facility
<b>VOM (\$/MWh) = VOMR + VOMW + VOMP + VOMM + VOMWW</b>	<b>\$</b>	<b>1.81</b>	