



Technical Support Document (TSD) for AERMOD-Based Assessments of Long-Range Transport Impacts for Primary Pollutants

Technical Support Document (TSD) for AERMOD-Based Assessments of Long-Range
Transport Impacts for Primary Pollutants

U.S. Environmental Protection Agency
Office of Air Quality Planning and Standards
Air Quality Assessment Division
Air Quality Modeling Group
Research Triangle Park, North Carolina

Preface

This document provides the results and interpretation of AERMOD screening and refined model simulations to estimate the pollutant concentration impacts in the near-field (i.e., less than 50km from source) and far-field (i.e., greater than 50km from source) for a wide range of source types for the purposes of informing the 2016 revisions to EPA's Guideline on Air Quality Models (published as Appendix W to 40 CFR Part 51). This document is not intended to demonstrate methods to assess facility impacts for NAAQS or PSD increment nor is it intended to provide any guidance on the usage of screening for long-range transport or any other regulatory analyses.

Contents

Preface	5
Contents	6
Tables	8
Figures	9
1. Introduction	10
2. Background	10
3.0 Approach to evaluating near-source and long-range impacts	13
3.1 Source Types and Characteristics	13
3.2 Modeling Assessment Overview	14
4. Summary of results	16
4.1 Phase 1: NO ₂ and SO ₂ NAAQS screening	16
4.2 Phase 2: Refined analyses for NO ₂ and SO ₂	23
4.2.1 1-hour NAAQS Results	24
4.2.2 3-hour, 24-hour, and annual PSD increment results	27
4.3 Phase 2: Refined analyses for PM ₁₀ and PM _{2.5}	28
4.3.1 24-hour NAAQS results	29
4.3.2 Annual NAAQS and PSD increment results	29
4.3.2 24-hour PSD increment results	30
5. Conclusions	31
6. Additional information	31
References	32
Appendix A	33
Plots and tables from the NO ₂ and SO ₂ NAAQS screening analysis	33
Appendix B	45
Plots from NO ₂ and SO ₂ refined analysis	45
B.1 Comparisons against the 1-hour NO ₂ and SO ₂ NAAQS	45
B.2 Comparisons against the 3 and 24-hour SO ₂ PSD increment	50
B.3 Comparisons against the annual NO ₂ and SO ₂ PSD increment	54
Appendix C	58
Plots from PM refined analysis	58
C.1 Comparisons against the PM _{2.5} 24-hour NAAQS	59
C.2 Comparisons against the annual PSD increment and NAAQS	63

C.3 Comparisons against the PM2.5 24-hour PSD increment..... 67

Tables

Table 1 - Significant Impact Levels (SILs) for NAAQS by Criteria Pollutant.....	11
Table 2 - PSD Increment and associated SILs for Criteria Pollutants by Class I, Class II, and Class III Areas.	12
Table 3 - Summary of Modeling Scenarios by Source Type from AERMOD Implementation Workgroup (AIWG).....	14
Table 4 - Phase 1 Screening Modeling Results for NO ₂ and SO ₂ by Facility type: Maximum Impact Results	20
Table 5 - Phase 1 screening modeling results for NO ₂ and SO ₂ by Facility type: Maximum Impact Results at 50 km scaled to Reflect Near-Field NAAQS Compliance.....	22
Table 6 - Summary of NO ₂ and SO ₂ emissions for the coal EGU facility	23
Table 7 – Phase 2 Refine Modeling Results for NO ₂ by NWS Station	25
Table 8 - Phase 2 Refine Modeling Results for SO ₂ by NWS Station.....	26
Table 9 - Scaling factors from NAAQS refined analysis for use in PSD increment refined analysis.....	27
Table 10 - Phase 2 refined modeling results for NO ₂ and SO ₂ PSD increments by NWS station.....	28
Table 11- - Summary of 2011 NEI emission data used in refined modeling analysis	29
Table 12 – Phase 2 refined modeling results for 24-hour PM _{2.5} NAAQS by NWS station.....	29
Table 13 – Phase 2 refined modeling results for annual PM _{2.5} NAAQS and PSD increment by NWS station	30
Table 14 – Phase 2 refined modeling results for 24-hour PM _{2.5} PSD increment by NWS station	30
Table A.1 - Phase 1 screening modeling results for NO ₂ and SO ₂ by Facility type: 8th and 4th high results from screening analysis.....	30
Table A.1 - Phase 1 screening modeling results for NO ₂ and SO ₂ by Facility type: 8th and 4th high results from screening analysis (continued).....	31

Figures

Figure 1 – Location of receptors for screening and refined runs.	17
Figure 2 - Results from the screening analysis for the asphalt plant.....	35
Figure 3 - Results from the screening analysis for the biomass plant	36
Figure 4 - Results from the screening analysis for the cement kiln.....	37
Figure 5 - Results from the screening analysis for the coal EGU	38
Figure 6 - Results from the screening analysis for the ethanol plant	39
Figure 7 - Results from the screening analysis for the flare	40
Figure 8 - Results from the screening analysis for the fuel oil turbine	41
Figure 9 - Results from the screening analysis for the landfill gas turbine	42
Figure 10 - Results from the screening analysis for the natural gas compressor station.....	43
Figure 11 - Results from the screening analysis for the pulp and paper plant.....	44
Figure 12 - Refined NO ₂ and SO ₂ results, ASX, max and design values, 1-hour NAAQS	46
Figure 13 - Refined NO ₂ and SO ₂ results, DHT, max and design values, 1-hour NAAQS.....	47
Figure 14 - Refined NO ₂ and SO ₂ results, OAK, max and design values, 1-hour NAAQS.....	48
Figure 15 - Refined NO ₂ and SO ₂ results, SMQ, max and design values, 1-hour NAAQS.....	49
Figure 16 - Refined SO ₂ results, ASX, 3 & 24-hour PSD increment	50
Figure 17 - Refined SO ₂ results, DHT, 3 & 24-hour PSD increment.....	51
Figure 18 - Refined SO ₂ results, OAK, 3 & 24-hour PSD increment	52
Figure 19 - Refined SO ₂ results, SMQ, 3 & 24-hour PSD increment.....	53
Figure 20 - Refined NO ₂ & SO ₂ results, ASX, annual NAAQS	54
Figure 21 - Refined NO ₂ & SO ₂ results, DHT, annual NAAQS	55
Figure 22 - Refined NO ₂ & SO ₂ results, OAK, annual NAAQS	56
Figure 23 - Refined NO ₂ & SO ₂ results, SMQ, annual NAAQS	57
Figure 24 - Refined PM _{2.5} results, ASX, 24-hour NAAQS	59
Figure 25 - Refined PM _{2.5} results, DHT, 24-hour NAAQS.....	60
Figure 26 - Refined PM _{2.5} results, OAK, 24-hour NAAQS	61
Figure 27 - Refined PM _{2.5} results, SMQ, 24-hour NAAQS	62
Figure 28 - Refined PM _{2.5} results, ASX, annual PSD increment and NAAQS	63
Figure 29 - Refined PM _{2.5} results, DHT, annual PSD increment and NAAQS.....	64
Figure 30 - Refined PM _{2.5} results, OAK, annual PSD increment and NAAQS	65
Figure 31 - Refined PM _{2.5} results, SMQ, annual PSD increment and NAAQS	66
Figure 32 - Refined PM _{2.5} results, ASX, 24-hour PSD increment.....	67
Figure 33 - Refined PM _{2.5} results, DHT, 24-hour PSD increment	68
Figure 34 - Refined PM _{2.5} results, OAK, 24-hour PSD increment	69
Figure 35 - Refined PM _{2.5} results, SMQ, 24-hour PSD increment	70

1. Introduction

For long-range transport (LRT) applications at distances of more than 50 km from a source, the final revisions to EPA's *Guideline on Air Quality Models* (published as Appendix W to 40 CFR Part 51) include recommendations for a screening approach for addressing the NAAQS and Prevention of Significant Deterioration (PSD) increment and removal of CALPUFF as an EPA preferred model for such applications. In supporting these final revisions, the purpose of the modeling assessment detailed in this document is to demonstrate what types of facilities may have significant impacts for NAAQS or PSD increment at distances greater than 50 km from the source. While EPA has not determined a replacement refined model for LRT applications under the revised *Guideline*, the information provided in this report indicates that the need for LTR assessments for NAAQS and PSD increment violations for inert pollutants is limited, thereby mitigating the necessity for a preferred regulatory model for LTR assessments. This document provides technical details of the modeling assessment, including summarizing the model scenarios and approach used to determine the air quality impact of a range of source types on pollutant concentrations in the near-field (*i.e.*, within 50 km) and far-field (beyond 50 km).

2. Background

The permitting process for the PSD program requires that a new or modifying source demonstrate that the additional emissions will not cause or contribute to a violation of the NAAQS or PSD increment. The traditional approach for demonstrating compliance is a two-stage approach, as recommended in section 9.2.3 of the *Guideline*, and has been applied in the PSD program for more than 25 years. Under this two-stage approach, permitting authorities have issued PSD permits based on a demonstration that the air quality impacts of a proposed source are below levels of impact considered to be significant. In this document, significant impact levels (SILs) are used for illustrative purposes as a demonstration tool to determine the culpability of a new or modifying source to any NAAQS or PSD increment violations. In this context, a modeled ambient impact from a proposed new or modified source that is determined to be less than the applicable SIL is generally considered not to "cause or contribute" to any modeled violations of the relevant NAAQS or PSD increment.

Table 1 shows the SIL levels for NAAQS by criteria pollutant (*i.e.*, PM_{2.5}, PM₁₀, SO₂, NO₂, and CO), while Table 2 shows the PSD increment levels and associated SIL levels of PM_{2.5}, PM₁₀, SO₂, and NO₂. In 1996, a rulemaking was proposed with Class I specific SILs for NO₂, SO₂, and PM₁₀ (U. S. EPA, 1996). Please note that these SILs for Class I PSD increments have never been promulgated; however, the values shown in Table 2 have been used in practice under the PSD program over the past 20 years.

For most PSD compliance demonstrations, the near-source impacts (*e.g.*, those occurring within 50 km of the new or modifying source) are the controlling factor in successfully meeting Clean Air Act (CAA) requirements. For the inert criteria pollutants, these near-source impacts are assessed with the EPA's preferred dispersion model, AERMOD (Cimorelli, et al, 2005). Due to variations in meteorology that are expected to occur beyond 50 km and the time required for a plume to travel this distance, steady-state plume models like AERMOD are expected to be conservative in the far-field. Thus, when LRT is expected to be important (*i.e.*, impacts beyond the nominal distance of 50 km), an alternative model is necessary for assessing impacts for those distances with the previous *Guideline* recommending the use of the CALPUFF modeling system (U. S. EPA, 2003). Section 6.2.3 of the 2005 version of the *Guideline* discusses the regulatory needs for LRT impact assessments. The focus in section 6.2.3 is the need to protect Class I

areas and, in particular, Class I PSD increments are identified as the most stringent regulatory benchmarks in the PSD program. While refined LRT modeling could also be needed for NAAQS, it is uncommon that a facility can demonstrate compliance for a NAAQS and not also comply with applicable PSD increment(s).

Table 1 - Significant Impact Levels (SILs) for NAAQS by Criteria Pollutant.

Pollutant	Class I	Class II	Class III	Source
Fine Particulate Matter (PM_{2.5})				
Annual mean	*	0.2 (0.3) ¹ ug/m ³	*	40 CFR 51.165 (b)(2) (U.S. EPA, 2016)
24-hour maximum	*	1.2 ug/m ³	*	
Particulate Matter (PM₁₀)				
Annual arithmetic mean	*	1 ug/m ³	*	40 CFR 51.165(b)(2)
24-hour maximum	*	5 ug/m ³	*	
Carbon Monoxide (CO)				
8-hour maximum	*	500 ug/m ³	*	40 CFR 51.165(b)(2)
1-hour maximum	*	2000 ug/m ³	*	
Sulfur Dioxide (SO₂)				
Annual mean	*	1 ug/m ³	*	40 CFR 51.165(b)(2)
24-hour maximum	*	5 ug/m ³	*	
3-hour maximum	*	25 ug/m ³	*	
1-hour maximum	*	3 ppb (~7.8 ug/m ³)	*	(U. S. EPA, 2010b)
Nitrogen Dioxide (NO₂):				
Annual mean	*	1 ug/m ³	*	40 CFR 51.165(b)(2)
1-hour maximum	*	4 ppb (~7.5 ug/m ³)	*	(U. S. EPA, 2010a)

On August 1, 2016 the EPA released draft guidance with new PM_{2.5} SILs based on a new technical analysis (U.S. EPA, 2016). The draft guidance recommended the most conservative values from either 51.165 and the new technical analysis, which is 0.2 ug/m³ for the annual standard and 1.2 ug/m³ for the 24-hour standard.

Table 2 - PSD Increment² and associated SILs for Criteria Pollutants by Class I, Class II, and Class III Areas.

Pollutant	Class I	Class II	Class III	Source
Fine Particulate Matter (PM_{2.5})				
Annual mean ug/m ³	1 (0.05)	4 (0.2)	8 (0.2)	(U.S. EPA, 2016) ³
24-hour maximum ug/m ³	2 (0.27)	9 (1.2)	18 (1.2)	(U.S. EPA, 2016)
Particulate Matter (PM₁₀)				
Annual mean ug/m ³	4 (0.2)	17 (1)	34 (1)	61 FR 38338 (July, 23 1996) ⁴
24-hour maximum ug/m ³	8 (0.3)	30 (5)	60 (5)	61 FR 38338 (July, 23 1996)
Sulfur Dioxide (SO₂)				
Annual mean ug/m ³	2 (0.1)	20 (1)	40 (1)	61 FR 38338 (July, 23 1996)
24-hour maximum ug/m ³	5 (0.2)	91 (5)	182 (5)	61 FR 38338 (July, 23 1996)
3-hour maximum ug/m ³	25 (1)	512 (25)	700 (25)	61 FR 38338 (July, 23 1996)
1-hour maximum	NA	NA	NA	
Nitrogen Dioxide (NO₂)				
Annual mean ug/m ³	2.5 (0.1)	25 (1)	50 (1)	61 FR 38338 (July, 23 1996)
1-hour maximum	NA	NA	NA	

² PSD Increments for all pollutants listed here are set in 40 CFR 52.21 (c).

³ The draft EPA guidance includes new PM_{2.5} SILs for PSD increment. The prior PM_{2.5} SILs for PSD increment from the 2010 rule were vacated. See (U.S. EPA, 2016) for more information.

⁴ The EPA published an NPRM in 1996 that included adding SILs for PSD increment for SO₂, PM₁₀, and NO₂ to the CFR. This proposed rule was never finalized. However, the proposed SILs for PSD increment have been used by states and industry permit applicants for PSD increment in the absence of any other guidance or rulemaking. These proposed SILs are thus used here in this analysis as a benchmark for the facility impacts.

3.0 Approach to evaluating near-source and long-range impacts

In order to assess the nature of LRT aspects of a PSD compliance demonstration, inert criteria pollutant emissions from a wide variety of facility types were modeled across a range of meteorology conditions to improve our understanding of the source impacts in the near-field (*i.e.*, within 50 km) and far-field (beyond 50 km).

3.1 Source Types and Characteristics

Table 3 provides a summary of the source types that were included in a modeling study conducted by EPA state agencies under the AERMOD Implementation Workgroup (AIWG). In 2011, EPA re-instituted the AIWG with a focus on the new 1-hour NO₂ and SO₂ NAAQS. The purpose of the workgroup was to provide insights into challenges being brought forward by stakeholders regarding modeling as part of compliance demonstrations for the new standards (Snyder & Thurman, 2012). The workgroup focused on modeling of “real world” examples utilizing existing and newly formed guidance for the NO₂ (U. S. EPA, 2010a) and SO₂ NAAQS (U. S. EPA, 2010b). The AIWG workgroup was composed of EPA staff from the Regional offices and the Office of Air Quality Planning and Standards (OAQPS) as well as modelers from state, territorial, and local air quality agencies. The workgroup compiled a list of source types or facilities that were of interest to various state and local agencies.

For each modeled facility, emissions and source characteristics were based on actual facilities from past permitting experiences but were modified to be generic facilities. AIWG participants conducted several modeling scenarios across multiple regions of the country that reflected changes in stack height, addition of controls, and modifications of facility boundaries reflecting changes in ambient air. Also for NO₂ sources, the modeling scenarios involved comparing the use of available Tier 3 methods under Appendix W: Plume Volume Molar Ratio Method (PVMRM) and Ozone Limiting Method (OLM). For complete details of the AIWG modeling study and results, the full report is available at:

http://www.epa.gov/ttn/scram/10thmodconf/review_material/AIWG_Summary.pdf

and

http://www.epa.gov/ttn/scram/10thmodconf/review_material/AIWG_Summary_v2.pdf.

Table 3 - Summary of Modeling Scenarios by Source Type from AERMOD Implementation Workgroup (AIWG)

Facility	Base emission (tpy) ⁵ NO ₂ /SO ₂	Stack heights (m) ^{6,7}
Asphalt plant	188/13.2	6, 3, 0.3
Biomass	244/174	55, 9, 9
Cement kiln	7140/3129	160, 160, 90 ⁸ , 908
Coal EGU	1863/4959	150, 100, 6, 5, 5
Ethanol plant	1180/890	11, 11, 2, 43, 25
Flare	104/6083	25
Fuel oil turbine	1184/417	25, 25, 25, 258, 258, 258, 258, 68, 68, 68
Landfill gas turbine	80/45	13,13,13,10
NG compressor	90/0.01	11, 11, 11, 11, 58
Pulp & paper plant	9657/3403	30, 30 ,29, 85, 85, 72, 72, 76, 8, 67, 67

3.2 Modeling Assessment Overview

The goal of this modeling assessment is to determine what types of facilities may have significant impacts in terms of NAAQS and PSD increment, as defined in this analysis as modeled concentrations above the applicable SIL, at distances greater than 50 km from the source. There are fundamentally four aspects that affect source impacts: 1) the source configuration (*e.g.*, stack height), 2) the emission rate, 3) the meteorology in the geographic area, and 4) the terrain in the geographic area. The source configurations and meteorology are closely tied when determining air quality impacts from a facility. These two aspects of a compliance demonstration under PSD are more constrained than the possible range of emissions. Any facility, whatever source configuration and meteorology, can have significant impacts at any distance if the emissions are high enough. Thus, it is essential to have emissions that reflect all possible realities with respect to the facility type, which makes the AIWG modeling scenarios ideal for this evaluation.

⁵ The analysis is based on annual emissions, which is what was available from the original AIWG databases. However, annual emissions may not fully represent impacts for NAAQS or PSD increment from short term emissions that can be evaluated separately for some facilities.

⁶ Primary stacks for NO₂ are colored blue, for SO₂ are colored red, for both are colored purple

⁷ Since the facilities were modeled in flat terrain, the stack heights here are a combination of the stack height and the stack elevation.

⁸ NO₂ only, no SO₂ emissions at this stack height.

Each original AIWG scenario was evaluated with a limited number of meteorological scenarios, which generally originated in the vicinity of the physical location of the facility that the scenario was based upon. However, to expand the usefulness of these scenarios for the purposes of this assessment and to more efficiently evaluate maximum potential impacts, a two-phased analysis was used here:

1. Screening modeling for NAAQS: The first phase consists of a screening analysis using worst-case meteorology generated by MAKEMET and AERMOD's SCREEN option (which calculates only plume-centerline concentrations). The results from this screening analysis generate the potential maximum 1-hour concentration from a particular source type in the near-field and at or about the 50km distance. Since the screening analysis only generates 1-hour concentrations, we limited this screening analysis to the 1-hour NAAQS for NO₂ and SO₂. To provide a more appropriate basis in assessing the significance of source impacts in the far-field, we assessed the source impacts at the 50km distance assuming NAAQS compliance in the near-field (i.e., scaling factors developed that reflect adjusting predicted near-field concentrations to comply with NAAQS). As such, source types with predicted impacts notably above the applicable NAAQS SIL at 50 km from this phase were considered for further analysis in the second phase.
2. Refined modeling for NAAQS and PSD Increment: The second phase consisted of a refined analysis based on 5-years of meteorology from 4 regionally varying NWS stations and AERMOD version 14134. For this second phase, the 1-hour, 3-hour, 24-hour and annual concentrations were computed for comparison to the appropriate SILs under more realistic modeling scenarios. Similar to the screening modeling, predicted impacts at the 50km distance were assessed assuming NAAQS compliance in the near-field. Since the screening analysis indicated that only facilities with tall stacks might comply in the near-field and still have significant impacts at 50 km, the refined analysis focused on a single tall-stack facility (i.e., coal EGU) that serves as a representative example of these source types.

The original AIWG scenarios included NO₂ and SO₂ emissions only, with NO₂ using full conversion. However, PSD increments exist for CO, PM₁₀, and PM_{2.5}. Since CO air quality levels and emissions are currently so low, this pollutant is rarely an issue in PSD permitting and therefore was not evaluated in this assessment. However, PM₁₀ and PM_{2.5} were necessary to include in this assessment and were evaluated along with NO₂ and SO₂. Since PM emissions were not included in the original AIWG scenarios, an analysis of the EPA's 2011 National Emissions Inventory (NEI, <http://www.epa.gov/ttn/chief/net/2011inventory.html>) was conducted to determine scaling factors to generate PM emissions based on the NO₂ and SO₂ emissions for a particular facility type.

4. Summary of results

4.1 Phase 1: NO₂ and SO₂ NAAQS screening

In the first phase, screening meteorology, generated by the MAKEMET tool included in AERSCREEN (U. S. EPA, 2011), was used to evaluate a source's maximum 1-hour concentration impacts that could occur from these "worst-case" meteorological datasets. The screening meteorology includes conditions ranging from low wind/high stability cases, which would give highest concentrations for near-surface releases, to high wind/highly unstable conditions, which would give the highest concentrations for elevated releases (tall stacks). In addition to using screening meteorology, this initial phase used the SCREEN option in AERMOD, which determines plume centerline concentrations, regardless of the wind direction and source/receptor spatial relationships. When using this option with multiple sources in a single AERMOD run, the estimated concentrations are biased to be higher because each receptor will see the plume centerline from each source, regardless of the wind direction. For these model simulations, receptors were placed at distances ranging from 100 m to 60 km. Figure 1 illustrates the multiple receptor heights that were used to evaluate the potential presence of terrain downwind, with receptor heights including 0, 25, 65, 100, 150, and 200 m. Due to the plume centerline option being used, only a single receptor at each distance and height was required. The results from this initial phase represent an extremely conservative estimate of plume impacts. For NO₂, full conversion was used, *i.e.*, the emissions were 100% NO₂, and the half-life option in AERMOD was not used for SO₂.

The screening analysis was conducted for NO₂ and SO₂ only. The results are summarized in Table 4 and in Figures 2 through 11 in Appendix A. For these screening runs, we estimated the maximum concentration for both NO₂ and SO₂ at each receptor. In addition, the 8th high 1-hour concentration for NO₂ and the 4th high 1-hour concentration for SO₂ were estimated at each receptor. The 8th and 4th high 1-hour concentrations are the concentration metrics typically used for determining compliance in a PSD demonstration. While the 8th and 4th high results are conservative (due to the plume centerline concentrations calculated in the screening analysis mentioned earlier), these metrics give some sense of the distribution of the highest concentrations and provide valuable perspective on the maximum concentrations.

As shown in Table 4, several of the facilities have predicted impacts below the respective 1-hour NAAQS SILs for both NO₂ and SO₂ at the 50 km distance. The landfill gas turbine and natural gas (NG) compressor were below the NAAQS SIL at 50 km for both NO₂ and SO₂. The flare was below the NAAQS SIL for NO₂ and the asphalt plant and biomass burning plant were below the NAAQS SIL for SO₂. Several other facilities were very close to the NAAQS SIL at 50 km or had some receptors above and some below the SIL, depending on the receptor height. When the conservative nature of the screening modeling is taken into account, it is apparent that the predicted impacts that are slightly above the NAAQS SIL in the screening analysis (*e.g.*, the asphalt and biomass plant have impacts just above the SIL at 50 km) can be expected to be below the NAAQS SIL under a refined modeling analysis with representative meteorological inputs. That said, there are still some source types that have impacts at the 50 km distance well above the NAAQS SILs, including the cement kiln, coal EGU, ethanol plant, flare, fuel oil turbine, and pulp and paper plant.





Figure 1 – Location of receptors for screening and refined runs.⁹

⁹ Panel A shows the x and y locations, with refined receptors colored in black and screening receptors in red. Panel B shows the x and z locations for all receptors along any x/y radial.

While the results of the source impacts at 50 km compared to the appropriate SILs shown in Table 4 are insightful, these screening modeling results do not reflect the fact that a PSD compliance demonstration necessitates demonstrating compliance with the NAAQS in the near-field. Thus, it is reasonable to assume that NAAQS compliance in the near field would need to be met before considering the source impacts at 50 km and comparing to the applicable SIL for NAAQS and/or PSD increments, particularly if the concentrations in the near field are orders of magnitude above the NAAQS (*i.e.*, the NAAQS is the controlling standard). While the screening results are not equivalent to a NAAQS demonstration (which would calculate 8th and 4th high values for NO₂ and SO₂, respectively, averaged over 5 years of modeling with actual meteorology), the results for many of the facilities suggest that the sources would need to reduce their emissions such that near-field compliance is achieved. Thus, the results in Table 5 present the ‘scaled-back’ results in that the predicted near-field concentrations have been used to estimate adjustments required to meet the NAAQS, and the resulting adjustment factors were used to then “scale back” the predicted 50km source impacts to yield estimates that reflect near-field NAAQS compliance. The adjustments are made according to the following equation:

Equation 1

$$\text{Scaled 50 km impact} = \text{Original 50 km impact} * \left(\frac{\text{NAAQS}}{\text{Representative near field impact}} \right)$$

Table 5 shows estimates of the ‘scaled-back’ source impact at 50 km based on meeting the NAAQS in the near-field. The representative near-field impact is determined as the average of the 8th and 4th high results for NO₂ and SO₂, respectively, across the six receptor heights from the screening results (See Appendix Table A.1, see next paragraph for more discussion on this selection). The 50 km scaled impact is the maximum impact at 50 km (as opposed to the 8th or 4th high) from all receptor heights scaled back such that the representative near-field concentration meets the NAAQS. That is, the highest 50 km impact from Table 4 has been reduced by a factor necessary for the percentile results to meet the NAAQS. For example, for the fuel oil turbine, the representative near-field concentration from the screening analysis for NO₂ (the average of the 8th maximum 1-hour averages shown in Appendix Table A.1) was 639.4 ppb, while the standard is 100 ppb and the maximum impact at 50 km was 12.5 ppb (Table 4). Even without considering background levels or contributions from nearby sources, the emissions would need to be reduced by a factor of 6 to satisfy a NAAQS compliance demonstration (*i.e.*, the 639.4 ppb impact would need to be less than or equal to 100 ppb, equating to roughly a reduction factor of 6). This reduction would also apply to the impact at 50 km, resulting in an impact of 1.4 ppb at 50 km, which is well below the SIL of 4 ppb. When the 50 km impacts are scaled-back from these facilities to meet the NAAQS in the near field, the predicted impacts from all the facilities at 50 km fall below the applicable 1-hour SILs for the NO₂ and SO₂ NAAQS.

While this analysis is insightful, the nature of the screening modeling, with multiple levels of receptors at each distance, can make the results somewhat difficult to interpret, particularly when determining which near-field concentration is indeed “representative”. The receptor grid was designed to reflect a variety of terrain possibilities, but certain combinations of receptors can also result in virtual terrain that is unrealistic. Thus, it is not an easy choice to select a near-field receptor to use in determining the near-field NAAQS compliance scaling discussed above. For example, the asphalt plant, which has the majority of the NO₂ emissions at 31 m, has the smallest impacts at the receptors with an elevation of 200 m. This is reasonable, as the plume from a 31 m stack has the farthest to travel to a 200 m receptor from the

potential receptor heights. However, if a hypothetical domain had terrain that had the facility at an elevation of 0 m with a stack of 31 m (as we modeled here) and some downwind receptor at a 200 m elevation, then this domain would out of necessity need to have receptor elevations between 0 m and 200 m. Thus, there should be receptors at intermediate elevations in between the source and the 200 m receptor that would see higher concentrations than the concentration at the 200 m receptor. Therefore, the concentration from the 200 m receptors is not representative as the domain-wide controlling concentration. However, the concentrations from the receptors at 65 m, which are close to the stack height, may not be representative either. This is because the maximum impacts at these receptor heights occur immediately at the fence line, which implies a terrain in which the facility fence line is located immediately adjacent to the base of some sort of cliff, such that the ground-level receptors are at an elevation of 65 m above the facility (which has a base elevation of 0 m). This is unlikely and thus the maximum impact from the 65 m receptors may not be representative either. This unlikely “cliff” scenario is exaggerated even more with taller stack facilities. For example, the coal EGU has its NO₂ emissions distributed between a 120 m and 172 m stack, with the maximum impacts occurring at the 200 m receptors. Again, these maximum impacts would be at fence line receptors, implying a significant terrain feature of 200 m immediately at the fence line of the facility. Conversely, it is unlikely that the terrain over the entire domain of almost 40,000 square km is flat (*i.e.*, all elevations are only 0 m) or that there is a plateau, such that all receptors are at an elevation of 25 m over the entire domain. Ultimately, no single concentration from Appendix Table A.1 can be considered representative of the near-field impacts from a variety of potential terrain arrangements. Thus, the average of the 4th high and 8th high near-field concentrations were chosen as the “representative” near-field concentration.

In general, when complex terrain, such as the cliffs and plateaus discussed above, is not a major factor in the compliance demonstration, the expectation is that most receptor elevations are not significantly different from the baseline elevation of the facility. In such cases, facilities with the lower release points (shorter stacks) have their maximum impacts in close proximity to the source such that their impacts at 50 km are much lower after the adjustment to meet the NAAQS. Conversely, facilities with emissions concentrated at tall stacks do not see their maximum impacts until much farther downwind because the plumes need more time to impact the surface (or for the terrain to raise to the plume centerline). As a result, the impacts at 50 km are not reduced as much as they are with short stacks when the NAAQS compliance is taken into account. As the discussion of receptor heights and near-field impacts highlights, the considerations of stack heights and receptor elevations are an important consideration in determining what kind of facilities can potentially have significant impacts at 50 km. Based on these considerations and the adjustments to reflect near-field NAAQS compliance indicates that facilities with emissions from the taller stacks are most likely to still have some impacts above the applicable SIL at 50 km.

Table 4 - Phase 1 Screening Modeling Results for NO₂ and SO₂ by Facility type: Maximum Impact Results

Facility	Receptor Elevation	NO ₂ NAAQS (impacts in ppb)		SO ₂ NAAQS (impacts in ppb)	
		Maximum 1-hour impact	Impact at 50 km (SIL 4 ppb) ¹⁰	Maximum 1-hour impact	Impact at 50 km (SIL 3 ppb) ¹⁰
Asphalt plant	0	291.0	5.7	96.1	0.7
	25	856.8	6.2	115.4	0.7
	65	884.7	4.4	50.0	0.2
	100	408.3	2.3	49.7	0.2
	150	181.1	1.6	49.3	0.1
	200	129.8	1.4	49.0	0.1
Biomass	0	17.5	1.0	11.2	0.7
	25	17.7	1.0	11.3	0.7
	65	548.5	1.7	351.4	1.1
	100	899.4	5.5	576.2	3.5
	150	534.6	2.8	342.5	1.8
	200	243.7	1.5	156.1	1.0
Cement kiln	0	148.7	12.6	60.8	5.2
	25	149.1	12.7	61.0	5.2
	65	150.4	12.7	61.5	5.2
	100	152.2	12.7	62.2	5.2
	150	1468.9	12.7	567.6	5.2
	200	6771.0	21.7	2397.5	8.8
Coal EGU	0	232.8	5.0	74.8	6.9
	25	970.7	6.0	74.9	6.9
	65	434.3	3.8	75.8	6.9
	100	222.1	3.8	77.3	6.9
	150	517.2	3.8	1328.8	6.9
	200	1572.6	6.1	4388.2	16.7
Ethanol plant	0	391.4	6.4	32.2	3.0
	25	811.9	6.4	175.6	3.0
	65	1735.2	7.4	1091.4	4.7
	100	1746.1	15.6	1223.5	11.0
	150	1871.6	13.7	1311.5	9.6
	200	1109.3	6.0	777.3	4.2

¹⁰ SILs used in the analysis are described in Section 2 above.

Table 4 - Phase 1 Screening Modeling Results for NO₂ and SO₂ by Facility type: Maximum Impact Results (continued)

Facility	Receptor Elevation	NO ₂ NAAQS (impacts in ppb)		SO ₂ NAAQS (impacts in ppb)	
		Maximum 1-hour impact	Impact at 50 km (SIL 4 ppb) ¹⁰	Maximum 1-hour impact	Impact at 50 km (SIL 3 ppb) ¹⁰
Flare	0	4.0	0.3	207.2	16.4
	25	17.2	0.3	897.8	16.4
	65	95.8	0.7	5014.2	37.7
	100	132.3	1.5	6924.3	77.3
	150	150.8	1.2	7888.0	60.9
	200	90.2	0.6	4718.9	29.9
Fuel oil turbine	0	78.3	3.2	22.0	0.9
	25	212.4	3.2	64.1	0.9
	65	770.3	5.8	275.6	1.4
	100	808.5	10.8	231.8	3.5
	150	1126.0	12.5	403.9	4.5
	200	907.9	7.4	325.1	2.7
Landfill gas turbine	0	28.1	1.0	13.0	0.4
	25	110.5	1.1	65.7	0.5
	65	230.5	1.9	136.9	1.0
	100	174.0	1.1	104.0	0.6
	150	75.5	0.5	45.1	0.3
	200	42.4	0.4	25.3	0.2
NG compressor	0	92.6	3.2	0.0	0.0
	25	835.8	3.7	0.1	0.0
	65	351.9	1.8	0.1	0.0
	100	181.9	1.2	0.0	0.0
	150	59.9	1.0	0.0	0.0
	200	43.1	1.0	0.0	0.0
Pulp & paper plant	0	5204.6	116.6	3586.2	39.4
	25	8493.1	117.5	21095.9	38.3
	65	192356.4	338.7	39363.7	88.0
	100	13176.6	87.8	4807.2	30.1
	150	3499.5	59.0	2034.3	19.8
	200	2681.9	59.0	1697.4	19.2

Table 5 - Phase 1 screening modeling results for NO₂ and SO₂ by Facility type: Maximum Impact Results at 50 km scaled to Reflect Near-Field NAAQS Compliance

Facility		NO ₂ NAAQS NAAQS: 100 SIL: 4 (ppb)	SO ₂ NAAQS NAAQS: 75 SIL: 3 (ppb)
Asphalt plant	Representative near-field impact (unscaled) ¹¹	445.7	68.2 ¹²
	50 km scaled impact ¹³	1.4	0.7
Biomass plant	Representative near-field impact (unscaled)	351.4	231.1
	50 km scaled impact	1.6	1.5
Cement kiln	Representative near-field impact (unscaled)	1452.3	531.6
	50 km scaled impact	1.5	1.6
Coal EGU	Representative near-field impact (unscaled)	545.9	812.1
	50 km scaled impact	1.1	2.1
Ethanol plant	Representative near-field impact (unscaled)	1238.9	765.5
	50 km scaled impact	1.3	1.4
Flare	Representative near-field impact (unscaled)	76.7	4201.6
	50 km scaled impact	1.5	1.8
Fuel oil turbine	Representative near-field impact (unscaled)	639.4	214.8
	50 km scaled impact	1.9	2.1
Landfill gas turbine	Representative near-field impact (unscaled)	104.1	62.9
	50 km scaled impact	1.8	1.0
NG compressor	Representative near-field impact (unscaled)	253.4	0.0
	50 km scaled impact	1.5	0.0
Pulp & paper plant	Representative near-field impact (unscaled)	36836.8	11993.1
	50 km scaled impact	0.9	0.6

¹¹ The representative near-field impact is calculated as the average of the “Maximum 1-hour impact” shown in Appendix Table A.1 across each receptor elevation.

¹² For several facilities, the representative near-field impact is below the level of the NAAQS. In these cases (highlighted in red), the 50 km impact is not scaled as described in the next footnote. Instead, the original result from Table 4 is taken directly for Table 5.

¹³ The 50 km scaled impact is calculated as the maximum of the “Impact at 50 km” values in Table 4 across each receptor elevation multiplied by the ratio of the level of the NAAQS to the representative near-field impact shown in this table. See Equation 1.

4.2 Phase 2: Refined analyses for NO₂ and SO₂

The second phase of the analysis focused on characterizing impacts from tall stack sources using a more refined approach to determine modeled source-level impacts. For this phase, AERMOD version 14134 was used with representative meteorological inputs from several sets of NWS stations across the nation (described further below). A variety of meteorological data sets were used to provide more complete and robust findings that better represent source impacts across the nation. Since the plume centerline concentrations were not calculated in this phase, a polar receptor grid was used with 1-degree radial spacing through 360 degrees. Receptor distances and heights matched those from Phase 1 screening analysis as shown in Figure 1. For this second phase, 1-hour, 3-hour, 24-hour and annual concentrations were calculated to compare to the SILs for various averaging periods.

This refined modeling approach will generate less conservative estimates of the impacts at 50 km from the various facilities relative to the screening analysis that indicated the potential for source impacts above the SIL at 50 km. As discussed above, when NAAQS compliance is considered, it appears that only facilities with tall stacks have the potential to show compliance in the near-field assessment for the NAAQS and still have impacts at 50 km near the SIL. The coal EGU and the cement kiln had the tallest stacks with the cement kiln emissions mainly at the 160 m stacks, while the coal EGU emissions are mainly at the 150 and 100 m stacks. While the screening analysis indicated that the pulp and paper facility had the highest near-field and 50 km impacts, the tallest stacks at this facility were roughly half the height of the primary stacks at the cement kiln and coal EDU. Therefore, we focused only on the coal EGU because its SO₂ emissions were concentrated at the tallest stack while its NO₂ emissions were distributed to the two tallest stacks (150 m and 100 m stack heights), thereby providing the most insightful test case for refined modeling. Table 6 shows the specific emissions for each stack at the coal EGU scenario for NO₂ and SO₂.

Table 6 - Summary of NO₂ and SO₂ emissions for the coal EGU facility

Stack height (m)	175 ¹⁴	120	51	50	50
NO ₂ emissions (tpy)	1564	174	104	10.4	10.4
SO ₂ emissions (tpy)	4867	87	4.3	.7	.3

For the refined modeling analysis, we used four meteorological datasets consisting of 5 years of meteorological data from 2006 to 2010, reflecting National Weather Service (NWS) stations located at JFK airport in Ashland, WI (ASX), Somerset airport in Somerville, NJ (SMQ), Dalhart airport in Dalhart, TX (DHT), and Oakland airport in Oakland, CA (OAK). These datasets were selected based on prior usage of a large set of meteorological datasets regularly used by the EPA and are known to represent a range of meteorological conditions. These data sets also provide spatial variability in the refined modeling analyses. The airports are all ASOS sites, with 1-minute observations processed through AERMINUTE and AERMET using the beta u* adjustment option (U. S. EPA, 2014). The maximum 1-hour concentration (5-

¹⁴ The 150 m stack is above GEP height, but was modeled at this height for illustrative purposes.

year average), NAAQS specific design value (5-year average of 98th percentile and 99th percentile daily 1-hour maximum concentrations), annual average (5-year average of each annual average), and 24-hour and 3-hour PSD increment levels (highest first and second values) for SO₂. As noted above, a polar grid was used with 1-degree separation and 360 degrees (receptor distances and heights matched those used in the screening analysis).

4.2.1 1-hour NAAQS Results

Plots summarizing the refined modeling analysis for NO₂ and SO₂ are presented in Appendix B and the results are summarized in Tables 7 and 8 for each 1-hour NAAQS. The most striking difference from the screening and refined analysis is the decrease in the maximum 1-hour values for both pollutants. For NO₂, the maximum from the screening (with unscaled emissions) was 1572 ppb, while the maximum from the refined runs was around 546 ppb (again, with unscaled emissions). For SO₂, the maximum concentrations decrease even further from 4388 ppb to 454 ppb. For NO₂, the maximum 1-hour concentrations at 50 km from the refined modeling (with unscaled emissions) are now well below the 1-hour NAAQS SIL at 50 km. However, the SO₂ concentrations are still above the SIL at 50 km with the unscaled emissions. If the SO₂ emissions are scaled such that the near-field results meet the NAAQS, then the impact at 50 km are below the 1-hour NAAQS SIL. However, the maximum impacts in the near-field for SO₂ are driven by results at the 150 and 200 m receptors, *i.e.*, elevated receptors reflective of terrain features in vicinity of the facility. The elevated receptors were included to evaluate the potential impacts of terrain on the modeling results. However, it is not likely that a large emitting facility with a 150 m stack would be built in the immediate vicinity of terrain near or above stack height because the facility would likely have issues providing a successful NAAQS compliance demonstration. Thus, it is somewhat unrealistic to consider these elevated receptors at the closest distances. If these elevated receptors are not considered in the near-field, then the EGU source type would satisfy the NAAQS compliance demonstration in the near-field, but be above the NAAQS SIL in the far-field. Thus, the near-field concentrations would not indicate a NAAQS violation because there would be no receptors near stack height and that a source of this type could possibly have significant impacts at 50 km or greater and need an LRT assessment.

Table 7 – Phase 2 Refine Modeling Results for NO₂ by NWS Station

Met station	Receptor Elevation	Maximum 1-hour impact (ppb, 1 st high)		98 th percentile 1-hour impact (ppb, 8 th high)	
		All receptors	50 km (SIL 4 ppb)	All receptors	50 km (SIL 4 ppb)
Ashland, WI (ASX)	0	546.81	1.50	366.15	0.94
	25	505.18	1.66	344.43	1.04
	65	373.36	1.34	270.46	0.97
	100	301.35	1.27	217.27	0.85
	150	311.18	1.39	217.01	0.99
	200	286.22	1.60	191.64	1.15
Dalhart, TX DHT	0	357.80	1.38	235.82	0.75
	25	340.30	1.45	210.89	0.76
	65	269.71	1.32	129.94	0.77
	100	216.93	1.28	118.30	0.73
	150	199.68	1.35	128.86	0.80
	200	239.83	1.50	127.65	0.96
Oakland, CA OAK	0	417.98	1.62	318.30	1.16
	25	397.27	1.75	302.32	1.17
	65	312.91	1.53	239.16	1.15
	100	250.09	1.52	191.94	1.12
	150	245.54	1.56	146.20	1.14
	200	212.50	1.91	138.62	1.19
Somerville, NJ SMQ	0	443.30	1.15	344.51	0.72
	25	425.08	1.22	370.58	0.81
	65	302.98	1.20	227.72	0.81
	100	243.67	1.09	183.29	0.72
	150	253.43	1.19	189.48	0.94
	200	250.14	1.32	184.82	1.08

Table 8 - Phase 2 Refine Modeling Results for SO₂ by NWS Station

Met scenario	Receptor Elevation	Maximum 1-hour impact (ppb, 1 st high)		99 th percentile 1-hour impact (ppb, 4 th high)	
		All receptors	50 km (SIL 3 ppb)	All receptors	50 km (SIL 3 ppb)
Ashland, WI (ASX)	0	23.65	2.58	14.22	1.98
	25	23.69	2.57	14.31	1.97
	65	24.08	2.57	14.68	1.96
	100	34.60	2.56	24.57	1.95
	150	68.70	2.56	57.76	1.95
	200	262.24	3.20	200.78	2.47
Dalhart, TX DHT	0	23.39	2.47	12.04	1.81
	25	23.60	2.46	12.07	1.80
	65	23.97	2.46	12.40	1.78
	100	49.53	2.46	42.82	1.77
	150	87.43	2.46	53.61	1.76
	200	652.11	3.15	454.48	2.28
Oakland, CA OAK	0	28.98	3.01	21.36	2.65
	25	29.01	2.99	21.52	2.64
	65	29.23	2.97	21.75	2.63
	100	43.59	2.96	28.06	2.63
	150	82.33	2.95	67.46	2.62
	200	394.67	4.04	329.24	2.97
Somerville, NJ SMQ	0	25.57	2.08	16.24	1.63
	25	25.63	2.07	16.35	1.63
	65	25.75	2.06	16.47	1.62
	100	34.85	2.05	24.03	1.62
	150	49.22	2.04	38.58	1.62
	200	177.58	2.40	139.80	2.12

4.2.2 3-hour, 24-hour, and annual PSD increment results

For the NO₂ and SO₂ PSD increment analysis, the results from the refined analysis presented in Section 4.2.1 have been used to scale down the impacts in the 3-hour and 24-hour SO₂ PSD increment and the annual NO₂ and SO₂ PSD increment calculations. The scaling factors are given in Table 9. As shown in Table 10 for the 3-hour and 24-hour SO₂ PSD increment, the scaled down impacts at 50 km are below the Class II PSD increment SILs and slightly above the respective Class I PSD increment SILs for three of the four meteorological data sets (Section B.2). However as shown in Table 10 for the annual NO₂ and SO₂ PSD increment, the source impacts at 50 km are well below both Class I and Class II PSD increment SILs for all cases (Section B.3). In general, these results show that the longer the averaging period, the less likely that there will be significant source impacts at distances of 50 km and greater.

Table 9 - Scaling factors from NAAQS refined analysis for use in PSD increment refined analysis

Meteorological dataset	NO₂ scaling factors	SO₂ scaling factors
ASX	0.27	0.37
DHT	0.42	0.17
OAK	0.31	0.23
SMQ	0.27	0.54

Table 10 - Phase 2 refined modeling results for NO₂ and SO₂ PSD increments by NWS station

	Elev.	ASX		DHT		OAK		SMQ	
		Max domain	50 km	Max domain	50 km	Max domain	50 km	Max domain	50 km
PSD Increment SILs: C1 - 1; C2 - 25 (ug/m3)									
3-hr SO2 H1H	100	25.1	1.11	8.0	0.55	10.2	1.23	26.3	1.77
	150	51.0	1.11	34.8	0.56	42.1	1.22	50.1	1.77
	200	223.6	1.32	214.9	0.90	193.2	1.20	221.1	1.79
3-hr SO2 H2H	100	15.4	1.05	6.6	0.50	9.6	1.07	21.6	1.71
	150	43.9	1.05	27.0	0.50	40.6	1.07	46.6	1.70
	200	199.4	1.21	200.5	0.69	169.6	1.07	210.9	1.77
PSD Increment SILs: C1 - 0.2; C2 - 5 (ug/m3)									
24-hr SO2 H1H	100	5.0	0.24	2.4	0.10	3.1	0.35	8.5	0.54
	150	23.6	0.27	12.2	0.10	16.7	0.35	22.6	0.53
	200	120.8	0.34	79.3	0.13	76.3	0.35	158.4	0.53
24-hr SO2 H2H	100	4.7	0.24	2.3	0.09	2.9	0.33	8.0	0.42
	150	17.2	0.25	8.5	0.10	15.1	0.33	20.2	0.43
	200	101.8	0.29	73.2	0.13	60.4	0.33	108.7	0.52
PSD Increment SILs: C1 - 0.1; C2 - 1 (ug/m3)									
Annual NO2	100	4.1	0.01	1.3	0.00	3.5	0.02	8.7	0.02
	150	4.0	0.01	1.2	0.00	3.7	0.02	8.2	0.02
	200	4.6	0.01	1.5	0.00	4.6	0.02	7.7	0.02
Annual SO2	100	0.4	0.02	0.7	0.01	0.7	0.07	0.6	0.02
	150	0.9	0.02	2.2	0.02	2.2	0.07	1.4	0.03
	200	4.3	0.03	10.3	0.02	9.5	0.07	3.9	0.03

4.3 Phase 2: Refined analyses for PM₁₀ and PM_{2.5}

Since the AIWG facilities did not include PM₁₀ or PM_{2.5} emissions, we derived these emissions by scaling from the emission rates for SO₂ and NO₂ based on emission ratios of these pollutants for EGUs listed in the NEI. The ratios of PM₁₀ and PM_{2.5} emissions to NO_x emissions for all EGUs with NO_x emissions greater than 40 tons were calculated. Similarly, emission ratios were computed for EGUs with SO₂ emissions greater than 40 tons. PM emissions were significantly lower than NO_x and SO₂ emissions. The emissions data used in the refined modeling analysis are summarized in Table 11. On average, the PM₁₀ emissions were about 22% of NO_x and SO₂ emissions, while PM_{2.5} emissions were around 19% of NO_x and SO₂ emissions. The facilities with the greatest PM₁₀ and PM_{2.5} emission ratios resulted in PM₁₀ and PM_{2.5} being 50% of NO_x and 38% of SO₂. Given how close PM₁₀ and PM_{2.5} emission ratios were, this assessment focused on PM_{2.5} emissions only, as the PM_{2.5} standard are more stringent than the PM₁₀ standards. Since both PM₁₀ and PM_{2.5} would be modeled as inert pollutants, the model would treat each pollutant equally with respect to dispersion, so modeling both PM₁₀ and PM_{2.5} with the approximately the same emission rates would result in roughly the same modeled concentrations. The average

emission ratios (20%) were used to scale the PM emissions for the PM analysis, based on the original NO₂ and SO₂ emissions presented in Section 3.1.

Table 11- - Summary of 2011 NEI emission data used in refined modeling analysis

NO _x ratios					
PM ₁₀ max	PM ₁₀ min	PM ₁₀ mean	PM _{2.5} max	PM _{2.5} min	PM _{2.5} mean
8.0%	49.4%	22.9%	4.8%	49.2%	19.5%
SO ₂ ratios					
PM ₁₀ max	PM ₁₀ min	PM ₁₀ mean	PM _{2.5} max	PM _{2.5} min	PM _{2.5} mean
3.1%	37.7%	22.6%	2.7%	37.6%	18.7%

4.3.1 24-hour NAAQS results

Plots summarizing the refined modeling analyses for PM_{2.5} are presented in Appendix C, broken out by averaging time and form. The comparison against the PM_{2.5} 24-hour NAAQS are presented in Section C.1. As shown in Table 12, the results for both the SO₂-scaled and NO₂-scaled emissions for all 4 meteorological data sets are generally below the 24-hour NAAQS SIL of 1.2 ug/m³ within the first 5 km from the source and are an order of magnitude below the SIL at 50 km.

Table 12 – Phase 2 refined modeling results for 24-hour PM2.5 NAAQS by NWS station

	ASX		DHT		OAK		SMQ		
	Elev.	Max domain	50 km	Max domain	50 km	Max domain	50 km	Max domain	50 km
		NAAQS SIL: 1.2 (ug/m ³)							
PM2.5 24-hr NAAQS NO₂-scaled, 8th high	100	10.7	0.03	7.4	0.02	11.5	0.07	13.5	0.04
	150	10.6	0.04	6.8	0.03	11.5	0.07	12.3	0.04
	200	10.7	0.04	9.0	0.03	14.8	0.07	12.4	0.05
PM2.5 24-hr NAAQS SO₂-scaled, 8th high	100	1.5	0.07	1.8	0.05	1.7	0.17	1.8	0.09
	150	4.5	0.08	5.5	0.06	5.5	0.17	3.9	0.09
	200	21.6	0.09	27.2	0.07	29.1	0.18	14.9	0.11

4.3.2 Annual NAAQS and PSD increment results

The comparisons against the annual NAAQS (0.2 ug/m³) and PSD increment (0.05 ug/m³) SILs is presented in Section C.2. As shown in Table 13, similar to the 24-hour NAAQS results, the refined modeling results for all 4 meteorological data sets are generally below the annual NAAQS SIL within the first 10 km and are below the annual PSD increment SIL within the first 20 km. The modeled impacts are again an order of magnitude below both SILs at 50 km.

Table 13 – Phase 2 refined modeling results for annual PM2.5 NAAQS and PSD increment by NWS station

	ASX		DHT		OAK		SMQ		
	Elev.	Max domain	50 km	Max domain	50 km	Max domain	50 km	Max domain	50 km
	NAAQS SIL: 0.2 PSD Increment SILs C1 - 0.05; C2 - 0.2 (ug/m3)								
PM2.5 annual NO₂-scaled	100	2.2	0.01	1.5	0.00	3.1	0.01	3.2	0.01
	150	2.2	0.01	1.4	0.00	3.2	0.01	3.0	0.01
	200	2.5	0.01	1.7	0.00	4.0	0.01	2.9	0.01
PM2.5 annual SO₂-scaled	100	0.3	0.01	0.4	0.01	0.5	0.04	0.5	0.02
	150	0.6	0.01	1.0	0.01	1.4	0.05	1.0	0.02
	200	3.2	0.02	4.9	0.01	6.2	0.05	2.9	0.02

4.3.2 24-hour PSD increment results

The comparisons against the 24-hour PSD increment (0.27 ug/m³) SILs is presented in Section C.2. As shown in Table 14, unlike the results for the 24-hour NAAQS and the annual NAAQS and PSD increment, the refined modeling impacts are not clearly below the SIL at 50 km. For the SO₂-scaled results, the impacts at 50 km are slightly above the SIL in all cases, while the NO₂-scaled results are slightly below the SIL in all cases. The results from the 24-hour and annual NAAQS analysis did not as clearly indicate issues with NAAQS compliance in the near-field (the maximum 24-hour results were around 10-12 ug/m³, while the maximum annual results were around 3-4 ug/m³). Thus, there is no clear suggestion that the emissions would need to be reduced to meet the NAAQS in the near-field such that the 24-hour PSD increment impacts would be reduced. Nonetheless, the impacts are fairly close to the 24-hour PSD increment SILs without emissions adjustments.

Table 14 – Phase 2 refined modeling results for 24-hour PM2.5 PSD increment by NWS station

	ASX		DHT		OAK		SMQ		
	Elev.	Max domain	50 km	Max domain	50 km	Max domain	50 km	Max domain	50 km
	PSD Increment SILs: C1 - 0.27; C2 - 1.2 (ug/m3)								
PM2.5 24-hr NO₂-scaled H1H	100	18.1	0.07	12.5	0.05	16.8	0.12	25.9	0.08
	150	19.3	0.07	12.3	0.06	16.7	0.12	27.9	0.09
	200	21.0	0.08	30.0	0.06	23.8	0.12	24.2	0.09
PM2.5 24-hr SO₂-scaled, H1H	100	2.7	0.13	2.8	0.11	2.7	0.30	3.1	0.20
	150	12.8	0.15	14.3	0.12	14.5	0.30	8.4	0.20
	200	65.3	0.18	93.3	0.15	66.3	0.31	58.7	0.20

5. Conclusions

While this analysis did not necessarily capture all occurrences of possible Class I area increment concern, the results indicate that for most source types, if NAAQS compliance with the short-term standards can be demonstrated in the near-field, then there are not likely to be significant source impacts at 50 km. Thus, for most facilities that show compliance in the near-field, no evaluation of LRT would seem to be necessary for NAAQS. There are indications, however, that for a select class of facilities, mainly those that have very tall stacks (greater than 100 m), there is a possibility of having an impact that is significant with respect to the short-term NO₂, SO₂ and PM_{2.5} PSD increment. These types of facilities may have their maximum impact much farther from the facility than most. The results also indicate that terrain features can be important for these types of facilities, as elevated terrain at or near stack height, can result in higher plume impacts much closer to the source. When this occurs, NAAQS compliance with the short-term standard may be sufficient to decrease long-range impacts and eliminate the potential need for an LRT assessment for NAAQS or PSD increment. Conversely, elevated receptors in the far-field can increase the need for LRT assessments, as these receptors may experience impacts closer to the plume centerline.

6. Additional information

Data for the analyses described in this TSD can be obtained by contacting:

Chris Owen, PhD
Office of Air Quality Planning and Standards, U. S. EPA
109 T.W. Alexander Dr.
RTP, NC 27711
919-541-5312
owen.chris@epa.gov

References

- Cimorelli, et al. (2005). AERMOD: A Dispersion Model for Industrial Source Applications. Part I: General Model Formulation and Boundary Layer Characterization. *J. App. Meterol*, 682-693.
- Snyder, E., & Thurman, J. (2012). AERMOD Implementation Workgroup NO₂ & SO₂ modeling. *10th Conference on Air Quality Modeling*. U. S. EPA, RTP, NC.
- U. S. EPA. (1996). 40 CFR Parts 51 and 52: Prevention of Significant Deterioration (PSD) and Nonattainment New Source Review (NSR). *FR, Vol. 61, No. 142, July 23, 1996*, 38249 - 38344.
- U. S. EPA. (2003). Guideline on Air Quality Models. *40 CFR Part 51 Appendix W (68 FR 18440)*.
- U. S. EPA. (2010a, June 29). *Guidance Concerning the Implementation of the 1-hour NO₂ NAAQS for the Prevention of Significant Deterioration Program*.
- U. S. EPA. (2010b, August 23). *Guidance Concerning the Implementation of the 1-hour SO₂ NAAQS for the Prevention of Significant Deterioration Program*.
- U. S. EPA. (2011, March). AERSCREEN User's Guide. pp. EPA-454/B-11-001.
- U. S. EPA. (2014, May). *Addendum to User's Guide for the AERMOD Meteorological Preprocessor (AERMET)*, EPA document number EPA-454/B-03-002. Retrieved from RTP, NC.
- U. S. EPA. (2014). Guidance for PM_{2.5} Permit Modeling, EPA report number EPA-454/B-14-001. *RTP, NC*, May.
- U. S. EPA. (2016). *Guidance on Significant Impact Levels for Ozone and Fine Particles in the Prevention of Significant Deterioration Permitting Program*. RTP, NC: Office of Air Quality Planning and Standards.

Appendix A

Plots and tables from the NO₂ and SO₂ NAAQS screening analysis

For all figures in this section, the NO₂ SIL is shown in blue and the SO₂ SIL is shown in red.

Table A.1 - Phase 1 screening modeling results for NO₂ and SO₂ by Facility type: 8th and 4th high results from screening analysis

Facility	Receptor Elevation	NO ₂ 8th high (ppb)		SO ₂ 4th high (ppb)	
		Maximum domain wide impact	Impact at 50 km (SIL 4 ppb)	Maximum domain wide impact	Impact at 50 km (SIL 3 ppb)
Asphalt plant	0	290.98	5.01	96.09	0.67
	25	834.55	5.86	115.35	0.70
	65	884.69	3.89	50.03	0.24
	100	355.51	2.00	49.72	0.16
	150	178.68	1.45	49.32	0.14
	200	129.77	1.30	48.96	0.14
Biomass plant	0	15.84	0.95	10.70	0.66
	25	15.96	0.95	10.79	0.66
	65	478.56	1.62	330.84	1.05
	100	826.66	4.76	538.14	3.18
	150	531.36	2.57	342.52	1.64
	200	239.94	1.26	153.73	0.87
Cement kiln	0	131.36	10.22	60.18	4.75
	25	132.24	10.25	60.42	4.75
	65	132.04	10.26	60.98	4.75
	100	132.31	10.27	61.85	4.75
	150	1468.85	10.28	567.58	4.75
	200	6716.97	17.61	2378.44	7.77
Coal EGU	0	232.76	4.96	74.15	6.50
	25	876.53	5.53	74.34	6.51
	65	425.18	3.33	75.22	6.52
	100	212.36	3.33	75.24	6.52
	150	517.19	3.32	1328.82	6.51
	200	1011.55	5.70	3244.59	15.27
Ethanol Plant	0	391.43	6.15	31.80	2.95
	25	789.49	6.13	174.55	2.95
	65	1735.24	6.26	1091.40	4.27
	100	1702.15	14.10	1206.21	10.40
	150	1706.04	13.23	1311.49	9.27
	200	1109.31	5.92	777.34	4.20

Table A.1 - Phase 1 screening modeling results for NO₂ and SO₂ by Facility type: 8th and 4th high results from screening analysis (continued)

Facility	Receptor Elevation	NO ₂ 8th high (ppb)		SO ₂ 4th high (ppb)	
		Maximum domain wide impact	Impact at 50 km (SIL 4 ppb)	Maximum domain wide impact	Impact at 50 km (SIL 3 ppb)
Flare	0	3.96	0.29	207.24	15.71
	25	17.16	0.29	897.76	15.72
	65	90.49	0.64	4962.82	34.24
	100	123.43	1.28	6534.81	67.90
	150	134.97	1.13	7888.02	60.57
	200	90.19	0.56	4718.89	29.92
Fuel oil turbine	0	78.29	3.03	22.03	0.85
	25	212.39	3.03	64.14	0.85
	65	770.30	5.15	275.63	1.39
	100	760.16	10.01	226.57	3.28
	150	1115.39	11.06	375.08	4.20
	200	899.59	7.29	325.10	2.63
Landfill gas turbine	0	28.07	0.85	13.04	0.40
	25	109.57	1.03	65.11	0.45
	65	202.29	1.69	125.04	0.96
	100	168.51	1.02	104.05	0.61
	150	74.95	0.47	44.81	0.31
	200	41.34	0.41	25.33	0.21
NG compressor	0	92.64	3.02	0.01	0.00
	25	804.09	3.51	0.12	0.00
	65	348.38	1.60	0.05	0.00
	100	179.34	1.18	0.03	0.00
	150	55.66	0.98	0.01	0.00
	200	40.27	0.96	0.01	0.00
Pulp & paper plant	0	279.81	23.97	423.68	10.58
	25	276.14	24.06	603.28	10.63
	65	815.05	24.12	3438.12	16.32
	100	9282.87	39.86	2624.44	11.39
	150	9242.13	80.56	2377.23	21.30
	200	7811.38	60.86	2235.38	18.24




Figure 2 - Results from the screening analysis for the asphalt plant.




Figure 3 - Results from the screening analysis for the biomass plant




Figure 4 - Results from the screening analysis for the cement kiln







Figure 5 - Results from the screening analysis for the coal EGU







Figure 6 - Results from the screening analysis for the ethanol plant







Figure 7 - Results from the screening analysis for the flare







Figure 8 - Results from the screening analysis for the fuel oil turbine




Figure 9 - Results from the screening analysis for the landfill gas turbine




Figure 10 - Results from the screening analysis for the natural gas compressor station




Figure 11 - Results from the screening analysis for the pulp and paper plant

Appendix B

Plots from NO₂ and SO₂ refined analysis

For all figures in this section, the NO₂ SIL is shown in blue and the SO₂ SIL is shown in red.

B.1 Comparisons against the 1-hour NO₂ and SO₂ NAAQS




Figure 12 - Refined NO₂ and SO₂ results, ASX, max and design values, 1-hour NAAQS







Figure 13 - Refined NO₂ and SO₂ results, DHT, max and design values, 1-hour NAAQS







Figure 14 - Refined NO₂ and SO₂ results, OAK, max and design values, 1-hour NAAQS







Figure 15 - Refined NO₂ and SO₂ results, SMQ, max and design values, 1-hour NAAQS

B.2 Comparisons against the 3 and 24-hour SO₂ PSD increment




Figure 16 - Refined SO₂ results, ASX, 3 & 24-hour PSD increment




Figure 17 - Refined SO₂ results, DHT, 3 & 24-hour PSD increment




Figure 18 - Refined SO₂ results, OAK, 3 & 24-hour PSD increment




Figure 19 - Refined SO₂ results, SMQ, 3 & 24-hour PSD increment

B.3 Comparisons against the annual NO₂ and SO₂ PSD increment




Figure 20 - Refined NO₂ & SO₂ results, ASX, annual NAAQS





Figure 21 - Refined NO₂ & SO₂ results, DHT, annual NAAQS





Figure 22 - Refined NO₂ & SO₂ results, OAK, annual NAAQS





Figure 23 - Refined NO₂ & SO₂ results, SMQ, annual NAAQS

Appendix C

Plots from PM refined analysis

For all figures in this section, the PM_{2.5} PSD increment is indicated on each plot. For the NO-scaled emissions, this is shown in blue and the SO₂-scaled emissions are shown in red.

C.1 Comparisons against the PM2.5 24-hour NAAQS




Figure 24 - Refined PM_{2.5} results, ASX, 24-hour NAAQS





Figure 25 - Refined PM_{2.5} results, DHT, 24-hour NAAQS





Figure 26 - Refined PM_{2.5} results, OAK, 24-hour NAAQS





Figure 27 - Refined PM_{2.5} results, SMQ, 24-hour NAAQS

C.2 Comparisons against the annual PSD increment and NAAQS




Figure 28 - Refined PM_{2.5} results, ASX, annual PSD increment and NAAQS





Figure 29 - Refined PM_{2.5} results, DHT, annual PSD increment and NAAQS





Figure 30 - Refined PM_{2.5} results, OAK, annual PSD increment and NAAQS






Figure 31 - Refined PM_{2.5} results, SMQ, annual PSD increment and NAAQS

C.3 Comparisons against the PM2.5 24-hour PSD increment

SO2-scaled ASX_PM25 H1H: SIL of 0.27



NO2-scaled ASX_PM25 H1H: SIL of 0.27




Figure 32 - Refined PM_{2.5} results, ASX, 24-hour PSD increment





Figure 33 - Refined PM_{2.5} results, DHT, 24-hour PSD increment





Figure 34 - Refined PM_{2.5} results, OAK, 24-hour PSD increment





Figure 35 - Refined PM_{2.5} results, SMQ, 24-hour PSD increment

United States
Environmental Protection
Agency

Office of Air Quality Planning and Standards
Air Quality Assessment Division
Research Triangle Park, NC

Publication No. EPA-454/B-16-007
December, 2016
