



United States Environmental Protection Agency
Region 2
 Water Division
 290 Broadway
 New York, New York 10007

NPDES NO. PR0000591

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

The following Permittee is authorized to discharge subject to the requirements set forth in this permit:

Permittee (mailing address)	Facility (location address)
Bacardi Corporation	Bacardi Rum Distillery
P.O. Box 363549	State Road No. 165, Km 2.6
San Juan, Puerto Rico 00936 - 3549	Cataño, Puerto Rico 00632
EPA has classified this discharge as a major discharge.	

The Permittee may discharge from the discharge points identified below:

Outfall	Effluent description	Outfall latitude	Outfall longitude	Receiving water name and classification
001	Boiler blowdown, wash and extraction; Mosto (distillation, fermentation and washes); Pump seal flush (anaerobic filters); Flavor steam traps; Sulfur plant rinses and condensate; Process washes; Molasses unloading and seal flush; Fermentation floor drains; Distillery floor wash; Barrel wash; Cooling towers blowdown; Sanitary wastewater treatment plant effluent; Process steam traps	18° 29' 5.46"	66° 08' 20.82"	Atlantic Ocean Class SB

Issuance date	Effective date (EDP)	Expiration date	Renewal application date
9/20/2021	November 1, 2021	October 31, 2026	April 30, 2026

To meet the provisions of the Clean Water Act (CWA) as amended, 33 *United States Code* (U.S.C.) 1251 *et seq.* and its implementing regulations, the Permittee must comply with the requirements in this permit.

I, **Javier Laureano**, do hereby certify that this permit with all attachments is a full, true, and correct copy of the permit issued by EPA and certified by the Puerto Rico Department of Natural and Environmental Resources, on

9/20/21

Javier Laureano, Director

Water Division
 U.S. Environmental Protection Agency Region 2

CONTENTS

PART I. Background

PART II. Effluent Limitations and Monitoring Requirements

PART III. Reporting Requirements and Compliance Determination

PART IV. Standard and Special Conditions

Attachment A: Definitions

Attachment B: Standard Conditions

PART I. BACKGROUND

- A. Rationale for Permit Requirements.** This permit is issued pursuant to CWA section 402 and implementing regulations adopted by EPA. EPA developed the requirements in this permit on the basis of information submitted as part of the complete application and monitoring and reporting requirements, and other available information. This permit contains technology-based effluent limitations (TBELS) based on **a case-by-case determination using Best Professional Judgment (BPJ) in accordance with 40 CFR 125.3** and water quality-based effluent limits (WQBELs) based on the Puerto Rico Water Quality Standards Regulation (PRWQS), as amended. The accompanying Fact Sheet contains detailed information and rationale for permit requirements.
- B. Water Quality Certificate.** Pursuant to CWA section 401(a)(1), after due consideration of the applicable provisions established in the PRWQS and CWA sections 208(e), 301, 302, 303, 304(e), 306 and 307, on **March 5, 2021** the Puerto Rico Department of Natural and Environmental Resources (DNER) certified that there is reasonable assurance that the allowed discharge will not cause violations to the applicable water quality standards for the receiving water body if the limitations and monitoring requirements in the Water Quality Certificate are met. Additional requirements could be required to comply with other sections of the CWA.
- C. Impaired Waters and Total Maximum Daily Loads (TMDLs).** This facility does not discharge to an impaired water. The effluent limitations in this permit are sufficient to ensure compliance with the applicable water quality standards [40 CFR 122.44(d)(1)(vii)(A)].
- D. Mixing Zone/Dilution Allowance.** DNER has approved a mixing zone or dilution allowance for this discharge. On March 5, 2021, DNER issued a mixing zone approval with a dilution ratio of 150:1.
- E. Antidegradation and Anti-backsliding Requirements.** The discharge is consistent with the federal anti-degradation provisions at 40 CFR 131.12, 72 Federal Register 238 (December 12, 2007, pages 70517-70526), and DNER's *Anti-Degradation Policy Implementation Procedure* in Attachment A of PRWQS. In addition, Some effluent limitations in this permit are less stringent than those in the previous permit and the rationale for these limitations is provided in the Fact Sheet for this permit. An anti-backsliding analysis has been conducted and EPA has determined that these limitations are consistent with the anti-backsliding requirements at 40 CFR 122.44(l).
- F. Public Participation.** Federal regulations at 40 CFR 124 require EPA to consider all significant comments on the draft permit received during the public comment period in the development of the final permit. Any comments received will be provided in a Responsiveness Summary issued with the final permit.

PART II. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

A. Effluent Limitations

Table A-1: Final Effluent Limitations—Outfall Number 001

During the period beginning on November 1, 2021 and lasting through October 31, 2026 the permittee must maintain compliance with the following effluent limitations at Outfall 001, with compliance measured at Monitoring Location 001 which occurs prior to combining with effluent from the PRASA Puerto Nuevo and Bayamón RWWTPs. The discharge at Outfall 001 is composed of:

a. Boiler blowdown, wash and extraction	e. Sulfur plant rinses and condensate	j. Barrel wash
b. Mosto (distillation, fermentation and washes)	f. Process washes	k. Cooling towers blowdown and other
c. Pump seal flush (anaerobic filters)	g. Molasses unloading and seal flush	l. Sanitary wastewater treatment plant effluent
d. Flavor steam traps	h. Fermentation floor drains	m. Process steam traps
	i. Distillery floor wash	

Parameter	Units	Effluent limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Effluent Flow	Mgd (m ³ /day)	Monitor only	Monitor only	1.7 (6,435.2)	Metered	Continuous	(1)
Arsenic (As)	µg/L			Monitor Only	Grab	1/Month	(2)
Effluent BOD, 5-day (20°C) (BOD ₅)	mg/L	17,700.00		Monitor Only	Composite	1/Month	(3)
Cadmium (Cd)	µg/L			14.6	Grab	1/Month	
Color	Pt-Co Units			140,000	Grab	1/Month	
Copper (Cu)	µg/L			3,756	Grab	1/Month	

Table A-1: Final Effluent Limitations—Outfall Number 001

During the period beginning on November 1, 2021 and lasting through October 31, 2026 the permittee must maintain compliance with the following effluent limitations at Outfall 001, with compliance measured at Monitoring Location 001 which occurs prior to combining with effluent from the PRASA Puerto Nuevo and Bayamón RWWTPs. The discharge at Outfall 001 is composed of:

a. Boiler blowdown, wash and extraction	e. Sulfur plant rinses and condensate	j. Barrel wash
b. Mosto (distillation, fermentation and washes)	f. Process washes	k. Cooling towers blowdown and other
c. Pump seal flush (anaerobic filters)	g. Molasses unloading and seal flush	l. Sanitary wastewater treatment plant effluent
d. Flavor steam traps	h. Fermentation floor drains	m. Process steam traps
	i. Distillery floor wash	

Parameter	Units	Effluent limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Chromium VI (Cr ⁺⁶)	µg/L			Monitor Only	Grab	1/Month	(2)
Cyanide, Free (CN)	µg/L			21.1	Grab	1/Month	(4), (5)
Dissolved Oxygen	mg/L			Monitor Only	Grab	1/Day	(3)
Enterococci	colonies/ 100 mL	564,911	--	--	Grab	2/Month	(6)
	90th Percentile of the samples	2,066,327	--	--	Calculated	2/Month	(6)
Lead (Pb)	µg/L			52.30	Grab	1/Month	
Mercury (Hg)	µg/L			0.200	Grab	1/Month	
Nickel (Ni)	µg/L			455.8	Grab	1/Month	

Table A-1: Final Effluent Limitations—Outfall Number 001

During the period beginning on November 1, 2021 and lasting through October 31, 2026 the permittee must maintain compliance with the following effluent limitations at Outfall 001, with compliance measured at Monitoring Location 001 which occurs prior to combining with effluent from the PRASA Puerto Nuevo and Bayamón RWWTPs. The discharge at Outfall 001 is composed of:

a. Boiler blowdown, wash and extraction	e. Sulfur plant rinses and condensate	j. Barrel wash
b. Mosto (distillation, fermentation and washes)	f. Process washes	k. Cooling towers blowdown and other
c. Pump seal flush (anaerobic filters)	g. Molasses unloading and seal flush	l. Sanitary wastewater treatment plant effluent
d. Flavor steam traps	h. Fermentation floor drains	m. Process steam traps
	i. Distillery floor wash	

Parameter	Units	Effluent limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Oil and Grease	mg/L	The waters of Puerto Rico shall be substantially free from floating non-petroleum oils and greases as well as petroleum derived oil and greases.			Grab	1/Month	
pH	standard units	Minimum 6.0 Maximum 9.0			Grab	1/Day	
Selenium (Se)	µg/L			Monitor Only	Grab	1/Month	(2)
Silver (Ag)	µg/L			8.0	Grab	1/Month	
Solids and Other Matter		The waters of Puerto Rico shall not contain floating debris, scum, or other floating materials attributable to the discharge in amounts sufficient to be unsightly or deleterious to the existing or designated uses of the water body.			----	----	
Sulfide (Undissociated H ₂ S)	µg/L			49,680.7	Grab	1/Month	(7)
Surfactants (as Methylene Blue Activate Substances)	µg/L			1,362	Grab	1/Month	

Table A-1: Final Effluent Limitations—Outfall Number 001

During the period beginning on November 1, 2021 and lasting through October 31, 2026 the permittee must maintain compliance with the following effluent limitations at Outfall 001, with compliance measured at Monitoring Location 001 which occurs prior to combining with effluent from the PRASA Puerto Nuevo and Bayamón RWWTPs. The discharge at Outfall 001 is composed of:

a. Boiler blowdown, wash and extraction	e. Sulfur plant rinses and condensate	j. Barrel wash
b. Mosto (distillation, fermentation and washes)	f. Process washes	k. Cooling towers blowdown and other
c. Pump seal flush (anaerobic filters)	g. Molasses unloading and seal flush	l. Sanitary wastewater treatment plant effluent
d. Flavor steam traps	h. Fermentation floor drains	m. Process steam traps
	i. Distillery floor wash	

Parameter	Units	Effluent limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Suspended, Colloidal or Settleable Solids (mL/L)	mL/L	Solids from wastewater sources shall not cause deposition in, or be deleterious to the existing or designated uses of the waterbody.			Grab	1/Day	
Taste and Odor-producing Substances		Shall not be present in amounts that will render any undesirable taste or odor to edible aquatic life.			----	----	
Temperature	°F(°C)			107.6 (42)	Grab	1/Day	
Thallium (Tl)	µg/L			20.00	Grab	1/Month	
Total Nitrogen (NO ₃ + NO ₂ +TKN)	µg/L			3,161,260	Grab	1/Month	
Total Suspended Solids (TSS)	mg/L	Monitor Only		Monitor Only	Composite	1/Month	
Turbidity	NTU			12,902	Grab	1/Month	
Zinc (Zn)	µg/L			2,907.85	Grab	1/Month	

Table A-1: Final Effluent Limitations—Outfall Number 001

During the period beginning on November 1, 2021 and lasting through October 31, 2026 the permittee must maintain compliance with the following effluent limitations at Outfall 001, with compliance measured at Monitoring Location 001 which occurs prior to combining with effluent from the PRASA Puerto Nuevo and Bayamón RWWTPs. The discharge at Outfall 001 is composed of:

a. Boiler blowdown, wash and extraction	e. Sulfur plant rinses and condensate	j. Barrel wash
b. Mosto (distillation, fermentation and washes)	f. Process washes	k. Cooling towers blowdown and other
c. Pump seal flush (anaerobic filters)	g. Molasses unloading and seal flush	l. Sanitary wastewater treatment plant effluent
d. Flavor steam traps	h. Fermentation floor drains	m. Process steam traps
	i. Distillery floor wash	

Parameter	Units	Effluent limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Whole Effluent Toxicity (WET) – Mysisidopsis bahia	LC50%	--	--	Monitor	24-hr Composite	1/Year	(8)
Whole Effluent Toxicity (WET) – Mysisidopsis bahia	NOEC %	--	--	Monitor	24-hr Composite	1/Quarter	(8)
Whole Effluent Toxicity (WET) – Cyprinodon variegatus	LC50%	--	--	Monitor	24-hr Composite	1/Year	(8)
Whole Effluent Toxicity (WET) – Cyprinodon variegatus	NOEC %	--	--	Monitor	24-hr Composite	1/Quarter	(8)
Whole Effluent Toxicity (WET) – Arbacia punctulata	NOEC %	--	--	Monitor	24-hr Composite	1/Quarter	(8)
Whole Effluent Toxicity (WET) – Chronic Effects	Minimum NOEC%	--	--	≥0.81%	24-hr Composite	1/Quarter	(8)

Notes, Footnotes and Abbreviations

Dashes (--) indicate there are no effluent limitations or monitoring requirements for this parameter.

- (1) All flow measurements must achieve accuracy within the range of plus or minus (\pm) 10%.
- (2) The permittee shall implement a monthly monitoring program using the analytical method approved by EPA with the lowest possible detection level, in accordance with Rule 1306.2(C) of the PRWQSR, as amended, for one (1) year period, after which they will be conducted annually. The monitoring program shall commence no later than December 1, 2021. The results of the monitoring program shall be submitted to DNER's Water Quality Area and to the Multimedia Permits and Compliance Branch in EPA's Region 2 Caribbean Environmental Protection Division, no later than sixty (60) days of completion of the one-year monitoring program. Based on the evaluation of the results obtained, the DNER will determine if an effluent limitation is necessary for this parameter. In such case, the WQC will be reopened to include the applicable effluent limitation.
- (3) The Effluent limitation for BOD₅ is based on the Mixing Zone Application for the Combined Ocean Outfall which discharges wastewater from the Bayamón RWWTP, Puerto Nuevo RWWTP and the Bacardi Rum Distillery, after determining that there is a reasonable assurance that this limit will not cause violations to the water quality standard for Dissolved Oxygen for Class SB waters.
- (4) The samples shall be analyzed using the method approved by EPA in letter of February 20, 2007.
- (5) See Part IV. B.1. Special Condition j.
- (6) Enterococci
 - (a) The enterococci density, in terms of geometric mean shall not exceed 564,911 colonies/mL in any 90-day interval; the 90th Percentile of the samples taken shall not exceed 2,066,327 colonies/100 mL in the same 90-day interval.
 - (b) The enterococci density geometric mean and the 90th Percentile shall be calculated on a monthly basis beginning on January 31, 2022, using the 6 point data set obtained during the previous 90-day interval. A monthly report with the calculations and the data set shall be submitted to DNER's Water Quality Area and to the Multimedia Permits and Compliance Branch of the EPA Region 2 Caribbean Environmental Protection Division, beginning on February 15, 2022 and during the effectiveness of the permit.
- (7) See Part IV. B.1. Special Conditions i.
- (8) See Part IV.B.2. *Whole Effluent Toxicity Testing* for monitoring and reporting requirements for acute and chronic WET. The effluent limitation result for all toxicity parameters must be a Minimum Daily.

Table A-2 – Mixing Zone Monitoring Stations							
During the period beginning on November 1, 2023 and lasting through October 31, 2026, the permittee shall perform monitoring at the mixing zone monitoring stations as specified below:							
Parameter	Units	Edge of Mixing Zone Limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Cadmium (Cd)	µg/L			7.95	Grab	As specified in Part IV. B.1.s	(4)
Color		Shall not be altered by other than natural phenomena.			Grab	As specified in Part IV. B.1.s	(4)
Copper (Cu)	µg/L			3.73	Grab	As specified in Part IV. B.1.s	(4)
Cyanide, Free (CN)	µg/L			1.0	Grab	As specified in Part IV. B.1.s	(1),(3),(4)
Dissolved Oxygen	mg/L	Shall contain no less than 5.0.			Grab	As specified in Part IV. B.1.s	(4)
Lead (Pb)	µg/L			8.52	Grab	As specified in Part IV. B.1.s	(4)
Mercury (Hg)	µg/L			0.051	Grab	As specified in Part IV. B.1.s	(4)
Nickel (Ni)	µg/L			8.28	Grab	As specified in Part IV. B.1.s	(4)
pH	standard units	Minimum 7.3 Maximum 8.5			Grab	As specified in Part IV. B.1.s	(4)
Silver (Ag)	µg/L			2.24	Grab	As specified in Part IV. B.1.s	(4)
Sulfide (Undissociated H ₂ S)	µg/L			2.0	Grab	As specified in Part IV. B.1.s	(2),(4)

Table A-2 – Mixing Zone Monitoring Stations							
During the period beginning on November 1, 2023 and lasting through October 31, 2026, the permittee shall perform monitoring at the mixing zone monitoring stations as specified below:							
Parameter	Units	Edge of Mixing Zone Limitations			Monitoring requirements		Footnotes
		Average monthly	Average weekly	Maximum daily	Sample type	Minimum sampling frequency	
Surfactants (as Methylene Blue Activate Substances)	µg/L			500	Grab	As specified in Part IV. B.1.s	(4)
Temperature	°F(°C)	Except by natural phenomena, no heat, which would cause the temperature of any site to exceed 86°F or 30°C, may be added to the waters of Puerto Rico.			Grab	As specified in Part IV. B.1.s	(4)
Thallium (Tl)	µg/L			0.47	Grab	As specified in Part IV. B.1.s	(4)
Total Nitrogen (NO ₃ + NO ₂ +TKN)	µg/L			5,000	Grab	As specified in Part IV. B.1.s	(4)
Turbidity	NTU			10	Grab	As specified in Part IV. B.1.s	(4)
Zinc (Zn)	µg/L			85.62	Grab	As specified in Part IV. B.1.s	(4)

Table A-2 Notes, Footnotes and Abbreviations

- (1) The samples shall be analyzed using the method approved by EPA in letter of February 20, 2007.
- (2) See Part IV. B.1. Special Condition i.
- (3) See Part IV. B.1. Special Condition j.
- (4) See Part IV. B.1. Special Condition s.

Table A-3 – Monitoring Requirements Background Sampling Station							
During the period beginning on November 1, 2021 and lasting through October 31, 2026, the permittee shall perform monitoring at the background sampling station as specified below:							
Parameter	Units				Monitoring requirements		Footnotes
					Sample type	Minimum sampling frequency	
Cadmium (Cd)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Color					Grab	As specified in Part IV. B.1.s	(4)
Copper (Cu)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Cyanide, Free (CN)	µg/L				Grab	As specified in Part IV. B.1.s	(1),(3),(4)
Dissolved Oxygen	mg/L				Grab	As specified in Part IV. B.1.s	(4)
Lead (Pb)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Mercury (Hg)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Nickel (Ni)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
pH	standard units				Grab	As specified in Part IV. B.1.s	(4)
Silver (Ag)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Sulfide (Undissociated H ₂ S)	µg/L				Grab	As specified in Part IV. B.1.s	(2),(4)

Table A-3 – Monitoring Requirements Background Sampling Station							
During the period beginning on November 1, 2021 and lasting through October 31, 2026, the permittee shall perform monitoring at the background sampling station as specified below:							
Parameter	Units				Monitoring requirements		Footnotes
					Sample type	Minimum sampling frequency	
Surfactants (as Methylene Blue Activate Substances)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Temperature	°F(°C)				Grab	As specified in Part IV. B.1.s	(4)
Thallium (TI)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Total Nitrogen (NO ₃ + NO ₂ +TKN)	µg/L				Grab	As specified in Part IV. B.1.s	(4)
Turbidity	NTU				Grab	As specified in Part IV. B.1.s	(4)
Zinc (Zn)	µg/L				Grab	As specified in Part IV. B.1.s	(4)

Table A-3 Notes, Footnotes and Abbreviations

- (1) The samples shall be analyzed using the method approved by EPA in letter of February 20, 2007.
- (2) See Part IV. B.1. Special Condition i.
- (3) See Part IV. B.1. Special Condition j.
- (4) See Part IV. B.1. Special Condition s.

Table A-4 – Effluent Limitations and Monitoring Requirements at the Edge of the Mixing Zone							
During the period beginning on November 1, 2021 and lasting through October 31, 2026, the permittee shall perform monitoring at the mixing zone monitoring stations as specified below:							
Parameter	Units	Gross Discharge Limitations			Monitoring requirements		Footnotes
					Sample type	Minimum sampling frequency	
Enterococci	Colonies/ 100 mL	The enterococci density, in terms of geometric mean shall not exceed 35 colonies/100 mL in any 90-day interval; neither the 90 th Percentile of the samples taken shall exceed 130 colonies/100 mL in the same 90-day interval.			Grab		(1), (2)

Table A-4 Notes, Footnotes and Abbreviations

- (1) See Part IV. B.1. Special Condition s.15)
- (2) The enterococci density geometric mean and the 90th Percentile shall be calculated on a frequency basis as established in the Quality Assurance Project Plan (QAPP) approved by the DNER according to Special Condition IV.B.1.s.16), using the three (3) points data set obtained during each sampling event. A report with the calculations and the data set shall be submitted to DNER's Water Quality Area and to the Multimedia Permits and Compliance Branch of EPA's Region 2 Caribbean Environmental Protection Division, within the sixty (60) days period after the completion of each monitoring event.

Table A-5 – Effluent Limitations and Monitoring Requirements at the Background Sampling Station							
During the period beginning on November 1, 2021 and lasting through October 31, 2026, the permittee shall perform monitoring at the mixing zone monitoring stations as specified below:							
Parameter	Units				Monitoring requirements		Footnotes
					Sample type	Minimum sampling frequency	
Enterococci	Colonies/ 100 mL				Grab		(1), (2)

Table A-5 Notes, Footnotes and Abbreviations

- (1) See Part IV. B.1. Special Condition s.15).
- (2) The enterococci density geometric mean and the 90th Percentile shall be calculated on a frequency basis as established in the Quality Assurance Project Plan (QAPP) approved by the DNER according to Special Condition IV.B.1.s.16), using the three (3) points data set obtained during each sampling event. A report with the calculations and the data set shall be submitted to DNER’s Water Quality Area and to the Multimedia Permits and Compliance Branch of EPA’s Region 2 Caribbean Environmental Protection Division, within the sixty (60) days period after the completion of each monitoring event.

Table A-6 Technology Based Requirements at Internal Outfall 002

During the period beginning on November 1, 2021 and lasting through October 31, 2026 the permittee is authorized to discharge from internal monitoring point 002. Such discharge shall be limited and monitored by the permittee as specified below:

Effluent Characteristics	Units				Monitoring Requirements		Footnote
		Quarterly Rolling Average (QRA)*	Monthly Avg. kg/day (lb/day)	Daily Maximum kg/day (lb/day)	Measurement Frequency	Sample Type	
Flow m ³ /day (MGD)	MGD			----	Continuous Recording		
BOD ₅	mg/L		30,000 (66,200)	42,400 (93,280)	Weekly	Composite	
Total Suspended Solids (mg/l)	mg/L		45,200 (99,440)	71,200 (156,640)	Weekly	Composite	
Influent BOD ₅ Concentration (mg/l)	mg/L	Monitor influent BOD ₅ concentration on a weekly basis			Weekly	Composite	
Effluent BOD ₅ Concentration (mg/l)	mg/L	Monitor influent BOD ₅ concentration on a weekly basis			Weekly	Composite	
Quarterly Rolling Average Calculation							(1)
(A) Influent QRA BOD ₅ Concentration (mg/l)	mg/L	Calculate and report QRA Influent BOD ₅ concentration on a monthly basis.*					(2)
(B) QRA Influent BOD ₅ Loading (lb/day)	(lb/day)	Calculate and report QRA Influent BOD ₅ loading on a monthly basis.*					(3)
(C) QRA Effluent BOD ₅ Loading (lb/day)	(lb/day)	Calculate and report QRA Effluent BOD ₅ loading on a monthly basis.*					(4)

Table A-6 Technology Based Requirements at Internal Outfall 002							
During the period beginning on November 1, 2021 and lasting through October 31, 2026 the permittee is authorized to discharge from internal monitoring point 002. Such discharge shall be limited and monitored by the permittee as specified below:							
Effluent Characteristics	Units				Monitoring Requirements		
		Quarterly Rolling Average (QRA)*	Monthly Avg. kg/day (lb/day)	Daily Maximum kg/day (lb/day)	Measurement Frequency	Sample Type	Footnote
Tiered QRA Percentage Removal Requirement							
When QRA Influent BOD ₅ Concentration (Row (A)) is ≥ 23,600 mg/l		Calculate and report QRA Percentage Removal monthly. QRA Percentage Removal shall be no less than 70%					(5)
When QRA Influent BOD ₅ Concentration (Row (A)) is < 23,600 mg/l		Calculate and report QRA Percentage Removal monthly.					(5)

Table A-6 Notes:

Internal monitoring point 002 is in the vicinity of a flow measuring device after anaerobic treatment, and is designed to monitor only all effluent flows from the anaerobic digesters prior to mixing with any other waste streams.

- (1) All Quarterly Rolling Averages (QRA) shall be calculated on a monthly basis, using the previous thirteen weekly results. Calculations shall be reported on a spreadsheet as a supplement to the DMR. This spreadsheet shall include all flow rates, concentrations, calculated loadings, and thirteen weeks of results used to calculate any QRA numbers.
- (2) The QRA Influent BOD₅ Concentration to the anaerobic digesters shall be calculated over the previous thirteen weeks and reported. The calculated result will determine whether the limitation of a minimum of 70% removal rate applies. This value must be reported in the DMR.
- (3) The QRA Influent BOD₅ Loading shall be calculated based on the influent concentration and the flow. This calculation must be included in the supplement to the DMR.
- (4) The QRA Effluent BOD₅ Loading shall be calculated based on the effluent concentration and flow. This calculation must be included in the supplement to the DMR.
- (5) The QRA Percentage Removal for BOD₅ shall be the calculated as the percentage difference between the QRA Influent BOD₅ Loading (Row (B)) results, and the QRA Effluent BOD₅ Loading results (Row (C)). This calculation shall be included in the supplement to the DMR. The calculated value shall be reported in the DMR.

Production data for the days of sampling for each month, in proof gallons per day, is required to be submitted with the DMR.

B. Narrative Limitations

In accordance with 40 CFR 122.44(d), the permit establishes the following narrative limitations.

1. The waters of Puerto Rico must not contain any substance, attributable to the discharge at such concentration which, either alone or as result of synergistic effects with other substances, is toxic or produces undesirable physiological responses in humans, fish, or other fauna or flora.
2. The discharge must not cause the presence of oil sheen in the receiving water body.
3. The waters of Puerto Rico must not contain floating debris, scum, or other floating materials attributable to discharges in amounts sufficient to be unsightly or deleterious to the existing or designated uses of the water body.
4. Solids from wastewater sources must not cause deposition in or be deleterious to the existing or designated uses of the waters.
5. Taste and odor-producing substances must not be present in amounts that will interfere with primary contact recreation, or will render any undesirable taste or odor to edible aquatic life.

C. Monitoring Requirements

1. Effluent monitoring and analyses must be conducted in accordance with EPA test procedures approved under 40 CFR Part 136, *Guidelines Establishing Test Procedures for the Analysis of Pollutants Under the Clean Water Act*, as amended. For situations where there may be interference, refer to *Solutions to Analytical Chemistry Problems with Clean Water Act Methods* (EPA 821-R-07-002). For effluent analyses, the Permittee must use a *Minimum Level (ML)* that is lower than the effluent limitations described in Effluent Limitations Table of this permit. If all published MLs are higher than the effluent limitations, the Permittee must use the test method procedure with the lowest ML. The Permittee must ensure that the laboratory uses a standard calibration where the lowest standard point is equal to or less than the ML. Priority pollutant analysis for metals must measure *total metal*, except as provided under 40 CFR 122.45(c). EPA method 1631E must be used for mercury analysis. Priority pollutant analysis for benzene, ethylbenzene, toluene and xylene must employ either EPA Method 602 or 624. Effluent analysis for xylene must measure *total xylene*.
2. The regulations at 40 CFR 122.48 require that all NPDES permits specify monitoring and reporting requirements. All monitoring must be in accordance with Standard Condition 10. *Monitoring and records* in Attachment B of this permit.
3. Sampling point for Outfall 001 must be located immediately after the primary flow measuring device of the effluent of the treatment system.
4. The Permittee must develop and implement a quality assurance (QA) plan for laboratory analyses for effluent and/or receiving water monitoring.

D. Monitoring Locations

The Permittee must establish the following monitoring locations to demonstrate compliance with the effluent limitations and other requirements in this permit:

Monitoring Locations Table

Outfall	Monitoring location	Monitoring location description
001	EFF-001	Shoreline Sampling Building prior to discharge to combine with PRASA effluents
002 inf	INF-002	Upstream of anaerobic digester treatment
002 eff	EFF-002	Outfall 002 sampling point following anaerobic digester treatment

PART III. REPORTING REQUIREMENTS AND COMPLIANCE DETERMINATION

A. Reporting Requirements

1. **Standard Conditions.** The Permittee must comply with all Standard Conditions in section IV.A below and Attachment B of this permit related to monitoring, reporting, and recordkeeping.
2. **Monitoring data submission.** The Permittee shall submit monitoring data to EPA electronically using NetDMR, a web-based tool that allows Permittees to electronically submit discharge monitoring reports (DMRs) via a secure internet connection. Specific requirements regarding submittal of data and reports in hard copy form and for submittal using NetDMR are described below:
 - a. **Submittal of Reports Using NetDMR.** DMR submittals must be submitted in accordance with Standard Condition 12.d. *Monitoring reports* in Attachment B of this permit. The Permittee will report the results for all monitoring specified in this permit. The Permittee shall submit monthly DMRs including the results of all required monitoring using EPA-approved test methods or other test methods specified in this permit as required. If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring must be included in the calculation and reporting of the data submitted in the DMR. DMRs and reports submitted electronically to EPA must be done using NetDMR at <http://www.epa.gov/netdmr>.
 - b. **Submittal of Reports in Hard Copy.** Non-DMR reports must be submitted in accordance III.A.3. Permittees shall continue to send hard copies of reports other than DMRs to the EPA and DNER until further notice from the EPA and DNER.
 - c. **Timing of submissions.** DMRs shall be submitted to EPA no later than the 28th day of the month following the completed reporting period. Monitoring results shall be summarized and reported using netDMR. The first report is due on **December 28, 2021**.
3. **Submission Requirements.** If submitting reports in hard copy form, DMRs must be signed and certified as required by Standard Condition 11. *Signatory requirements* in Attachment B of this permit. The Permittee must submit the original signed DMR to 3.a below and duplicate signed copies and all other reports required in this permit to 3.b below:
 - a. U.S. Environmental Protection Agency, Region 2
290 Broadway, 21st Floor
New York, NY 10007-1866
Attention: Compliance Assistance and Program Support Branch
 - b. Puerto Rico Department of Natural and Environmental Resources
P.O. Box 11488
Santurce, PR 00910
Attention: Water Quality Area
4. **Analytical Determinations.** The Permittee must report the results on the DMR of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:
 - a. Sample results greater than or equal to the ML must be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
 - b. Sample results less than the ML must be reported as <ML, where the ML equals the ML reported by the laboratory.
 - c. Permittees are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Permittee to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.
5. **Bacterial Monitoring.**

The enterococci density geometric mean and the 90th Percentile shall be calculated on a monthly basis beginning on January 31, 2022, using the 6 point data set obtained during the previous 90-day interval. A monthly report with the calculations and the data set shall be submitted to DNER's Water Quality Area and to

the Multimedia Permits and Compliance Branch of the EPA Region 2 Caribbean Environmental Protection Division, beginning on February 15, 2022 and during the effectiveness of the permit.

B. Compliance Determination

Compliance with effluent limitations contained in this permit will be determined as specified below:

1. **General.** Compliance with effluent limitations for priority pollutants must be determined using sample reporting protocols defined in section III. A and Attachment A. *Definitions.*
2. **Average Monthly Discharge Limitation (AML).** If the average or, when applicable, the median of daily discharges that were measured in a calendar month exceeds the AML for a given parameter, this will represent a single violation, though the Permittee will be considered out of compliance for each day of that month for that parameter (e.g., resulting in 31 days of noncompliance in a 31-day month). If only a single sample is taken during the calendar month and the analytical result for that sample exceeds the AML, the Permittee will be considered out of compliance for that calendar month. The Permittee will be considered out of compliance for only the days when the discharge occurs. For any one calendar month during which no sample (daily discharge) is taken yet sampling is required, the Permittee will be considered out of compliance for that calendar month.
3. **Average Weekly Discharge Limitation (AWL).** If the average or, when applicable, the median of daily discharges over a calendar week exceeds the AWL for a given parameter, this will represent a single violation, though the Permittee will be considered out of compliance for each day of that week for that parameter, resulting in 7 days of noncompliance. If only a single sample is taken during the calendar week and the analytical result for that sample exceeds the AWL, the Permittee will be considered out of compliance for that calendar week. The Permittee will be considered out of compliance for only the days when the discharge occurs. For any one calendar week during which no sample (daily discharge) is taken yet sampling is required, the Permittee will be considered out of compliance for that calendar week.
4. **Maximum Daily Discharge Limitation (MDL).** If a daily discharge exceeds the MDL for a given parameter, the Permittee will be considered out of compliance for that parameter for that 1 day only in the reporting period. For any one day during which no sample is taken yet a sampling is required, the Permittee will be considered out of compliance for that day.

PART IV. STANDARD AND SPECIAL CONDITIONS

A. Standard Conditions

1. Standard Conditions Applicable to All Facilities

- a. The Permittee must comply with all Standard Conditions that apply to all NPDES permits in accordance with 40 CFR 122.41 (Attachment B of this permit), and additional conditions applicable to specific categories of facilities in accordance with 40 CFR 122.42.
- b. The Permittee must comply with the Reopener Clause in Standard Condition 17. *Reopener clause for toxic effluent limitations*, in Attachment B of this permit, which applies to all NPDES permits in accordance with 40 CFR 122.44(b). EPA reserves the right to revoke and reissue or modify this permit to establish effluent limitations, additional monitoring, schedules of compliance or other permit conditions based on new information, including any changes to the final Water Quality Certificate from DNER.

2. Standard Conditions Applicable to Specific Facilities—Notification Levels

All POTWs must provide adequate notice to EPA of all of the following [40 CFR 122.42(b)]:

- a. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to CWA sections 301 or 306 if it were directly discharging those pollutants [40 CFR 122.42(b)(1)].
- b. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of this permit [40 CFR 122.42(b)(2)].
- c. Adequate notice must include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW [40 CFR 122.42(b)(3)].

Existing manufacturing, commercial, mining, and silvicultural dischargers must notify EPA as soon as they know or have reason to believe [40 CFR 122.42(a)]:

- a. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this permit, if that discharge will exceed the highest of any one of the following *notification levels* [40 CFR 122.42(a)(1)]:
 - 1) 100 micrograms per liter ($\mu\text{g/L}$) [40 CFR 122.42(a)(1)(i)].
 - 2) 200 $\mu\text{g/L}$ for acrolein and acrylonitrile; 500 $\mu\text{g/L}$ for 2,4 dinitrophenol and 2 methyl 4,6 dinitrophenol; and 1 milligrams per liter (mg/L) for antimony [40 CFR 122.42(a)(1)(ii)].
 - 3) Five times the maximum concentration value reported for that pollutant in the DMR [40 CFR 122.42(a)(1)(iii)].
 - 4) The level established by EPA in accordance with 40 CFR 122.44(f) [40 CFR 122.42(a)(1)(iv)].
- b. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this permit, if that discharge will exceed the highest of any one of the following *notification levels* [40 CFR 122.42(a)(2)]:
 - 1) 500 $\mu\text{g/L}$ [40 CFR 122.42(a)(2)(i)].
 - 2) 1 mg/L for antimony [40 CFR 122.42(a)(2)(ii)].
 - 3) Ten times the maximum concentration value reported for that pollutant in the DMR [40 CFR 122.42(a)(2)(iii)].
 - 4) The level established by EPA in accordance with 40 CFR 122.44(f) [40 CFR 122.42(a)(2)(iv)].

B. Special Conditions

1. Special Conditions from the Water Quality Certificate

- a. The flow of discharge 001 shall not exceed the limitation of 6,435.2 m^3/day (1.7 MGD) as daily maximum. No increase in flow shall be authorized without a recertification from the Department of Natural and Environmental Resources (DNER).
- b. No changes in the design or capacity of the treatment system will be permitted without the previous authorization of DNER.
- c. Prior to the construction of any additional treatment system or the modification of the existing one, the permittee shall obtain the approval from DNER of the engineering report, plans and specifications.
- d. The permittee shall install, maintain and operate all water pollution control equipment in such manner as to be in compliance with the applicable Rules and Regulations.
- e. No toxic substances shall be discharged, in toxic concentrations, other than those allowed as specified in the NPDES permit. Those toxic substances included in the permit renewal application, but not regulated by the NPDES permit, shall not exceed the concentrations as specified in the applicable regulatory limitations.
- f. The waters of Puerto Rico shall not contain any substance attributable to discharge 001, at such concentration which, either alone or as result of synergistic effects with other substances, is toxic or produces undesirable physiological responses in human, fish or other fauna or flora.
- g. The discharge 001 shall not cause the presence of oil sheen in the receiving water body.
- h. All sample collection, preservation, and analysis shall be carried out in accordance with the Title 40 of the Code of Federal Regulations (40 CFR), Part 136. A licensed chemist authorized to practice the profession in Puerto Rico shall certify all chemical analyses. All bacteriological tests shall be certified by a microbiologist or licensed medical technologist authorized to practice the profession in Puerto Rico.
- i. The permittee shall use the analytical method approved by the EPA, with the lowest possible detection limit, in accordance with the 40 CFR, Part 136 for Sulfide (as S). Also, the permittee shall complete the calculations specified in Method 4500-S² F, Calculation of Un-ionized Hydrogen Sulfide, of Standards

Methods 18th Edition, 1992, to determine the concentration of undissociated H₂S. If the sample results of Dissolved Sulfide are below the detection limit of the EPA approved method established in the 40 CFR, Part 136, then, the concentration of undissociated H₂S shall be reported as "below detection limit".

- j. The samples taken for the analysis of free cyanide shall be analyzed using the analytic method approved by the EPA with the lowest possible detection level, in accordance with Rule 1306.8 of the Puerto Rico Water Quality Standards Regulation (PRWQSR), as amended.
- k. The flow-measuring device for the discharge 001, shall be periodically calibrated and properly maintained. Calibration and maintenance records must be kept in compliance with the Applicable Rules and Regulations.
- l. The sampling point for discharge 001 shall be located immediately after the primary flow-measuring device of the effluent of the treatment system.
- m. The sampling point for discharge 001 shall be labeled with an 18 inches per 12 inches (minimum dimensions) sign that reads as follows:

"PUNTO DE MUESTREO PARA LA DESCARGA 001"

- n. All water or wastewater treatment facility, whether publicly or privately owned, must be operated by a person licensed by the Examination Board of Water and Wastewater Treatment Plant Operators of Puerto Rico.
- o. The solid wastes such as sludge, screenings and grit, generated due to the operation of the Bacardi Corporation Treatment System shall be:
 - 1) Disposed in compliance with the applicable requirements established in the 40 CFR, Part 257. A semiannual report shall be submitted to the Water Quality Area and Land Pollution Control Area of the DNER and the Multimedia Permits and Compliance Branch of EPA's Region 2 Caribbean Environmental Protection Division, notifying the method or methods used to dispose the solid waste generated in the facility. Also, copy of the approval or permit applicable to the disposal method used shall be submitted, if any.
 - 2) Transported adequately in such way that access is not gained to any water body or soil. In the event of a spill of solid waste on land or into a water body, the permittee shall notify the Point Sources Permits Division of the DNER's Water Quality Area in writing within a term no longer than twenty-four (24) hours after the spill to the following electronic address: bypass@jca.pr.gov.

This notification shall include the following information:

- a) spill material,
- b) spill volume,
- c) measures taken to prevent the spill material to gain access to any water body.

This special condition does not relieve the permittee from its responsibility to obtain the corresponding permits from the DNER's Land Pollution Control Area and other state and federal agencies, if any.

- p. A logbook must be kept for the material removed from the Bacardi Corporation Treatment System, such as sludge, screenings and grit, detailing the following items:
 - 1) removed material, date and source of it;
 - 2) approximate volume and weight;
 - 3) method by which it is removed and transported;
 - 4) final disposal and location;
 - 5) person that performs the service.

A copy of the Non-Hazardous Solid Waste Collection or Transportation Services Permit issued by the authorized official from the DNER must be attached to the logbook.

- q. The sludge produced within the facility due to the operation of the treatment system shall be analyzed and all constituents shall be identified as required by “Standards for the Use or Disposal of Sewage Sludge” (40 CFR, Part 503). The sludge shall be disposed properly in such manner that water pollution or other adverse effects to surface waters or to ground water do not occur.
- r. If any standard or prohibition to the sanitary sludge disposal is promulgated and said prohibition or standard is more stringent than any condition, restriction, prohibition or standard contained in the NPDES permit, such permit shall be modified accordingly or revoked and reissued to be adjusted with regard to such prohibition or standard.
- s. The DNER has defined and authorized a Mixing Zone (MZ) pursuant to Rule 1305 of the PRWQSR.

1) The MZ is delineated by the following points (See Diagram I):

Geographic Coordinates*

Point 1	Lat. 18° 29' 04.50” Long. 66° 08' 21.12”
Point 2	Lat. 18° 29' 10.92” Long. 66° 08' 31.26”
Point 3	Lat. 18° 29' 12.48” Long. 66° 08' 30.12”
Point 4	Lat. 18° 29' 06.36” Long. 66° 08' 20.52”
Point 5	Lat. 18° 29' 06.18” Long. 66° 08' 09.00”
Point 6	Lat. 18° 29' 04.32” Long. 66° 08' 09.00”

* NAD 83 State Plane Coordinates

The diffuser configuration is a one hundred twenty (120) degree “Y” type consisting of two (2) legs: the western leg of one thousand twenty-eight (1,028) feet long and the eastern leg of one thousand twenty-four (1,024) feet long; and a constant diameter of eighty-four (84) inches. A total of one hundred two (102) ports along the east diffuser’s leg shall be opened, distributed as follows: eighty-one (81) six (6)-inch ports, twenty (20) seven (7)-inch ports and one (1) ten (10)-inch port (on the end gate). In addition, a total of one hundred one (101) ports along the west diffuser’s leg shall be opened, distributed as follows: eighty (80) six (6)-inch ports, nineteen (19) seven (7)-inch ports, one (1) ten (10)-inch port (on the end gate), and a leak simulated as a one (1)-inch port. The ports discharge in alternate directions at a constant spacing of 12.89 feet, except for the leak which is 4.98 feet and the end gate port which is 13.22 feet.

- 2) The mixing zone sampling stations shall be located at the six (6) points described in Part “1” of this special condition.
- 3) The background sampling station shall be located one hundred (100) meters from Point 3 or Point 5 of the mixing zone, depending of the current direction at the time of sampling. The background stations shall be located at the following geographic coordinates:

Geographic Coordinates

BG1 Lat. 18° 29' 14.34"
Long. 66° 08' 33.00"

BG2 Lat. 18° 29' 06.12"
Long. 66° 08' 05.58"

* NAD 83 State Plane Coordinates

- 4) The permittee shall maintain records of the equipment used to situate at the mixing zone boundaries. Such records shall include the date when the equipment was obtained or leased, calibration date, serial number, model, etc.

To identify the location of the sampling points of the mixing zone and the background, the permittee shall use the procedure established in the EPA-QA/QC for 301(h) Document (Table D-1 Example ZID Boundary Stations Locations).

If the permittee determines to use another method to identify the sampling points of the mixing zone, the permittee shall, prior to the utilization of such method, obtain written approval from DNER.

- 5) The MZ is defined for the following parameters:

<u>Parameter</u>	<u>Daily Maximum Discharge Limitation at Outfall Serial Number 001</u>	<u>Daily Maximum Limitation at the Edge of the MZ</u>
Cadmium (Cd) (µg/L)	14.6	7.95
Color (Pt-Co)	140,000	Ω
Copper (Cu) (µg/L)	3,756	3.73
Cyanide, Free (CN)(µg/L)	21.1	1.0
Dissolved Oxygen (mg/L)	Monitoring Only	≥5.0
Enterococci (col/100 mL), Geometric Mean	564,911 [‡]	*
Enterococci (col/100 mL), 90 th Percentile	2,066,237 [‡]	**
Lead (Pb) (µg/L)	52.30	8.52
Mercury (Hg) (µg/L)	0.200	0.051
Nickel (Ni) (µg/L)	455.8	8.28
pH (SU)	6.0 – 9.0	7.3 – 8.5
Silver (Ag) (µg/L)	8.0	2.24
Sulfide (undissociated H ₂ S) (µg/L)	49,680.7	2.0
Surfactants (as MBAS) (µg/L)	1,362	500
Temperature °F (°C)	107.6 (42)	86 (30.0) ^δ
Thallium (Tl) (µg/L)	20.00	0.47
Total Nitrogen (NO ₂ +NO ₃ +TKN) (µg/L)	3,161,260	5,000
Turbidity (NTU)	12,902	10
Zinc (Zn) (µg/L)	2,907.85	85.62

Ω The color at the edge of the mixing zone shall not exceed the color of the receiving water body (background monitoring station).

δ Except by natural phenomena, no heat which would cause the temperature of any site to exceed 86°F or 30.0°C, may be added to the waters of Puerto Rico.


‡ The enterococci density geometric mean and the 90th Percentile shall be calculated on a monthly basis beginning on January 31, 2022, using the 6 points data set obtained during the previous 90-day interval.

- * The enterococci density in terms of geometric mean shall not exceed 35/100 mL in any 90-day interval.
 - ** The 90th Percentile of the enterococci density shall not exceed 130/100 mL in any 90-day interval.
- 6) Monitoring samples for these parameters shall be taken at the sampling point for discharge 001, the background monitoring station and at the sampling stations of the MZ. The discharge shall comply with the water quality standards limitations for all the other substances at sampling point for discharge 001.
 - 7) The monitoring samples at the six (6) stations in the boundaries of the MZ and the background monitoring station shall be taken at three (3) depths in each station: 10%, 50%, 90% of the depth.
 - 8) Solids from wastewater sources shall not cause deposition in, or be deleterious to the existing or designated uses of the receiving water body.
 - 9) The discharge shall not cause the growth or propagation of organisms that negatively disturb the ecological equilibrium in the areas adjacent to the mixing zone.
 - 10) The mixing zone shall be free of debris, scum, floating oil and any other substances that produce objectionable odors.
 - 11) The permittee shall maintain in good operating conditions the discharge system [discharge outfall (land and submarine), diffuser, ports, etc.]. The discharge system shall be inspected during the third year of the effectiveness of the NPDES permit. This inspection should be performed to determine if any repairs, replacements, etc. are necessary in the system. A report of such inspection shall be submitted to the DNER's Water Quality Area and the Multimedia Permits and Compliance Branch of the EPA's Region 2 Caribbean Environmental Protection Division no later than sixty (60) days after the performance of the inspection.
 - 12) The DNER can require that the permittee conduct bioaccumulation studies, dye studies, water quality studies or any other pertinent studies. If the DNER require one or more of the aforementioned studies, the permittee will be notified to conduct such study(ies). One hundred and twenty (120) days after the notification of the DNER, the permittee shall submit, for evaluation and approval of the DNER, a protocol to conduct such study(ies). Sixty (60) days after the DNER approval, the permittee shall initiate such study(ies). Ninety (90) days after conducting such study(ies), the permittee shall submit a report that includes the results of such study(ies).
 - 13) The permittee shall conduct a confirmatory sampling event at the MZ for the parameters included in Part "5" of this special condition except for Enterococci, to verify compliance with the applicable provisions of the PRWQSR. The confirmatory sampling event shall be conducted at the six (6) stations at the boundaries of the MZ, at the background sampling station and at the sampling point for discharge 001, during the third year of the effectiveness of the NPDES permit. For enterococci see item "15" of this special condition.
 - 14) A Protocol and Quality Assurance Project Plan (QAPP) for the sampling event described in Part "13" of this special condition, shall be submitted to the Water Quality Area of the DNER, no later than May 1, 2023.
 - 15) The permittee shall implement a monitoring program for Enterococci to verify compliance with the applicable provisions of the PRWQSR at the edge of the MZ. The monitoring program shall be conducted as follows:
 - a. Monitoring samples for this parameter shall be taken at the sampling point for discharge 001, the background monitoring station and at the sampling stations of the MZ.

- b. The monitoring samples at the six (6) stations in the boundaries of the MZ and the background monitoring station shall be taken at three (3) depths in each station: 10%, 50%, 90% of the depth.
 - c. The permittee shall conduct three (3) sampling events within a 90-day period, in two occasions during the effectiveness of the NPDES Permit. The compliance evaluation shall be based on the geometric mean and the 90th percentile values of the three (3) values obtained during each sampling event for each depth at each monitoring station.
- 16) A QAPP for the monitoring program described in item 15 of this special conditions shall be submitted no later than January 31, 2022. The monitoring program for Enterococci shall commence after the written approval of the corresponding QAPP.
- 17) The authorization for the mixing zone will not be transferable and does not convey any property rights of any sort or any exclusive privileges, nor does it authorize any injury to persons or property or invasion of other private rights, or any infringement of Federal or State laws or regulations.

DIAGRAM-I

Bacardí Mixing Zone



Geographic Coordinates*

Point 1	Lat. 18° 29' 04.50" Long. 66° 08' 21.12"
Point 2	Lat. 18° 29' 10.92" Long. 66° 08' 31.26"
Point 3	Lat. 18° 29' 12.48" Long. 66° 08' 30.12"

Point 4	Lat. 18° 29' 06.36" Long. 66° 08' 20.52"
Point 5	Lat. 18° 29' 06.18" Long. 66° 08' 09.00"
Point 6	Lat. 18° 29' 04.32" Long. 66° 08' 09.00"
BG1	Lat. 18° 29' 14.34" Long. 66° 08' 33.00"
BG2	Lat. 18° 29' 06.12" Long. 66° 08' 05.58"

*NAD 83 State Plane Coordinates

2. Whole Effluent Toxicity Testing

a. Acute and Chronic Whole Effluent Toxicity Testing

- 1) **Monitoring Frequency and Sample Type.** No later than May 1, 2022, the Permittee shall conduct annual definitive chronic toxicity tests on flow-weighted 24-hour composite effluent samples of the combined Bacardí Corporation, Puerto Nuevo RWWTP and Bayamón RWWTP discharges (referred herein as "combined discharge") for fertilization using the organism *Arbacia punctulata* and definitive acute and chronic toxicity tests using the organisms *Mysidopsis bahia* and *Cyprinodon variegatus*. An effluent limitation of a minimum NOEC %effluent of $\geq 0.81\%$ has been included for the combined discharge based on reasonable potential to cause or contribute to an exceedance of the chronic toxicity water quality criterion of 1.0 TUC at the edge of the mixing zone. Chronic toxicity tests will be conducted quarterly on the combined discharge to determine compliance with the effluent limitation and whether accelerated testing and toxicity reduction activities should be initiated.
- 2) By December 1, 2021, the permittee shall submit, for evaluation and approval by the DNER, a protocol to conduct such toxicity tests.

Such protocol shall include, but will not be limited to:

- i. An identification of the organizations responsible for conducting the tests, including a full description of the laboratory capabilities and personnel expertise and the species to be tested.
 - ii. A detailed description of the methodology to be utilized in the conduct of the tests, including equipment, sample collection, dilution water and source of test organisms.
 - iii. A schematic diagram which depicts the sampling point for the combined discharge in relation to the wastewater treatment system and discharge point 001 of each individual facility that compose the combined discharge.
- 3) The toxicity tests shall be conducted according to the most recent editions of the following publications of the EPA:
 - i. *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (EPA-821-R-02-012, Fifth Edition, 2002);
 - ii. *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, (EPA-821-R-02-014, Fourth Edition, 2002);
 - iii. Table IA of 40 CFR Part 136.

The tests must be static renewal tests. The effluent samples for the toxicity tests shall be used in or before 36 hours after being collected unless an alternate agreement is made, in writing, with EPA. The

acute toxicity tests must provide a measure of the acute toxicity as determined by the effluent concentration that represents the LC_{50} . Test results must be expressed in terms of the LC_{50} and reported in TU_a on the monthly DMR, where $TU_a = 100 / LC_{50}$.

If the acute WET test does not meet all test acceptability criteria as specified in the test method, the Permittee must re-sample and re-test as soon possible, not to exceed 14 days following notification of invalid test results. Data from invalid and valid tests must be submitted in the Permittee's DMR.

The chronic toxicity tests must provide a measure of the chronic toxicity as determined by the effluent concentration that represents the No Observable Effects Concentration (NOEC). Test results must be expressed in terms of the NOEC and reported in TU_c on the monthly DMR, where $TU_c = 100/NOEC$."

The procedures, methods, techniques, and conditions included in the above mentioned publications shall be followed at all times. Any exception to the practices outlined above would require written approval from the EPA and the DNER, and would only be considered in the case that the specific nature or conditions of this case prevent adherence to such publications.

- 4) **Test Species.** The test species for Acute testing shall be *Mysidopsis bahia* and *Cyprinodon variegatus*. The test should be static renewal type. For *Arbacia punctulata*, Bacardi must only do the Chronic Toxicity Tests since there is no acute test available for this species.
- 5) **Dilution Allowance.** For this discharge, DNER has authorized a mixing zone or dilution allowance for acute and chronic toxicity.

b. Toxicity Reduction Evaluation (TRE) Workplan. Within 90 days after the effective date of this permit, the Permittee must prepare and submit a TRE Workplan to EPA, which must include steps the Permittee intends to follow if toxicity is measured in the combined effluent at levels higher than the trigger point. The workplan must include, at a minimum:

- 1) A description of the investigation and evaluation techniques that would be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
- 2) A description of methods for maximizing in-house treatment system efficiency, good housekeeping practices, and a list of all chemicals used in operations at the facility.
- 3) Potential actions to be undertaken by the Permittee to investigate, identify, and correct the causes, and prevent the recurrence of toxicity.
- 4) Identification of responsible persons/parties for conducting the TRE.
- 5) Possible source reduction measures and pollution prevention measures opportunities to reduce toxicity.

c. Accelerated Toxicity Testing and TRE Initiation. If the discharge displays an acute or chronic toxicity result that exceeds the effluent limitation or trigger, the Permittee must conduct six additional toxicity tests of the combined discharge using the same species and test method as that of the observed toxicity, every two weeks, over a 12 week period.

- 1) Accelerated testing must begin within 14 days of the Permittee's receipt of the test result exceeding the effluent limit or trigger. If none of the six additional toxicity tests exceeds the effluent limit or trigger, then the Permittee may return to its regular testing frequency. All accelerated laboratory test results must be submitted to EPA and DENR within 30 days of receipt by the Permittee, as required in the Reporting of Toxicity Monitoring Results section below.
- 2) If the result of any accelerated toxicity test for the discharge exceeds the effluent limit or trigger, the Permittee is in violation of this permit and must cease accelerated monitoring and initiate a TRE within 14 days of receipt of this test result to investigate the cause(s) of and identify corrective actions to reduce or eliminate effluent toxicity. The TRE must use the same species and test method as that of the observed toxicity. The Permittee must use the following EPA guidance manual to conduct the TRE: *Generalized Methodology for Conducting Industrial Toxicity Reduction Evaluations* (EPA-600-2-88-070, 1989).
- 3) The Permittee may also use the following manuals for Toxicity Identification Evaluation (TIE) to identify and abate the causes of toxicity:
 - a) *Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I* (EPA-600-6-91-005F, 1992).

- b) *Methods for Aquatic Toxicity Identification Evaluations, Phase II Toxicity Identification Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA-600-R-92-080, 1993).
 - c) *Methods for Aquatic Toxicity Identification Evaluations, Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity* (EPA-600-R-92-081, 1993).
 - d) *Marine Toxicity Identification Evaluation (TIE): Phase I Guidance Document* (EPA-600-R-96-054, 1996).
- 4) The Permittee must submit accelerated test results within 30 days after the Permittee's receipt of the laboratory reports for accelerated monitoring. Test results that were conducted because of accelerated monitoring may be used to satisfy the normal **acute AND/OR chronic** Toxicity Testing requirements above, provided that all requirements (including species, test type, frequency, timing, and sample requirements) are met.

d. Reporting of Toxicity Monitoring Results.

- a) A report on the toxicity tests conducted shall be submitted to the DNER's Water quality Area during the sixty (60) days period after the tests were conducted. This report shall be prepared according to the aforementioned publications of EPA.
- b) For any WET testing event, the Permittee must report the WET results in TU_a or TU_c on the DMR for the month in which the toxicity test was conducted. In addition, a full laboratory report must be submitted to the addresses in Part III.A.3 of this permit as an attachment to the DMR, reported according to the test methods manual chapter on report preparation and test review, and must include, at a minimum, the following:
 - 1) The acute WET toxicity results expressed in LC₅₀ and TU_a. For tests where the IWC is 100 percent effluent that does not result in a toxic response, the result must be reported at <0.3 TU_a.
 - 2) The dates of sample collection and initiation of each toxicity test.
 - 3) The statistical methods used to calculate endpoints.
 - 4) The statistical output page, which includes the calculation of the percent minimum significant difference (PMSD).
 - 5) All results for effluent parameters monitored concurrently with the toxicity test(s).
 - 6) The results compared to the numeric toxicity effluent limitation or trigger.
 - 7) Progress reports on any TRE/TIE investigations.

Toxicity Reporting Table

Task	Due Date
Submit a TRE Workplan	January 31, 2022
Submit WET Report for quarterly monitoring	30 days following receipt of the quarter's last testing results
Submit WET Report for annual monitoring	30 days following receipt of the quarter's last testing results
Notify Toxicity in Effluent	<48 hours of receipt of test results that exceed limit or trigger
Conduct Accelerated Monitoring	≤ 14 days of exceedance of limit or trigger
Submit Accelerated Monitoring Report	≤ 30 days of receipt of test results
Initiate a TRE	≤ 14 days of accelerated test results that exceed limit or trigger

- e. **Reopener Clause for Toxicity.** In accordance with 40 CFR Parts 122 and 124, this permit may be reopened to establish additional toxicity requirements to address toxicity in the effluent or receiving water, including other toxicity/treatability studies, effluent limitations or monitoring requirements.

Based on the review of the test results, the DNER can require additional toxicity tests, including toxicity/treatability studies and can revoke the mixing zone authorization according with Rule 1305.14 of the PRWQSR.

3. Best Management Practices and Pollution Prevention

a. Preventive Maintenance Plan (PMP) and Pollution Prevention

- 1) The Permittee must during the term of this permit operate the facility in accordance with the PMP and in accordance with subsequent amendments to the plan. The Permittee must amend the plan to incorporate practices to achieve the objectives and specific requirements listed below, and a copy of the amended plan must be submitted to the addresses in Part III.A.3 of this permit by January 31, 2022. The amended plan must be implemented as soon as possible but not later than May 31, 2022.
- 2) **Purpose.** Through implementation of the PMP, the Permittee must prevent or minimize the generation and the potential for the release of pollutants from the facility to the waters of the United States through normal operations and ancillary activities.
- 3) **Objectives.** The Permittee must develop and amend the PMP consistent with the following objectives for the control of pollutants.
 - a) The number and quantity of pollutants and the toxicity of effluent generated, discharged, or potentially discharged at the facility must be minimized by the Permittee to the extent feasible by managing each influent waste stream in the most appropriate manner.
 - b) Under the PMP, and any Standard Operating Procedures (SOPs) included in the plan, the Permittee must ensure proper operation and maintenance of the treatment facility as required by 40 CFR 122.41(e).
 - c) The Permittee must establish specific objectives for the control of pollutants by conducting the following evaluations:
 - i. Each facility component or system must be examined for its waste minimization opportunities and its potential for causing a release of significant amounts of pollutants to waters of the United States because of equipment failure, improper operation, and natural phenomena such as rain or snowfall, etc. The examination must include all normal operations and ancillary activities including material storage areas, plant site runoff, in-plant transfer, process and material handling areas, loading or unloading operations, spillage or leaks, sludge and waste disposal, or drainage from raw material storage.
 - ii. Where experience indicates a reasonable potential for equipment failure (e.g., a tank overflow or leakage), natural condition (e.g., precipitation), or other circumstances that could result in significant amounts of pollutants reaching surface waters, the program should include a prediction of the direction, rate of flow, and total quantity of pollutants that could be discharged from the facility as a result of each condition or circumstance.
- 4) **Requirements.** The PMP must be consistent with the objectives in the Objectives section above and the general guidance contained in the publication titled *Guidance Manual for Developing Best Management Practices (BMPs)* (EPA 833-B-93-004, 1993) or any subsequent revisions to the guidance document.
 - a) The PMP must be documented in narrative form, include any necessary plot plans, drawings or maps, and be developed in accordance with good engineering practices. The PMP must be organized and written with the following structure:
 - i. Name and location of the facility.
 - ii. Statement of PMP policy.
 - iii. Structure, functions, and procedures of the PMP Committee.
 - iv. Specific management practices and standard operating procedures to achieve the above objectives, including modifying equipment, facilities, technology, processes, and procedures;

reformulating or redesigning products; substituting materials; and improving management, inventory control, materials handling or general operational phases of the facility.

- v. Risk identification and assessment.
 - vi. Reporting of PMP incidents.
 - vii. Materials compatibility.
 - viii. Good housekeeping.
 - ix. Preventative maintenance.
 - x. Inspections and records.
 - xi. Security.
 - xii. Employee training.
- b) The PMP must include the following provisions concerning PMP review:
- i. Review by plant engineering staff and the plant manager.
 - ii. Review and endorsement by the Permittee's PMP Committee.
 - iii. A statement that the above reviews have been completed and that the PMP fulfills the requirements set forth in this permit. The statement must include the dated signatures of each BMP Committee member as certification of the reviews.
- c) The PMP must establish specific BMPs to meet the objectives identified in the Objectives section above, addressing each component or system capable of generating or causing a release of significant amounts of pollutants, and identifying specific preventive or remedial measures to be implemented.
- d) The PMP must establish specific BMPs or other measures that ensure that the following specific requirements are met:
- i. Ensure proper management of solid and hazardous waste in accordance with regulations promulgated under the Resource Conservation and Recovery Act (RCRA). Management practices required under RCRA regulations must be referenced in the BMP plan.
 - ii. Reflect requirements for Spill Prevention, Control, and Countermeasure (SPCC) plans under CWA section 311 and 40 CFR Part 112 and may incorporate any part of such plans into the PMP by reference.
 - iii. Reflect requirements for stormwater control under CWA section 402(p) and the regulations at 40 CFR 122.26 and 122.44, and otherwise eliminate to the extent practicable, contamination of stormwater runoff.
- 5) **Documentation.** The Permittee must maintain a copy of the PMP at the facility and must make the plan available to EPA upon request.
- 6) **PMP Modification.** The Permittee must amend the PMP whenever there is a change in the facility or in the operation of the facility that materially increases the generation of pollutants or their release or potential release to the receiving waters. The Permittee must also amend the plan, as appropriate, when plant operations covered by the PMP change. Any such changes to the PMP must be consistent with the objectives and specific requirements listed above. All changes in the PMP must be reported to EPA in writing.
- 7) **Modification for Ineffectiveness.** If at any time the PMP proves to be ineffective in achieving the general objective of preventing and minimizing the generation of pollutants and their release and potential release to the receiving waters and/or the specific requirements above, the permit and/or the PMP must be subject to modification to incorporate revised BMP requirements.

b. Biosolids (Sewage Sludge) Requirements

1) General Biosolids Requirements

- a) All biosolids generated by the Permittee must be used or disposed of in compliance with the applicable portions of the following:
 - i. 40 CFR Part 503—for biosolids that are land applied, placed in a surface disposal site (dedicated land disposal site, monofill, or sludge-only parcel at a municipal landfill), or incinerated.
 - ii. 40 CFR Part 258—for biosolids disposed of in a municipal solid waste landfill (with other material).
 - iii. 40 CFR Part 257—for all biosolids use and disposal practices not covered under 40 CFR Parts 258 or 503.
- b) The regulation at 40 CFR Part 503, Subpart B (land application) sets requirements for biosolids that are applied for the purpose of enhancing plant growth or for land reclamation. The regulation at 40 CFR Part 503, Subpart C (surface disposal) sets requirements for biosolids that are placed on the land for the purpose of disposal, and 40 CFR Part 503, Subpart E, sets requirements for biosolids incinerated in a biosolids incinerator.
- c) The Permittee must be responsible for assuring that all biosolids produced at its facility are used or disposed of in accordance with these rules, whether the Permittee uses or disposes of the biosolids itself or transfers the biosolids to another party for further treatment, use, or disposal. The Permittee must be responsible for informing subsequent preparers, appliers, and disposers of the requirements that they must meet under these rules.
- d) The Permittee must assure that haulers transporting biosolids off site for treatment, storage, use, or disposal take all necessary measures to keep the biosolids contained. All haulers must have spill cleanup procedures. If a spill of biosolids on land or into a body of water occurs, the Permittee must notify the Point Sources Permits Division of the DNER Water Quality Area in the following manner:
 - i. By telephone communication within a term no longer than 24 hours after the spill; (787) 767-8073.
 - ii. By letter, within a term no longer than 5 days after the spill, which must include the spill material, spill volume, and measures taken to prevent the spill material to gain access to any body of water. This special condition does not relieve the Permittee from its responsibility to obtain the corresponding permits from DNER's Solid Wastes Program and other state and federal agencies, if any.

2) Biosolids Monitoring Requirements

- a) The 40 CFR Part 503 requirements apply differently depending on the use or disposal practice followed by the Permittee and depends on the quality of the biosolids produced by the facility.
- b) Biosolids must be monitored for pollutant concentrations, pathogen reduction and vector attraction (land application and surface disposal) at the following frequency. This frequency is based on the volume of biosolids generated at the facility in dry metric tons per year:
 - i. less than 290 1/year
 - ii. 290 to less than 1,500 1/quarter (4/year)
 - iii. 1,500 to less than 15,000 1/60 days (6/year)
 - iv. equal to or greater than 15,000 1/month (12/year)

3) Biosolids Reporting Requirements

- a) **Annual Biosolids Report.** By February 19 of each year, the Permittee must submit an annual report covering information and data collected during the previous calendar year to EPA and DNER at the address in Part (d) of this section below. This report must contain the following:
 - i. Amount of sludge generated, in dry metric tons.

- ii. Use or disposal practices.
 - iii. Amount of sludge that goes to each use or disposal practice (amount of sludge that goes to each use or disposal site, in dry metric tons).
 - iv. Name and address of the preparer or the person who receives sludge next (name and address of each preparer or person who receives sludge next), if applicable.
 - v. Name and address of the land applier and owner/operator of the surface disposal site, if different from the generator.
 - vi. Analytical results from monitoring pollutant concentrations in sewage sludge which should include results of all analyses performed during the reporting period using the prescribed method(s) in milligrams per kilograms (mg/kg) dry weight. Reports should also indicate which analytical methods were used, how frequently sludge was monitored, and the types of samples collected. Preparers may have to report additional information regarding pollutants if they beneficially use or dispose of the sludge themselves.
 - vii. A certification and description of how the pathogen reduction requirements were met, including a detailed description of the pathogen treatment process that specifies the type of process used, standard operating procedures, and a schematic diagram. All pathogen density laboratory results (such as fecal coliform or salmonella), if monitored for must comply with pathogen reduction requirements.
 - viii. A description of how one of the vector attraction reduction requirements was met if one of the sludge processing options was used (Options 1-8, 40 CFR 503.33(b)(1) - (b)(8)) and a certification that the vector attraction reduction requirements were met.
 - ix. A listing of all relevant environmental (federal, state, or local) permits or construction approvals applied for or received.
- b) **Certification Statement.** The incinerator owner/operator of the sewage sludge incinerator should submit the signed certification statement (described in section H, page 17 of the *THC Continuous Emission Monitoring Guidance for Part 503 Sewage Sludge Incinerators*) as part of the Annual Biosolids Report. Specifically, the owner/operator in conjunction with the CEM manufacturer, if appropriate, should certify that the THC/CO CEM system is installed, operated, and maintained pursuant to the manufacturer's written instructions and recommendations, meets performance specification criteria, and is suitable for compliance evaluation purposes. The report must include the information in 40 CFR 503.47(b) through 40 CFR 503.47(h). The incinerator owner/operator of the sewage sludge incinerator should submit the 40 CFR Part 503 site-specific metals limits that are required to be determined as per 40 CFR 503.43.
- c) **MSW Landfill Disposal.** Preparers who send their sludge to a Municipal Solid Waste (MSW) landfill are required to submit the information indicated in 1) through 3) above, the name and address of each MSW landfill, in addition to submitting documentation that sludge quality is in compliance with 40 CFR Part 258 requirements (sludge is non-hazardous and passes the paint filter test).
- d) **Biosolids Reporting.** All reports must be submitted to:
- i. U.S. Environmental Protection Agency, Region 7
WWPD/WENF
11201 Renner Boulevard
Lenexa, Kansas 66219
Attention: Biosolids Center
 - ii. Puerto Rico Department of Natural and Environmental Resources
P.O. Box 11488
Santurce, PR 00910
Attention: Water Quality Area
- e) **Biosolids Reporting Schedule.** All reports must be submitted according to the following table:

Biosolids Reporting Table

Task	Due date
If a spill of biosolids on land or into a body of water occurs	Telephone <24 hours after the spill and Letter <5 days after the spill
Annual Biosolids Report	February 19th of each year

ATTACHMENT A: DEFINITIONS

Acute Toxicity Test means any toxicity test designed to determine the concentration in which a response to a stimulus, such as a total effluent, specific substance or combinations of these, has sufficient severity to induce an adverse effect on a group of test organisms during a period of 96 hours or less; even if said effect is not necessarily the death of the organisms.

Acute Toxicity Unit (TU_a) means the reciprocal of the effluent concentration that causes 50 percent of the organisms to die in an acute toxicity test or induce a response halfway between the base line and maximum as defined by the following equation:

$$TU_a = 100 / (LC_{50})$$

(The LC₅₀ should be expressed in terms of the percent of effluent in the dilution water.)

Average Monthly Discharge Limitation (AML) means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. [40 CFR 122.2]

Average Weekly Discharge Limitation (AWL) means the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. [40 CFR 122.2]

Best Management Practices (BMP) means the most effective practicable means of preventing or reducing the amount of pollution generated by nonpoint and point sources to a level more compatible to the water quality goals, including, but not limited to, structural and non-structural controls and operating and maintenance procedures. [40 CFR 122.2]

Biosolids means non-hazardous sewage sludge, as defined in 40 CFR Part 503.9. Sewage sludge that is hazardous, as defined in 40 CFR Part 261, must be disposed of in accordance with Resource Conservation and Recovery Act.

Bypass means the intentional diversion of waste streams from any portion of a treatment facility as discussed in 13. Bypass of Attachment B of this permit. [40 CFR 122.41(m)]

Composite means a combination of individual (or continuously taken) samples obtained at regular intervals over the entire discharge day. The volume of each sample must be proportional to the discharge flow rate. For a continuous discharge, a minimum of 24 individual grab samples (at hourly intervals) must be collected and combined to constitute a 24-hour composite sample. For intermittent discharges of more than 4 hours duration, grab samples must be taken at a minimum of 30-minute intervals.

Chronic Toxicity Test means any toxicity test designed to determine the concentration in which a response to a stimulus, such as a total effluent, a specific substance, or combination of these, has sufficient severity to induce a long-term adverse effect on a group of test organisms. A chronic effect could be lethality, reduction of growth rate, reduction of reproduction rate, etc.

Chronic Toxicity Unit (TU_c) means the reciprocal of the effluent concentration that causes no observable effect on the test organisms by the end of the chronic exposure period obtained during a chronic toxicity test as defined by the following equation:

$$TU_c = 100 / NOEC$$

(The NOEC value should be expressed in terms of the percent of effluent in the dilution water.)

Critical Initial Dilution means the minimum dilution to be determined by means of the use of a mathematical model to be approved by EQB, and according to the procedures described in the *Mixing Zone and Bioassay Guidelines*, approved by EQB.

Daily Discharge is defined as either (1) the total mass of the constituent discharged over the calendar day (12:00 a.m. through 11:59 p.m.) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass; or (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day. For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends. [40 CFR 122.2]

Director means the *Regional Administrator* or the *State Director*, as the context requires, or an authorized representative. Until Puerto Rico has an approved state program authorized by EPA under 40 CFR Part 123, *Director* means the Regional Administrator. Following authorization, *Director* means the State Director. Even in such circumstances, EPA may retain authority to take certain action (see, for example, 40 CFR 123.1(d), 45 *Federal Register* 14178, April 1, 1983, on the retention of jurisdiction over permits EPA issued before program approval). If any condition of this permit requires the reporting of information or other actions to both the Regional Administrator and the State Director, regardless of who has permit issuing authority, the terms *Regional Administrator* and *State Director* will be used in place of *Director*. [40 CFR 122.2]

Discharge Monitoring Report (DMR) means EPA uniform national form, including any subsequent additions, revisions, or modifications, for the reporting of self-monitoring results by the Permittee. [40 CFR 122.2]

Geometric Mean means the n th root of the product of n numbers.

Grab means an individual sample collected in less than 15 minutes.

ICIS means EPA's Integrated Compliance Information System that provides web access to enforcement and compliance assurance data to EPA and state agencies.

Inhibition Concentration 25 (IC₂₅) means a point estimate of the effluent concentration that would cause a 25-percent reduction in a non-lethal (e.g., reproduction, growth) or lethal (mortality) biological measurement.

Lethal Concentration (LC₅₀) means the concentration of effluent, specific substances or combination of these that is lethal to 50 percent of test organisms exposed during a specific period in a toxicity test.

Lowest Observable Effects Concentration (LOEC) means the lowest concentration of an effluent or toxicant that results in adverse effects on the test organisms. That is, where the values for the observed endpoints are statistically different from the control.

Maximum Daily Discharge Limitation (MDL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, the median = $X_{(n+1)/2}$. If n is even, the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method-specified sample weights, volumes, and processing steps have been followed.

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects on the overall water body.

Monthly means one day each month (the same day each month) and a normal operating day (e.g., the 2nd Tuesday of each month).

No Observed Effect Concentration (NOEC) means the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation.

Not Detected (ND) are those sample results less than the ML.

Regional Administrator means the Regional Administrator of EPA Region 2 or the authorized representative of the Regional Administrator.

Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

Toxic pollutant means any of the pollutants listed in 40 CFR 401.15 (45 *Federal Register* 44503, July 30, 1979) and any modification to that list in accordance with CWA section 307(a)(1). [40 CFR 122.2]

Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of collecting data relevant to the toxicity, including additional toxicity testing, and evaluating facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

Total Maximum Daily Loads (TMDLs) are calculations of the maximum amount of a pollutant that a water body can receive and still safely meet water quality standards. TMDLs are the sum of the individual wasteload allocations for point sources and load allocations for nonpoint sources and natural background. [40 CFR 130.2(i)]

Upset is an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation as discussed in 14. Upset of Attachment B of this permit. [40 CFR 122.41(n)]

Waters of Puerto Rico means all coastal waters, surface waters, estuarine waters, ground waters and wetland as defined in Puerto Rico Water Quality Standards Regulations, as amended.

Weekly means every seventh day (the same day of each week) and a normal operating day

ATTACHMENT B: STANDARD CONDITIONS

General Conditions language in this attachment for sections 1 through 14, and 17 is based on the *Code of Federal Regulations* (CFR) published on July 1, 2013. Reference to provisions in the *United States Code* (U.S.C.) is based on the date of permit issuance.

Table of Regulatory References for General Conditions

<u>Section</u>	<u>Section Title</u>	<u>Reference</u>
1.	Duty to comply	40 CFR 122.41(a)
2.	Duty to reapply	40 CFR 122.41(b)
3.	Need to halt or reduce not a defense	40 CFR 122.41(c)
4.	Duty to mitigate	40 CFR 122.41(d)
5.	Proper operation and maintenance	40 CFR 122.41(e)
6.	Permit actions	40 CFR 122.41(f)
7.	Property rights	40 CFR 122.41(g)
8.	Duty to provide information	40 CFR 122.41(h)
9.	Inspection and entry	40 CFR 122.41(i)
10.	Monitoring and records	40 CFR 122.41(j)
11.	Signatory requirements	40 CFR 122.41(k)
12.	Reporting requirements	40 CFR 122.41(l)
13.	Bypass	40 CFR 122.41(m)
14.	Upset	40 CFR 122.41(n)
15.	Removed substances	33 U.S.C. 1311
16.	Oil and hazardous substance liability	33 U.S.C. 1321
17.	Reopener clause for toxic effluent limitations	40 CFR 122.44(b)(1)
18.	State laws	33 U.S.C. 1370
19.	Availability of information	33 U.S.C. 1318
20.	Severability	-

1. Duty to Comply [40 CFR 122.41(a)].

- a. The Permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.
- b. The Permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the Clean Water Act within the time provided in the regulations that establish these standards or prohibitions or standards for sewage sludge use or disposal, even if the permit has not yet been modified to incorporate the requirement.
- c. The Clean Water Act provides that any person who violates sections 301, 302, 306, 307, 308, 318 or 405 of the Clean Water Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402, or any requirement imposed in a pretreatment program approved under sections 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to a civil penalty not to exceed \$25,000 per day for each violation (\$37,500 as adjusted by 40 CFR Part 19).
- d. The Clean Water Act provides that any person who negligently violates sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act, or any permit condition or limitation implementing any such sections in a permit issued under section 402 of the Clean Water Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to criminal penalties of not less than \$2,500 nor more than \$25,000 per day of violation, or imprisonment of not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation

of the Clean Water Act, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.

- e. The Clean Water Act provides that any person who knowingly violates sections 301, 302, 306, 307, 308, 318, or 405 of the Clean Water Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Clean Water Act, or any requirement imposed in a pretreatment program approved under section 402(a)(3) or 402(b)(8) of the Clean Water Act, is subject to criminal penalties of not less than \$5,000 nor more than \$50,000 per day of violation, or imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation of the Clean Water Act, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.
 - f. Any person who knowingly violates sections 301, 302, 303, 306, 307, 308, 318 or 405 of the Clean Water Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of the Clean Water Act, and who knows at that time that he thereby places another person in imminent danger of death or serious bodily injury, shall, upon conviction, be subject to a fine of not more than \$250,000 or imprisonment of not more than 15 years, or both. A person which is an organization, as defined at 33 U.S.C. 309(c)(3)(B)(iii), shall, upon conviction be subject to a fine of not more than \$1,000,000. In the case of a second or subsequent conviction for a knowing endangerment violation of the Clean Water Act, the maximum punishment shall be doubled with respect to both fine and imprisonment.
 - g. Any person who knowingly makes any false material statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under the Clean Water Act or who knowingly falsifies, tampers with, or renders inaccurate any monitoring device or method required to be maintained under this chapter, shall upon conviction, be punished by a fine of not more than \$10,000, or imprisonment for not more than 2 years, or both. In the case of a second or subsequent conviction, under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or both.
 - h. Any person may be assessed an administrative penalty by the Administrator for violating sections 301, 302, 306, 307, 308, 318 or 405 of this Act, or any permit condition or limitation implementing any of such sections in a permit issued under section 402 of this Act. Administrative penalties for Class I violations are not to exceed \$10,000 per violation (\$16,000 as adjusted by 40 CFR Part 19), with the maximum amount of any Class I penalty assessed not to exceed \$25,000 (\$37,500 as adjusted by 40 CFR Part 19). Penalties for Class II violations are not to exceed \$10,000 per day for each day during which the violation continues (\$16,000 as adjusted by 40 CFR Part 19), with the maximum amount of any Class II penalty not to exceed \$125,000 (\$177,500 as adjusted by 40 CFR Part 19).
2. Duty to Reapply [40 CFR 122.41(b)]. This permit and the authorization to discharge shall terminate on the expiration date indicated on the first page. In order to receive authorization to discharge after the expiration date of this permit, the Permittee shall apply for and obtain a new permit. If the permit issuing authority remains the EPA, the Permittee shall complete, sign, and submit an application to the Director no later than 180 days before the expiration date. All applications must be submitted to:

Javier Laureano, Director
Water Division
U.S. Environmental Protection Agency, Region 2
290 Broadway, 24th Floor
New York, NY 10007-1866
Attention: Clean Water Regulatory Branch
 3. Need to Halt or Reduce not a Defense [40 CFR 122.41(c)]. It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
 4. Duty to Mitigate [40 CFR 122.41(d)]. The Permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.
 5. Proper operation and maintenance [40 CFR 122.41(e)]. The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Permittee to achieve compliance with the conditions of this permit. Proper operation and

maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back up or auxiliary facilities or similar systems which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

6. Permit actions [40 CFR 122.41(f)]. This permit may be modified, revoked and reissued, or terminated during its term pursuant to 40 CFR Part 122, Subpart D. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.
7. Property rights [40 CFR 122.41(g)]. This permit does not convey any property rights of any sort, or any exclusive privileges.
8. Duty to provide information [40 CFR 122.41(h)]. The Permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The Permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.
9. Inspection and Entry [40 CFR 122.41(i)]. The Permittee shall allow the Director, or an authorized representative (including an authorized contractor acting as a representative of the Administrator), upon presentation of credentials and other documents as may be required by law, to:
 - a. Enter upon the Permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
 - c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
 - d. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.
10. Monitoring and records [40 CFR 122.41(j)].
 - a. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
 - b. Except for records of monitoring information required by this permit related to the Permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 CFR Part 503), the Permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement report or application. This period may be extended by request of the Director at any time.
 - c. Records of monitoring information shall include:
 - 1) The date, exact place, and time of sampling or measurements;
 - 2) The individual(s) who performed the sampling or measurements;
 - 3) The date(s) analyses were performed;
 - 4) The individual(s) who performed the analyses;
 - 5) The analytical techniques or methods used; and
 - 6) The results of such analyses.
 - d. Monitoring must be conducted according to test procedures approved under 40 CFR Part 136 and any subsequent changes to the methods contained therein unless another method is required under 40 CFR subchapters N or O.
 - e. The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or by both. If a conviction of a person is for a violation committed after a first conviction of such person

under this paragraph, punishment is a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. [See U.S.C. 1319(c)(4)].

11. Signatory requirements [40 CFR 122.41(k)]. All applications, reports, or information submitted to the Director shall be signed and certified. (See 40 CFR 122.22)

a. Applications. All permit applications shall be signed as follows:

- 1) For a corporation. By a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.

Note: EPA does not require specific assignments or delegations of authority to responsible corporate officers identified in 40 CFR 122.22(a)(1)(i). EPA will presume that these responsible corporate officers have the requisite authority to sign permit applications unless the corporation has notified the Director to the contrary. Corporate procedures governing authority to sign permit applications may provide for assignment or delegation to applicable corporate positions under 40 CFR 122.22(a)(1)(ii) rather than to specific individuals.

- 2) For a partnership or sole proprietorship. By a general partner or the proprietor, respectively; or
- 3) For a municipality, state, federal, or other public agency. By either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a federal agency includes: a) The chief executive officer of the agency, or b) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of EPA).

b. All reports required by permits, and other information requested by the Director shall be signed by a person described in paragraph 11.a of Part II.B, or by a duly authorized representative of that person. A person is a duly authorized representative only if:

- 1) The authorization is made in writing by a person described in paragraph 11.a;
- 2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company, (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) and,
- 3) The written authorization is submitted to the Regional Administrator, U.S. Environmental Protection Agency, Region 2, 290 Broadway, New York, NY 10007-1866, Attention: Compliance Assistance Program Support Branch, and to EQB.

c. Changes to authorization. If an authorization under paragraph 11.b of Part II.B is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph 11.b of Part II.B must be submitted to the Director prior to or together with any reports, information, or applications to be signed by an authorized representative.

d. Certification. Any person signing a document under paragraph 11.a or 11.b of Part II.B shall make the following certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is,

to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

- e. The Clean Water Act provides that any person who knowingly makes any false material statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than 6 months per violation, or by imprisonment for not more than 6 months per violation, or by both. If a conviction is for a violation committed after a first conviction of such person under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four years, or both. (See CWA section 309.c.4).

12. Reporting Requirements [40 CFR 122.41(l)].

- a. **Planned changes.** The Permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
 - 1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b);
 - 2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under paragraph 4.a of Part I.B (40 CFR 122.42(a)(1)); or
 - 3) The alteration or addition results in a significant change in the Permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.
- b. **Anticipated noncompliance.** The Permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- c. **Transfers.** This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the Permittee and incorporate such other requirements as may be necessary under the Clean Water Act. (See 40 CFR 122.61; in some cases, modification or revocation and reissuance is mandatory.)
- d. **Monitoring reports.** Monitoring results shall be reported at the intervals specified in Part III of this permit.
 - 1) Monitoring results shall be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices.
 - 2) If the Permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR Part 136, or another method required for an industry-specific waste stream under 40 CFR subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.
 - 3) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.
- e. **Compliance Schedules.** Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- f. **Twenty four hour reporting.**
 - 1) The Permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Permittee becomes aware of the circumstances to EPA Region 2, Caribbean Environmental Protection Division at (787) 977-5870 and State Director. A written submission shall also be provided within 5 days of the time the Permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if

the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

- 2) The following shall be included as information which must be reported within 24 hours under this paragraph.
 - a) Any unanticipated bypass (see 13 below) which exceeds any effluent limitation in the permit. [See 40 CFR 122.41(g)].
 - b) Any upset (see 14 below) which exceeds any effluent limitation in the permit.
 - c) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in the permit to be reported within 24 hours. (See 40 CFR 122.44(g)).
- 3) The Director may waive the written report on a case by case basis for reports under paragraph 12.f.(2) of Part II.B if the oral report has been received within 24 hours.
- g. Other noncompliance. The Permittee shall report all instances of noncompliance not reported under paragraphs 12.d, e, and f of Part II.B, at the time the monitoring reports are submitted. The reports shall contain the information listed in paragraph 12.f of Part II.B.
- h. Other information. Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

13. Bypass [40 CFR 122.41(m)].

- a. Bypass not exceeding limitations. The Permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 13.b. and 13.c of Part II.B.
- b. Notice.
 - 1) Anticipated bypass. If the Permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.
 - 2) Unanticipated bypass. The Permittee shall submit notice of an unanticipated bypass as required in paragraph 12.f of Part II.B (24-hour notice).
- c. Prohibition of bypass.
 - 1) Bypass is prohibited, and the Director may take enforcement action against a Permittee for bypass, unless:
 - a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - c) The Permittee submitted notices as required under paragraph 13.b of Part II.B.
 - 2) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 13.b.(1) of Part II.B.

14. Upset [40 CFR 122.41(n)].

- a. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of paragraph 14.(b) of Part II.B are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- b. Conditions necessary for a demonstration of upset. A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - 1) An upset occurred and that the Permittee can identify the cause(s) of the upset;

- 2) The permitted facility was at the time being properly operated;
 - 3) The Permittee submitted notice of the upset as required in paragraph 12.f.(2)(b) of Part II.B (24 hour notice); and
 - 4) The Permittee complied with any remedial measures required under paragraph 4 of Part II.B (duty to mitigate).
- c. Burden of proof. In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.
15. Removed substances (33 U.S.C. 1311). Pursuant to section 301 of the Clean Water Act, solids, sludges, filter backwash or other pollutants removed in the course of treatment or control of wastewaters and/or the treatment of intake waters shall be disposed of in a manner such as to prevent any pollutant from such materials from entering navigable waters. The following data shall be reported together with the monitoring data required in paragraph 2 of Part III.B:
- a. The sources of the materials to be disposed of;
 - b. The approximate volumes and weights;
 - c. The method by which they were removed and transported; and
 - d. Their final disposal locations.
16. Oil and hazardous substance liability (33 U.S.C. 1321). The imposition of responsibilities upon, or the institution of any legal action against the Permittee under CWA section 311 shall be in conformance with regulations promulgated pursuant to Section 311 to discharges from facilities with NPDES permits.
17. Reopener clause for toxic effluent limitations [40 CFR 122.44(B)(1)]. Other effluent limitations and standards under CWA sections 301, 302, 303, 307, 318 and 405. If any applicable toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under CWA section 307(a) for a toxic pollutant and that standard or prohibition is more stringent than any limitation on the pollutant in the permit, the Director shall institute proceedings under these regulations to modify or revoke and reissue the permit to conform to the toxic effluent standard or prohibition. See also 40 CFR 122.41(a).
18. State laws (33 U.S.C. 1370). Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the Permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by CWA section 510. The issuance of this permit does not preempt any duty to obtain state or local assent required by law for the discharge.
19. Availability of information (33 U.S.C. 1318). (CWA section 308)
- a. NPDES permits, effluent data, and information required by NPDES application forms provided by the Director under 40 CFR 122.21 (including information submitted on the forms themselves and any attachments used to supply information required by the forms) shall be available for public inspection at the offices of the Regional Administrator and State Director.
 - b. In addition to the information set forth in subsection a., any other information submitted to EPA in accordance with the conditions of this permit shall be made available to the public without further notice unless a claim of business confidentiality is asserted at the time of submission in accordance with the procedures in 40 CFR Part 2 (Public Information).
 - c. If a claim of confidentiality is made for information other than that enumerated in subsection a., that information shall be treated in accordance with the procedures in 40 CFR Part 2. Only information determined to be confidential under those procedures shall not be made available by EPA for public inspection.
20. Severability. The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.