

NPDES authorization to discharge to waters of the United States, Permit No. LA0050971

The applicant's mailing address is:

Ms. April Wyatt
Chief Administrative Officer
P.O. Box 661
Charenton, LA 70523

Is authorized to discharge from facility located at 832 Martin Luther King Road, Charenton, St. Mary Parish, Louisiana. The discharge is to an unnamed ditch, thence Bayou Teche in Louisiana subsegment No. 060401 of the Vermilion-Teche River Basin. The known uses of the receiving water(s) are primary contact recreation, secondary contact recreation, fish and wildlife propagation.

Under The Standard Industrial Classification Code 4952, the applicant will operate a POTW with a design flow capacity of 0.22 MGD serving a population of approximately 650.

This is a renewal of a permit issued February 21, 2017, with an effective date of March 1, 2017 and an expiration date of February 28, 2022.

Changes from the previous permit are:

- a. Total Chlorine Residue limit has been changed from 19 μ g/L is changed to a limit of 11 μ g/L for chronic protection with a 100% effluent.
- b. EPA reassessed monitoring frequencies and determined that reducing temperature monitoring frequency to two (2) times per month would be sufficient to track compliance with permit limits and provide data for use in future permitting actions.

A fact sheet is available.

If you want to comment submit written comments within the 30 day public comment period to:

Evelyn Rosborough (6WQ-NP)
U.S. Environmental Protection Agency
Region 6
1201 Elm Street, Suite 500
Dallas, Texas 75270
Phone (214) 665-7515
rosborough.evelyn@epa.gov