

Sample Location	Date Sampled	Analysis Description	Analyte	Results (ppb)	MRL (ppb)	MCL (ppb)
CURTIS CONVENTIONAL	9/21/22 12:28	Haloacetic Acid	Dichloroacetic Acid (DCAA)	26.8	1.00	*
CURTIS CONVENTIONAL	9/21/22 12:28	Haloacetic Acid	Monochloroacetic Acid (MCAA)	2.09	1.00	*
CURTIS CONVENTIONAL	9/21/22 12:28	Haloacetic Acid	HAA5	58.8	1.00	60.00
CURTIS CONVENTIONAL	9/21/22 12:28	Haloacetic Acid	Trichloroacetic Acid (TCAA)	29.6	1.00	*
CURTIS CONVENTIONAL	9/21/22 12:28	Trihalomethanes	Bromodichloromethane	2.62	1.00	*
CURTIS CONVENTIONAL	9/21/22 12:28	Trihalomethanes	Chloroform	68.6	1.00	*
CURTIS CONVENTIONAL	9/21/22 12:28	Trihalomethanes	TTHM	71.2	1.00	80.00
CURTIS MEMBRANE	9/21/22 16:15	Haloacetic Acid	Dichloroacetic Acid (DCAA)	22	1.00	*
CURTIS MEMBRANE	9/21/22 16:15	Haloacetic Acid	Monochloroacetic Acid (MCAA)	1.47	1.00	*
CURTIS MEMBRANE	9/21/22 16:15	Haloacetic Acid	HAA5	36.2	1.00	60.00
CURTIS MEMBRANE	9/21/22 16:15	Haloacetic Acid	Trichloroacetic Acid (TCAA)	12.7	1.00	*
CURTIS MEMBRANE	9/21/22 16:15	Trihalomethanes	Chloroform	33.1	1.00	*
CURTIS MEMBRANE	9/21/22 16:15	Trihalomethanes	TTHM	33.1	1.00	80.00
FEWELL	9/21/22 15:00	Haloacetic Acid	Dichloroacetic Acid (DCAA)	22.4	1.00	*
FEWELL	9/21/22 15:00	Haloacetic Acid	Monobromoacetic Acid (MBAA)	2.11	1.00	*
FEWELL	9/21/22 15:00	Haloacetic Acid	HAA5	44.6	1.00	60.00
FEWELL	9/21/22 15:00	Haloacetic Acid	Trichloroacetic Acid (TCAA)	19.4	1.00	*
FEWELL	9/21/22 15:00	Trihalomethanes	Bromodichloromethane	3.03	1.00	*
FEWELL	9/21/22 15:00	Trihalomethanes	Chloroform	35.1	1.00	*
FEWELL	9/21/22 15:00	Trihalomethanes	TTHM	38.1	1.00	80.00
SM07	9/21/22 14:00	Haloacetic Acid	Dichloroacetic Acid (DCAA)	18.6	1.00	*
SM07	9/21/22 14:00	Haloacetic Acid	Monochloroacetic Acid (MCAA)	2.4	1.00	*
SM07	9/21/22 14:00	Haloacetic Acid	HAA5	35.4	1.00	60.00
SM07	9/21/22 14:00	Haloacetic Acid	Trichloroacetic Acid (TCAA)	14.3	1.00	*
SM07	9/21/22 14:00	Trihalomethanes	Bromodichloromethane	3.06	1.00	*
SM07	9/21/22 14:00	Trihalomethanes	Chloroform	35.2	1.00	*
SM07	9/21/22 14:00	Trihalomethanes	TTHM	38.3	1.00	80.00
SM09	9/21/22 12:00	Haloacetic Acid	Dichloroacetic Acid (DCAA)	3.28	1.00	*
SM09	9/21/22 12:00	Haloacetic Acid	HAA5	14.8	1.00	60.00
SM09	9/21/22 12:00	Haloacetic Acid	Trichloroacetic Acid (TCAA)	10.7	1.00	*
SM09	9/21/22 12:00	Trihalomethanes	Chloroform	34.9	1.00	*
SM09	9/21/22 12:00	Trihalomethanes	TTHM	34.9	1.00	80.00

SM11	9/21/22 14:30	Haloacetic Acid	Dichloroacetic Acid (DCAA)	22.5	1.00	*
SM11	9/21/22 14:30	Haloacetic Acid	Monochloroacetic Acid (MCAA)	2.84	1.00	*
SM11	9/21/22 14:30	Haloacetic Acid	HAA5	36.2	1.00	60.00
SM11	9/21/22 14:30	Haloacetic Acid	Trichloroacetic Acid (TCAA)	9.8	1.00	*
SM11	9/21/22 14:30	Trihalomethanes	Chloroform	33.9	1.00	*
SM11	9/21/22 14:30	Trihalomethanes	TTHM	33.9	1.00	80.00
SM13	9/21/22 15:40	Haloacetic Acid	Dichloroacetic Acid (DCAA)	18.6	1.00	*
SM13	9/21/22 15:40	Haloacetic Acid	Monochloroacetic Acid (MCAA)	1.85	1.00	*
SM13	9/21/22 15:40	Haloacetic Acid	HAA5	35.8	1.00	60.00
SM13	9/21/22 15:40	Haloacetic Acid	Trichloroacetic Acid (TCAA)	15.3	1.00	*
SM13	9/21/22 15:40	Trihalomethanes	Bromodichloromethane	1.54	1.00	*
SM13	9/21/22 15:40	Trihalomethanes	Chloroform	42.8	1.00	*
SM13	9/21/22 15:40	Trihalomethanes	TTHM	44.3	1.00	80.00
SM14	9/21/22 13:45	Haloacetic Acid	Dichloroacetic Acid (DCAA)	22.7	1.00	*
SM14	9/21/22 13:45	Haloacetic Acid	Monobromoacetic Acid (MBAA)	1.23	1.00	*
SM14	9/21/22 13:45	Haloacetic Acid	Monochloroacetic Acid (MCAA)	2.64	1.00	*
SM14	9/21/22 13:45	Haloacetic Acid	HAA5	44.3	1.00	60.00
SM14	9/21/22 13:45	Haloacetic Acid	Trichloroacetic Acid (TCAA)	17.4	1.00	*
SM14	9/21/22 13:45	Trihalomethanes	Bromodichloromethane	3.42	1.00	*
SM14	9/21/22 13:45	Trihalomethanes	Chloroform	39.7	1.00	*
SM14	9/21/22 13:45	Trihalomethanes	TTHM	43.1	1.00	80.00
SM15	9/21/22 13:30	Haloacetic Acid	Dichloroacetic Acid (DCAA)	2.88	1.00	*
SM15	9/21/22 13:30	Haloacetic Acid	HAA5	14.4	1.00	60.00
SM15	9/21/22 13:30	Haloacetic Acid	Trichloroacetic Acid (TCAA)	11.5	1.00	*
SM15	9/21/22 13:30	Trihalomethanes	Bromodichloromethane	1.07	1.00	*
SM15	9/21/22 13:30	Trihalomethanes	Chloroform	37.9	1.00	*
SM15	9/21/22 13:30	Trihalomethanes	TTHM	39	1.00	80.00
SM18	9/21/22 12:28	Haloacetic Acid	Dichloroacetic Acid (DCAA)	19.6	1.00	*
SM18	9/21/22 12:28	Haloacetic Acid	Monochloroacetic Acid (MCAA)	2.35	1.00	*
SM18	9/21/22 12:28	Haloacetic Acid	HAA5	33.2	1.00	60.00
SM18	9/21/22 12:28	Haloacetic Acid	Trichloroacetic Acid (TCAA)	11.3	1.00	*
SM18	9/21/22 12:28	Trihalomethanes	Bromodichloromethane	1.06	1.00	*
SM18	9/21/22 12:28	Trihalomethanes	Chloroform	38.4	1.00	*
SM18	9/21/22 12:28	Trihalomethanes	TTHM	39.5	1.00	80.00

SM20	9/21/22 15:24	Haloacetic Acid	Dichloroacetic Acid (DCAA)	21.3	1.00	*
SM20	9/21/22 15:24	Haloacetic Acid	Monochloroacetic Acid (MCAA)	2.55	1.00	*
SM20	9/21/22 15:24	Haloacetic Acid	HAA5	40.4	1.00	60.00
SM20	9/21/22 15:24	Haloacetic Acid	Trichloroacetic Acid (TCAA)	16.5	1.00	*
SM20	9/21/22 15:24	Trihalomethanes	Bromodichloromethane	1.33	1.00	*
SM20	9/21/22 15:24	Trihalomethanes	Chloroform	42.3	1.00	*
SM20	9/21/22 15:24	Trihalomethanes	TTHM	43.6	1.00	80.00

* MCL is based on summation of 5 haloacetic acids (HAA5) and total trihalomethanes (TTHM).

Notes:

The data presented is for investigative purposes. This data is not used for regulatory compliance.

Disinfection By-Product (DBP) samples were collected at the city's designated sampling points within the distribution system.

National Primary Drinking Water Contaminant results from distribution system entry points are presented in a separate table.

MRL - Minimum Reporting Limit - The lowest demonstrated level of acceptable quantitation.

MCL - Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water.