

Sample Station	Date Sampled	Analysis Description	Analyte	Result (ug/L)	MRL (ug/L)	MCL (ug/L)	Notes
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Arsenic	0.58	0.5	10	
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Barium	28	0.5	2000	
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Calcium	8100	250		Unregulated
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Copper	22	0.5		Action Level 1300 ug/L
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Iron	140	100		Fe is a SMCL
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Lead	0.78	0.5		Action Level 15 ug/L
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Magnesium	900	250		Unregulated
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Manganese	28	5		Mn is a SMCL
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Potassium	2200	1000		Unregulated
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Sodium	1800	1000		Unregulated
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Strontium	25	5		Unregulated
CURTIS CONVENTIONAL	9/21/2022 12:28	Total Metals	Zinc	75	10		Zn is a SMCL
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Arsenic	0.83	0.5	10	
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Barium	19	0.5	2000	
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Calcium	5900	250		Unregulated
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Copper	0.71	0.5		Action Level 1300 ug/L
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Magnesium	850	250		Unregulated
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Manganese	96	5		Mn is a SMCL
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Potassium	2200	1000		Unregulated
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Sodium	1700	1000		Unregulated
CURTIS MEMBRANE	9/21/2022 12:00	Total Metals	Strontium	23	5		Unregulated
FEWELL	9/21/2022 16:15	Total Metals	Barium	27	0.5	2000	
FEWELL	9/21/2022 16:15	Total Metals	Calcium	36000	250		Unregulated
FEWELL	9/21/2022 16:15	Total Metals	Copper	0.81	0.5		Action Level 1300 ug/L
FEWELL	9/21/2022 16:15	Classical/Nutrients	Fluoride	0.82	0.05	4000	
FEWELL	9/21/2022 16:15	Total Metals	Magnesium	1400	250		Unregulated
FEWELL	9/21/2022 16:15	Total Metals	Manganese	98	5		Mn is a SMCL
FEWELL	9/21/2022 16:15	Total Metals	Potassium	2100	1000		Unregulated
FEWELL	9/21/2022 16:15	Total Metals	Sodium	3500	1000		Unregulated
FEWELL	9/21/2022 16:15	Total Metals	Strontium	70	5		Unregulated

**Notes:**

The data presented is for investigative purposes. This data is not used for regulatory compliance.

National Primary Drinking Water Contaminant samples were collected at the designated entry points to the city distribution system.

Disinfection By-Product sample results are presented in a separate table.

MRL - Minimum Reporting Limit - The lowest demonstrated level of acceptable quantitation.

MCL - Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water.

SMCL - Secondary Maximum Contaminant Level - Guidelines for aesthetic considerations. Not considered to present risk to human health at SMCL.