

Table 3-32 State Settlements in EPA Platform v6 2022 Reference Case

| Company and Plant | State | Unit | State Enforcement Actions | | | | | | | | | | | | | | Notes |
|-------------------|----------|--------|---|----------------|-------------------------|-------------------------|----------------|-------------------------|------------------------|----------------|-------------------------|----------|----------------|-------------------------|------|---|---|
| | | | Retire/Repower | | SO ₂ Control | | | NO _x Control | | | PM Control | | | Mercury Control | | | |
| | | | Action | Effective Date | Equipment | Percent Removal or Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | Effective Date | |
| Old AES | | | | | | | | | | | | | | | | | |
| | | | If the MPC project is discontinued at Greenidge Unit 4 by 12/31/2009, Unit 4 will be subject to the following SO ₂ emission caps: 2005 will be 12,125 tons, 2006 will be 11,800 tons, 2007 will be 11,475 tons, 2008 will be 11,150 tons, and 2009 will be 10,825 tons. By 12/31/2009, AES shall control, repower, or cease operations at Westover Unit 7. Beginning in 2005, Unit 8 will be subject to the following SO ₂ emission caps: 2005 is 9500 tons, 2006 is 9250, 2007 is 9000, 2008 is 8750, 2009 is 8500 tons. | | | | | | | | | | | | | | http://www.sq.ny.gov/press-releases/govemor-and-attomey-general-announce-new-yorks-largest-coal-plants-slash-pollution |
| Greenidge | New York | Unit 4 | Update: as of May 2009, CONSOL and AES describe the Greenidge Unit 4 MPC effort as a success. | | | | | | | | | | | | | | http://www.aes.com/investors/press-releases/press-release-details/2009/CONSOL-Enemy-and-AES-Greenidge-Announce-Successful-Demonstration-of-Multi-Pollutant-Control-Technology-for-Smaller-Coal-Fired-Plants/default.aspx |
| | | | | | | | | | Operate SCR and SNCR | 0.08 | 09/07/2016 – 09/06/2021 | Baghouse | 48.9 tpy | 09/07/2016 – 09/06/2021 | | | |
| | New York | Unit 3 | Retired | 2011 | Install BACT | | 12/31/09 | Install BACT | | 12/31/09 | | | | | | Unit has retired | |
| Westover | | | Update: as of May 2009, NO _x emissions appear to be above the specified 0.15 lbs/MMBtu | | | | | | | | | | | | | | http://www.powermag.com/print/environmental/Apply-the-fundamentals-to-improve-emissions-performance_574.html |
| | New York | Unit 8 | Retired | 2010 | | 90% | 12/31/10 | Install SCR | 0.15 | 12/31/10 | | | | | | Unit has retired | |
| | New York | Unit 7 | Retired | 2010 | Install BACT | | 12/31/09 | Install BACT | | 12/31/09 | | | | | | Unit has retired | |
| Hickling | New York | Unit 1 | Retired | 2010 | Install BACT | | 05/01/07 | Install BACT | | 05/01/07 | | | | | | Unit has retired | |
| | New York | Unit 2 | Retired | 2010 | Install BACT | | 05/01/07 | Install BACT | | 05/01/07 | | | | | | Unit has retired | |
| Cayuga | New York | Unit 1 | | | FGD | | | SCR | Meets System Wide RACT | | ESP | 98% | | | | Cayuga Unit 1 has been mothballed | |
| | New York | Unit 2 | | | FGD | | | LN Concentric Firing | Meets System Wide RACT | | ESP | 98% | | | | Cayuga Unit 2 has been mothballed | |
| Jennison | New York | Unit 1 | Retired | 2010 | Install BACT | | 05/01/07 | Install BACT | | 05/01/07 | | | | | | Unit has retired | |
| | New York | Unit 2 | Retired | 2010 | Install BACT | | 05/01/07 | Install BACT | | 05/01/07 | | | | | | Unit has retired | |
| Entergy | | | | | | | | | | | | | | | | | |
| Indian Point | New York | Unit 2 | Retire | 04/30/2020 | | | | | | | | | | | | Indian Point unit 2 may extend its operating time if mutually agreed upon between NYS and Entergy, but must retire no later than April 30, 2024 | |
| | New York | Unit 3 | Retire | 04/30/2021 | | | | | | | | | | | | Indian Point unit 3 may extend its | |

| Company and Plant | State | Unit | State Enforcement Actions | | | | | | | | | | | | | Notes | |
|--------------------------------------|------------|---------------|---------------------------|----------------|-------------------------------------|--------------------------------|----------------|---|---------------------------------|----------------|--|-------|--------------------------------------|---|----------|---|---|
| | | | Retire/Repower | | SO ₂ Control | | | NO _x Control | | | PM Control | | | Mercury Control | | | |
| | | | Action | Effective Date | Equipment | Percent Removal or Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | | Effective Date |
| | | | | | | | | | | | | | | | | | operating time if mutually agreed upon between NYS and Entergy, but must retire no later than April 30, 2025 Indian Point units 2 and 3 can operate until retirement without updating their existing cooling water intake technologies. https://www.riverkeeper.org/wp-content/uploads/2017/01/Indian-Point-Closure-Agreement-January-8-2017.pdf |
| Niagara Mohawk Power | | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | http://www.aq.ny.gov/press-release/governor-and-attorney-general-announce-new-yorks-largest-coal-plants-slash-pollution |
| Huntley | New York | Units 63 – 66 | Retire | Before 2008 | | | | | | | | | | | | | |
| Public Service Co. of NM | | | | | | | | | | | | | | | | | |
| San Juan | New Mexico | Unit 1 | | | State-of-the-art technology | 90% | 10/31/08 | State-of-the-art technology | 0.3 | 10/31/08 | Operate Baghouse and demister technology | 0.015 | 12/31/09 | Design activated carbon injection technology (or comparable tech) | | 12/31/09 | All four units have installed Wet Scrubbers. Unit 1 and 4 NO _x controls [SNCR] are hardwired into EPA Platform v6. |
| | New Mexico | Unit 2 | | | | | 03/31/09 | | | 03/31/09 | | | 12/31/09 | | | 12/31/09 | |
| | New Mexico | Unit 3 | | | | | 04/30/08 | | | 04/30/08 | | | 04/30/08 | | | 04/30/08 | |
| | New Mexico | Unit 4 | | | | | 10/31/07 | | | 10/31/07 | | | 10/31/07 | | | 10/31/07 | |
| Public Service Co of Colorado | | | | | | | | | | | | | | | | | |
| Comanche | Colorado | Unit 1 | | | Install and operate FGD | 0.1 lbs/MMBtu combined average | 07/01/09 | Install low-NO _x emission controls | 0.15 lbs/MMBtu combined average | 07/01/09 | | | Install sorbent injection technology | | 07/01/09 | Comanche units 1 and 2 taken together shall not exceed a 0.15 heat rate for NO _x , nor 0.10 for SO ₂ no later than 180 days after initial start-up of control equipment, or by 7/01/2009, whichever is earlier. | |
| | Colorado | Unit 2 | | | Install and operate FGD | | 07/01/09 | Install low-NO _x emission controls | | 07/01/09 | | | Install sorbent injection technology | | 07/01/09 | | |
| | Colorado | Unit 3 | | | Install and operate FGD | 0.1 lbs/MMBtu | | Install and operate SCR | 0.08 | | Install and operate a fabric filter dust collection system | 0.013 | | Install sorbent injection technology | | Within 180 days of start-up | http://content.sierraclub.org/coal/sites/content.sierraclub.org/coal/files/elp/docs/co-comanche_agree-sign_2004-12-02.pdf |
| Rochester Gas & Electric | | | | | | | | | | | | | | | | | |
| Russell Plant | New York | Units 1 – 4 | Retire all units | | | | | | | | | | | | | | http://www.aq.ny.gov/press-release/cuomo-announces-settlement-close-rochester-gas-electrics-coal-burning-russell-power |
| Mirant New York | | | | | | | | | | | | | | | | | |
| Lovett Plant | New York | Unit 1 | Retire | 05/07/07 | | | | | | | | | | | | | http://www.nytimes.com/2007/05/11/nyregion/11plant.html?_r=1&pagewanted=print |
| | New York | Unit 2 | Retire | 04/30/08 | | | | | | | | | | | | | Retirements are pursuant to a 2003 consent decree, and the plant's failure to comply with the required reductions. |
| TVA | | | | | | | | | | | | | | | | | |
| Allen | Tennessee | Units 1 - 3 | | | Remove from Service, FGD, or Retire | | 12/31/2018 | Install SCR | | Effective Date | | | | | | | http://www2.epa.gov/sites/production/files/documents/tvacoal-fired-cd.pdf |
| Bull Run | Tennessee | Unit 1 | | | Install Wet FGD | | Effective Date | Install SCR | | Effective Date | | | | | | | |

| Company and Plant | State | Unit | State Enforcement Actions | | | | | | | | | | | | | Notes | | |
|----------------------------------|---------------|--------------|---------------------------|--|---|-------------------------|----------------|---|---|----------------|------------|------|----------------|-----------------|------|-------|----------------|---|
| | | | Retire/Repower | | SO ₂ Control | | | NO _x Control | | | PM Control | | | Mercury Control | | | | |
| | | | Action | Effective Date | Equipment | Percent Removal or Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | | Effective Date | |
| Colbert | Alabama | Units 1 - 4 | | | Remove from Service, FGD, Repower to Renewable Biomass, or Retire | | 6/30/2016 | Remove from Service, SCR, Repower to Renewable Biomass, or Retire | | 6/30/2016 | | | | | | | | |
| | | Unit 5 | | | Remove from Service, FGD, or Retire | | 12/31/2015 | Install SCR | | Effective Date | | | | | | | | |
| Cumberland | Tennessee | Units 1 & 2 | | | Install Wet FGD | | Effective Date | Install SCR | | Effective Date | | | | | | | | |
| Gallatin | Tennessee | Units 1 - 4 | | | FGD, Repower to Renewable Biomass, or Retire | | 12/31/2017 | Install SCR, Repower to Renewable Biomass, or Retire | | 12/31/2017 | | | | | | | | |
| John Sevier | Tennessee | Units 1 & 2 | Retire | 12/31/2012 | | | | | | | | | | | | | | |
| | | Units 3 & 4 | Remove from Service | 12/31/2012 | FGD, Repower to Renewable Biomass, or Retire | | 12/31/2015 | Install SCR, Repower to Renewable Biomass, or Retire | | 12/31/2015 | | | | | | | | |
| Johnsonville | Tennessee | Units 1 - 10 | Retire | 6 Units by 12/31/15, 4 Units by 12/31/18 | | | | | | | | | | | | | | |
| Kingston | Tennessee | Units 1 - 9 | | | Install Wet FGD | | Effective Date | Install SCR | | Effective Date | | | | | | | | |
| Paradise | Kentucky | Units 1 & 2 | | | Upgrade FGD | 93% Removal | 12/31/2012 | Install SCR | | Effective Date | | | | | | | | |
| | | Unit 3 | | | Install Wet FGD | | Effective Date | Install SCR | | Effective Date | | | | | | | | |
| Shawnee | Kentucky | Units 1 & 4 | | | FGD, Repower to Renewable Biomass, or Retire | | 12/31/2017 | Install SCR, Repower to Renewable Biomass, or Retire | | 12/31/2017 | | | | | | | | |
| Widows Creek | Alabama | Units 1 & 2 | Retire | 7/31/2013 | | | | | | | | | | | | | | |
| | | Unit 3 & 4 | Retire | 7/31/2014 | | | | | | | | | | | | | | |
| | | Units 5 & 6 | Retire | 7/31/2015 | | | | | | | | | | | | | | |
| | | Units 7 & 8 | | | Install Wet FGD | | Effective Date | Install SCR | | Effective Date | | | | | | | | |
| RC Cape May Holdings, LLC | | | | | | | | | | | | | | | | | | |
| B L England | New Jersey | Unit 1 | Retire/Repower | 05/01/14 | | | | | | | | | | | | | | http://www.nj.gov/dep/docs/20120613104728.pdf |
| | | Unit 2 | Retire/Repower | 05/01/17 | FGD | | | SNCR & OFA | 0.42 lb/MMBtu | | | | | | | | | BL England units have retired |
| First Energy | | | | | | | | | | | | | | | | | | |
| Harrison | West Virginia | 1,3 | | | FGD | | | SCR | 0.25 lb/MMBtu, 30-day rolling average, Annual basis 0.20 lb/MMBtu 30-day rolling average, Ozone Season basis | 5/26/2016 | | | | ESP | | | | Permit R13-2988A |

| Company and Plant | State | Unit | State Enforcement Actions | | | | | | | | | | | | | | Notes | |
|-------------------|---------------|------|---------------------------|----------------|-------------------------|-------------------------|----------------|-------------------------|------|--|------------|------|----------------|-----------------|------|----------------|-------|--|
| | | | Retire/Repower | | SO ₂ Control | | | NO _x Control | | | PM Control | | | Mercury Control | | | | |
| | | | Action | Effective Date | Equipment | Percent Removal or Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | Effective Date | Equipment | Rate | Effective Date | | |
| | | 2 | | | | | | | | 0.25 lb/MMBtu, 30-day rolling average, Annual basis 0.20 lb/MMBtu 30-day rolling average, Ozone Season basis For Unit 2 boiler only, during the five consecutive 30 day periods of May through September 2016, preceding and during a catalyst replacement: 0.28 lb/MMBtu on a 30 day rolling average. | 5/26/2016 | | | | | | | Permit R13-2988A |
| Pleasants | West Virginia | 1,2 | | | FGD | | | | SCR | 0.25 lb/MMBtu, 30-day rolling average, Annual basis 0.20 lb/MMBtu 30-day rolling average, Ozone Season basis | 5/26/2016 | | | | ESP | | | Appeal No. 16-01-AQB, Permit R13-3082A |